



bcc to DAC:ADM:
CENTRAL FILES
PDR:HQ
LPDR
~~TIC~~
NSIC

ARKANSAS POWER & LIGHT COMPANY
POST OFFICE BOX 551 LITTLE ROCK, ARKANSAS 72203 (501) 371-4000

STATE

November 29, 1979

1-119-20

Mr. K. V. Seyfrit, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

Subject: Arkansas Nuclear One - Unit 1
Docket No. 50-313
License No. DPR-51
IE Bulletin 79-13
(File: 1510)

Gentlemen:

The following is provided in response to Item 2 of IE Bulletin 79-13, Revision 2:

1. Arkansas Nuclear One - Unit 1 utilizes three different feedwater systems. Auxiliary and main feedwater feed the steam generators through shared spargers while the emergency feedwater feeds through spargers used by that system only.
2. We will not perform the inspections required by Item 2(b) for the following reasons. In all cases where auxiliary feedwater injection is used it is preheated. Emergency feedwater is not used to maintain steam generator level during any normal operating mode.
3. The inspections required by Item 2(c) were performed as part of the effort required for IE Bulletins 79-02 and 79-14. Any discrepancies found will be reported as required by them.

Very truly yours,

David C. Trimble

David C. Trimble
Manager, Licensing

DCT:MOW:pw

cc: Mr. Norman C. Mose'y, Director
Div. of Reactor Operations Inspection
Nuclear Regulatory Commission
4350 East West Highway
Bethesda, Maryland 20555

Mr. W. D. Johnson
U.S. Nuclear Regulatory Commission
P. O. Box 2090
Russellville, Arkansas 72801

8002150

360