

CON'T

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CONTROL BLOCK:

[illegible]

CON'T

CON'T

0	1
---	---

REPORT SOURCE L 6 0 5 0 - 0 3 4 6 7 1 0 3 1 7 8 8 1 1 2 7 7 8 9

60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

VENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)  
During the conduct of ST 5081.01, "Diesel Generator (DG) Monthly Test" on DG 1-2, the room temperature rose to 110°F. The outside air damper would not open. DG 1-2 was declared inoperable at 2045 hours on 10/31/78. This placed the unit in the Action Statement of Technical Specification 3.8.1.1. DG 1-1 was operable and would have been available if offsite power was lost. DG 1-2 would start and would have continued to function for an undetermined amount of time. (NP-33-78-125)

0	8	SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE				COMP. SUBCODE		VALVE SUBCODE					
0	8	E	E	E		B		V	A	L	V	O	P	C		Z			
1	9	9	10	11	12	12	13	13	14	15	16	17	18	19	20				
LER/RO REPORT NUMBER		EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.									
17		7	8	1	0	7	0	3	L		1								
21	22	23	24	25	26	27	28	29	30	31	32								
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER			
B		Z		Z		Z		0	0	0	Y	N		A		I	2	0	6
33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52

33 34 35 36

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

It was discovered the damper linkage was out of adjustment and bound in a guide. The linkage was disassembled and readjusted. The damper was stroked six times.

ST 5081.01 was completed, and Diesel Generator 1-2 declared operable at 2345 hours on October 31, 1978. This removed the unit from the Action Statement of Technical Specification 3.8.1.1.

FACILITY STATUS		% POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION	
1	5	0	0	3	NA	B	Surveillance Test ST 5081.01		
ACTIVITY		CONTENT		AMOUNT OF ACTIVITY		LOCATION OF RELEASE			
1	6	Z	Z	NA	NA				
PERSONNEL EXPOSURES		TYPE		DESCRIPTION					
1	7	0	0	Z	NA				
PERSONNEL INJURIES		DESCRIPTION							
1	8	0	0	NA					
LOSS OF OR DAMAGE TO FACILITY		DESCRIPTION							
1	9	Z	NA						
PUBLICITY		ISSUED		DESCRIPTION					
2	0	N	NA						

7903050 344

NRC USE ONLY

DVR 78-161

NAME OF PREPARER John P. Hartigan

PHONE: 419-259-5000, Ext. 253