## LICENSEE EVENT REPORT

| LICENSEE EVENT REPORT  |
|--|
| CONTROL BLOCK:   |
| 0 1 1 L 2 T S 1 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 1 4 5 CAT 58   |
| CON'T  SOURCE   16 0 5 0 0 0 2 9 5 7 0 2 0 6 7 9 8 0 2 2 7 7 9 9  OCKET NUMBER 66 69 EVENT DATE 74 75 REPORT DATE 80   |
| EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)   |
| [0]2 During normal operation, the gas decay tank radiation monitor,  |
| [0]3 ORT-PRO2B, alarmed high. The high alarm would not reset. The monitor  |
| [0]4] was taken OOS and shiftly grab samples were taken, as required by  |
| Tech Spec 3.14.1.C. There were no safety implications and the health   |
| and safety of the general public was not affected.   |
| 07   |
| [0] 1<br>7 8 9   |
| SYSTEM CAUSE CAUSE COMPONENT CODE SUBCODE SUBC |
| 7 8 3 10 11 12 13 18 19 20 SECUENTIAL OCCURRENCE REPORT REVISION   |
| 17 REPORT NUMBER 21 22 23 24 26 27 28 29 30 30 31  |
| ACTION FUTURE EFFECT SHUTDOWN HOURS (22) ATTACHMENT NPRD-4 PRIME COMP. COMPONENT METHOD HOURS (22) SUBMITTED FORM SUB. SUPPLIER MANUFACTURER   |
| [A 10 2 0 2 0 2 0 0 0 0 0 1 N 2 N 2 LA 2 T. 1 5 5 2  |
| CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)  |
| On inspection the Instrument Maintenance department found a failed   |
| [1]   transistor on circuit board AA70. The exact cause of the failure is  |
| unknown. The transistor, Texas Instruments P/N 2N3711, was replaced.   |
| The monitor was functionally tested and restored to service. No  |
| further corrective action is necessary.  |
| FACILITY STATUS 30 METHOD OF DISCOVERY DESCRIPTION 32  |
| 7 8 9 10 12 13 44 45 46 80   |
| RELEASED OF RELEASE AMOUNT OF ACTIVITY (35)  NA LOCATION OF RELEASE (36)  NA NA  |
| 7 8 9 10 11 44 45 80 PERCONNEL EXPOSURES NUMBER TYPE DESCRIPTION (39)  |
| 1 7 0 0 0 0 37 38 NA   |
| PERSONNEE INJURIES NUMBER DESCRIPTION (4) NA   |
| 7 8 9 11 17 80 80  |
| I Z O NA   |
| 7 8 9 10 PUBLICITY ISSUED DESCRIPTION (45) 7903140307 NRC USE ONLY 80  |
| 2 0 N (41) NA 68 69 80.5   |
| NAME OF PREPARER Fred Ost 84312-746-2084 EXT 251   |