## LICENSEE EVENT REPORT

CONTROL BLOCK:           (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)
0 1 P A B V S 1 2 0 0 - 0 0 0 0 - 0 0 3 4 1 1 1 1 1 4 5 5 TENNER NUMBER 25 26 LICENSE TYPE 30 57 CAT 58
CON'T    O   1   REPORT   L   O   O   O   O   O   O   O   O   O
0 2 During the startup of the Boric Acid Cleanup System, the deborating demineralizer
0 3 was filled with primary grade water. When the demineralizer was cut into service,
0 4 the boron concentration in the inservice boric acid tank was diluted to less than
0 5 the required 7000 PPM. The standby boric acid tank was immediately placed in
0 6 service with the required boric acid concentration.
0 7
7 8 9 SYSTEM CAUSE CAUSE COMP. VALVE
CODE SUBCODE COMPONENT CODE SUBCODE  R B 10 11 D 12 Z 13 Z Z Z Z Z Z Z 16 Z 16  REVISION
17 REPORT   7 9   -   0 4 5   0 3   L   0 0 3   1 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0
ACTION FUTURE ON PLANT SHUTDOWN HOURS 22 ATTACHMENT NPRD.4 PRIME COMP. COMPONENT MANUFACTURER  G 8 Z 19 Z 20 Z 21 0 0 0 0 0 N 23 N 24 Z 25 Z 9 9 9 9 26  33 34 34 42 43 45
CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)    The incident resulted from failure of the cleanup system startup procedure to
[1]
The added to the procedure to assure dilution is taken into account when cutting in
1 2 be added to the procedure to assure dilution is taken into account when cutting in
1 3 the system.
7 8 9
FACILITY STATUS OTHER STATUS OF DISCOVERY DESCRIPTION (32)  1 5 E 28 0 3 8 29 N/A A 31 Operator observation
7 8 9 10 12 13 44 45 46 80  ACTIVITY CONTENT AMOUNT OF ACTIVITY 35 LOCATION OF RELEASE 36
1 6 Z 33 Z 34 N/A
NUMBER   TYPE   DESCRIPTION (39)   N/A   N
PERSONNEL INJURIES DESCRIPTION 41
N/A U OUN UNIVAL 80
LOSS OF OR DAMAGE TO FACILITY 43 TYPE DESCRIPTION N/A  1555 071
LOSS OF OR DAMAGE TO FACILITY (43)