

Docket #50-324
Control # 9298
Date Recvd. 8-27-76
Regulatory Docket File

ATTACHMENT 1

EFFLUENT, WASTE DISPOSAL, AND POTENTIAL DOSES SEMIANNUAL REPORT

January - June 1976

Brunswick Steam Electric Plant

August 12, 1976

RETURN TO REGULATORY CENTRAL FILES
ROOM 016

1578 014

7912140

317

3A

EFFLUENT AND WASTE DISPOSAL SEMI-ANNUAL REPORT

1976

Supplemental Information

Facility Brunswick Steam Electric Plant License Carolina Power & Light Co.

1. Regulatory Limits

a. Fission & activation gases

$$\overline{\Sigma E}_{\beta} \{0.72 Q_S + 290 Q_V\} \leq 1 \text{ quarterly average}$$

$$\overline{\Sigma E}_{\gamma} \{22 Q_S + 200 Q_V\} \leq 1 \text{ quarterly average}$$

$$\overline{\Sigma E}_{\beta} \{1.4 Q_S + 580 Q_V\} \leq 1 \text{ 12 month average}$$

$$\overline{\Sigma E}_{\gamma} \{45 Q_S + 400 Q_V\} \leq 1 \text{ 12 month average}$$

b. Iodines

2 Curies per quarter

4 Curies per 12 months

c. Particulates, half-lives >8 days

$$\{4.7 \times 10^5\} Q_S + \{7.2 \times 10^7\} Q_V \leq 1 \text{ quarterly average}$$

$$\{9.3 \times 10^5\} Q_S + \{1.5 \times 10^8\} Q_V \leq 12 \text{ month average}$$

d. Liquid effluents

10 Curies per quarter

20 Curies per 12 months

2. Maximum Permissible Concentrations

a. Fission & activation Gases

$$\Sigma Q_S \{4.0 \overline{E}_{\gamma} + 0.23 \overline{E}_{\beta}\} + Q_V \{35 \overline{E}_{\gamma} + 92 \overline{E}_{\beta}\} \leq 1$$

b. Iodines

$$\{3.7 \times 10^4\} Q_S + \{5.8 \times 10^6\} Q_V \leq 1$$

c. Particulates, half-lives > 8 days

$$\{3.7 \times 10^4\} Q_S + \{5.8 \times 10^6\} Q_V \leq 1$$

d. Liquid Effluents

Values specified in 10CFR Part 20, Appendix B, Table II, Column 2 for unrestricted areas.

1578 015

3. Average Energy

$$E_{\gamma} = 1.05 \text{ MEV}$$

$$E_{\beta} = 0.279 \text{ MEV}$$

4. Measurements and Approximate Annual Radioactivity

a. Fission and activation gamma

Analysis for specific radionuclides in representative grab samples by gamma spectroscopy.

b. Iodines

Analysis for specific radionuclides collected on charcoal cartridges by gamma spectroscopy.

c. Particulates

Analysis for specific radionuclides collected on filter papers by gamma spectroscopy.

d. Liquid effluents

Analysis for specific radionuclides by individual releases by gamma spectroscopy.

Relative variance for each measurement used in calculating activity values were combined using the additive property of variance. The square root of the combined variance was extracted to obtain an estimate of the standard deviation of the multistep process. The standard deviation was used to evaluate the error in the calculated activities at the 95% confidence level.

5. Batch Releases

a. Liquid

1. Number of Batch releases: 594
2. Total time period for batch releases: 4.83 E04 minutes
3. Maximum time period for a batch release: 2010 minutes
4. Average time period for batch releases: 81.3 minutes
5. Minimum time period for a batch release: 4 minutes
6. Average stream flow during periods of release of effluent into a flowing stream: not applicable

b. Gaseous

1. Number of batch releases: none
2. Total time period for a batch release: not applicable
3. Maximum time period for a batch release: not applicable
4. Average time period for a batch release: not applicable
5. Minimum time period for a batch release: not applicable

1578 016

6. Abnormal Release

a. Liquid

1. Number of releases: none
2. Total activity released: none

b. Gaseous

1. Number of release: 1
2. Total activity released: $3.81E-4Ci$

1578 017

TABLE 1A

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT (YEAR) 1976

GASEOUS EFFLUENTS-SUMMATION OF ALL RELEASES

	Unit II	Quarter I	Quarter II	Est.Total Error, %
A. Fission & activation gases				
1. Total release	Ci	150.06	69.21	1.33E01
2. Average release rate for period	$\mu\text{Ci}/\text{sec}$	2.07E-05	2.50E-05	
3. Percent of Technical specification limit	%	2.40E-02	8.93E-03	
B. Iodines				
1. Total iodine-131	Ci	3.15E-03	1.13E-04	1.33E01
2. Average release rate for period	$\mu\text{Ci}/\text{sec}$	4.30E-10	2.16E-11	
3. Percent of technical specification limit	%	7.08E-02	2.80E-05	
C. Particulates				
1. Particulates with half-lives > 8 days	Ci	1.01E-02	3.58E-03	1.33E01
2. Average release rate for period	$\mu\text{Ci}/\text{sec}$	1.35E-09	6.97E-10	
3. Percent of technical specification limit	%	1.92E00	1.67E00	
4. Gross alpha radioactivity	Ci	0.00	0.00	
D. Tritium				
1. Total release	Ci	1.77E01	3.49E00	1.45E01
2. Average release rate for period	$\mu\text{Ci}/\text{sec}$	2.44E-06	6.73E-07	
3. Percent of technical specification limit	%	6.96E-02	3.19E-03	

1578 018

TABLE 1B

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT (YEAR) 1976

GASEOUS EFFLUENTS-ELEVATED RELEASE

Nuclides Released	II Unit	Continuous Mode		Batch Mode	
		1st Quarter	2nd Quarter	Quarter	Quarter
1. Fission gases					
krypton-85	Ci	0.00E-00	0.00E-00		
krypton-85m	Ci	2.00E00	4.77E00		
krypton-87	Ci	1.56E01	9.88E00		
krypton-88	Ci	0.00E00	4.25E00		
xenon-133	Ci	0.00E-00	6.03E00		
xenon-135	Ci	1.90E01	0.00E00		
xenon-135m	Ci	0.00E00	0.00E00		
xenon-138	Ci	0.00E00	0.00E00		
Argon-41	Ci	1.14E02	3.62E01		
	Ci				
	Ci				
unidentified	Ci	0.00E-00	0.00E00		
Total for period	Ci	1.50E02	6.92E01		
2. Iodines					
iodine-131	Ci	3.03E-3	1.13E-04		
iodine-133	Ci	1.02E-03	3.03E-04		
iodine-135	Ci	3.74E-05	2.83E-05		
Total for period	Ci	2.60E-2	4.43E-04		
3. Particulates					
strontium-89	Ci	6.58E-06	1.02E-05		
strontium-90	Ci	0.00E-00	0.00E00		
cesium-134	Ci	0.00E-00	0.00E-00		
cesium-137	Ci	0.00E-00	0.00E-00		
barium-lanthanum-140	Ci	0.00E-00	0.00E-00		
Cobalt-58	Ci	1.25E-05	7.86E-08		
Manganese-54	Ci	6.55E-03	0.00E-00		
Cerium-139	Ci	0.00E-00	5.23E-07		
unidentified	Ci	0.00E-00	0.00E-00		
Total for period	Ci	6.57E-03	1.03E-05		

1578 019

TABLE 1C

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT (YEAR) 1976

GASEOUS EFFLUENTS-GROUND-LEVEL RELEASES

Nuclides Released	II Unit	Continuous Mode		Batch Mode	
		1st Quarter	2nd Quarter	Quarter	Quarter
1. Fission gases					
krypton-85	Ci	0.00E-00	0.00E-00		
krypton-85m	Ci	0.00E-00	0.00E-00		
krypton-87	Ci	0.00E-00	0.00E-00		
krypton-88	Ci	0.00E-00	0.00E-00		
xenon-133	Ci	0.00E-00	0.00E-00		
xenon-135	Ci	0.00E-00	0.00E-00		
xenon-135m	Ci	0.00E-00	0.00E-00		
xenon-138	Ci	0.00E-00	0.00E-00		
	Ci				
	Ci				
	Ci				
unidentified	Ci	0.00E-00	0.00E-00		
Total for period	Ci	0.00E-00	0.00E-00		
2. Iodines					
iodine-131	Ci	1.23E-04	0.00E-00		
iodine-133	Ci	1.20E-04	0.00E-00		
iodine-135	Ci	3.88E-06	0.00E-00		
Total for period	Ci	2.47E-04	0.00E-00		
3. Particulates					
strontium-89	Ci	8.32E-06	7.62E-06		
strontium-90	Ci	0.00E-00	0.00E-00		
cesium-134	Ci	0.00E-00	0.00E-00		
cesium-137	Ci	0.00E-00	0.00E-00		
barium-lanthanum-140	Ci	0.00E-00	0.00E-00		
Cobalt-58	Ci	5.30E-04	7.44E-04		
Cobalt-60	Ci	1.79E-04	5.85E-04		
Chromium-51	Ci	1.45E-03	7.85E-04		
Zirconium-Niobium-95	Ci	3.31E-04	3.33E-04		
Zinc-65	Ci	1.39E-04	2.56E-04		
Iron-59	Ci	2.39E-04	1.35E-04		
Manganese-54	Ci	4.10E-04	7.28E-04		
Molybdenum-99	Ci	9.28E-05	0.00E-00		
Technetium-99	Ci	9.87E-05	0.00E-00		
Zirconium-97	Ci	0.00E-00	4.38E-09		
Niobium-97m	Ci	0.00E-00	4.20E-09		
unidentified	Ci	0.00E-00	0.00E-00		
Total for period	Ci	3.48E-03	3.57E-03		

1578 020

NOTES:

- 1) Minimum detectable concentrations for radionuclides not detected (uCi/cc):

Kr-85	5.40E-06
Kr-88	6.05E-08
Xe-133	4.15E-08
Xe-135m	2.87E-08
Xe-138	1.85E-08
Cs-134	1.74E-14
Cs-137	1.29E-14
Ba-La-140	2.93E-14

- 2) No batch releases were made during the first or second quarter.

1578 021

TABLE 2A

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT (YEAR) 1976

LIQUID EFFLUENTS-SUMMATION OF ALL RELEASES

Unit	Quarter 1st	Quarter 2nd	Est. Total Error, %
------	----------------	----------------	------------------------

A. Fission and activation products

1. Total release (not including tritium, gases, alpha)	Ci	6.00E-01	5.47E-01	1.15E01
2. Average diluted concentration during period	uCi/ml	1.49E-08	9.79E-09	
3. Percent of applicable limit	%	3.00E-00	2.74E-00	

B. Tritium

1. Total release	Ci	1.12E00	1.01E00	1.33E01
2. Average diluted concentration during period	uCi/ml	2.78E-08	1.81E-08	
3. Percent of applicable limit	%	9.26E-4	6.00E-04	

C. Dissolved and entrained gases

1. Total release	Ci	2.2E-03	2.11E-04	1.15E01
2. Average diluted concentration during period	uCi/ml	5.46E-11	3.77E-12	
3. Percent of applicable limit	%	1.81E-05	1.23E-06	

D. Gross alpha radioactivity

1. Total release	Ci	0.00E00	0.00E00	1.22E01
------------------	----	---------	---------	---------

E. Volume of waste released (prior to dilution)

Volume of waste released (prior to dilution)	liters	6.45E06	1.36E07	5.66E00
--	--------	---------	---------	---------

F. Volume of dilution water used during period

Volume of dilution water used during period	liters	4.03E10	5.59E10	1.10E01
---	--------	---------	---------	---------

TABLE 2B

EFFLUENT AND WASTE DISPOSAL SEMI-ANNUAL REPORT (YEAR) 1976

LIQUID EFFLUENTS

Nuclides Released	Unit	Continuous Mode		Batch Mode	
		Quarter	Quarter	1st Quarter	2nd Quarter
strontium-87	Ci			1.46E-05	1.43E-04
strontium-90	Ci			8.82E-06	6.68E-05
cesium-134	Ci			1.56E-06	0.00E00
cesium-137	Ci			2.27E-06	0.00E00
iodine-131	Ci			1.45E-04	0.00E00
cobalt-58	Ci			4.76E-02	5.86E-02
cobalt-60	Ci			1.67E-02	4.49E-02
iron-59	Ci			2.13E-02	2.45E-02
zinc-65	Ci			1.08E-02	2.87E-02
manganese-54	Ci			2.89E-02	5.48E-02
chromium-51	Ci			1.60E-01	1.11E-01
zirconium-niobium-95	Ci			9.44E-03	8.98E-02
molybdenum-99	Ci			2.40E-03	2.26E-04
technetium-99m	Ci			3.29E-03	2.06E-04
barium-lanthanum-140	Ci			0.00E00	2.31E-06
cerium-141	Ci			8.91E-06	0.00E00
Carbon-14	Ci			0.00E00	2.50E-04
Fluorine-18	Ci			1.06E-01	6.18E-02
Sodium-24	Ci			8.36E-02	1.35E-02
Scandium-46	Ci				6.65E-06
Manganese-56	Ci			1.35E-03	6.73E-04
Copper-54	Ci			5.63E-02	1.79E-02
Cobalt-57	Ci			2.56E-06	5.94E-04
Gallium-72	Ci			1.44E-03	7.67E-03
Arsenic-76	Ci			1.89E-02	3.67E-03
Niobium-97	Ci			1.29E-03	1.88E-04
Tin-113	Ci			1.30E-05	3.43E-05
Indium-113m	Ci			2.32E-05	5.26E-05
Tin-117m	Ci			8.24E-06	0.00E00
Antimony-122	Ci			1.24E-04	0.00E00
Antimony-124	Ci			6.89E-04	1.04E-03
Iodine-132	Ci			1.81E-04	4.28E-07
Iodine-133	Ci			9.62E-04	2.53E-06
Cerium-139	Ci			3.95E-06	0.00E00
Barium-139	Ci			2.47E-05	0.00E00
Tungsten-187	Ci			1.98E-06	0.00E00
Yttrium-91	Ci			0.00E00	1.10E-03
unidentified	Ci			2.86E-02	2.61E-02

Total for period above	Ci			6.00E-01	5.47E-01
------------------------	----	--	--	----------	----------

Argon-41	Ci			1.58E-03	
xenon-133	Ci			0.00E00	0.00E00
xenon-135	Ci			6.15E-04	2.11E-04
Total for period	Ci			2.20E-03	2.11E-04

- NOTES: 1) No continuous releases were made during the first or second quarter.
 2) Minimum detectable concentrations for radionuclides not detected (uCi/ml):

Cs-134 3.50E-08
 I-131 2.89E-08
 Ba-La-140 9.65E-08

Ce-141 4.50E-08
 Xe-133 4.98E-08

1578 023

TABLE 3

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT (YEAR) 1976

SOLID WASTE AND IRRADIATED FUEL SHIPMENTS

A. Solid Waste Shipped Offsite for Burial or Disposal (Not irradiated fuel)

1. Type of waste	Unit	6-month period	Est. Total Error, %
a. Spent resins, filter sludges, evaporated bottoms, etc.	m ³ Ci	326.76 141.41	±1.5E01
b. Dry compressible waste, contaminated equip, etc.	m ³ Ci	367.58 16.88	±2.0E01
c. Irradiated components, control rods, etc.	m ³ Ci	0.44 0.15	±1.0E01
d. Other (describe)	m ³ Ci	1.00 5.30	±1.2E01

2. Estimate of major nuclide composition (by type of waste)

a+b	Cobalt-58	39.7	%
	Chromium-51	34.5	%
	Manganese-54	10.6	%
	Cobalt-60	6.9	%
	Iron-59	4.2	%
	Zinc-65	3.9	%
c.	Uranium-235	99	%
			%
			%
d.	Americium-Beryllium-	99	%
			%
			%

3. Solid Waste Disposition

<u>Number of Shipments</u>	<u>Mode of Transportation</u>	<u>Destination</u>
88	(85) Sole use vehicle	See attached sheet
	(2) Parcel post	See attached sheet
	(1) Hand carry	See attached sheet

B. Irradiated Fuel Shipments (Disposition)

<u>Number of Shipments</u>	<u>Mode of Transportation</u>	<u>Destination</u>
None		

1578 024

<u>NO. of shipments</u>	<u>Destination</u>
37	Southern Space Inc. Columbia SC
35	Chem-Nuclear Systems, Inc. Barnwell, SC
10	Harris Energy & Environmental Lab Raleigh, NC
5	Vallecitos Nuclear Center Pleasanton, CA
1	Peach Bottom Atomic Power Station Delta, PA

1578 025

AIR SUBMERSION SKIN DOSE, mRem/6 Months
BRUNSWICK STEAM ELECTRIC PLANT
Jan 1 to June 30, 1976

SECTOR	MILES									
	.5	1.5	2.5	3.5	4.5	7.5	15.0	25.0	35.0	45.0
NNK	3.55E-03	5.372E-03	5.368E-03	4.627E-03	3.886E-03	2.405E-03	1.147E-03	6.291E-04	4.256E-04	3.145E-04
NE	4.474E-03	7.221E-03	7.033E-03	5.922E-03	5.009E-03	2.960E-03	1.406E-03	7.586E-04	5.180E-04	3.700E-04
ENE	2.086E-03	3.710E-03	4.260E-03	3.888E-03	3.332E-03	2.221E-03	1.055E-03	6.107E-04	4.256E-04	3.146E-04
E	5.127E-04	1.396E-03	1.614E-03	1.483E-03	1.297E-03	8.707E-04	4.630E-04	2.777E-04	1.851E-04	1.481E-04
ESE	1.315E-03	1.524E-03	1.539E-03	1.353E-03	1.148E-03	7.224E-04	3.519E-04	2.037E-04	1.351E-04	1.018E-04
SE	1.216E-03	1.252E-03	1.172E-03	1.022E-03	8.728E-04	5.752E-04	2.967E-04	1.817E-04	1.297E-04	1.001E-04
SSE	1.688E-03	2.049E-03	2.042E-03	1.651E-03	1.354E-03	7.975E-04	3.708E-04	2.039E-04	1.353E-04	1.001E-04
S	1.417E-03	2.044E-03	1.854E-03	1.594E-03	1.315E-03	7.966E-04	3.889E-04	2.222E-04	1.518E-04	1.148E-04
SSW	1.256E-03	2.044E-03	2.965E-03	2.593E-03	2.222E-03	1.388E-03	6.665E-04	3.887E-04	2.592E-04	1.851E-04
SW	2.061E-03	1.863E-03	1.834E-03	1.629E-03	1.388E-03	8.701E-04	4.257E-04	2.406E-04	1.573E-04	1.166E-04
WSW	3.542E-03	2.595E-03	2.407E-03	2.036E-03	1.684E-03	1.073E-03	5.182E-04	2.961E-04	2.035E-04	1.462E-04
W	4.078E-03	2.592E-03	2.221E-03	1.850E-03	1.554E-03	9.807E-04	4.810E-04	2.779E-04	2.035E-04	1.498E-04
WNW	3.354E-03	2.224E-03	2.037E-03	1.846E-03	1.555E-03	1.036E-03	5.552E-04	3.516E-04	2.590E-04	2.035E-04
NW	3.526E-03	1.685E-03	1.407E-03	1.203E-03	1.018E-03	6.662E-04	3.516E-04	2.040E-04	1.480E-04	1.129E-04
NNW	2.419E-03	2.222E-03	2.406E-03	2.220E-03	2.035E-03	1.332E-03	6.846E-04	4.076E-04	2.775E-04	2.220E-04
N	2.438E-03	2.966E-03	2.963E-03	2.592E-03	2.221E-03	1.406E-03	6.663E-04	3.701E-04	2.601E-05	1.850E-04

MAXIMUM OFFSITE SKIN DOSE mREM/6Months 7.221E-03

1578 026

AIR SUBMERSION WHOLE BODY DOSE, mRem/6 Months
BRUNSWICK STEAM ELECTRIC PLANT
Jan 1 to June 30, 1975

SECTOR	MILES									
	0.5	1.5	2.5	3.5	4.5	7.5	15.0	25.0	35.0	45.0
NNE	2.387E-03	3.627E-03	3.626E-03	3.125E-03	2.625E-03	1.625E-03	7.751E-04	4.250E-04	2.875E-04	2.125E-04
NE	3.011E-03	4.877E-03	4.751E-03	4.000E-03	3.379E-03	2.000E-03	9.500E-04	5.125E-04	3.500E-04	2.500E-04
ENE	1.391E-03	2.503E-03	2.876E-03	2.626E-03	2.250E-03	1.500E-03	7.126E-04	4.125E-04	2.875E-04	2.125E-04
E	3.285E-04	9.405E-04	1.089E-03	1.001E-03	8.757E-04	5.879E-04	3.126E-04	1.875E-04	1.250E-04	1.000E-04
ESE	8.747E-04	1.027E-03	1.038E-03	9.133E-04	7.755E-04	4.878E-04	2.376E-04	1.375E-04	9.129E-05	6.878E-05
SE	7.970E-04	8.415E-04	7.896E-04	6.889E-04	5.885E-04	3.880E-04	2.002E-04	1.226E-04	8.758E-05	6.756E-05
SSE	1.112E-03	1.379E-03	1.377E-03	1.114E-03	9.137E-04	5.381E-04	2.502E-04	1.376E-04	9.135E-05	6.757E-05
S	9.405E-04	1.378E-03	1.251E-03	1.076E-03	8.882E-04	5.378E-04	2.626E-04	1.500E-04	1.025E-04	7.754E-05
SSW	8.297E-04	1.878E-03	2.001E-03	1.751E-03	1.500E-03	9.379E-04	4.501E-04	2.625E-04	1.750E-04	1.350E-04
SW	1.383E-03	1.239E-03	1.238E-03	1.100E-03	9.379E-04	5.877E-04	2.875E-04	1.625E-04	1.062E-04	7.877E-05
WSW	2.838E-03	1.751E-03	1.625E-03	1.375E-03	1.137E-03	7.252E-04	3.500E-04	2.000E-04	1.375E-04	9.877E-05
W	2.753E-03	1.750E-03	1.500E-03	1.250E-03	1.050E-03	6.265E-04	3.250E-04	1.876E-04	1.375E-04	1.012E-04
WNW	2.257E-03	1.501E-03	1.373E-03	1.242E-03	1.050E-03	7.001E-04	3.750E-04	2.375E-04	1.750E-04	1.375E-04
NW	2.378E-03	1.138E-03	9.503E-04	8.127E-04	6.876E-04	4.500E-04	2.375E-04	1.376E-04	1.000E-04	7.625E-05
NNW	1.629E-03	1.500E-03	1.625E-03	1.500E-03	1.375E-03	9.000E-04	4.625E-04	2.752E-04	1.875E-04	1.500E-04
N	2.657E-03	2.002E-03	2.001E-03	1.750E-03	1.500E-03	9.502E-04	4.501E-04	2.500E-04	1.753E-05	1.250E-04

MAXIMUM OFFSITE WHOLE BODY DOSE mREM/6Months 4.877E-03

1578 027

WORST CASE SITE BOUNDARY DOSES
RELATED TO AIRBORNE IODINE RELEASES

(Hypothetical Cow and Leafy Vegetables at Site Boundary)

Thyroid Dose due to inhalation, mRem/6 Months

1 year old	4.20E-4
4 years old	4.07E-4
14 years old	2.69E-4
Adult	3.59E-4

Thyroid Dose due to Milk Pathway mRem/6 Months

1 year old	1.11E-1
4 years old	4.60E-2
14 years old	1.59E-2
Adult	1.23E-2

Thyroid Dose due to Eating Green Leafy Vegetables, mRem/6 Months

1 year old	0
4 years old	7.63E-3
14 years old	4.44E-3
Adult	4.69E-3

1578 028

SUMMARY OF DOSES DUE TO LIQUID RELEASES

Dose Due to Eating Fish
Caught in Discharge Canal

Whole Body	3.63E-6 mRem/6 months
G. I. Tract	1.91E-5 mRem/6 months
Thyroid	2.47E-8 mRem/6 months
Bone	5.25E-6 mRem/6 months

Shoreline Sediment Dose Along Discharge Canal	4.28E-7 mRem/6 months
Ocean Swimming Dose	3.06E-10 mRem/6 months

Radological Impact on Man from from direct radiation from
the facility is negligible based on the results from
environmental TLD's.

1578 029