

**RADIOACTIVE EFFLUENT RELEASE  
REPORT**

**INDIANA & MICHIGAN POWER  
COMPANY**

**DONALD C. COOK NUCLEAR PLANT UNIT NOS. 1&2  
BRIDGMAN, MICHIGAN**

**POOR ORIGINAL**

JANUARY 1, 1975

THROUGH JUNE 30, 1978

**— NOTICE —**

THE ATTACHED FILES ARE OFFICIAL RECORDS OF THE DIVISION OF DOCUMENT CONTROL. THEY HAVE BEEN CHARGED TO YOU FOR A LIMITED TIME PERIOD AND MUST BE RETURNED TO THE RECORDS FACILITY BRANCH 016. PLEASE DO NOT SEND DOCUMENTS CHARGED OUT THROUGH THE MAIL. REMOVAL OF ANY PAGE(S) FROM DOCUMENT FOR REPRODUCTION MUST BE REFERRED TO FILE PERSONNEL.

DEADLINE RETURN DATE

*50-315 ENVIR*

RETURN TO REGULATORY CENTRAL FILES

50-315 AND 50-316  
S. DPR-58 AND DPR-74

ROOM 016

*w/ Mr. 8/31/78*

*#782500203*

*A.C.*

RECORDS FACILITY BRANCH

1578 176

7912140

*354*

## I. INTRODUCTION

This report discusses and summarizes the radioactive discharges from both Unit I and II of Donald C. Cook Nuclear Plant during the first six months of calendar year 1978. The format presented in Section 5.4.1B of "Appendix B Technical Specifications" for the aforementioned units has been followed in preparing this document.

Unit I started 1978 operating at 100% power. On January 17, the unit was shutdown from 100% due to high conductivity in steam generators caused by acid getting into the condensate system while regenerating resin in the make-up plant. Unit I was returned to service on January 19, 1978. During the month of February, Unit I operated in the deicing mode, and for a period of 7.5 hours lost reserve power when an insulator flashed over and tripped breakers causing an unscheduled outage. No other major unscheduled outages occurred.

On April 6, 1978 during this reporting period, Unit I was removed from service to conduct the Cycle II/III Refueling Outage. This outage began on April 7th, and the unit was returned to full service on June 24, 1978.

The Unit II Facility Operating License, No. DPR-74, was issued on December 23, 1977. Initial fuel loading commenced on December 26 and was completed on January 2, 1978. Post core loading tests were conducted throughout the month of February and initial criticality was achieved on March 10, 1978, after which the turbine/generator system was paralleled to the system on the same date.

On March 29, the Unit was made subcritical. Investigation of condenser vacuum problems revealed failed tubes in "A" condensers. Damage was caused by steam impingement from steam dump valves. In preparation for a unit start-up, the steam leads were pressurized. This outage continued until April 1, 1978.

On April 19th, the Unit was once again removed from service. Cold shutdown was brought about for various maintenance and modification work. Unit II remained out of service until the end of the month.

Another unplanned outage started May 19, 1978 due to an unidentified reactor coolant system leakage in excess of 1 gpm. It was found that the failed fuel detector safety valve was leaking. Isolating the fuel detector reduced the leakage from 3.26 gpm to .158 gpm. The unit was then kept out of service to perform

moisture separator reheater modifications and remained as such until June 1, 1978.

The next major forced outage occurred in the month of June, after several reoccurring low vacuum trips due to an impulse pressure effect on the low vacuum trip devices from an alternate drain line discharging on the immediate vicinity of the condenser vacuum sensing lines. The sensing valves were relocated to the opposite side of the condenser. Following the outage for moisture separator reheater modifications, power ascension testing continued and the unit attained 97% power.

1578 178

## II. RADIOACTIVE RELEASES

The details and data concerning radioactive discharges from both Units I and II have been handled as joint responses rather than independently for the first six months of 1978. Appendix A presents this information in accordance with the format cited in Section 5.4 of Appendix B, Environmental Technical Specification. As in reports preceeding this one, the effluents were well within the limits set forth in Appendix B Environmental Tech Specification for the D.C. Cook Nuclear Plant and Appendix I to 10 CFR Part 50.

1578 179

APPENDIX A  
RADIOACTIVE RELEASE DATA

1578 180

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT - 1978

LIQUID EFFLUENTS

Nuclides Released	Unit	BATCH	
		1st Quarter	2nd Quarter
Stronium - 89	Ci	<1.184 E-4	<1.911 E-4
Stronium - 90	Ci	<1.018 E-4	<1.643 E-4
Cesium - 134	Ci	1.229 E-1	1.251 E-1
Cesium - 137	Ci	1.395 E-1	1.331 E-1
Iodine - 131	Ci	1.163 E-2	3.234 E-3
Cobalt - 58	Ci	5.594 E-2	1.038 E-1
Cobalt - 60	Ci	8.651 E-2	8.238 E-2
Iron - 59	Ci	<1.626 E-4	7.742 E-4
Zinc - 65	Ci	<1.018 E-3	<1.382 E-3
Manganese - 54	Ci	1.573 E-2	1.094 E-2
Chromium - 51	Ci	3.785 E-3	1.011 E-2
Zirconium-niobium - 95	Ci	4.164 E-3	4.917 E-3
Molybdenum - 99	Ci	<7.482 E-6	<1.207 E-5
Technetium - 99m	Ci	<5.628 E-5	<9.081 E-5
Barium-lanthanum - 140	Ci	<3.468 E-4	<5.595 E-4
Cerium - 141	Ci	<1.031 E-4	<1.664 E-4
Cesium - 136	Ci	5.635 E-4	7.840 E-4
Sodium - 24	Ci	2.393 E-3	7.835 E-3
Iodine - 133	Ci	4.436 E-4	1.242 E-4
Cobalt - 57	Ci	7.028 E-5	1.862 E-4
Zirconium - 97	Ci	3.811 E-4	7.196 E-5
Silver - 110m	Ci	1.603 E-4	1.557 E-3
Sb -124	Ci	< 4.782 E-5	1.707 E-2
Sb-125	Ci	< 1.535 E-4	8.074 E-4

1578 181

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT - 1978

LIQUID EFFLUENTS - SUMMATION OF ALL RELEASES

	Unit	1st Quarter	2nd Quarter	Est. Total Error, %
<b>FISSION AND ACTIVATION PRODUCTS</b>				
Total release (not including tritium, gases, alpha)	Ci	4.443 E-1	5.028 E-1	3.03
Average diluted concentration during period	μCi/ml	2.359 E-8	2.017 E-8	
Percent of applicable limit	%	.338	.148	
<b>TRITIUM</b>				
Total release	Ci	84.279	208.659	.260
Average diluted concentration during period	μCi/ml	1.182 E-6	2.212 E-6	
Percent of applicable limit	%	.039	.074	
<b>DISSOLVED AND ENTRAINED GASES</b>				
Total release	Ci	6.882 E-1	1.794 E-2	1.70
Average diluted concentration during period	μCi/ml	3.654 E-8	7.198 E-10	
Percent of applicable limit	%	*	*	
<b>GROSS ALPHA RADIOACTIVITY</b>				
Total release	Ci	<2.930 E-3	<9.577 E-3	
VOLUME OF WASTE RELEASED (PRIOR TO DILUTION)	liters	3.2529 E 6	5.2490 E 6	2.00
VOLUME OF DILUTION WATER USED DURING PERIOD	liters	1.8833 E 10	2.4919 E10	3.48

\* applicable limit

1578 182

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT - 1978

GASEOUS EFFLUENTS - SUMMATION OF ALL RELEASES

	Units	1st Quarter	2nd Quarter	Est. Total Error, %
<b>FISSION AND ACTIVATION GASES</b>				
Total release	Ci	9.986 E 3	2.520 E 2	1.4
Average release rate for period	$\mu\text{Ci}/\text{Sec}$	1.284 E 3	3.205 E 1	
Percent of technical specification limit	%	6.15	0.19	
<b>IODINES</b>				
Total iodine - 131	Ci	2.964 E-4	9.846 E-3	13.9
Average release rate for period	$\mu\text{Ci}/\text{Sec}$	3.812 E-5	1.25 E-3	
Percent of technical specification limit	%	0.007	.225	
<b>PARTICULATES</b>				
Particulates with half-lives > 8 days	Ci	<1.771 E-3	9.637 E-2	18.0
Average release rate for period	$\mu\text{Ci}/\text{Sec}$	<2.278 E-4	5.153 E-9	
Percent of technical specification limit	%		9.28 E-7	
Gross alpha radioactivity	Ci	<3.160 E-12	< 3.16 E-12	
<b>TRITIUM</b>				
Total release	Ci	6.840 E-1	1.312 E 1	2.0
Average release rate for period	$\mu\text{Ci}/\text{Sec}$	8.796 E-2	1.669 E 0	
Percent of technical specification limit	%	.67	12.8	

1578 183



EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT - 1978

GASEOUS EFFLUENTS - ELEVATED RELEASE

Nuclides Released	Unit	CONTINUOUS MODE		BATCH	MODE
		1st Quarter	2 nd Quarter	1st Quarter	2nd Quarter
<b>FISSION GASES</b>					
Krypton - 85	Ci			6.979 E 1	5.462 E 1
Krypton - 85m	Ci			7.430 E-1	7.042 E-1
Krypton - 87	Ci				1.221 E-1
Krypton - 88	Ci				1.364 E 0
Xenon - 133	Ci	4.173 E 2	7.340 E 1	9.384 E 3	1.156 E 2
Xenon - 135	Ci	4.009 E 0		3.671 E 1	5.439 E 0
Xenon - 135m	Ci				
Xenon - 138	Ci				
Xenon - 133m	Ci			7.388 E 1	7.141 E-1
Total for period	Ci	4.213 E 2	7.340 E 1	9.565 E 3	1.786 E 2
<b>IODINES</b>					
Iodine - 131	Ci	2.122 E-4	7.850 E-4	8.424 E-5	9.061 E-3
Iodine - 133	Ci	2.664 E-5	1.387 E-5		1.033 E-5
Iodine - 135	Ci				
Total for period	Ci	2.389 E-4	7.989 E-4	8.424 E-5	9.071 E-3
<b>PARTICULATES</b>					
Strontium - 89	Ci				
Strontium - 90	Ci				
Cesium - 134	Ci				8.621 E-10
Cesium - 137	Ci				5.316 E-6
Barium-lanthanum - 140	Ci				
Cobalt - 58	Ci		4.596 E-6		4.325 E-2
Cobalt - 60	Ci		1.505 E-5		4.087 E-2
Cesium -138	Ci		1.706 E-6		3.196 E-4
Magnesium - 54					2.023 E-3
Chromium - 51					4.883 E-3
Zirconium - 95					8.010 E-5
Niobium - 95					1.340 E-4
Antimony -124					4.781 E-3
Rubidium - 88					2.137 E-2

1578 184

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT - 1978

SOLID WASTE AND IRRADIATED FUEL SHIPMENTS

A. Solid waste shipped offsite for burial or disposal

1. Type of waste

- a. Spent resins, filter sludges, evaporator bottoms, etc.
- b. Dry compressible waste, contaminated equipment, etc.
- c. Irradiated components, control rods, etc.
- d. Other

Unit	6-month period	Est. Total Error, %
m <sup>3</sup>	6.113 E 2	1
Ci	1.398 E 2	4
m <sup>3</sup>	2.031 E 2	1
Ci	2.026 E 1	200
m <sup>3</sup>		
Ci		
m <sup>3</sup>		
Ci		

2. Estimate of major nuclide composition

- a. CS-137                   % 55.5
- CS-134               % 40.4
- CO-58 & 60          % 4.0
- b. ~~CO~~-60               % 85.0
- ~~Co~~-58               % 15.0

3. Solid Waste Disposition

<u>Number of Shipments</u>	<u>Mode of Transportation</u>	<u>Destination</u>
17	Truck	Sheffield, Ill
37	Truck	Bannell, S. C.

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT - 1978

MDA GASEOUS EFFLUENTS - ELEVATED RELEASE

Nuclides Released	Unit	CONTINUOUS MODE		BATCH	MODE
		1st Quarter	2nd Quarter	1st Quarter	2nd Quarter
<b>FISSION GASES</b>					
Krypton - 85	Ci	<8.119 E 3	<9.064 E 3	<5.975 E 1	<2.870 E 0
Krypton - 85m	Ci	<2.553 E 1	<2.850 E 1	<1.519 E-1	<7.297 E-3
Krypton - 87	Ci	<3.771 E 1	<4.210 E 1	<2.775 E-1	<1.333 E-2
Krypton - 88	Ci	<5.429 E 1	<6.061 E 1	<3.994 E-1	<1.919 E-2
Xenon - 133	Ci	<6.407 E 1	<7.153 E 1	<4.714 E-1	<2.265 E-2
Xenon - 135	Ci	<1.629 E 2	<1.819 E 2	<1.198 E 0	<5.758 E-2
Xenon - 135m	Ci	<6.114 E 2	<6.826 E 2	<4.498 E 0	<2.161 E-1
Xenon - 138	Ci	<3.169 E 2	<3.538 E 2	<2.332 E 0	<1.120 E-1
Xenon - 133m	Ci	<1.340 E 2	<1.496 E 2	<9.861 E-1	<4.737 E-2
Total for period	Ci	<9.526 E 3	<1.064 E 4	<7.006 E 1	<3.366 E 0
<b>IODINES</b>					
Iodine - 131	Ci	<4.174 E-6	<4.660 E-6	<1.807 E-4	<9.429 E-6
Iodine - 133	Ci	<6.153 E-6	<6.869 E-6	<2.663 E-4	<1.390 E-5
Iodine - 135	Ci	<1.141 E-5	<1.274 E-5	<4.915 E-4	<2.565 E-5
Total for period	Ci	<2.174 E-5	<2.427 E-5	<9.385 E-4	<4.898 E-5
<b>PARTICULATES</b>					
Strontium - 89	Ci	<3.084 E-6	<3.443 E-6		
Strontium - 90	Ci	<1.066 E-6	<1.190 E-6		
Cesium - 134	Ci	<6.231 E-6	<6.956 E-6	<2.697 E-4	<1.408 E-5
Cesium - 137	Ci	<6.060 E-6	<6.765 E-6	<2.623 E-4	<1.369 E-5
Barium-lanthanum - 140	Ci	<2.762 E-5	<3.084 E-5	<1.195 E-3	<6.238 E-5

1578 186







RADIOACTIVE EFFLUENT RELEASE REPORT

INDIANA & MICHIGAN POWER COMPANY  
DONALD C. COOK NUCLEAR PLANT UNIT NOS. 1 & 2  
BRIDGMAN, MICHIGAN

July 1, 1978 through December 31, 1978

*dupl  
7903290149*

1578 190

Docket Nos. 50-315 & 50-316  
License Nos. DPR-58 & DPR-74

(A.D)

DUPLICATE DOCUMENT

Entire document previously  
entered into system under:

ANO 7903290149

No. of pages: 21

Donald C. Cook Nuclear Plant • Units 1 & 2

# Semi-Annual Radioactive Effluent Release Report

January 1 - June 30, 1979

POOR ORIGINAL

## — NOTICE —

THE ATTACHED FILES ARE OFFICIAL RECORDS OF THE DIVISION OF DOCUMENT CONTROL. THEY HAVE BEEN CHARGED TO YOU FOR A LIMITED TIME PERIOD AND MUST BE RETURNED TO THE RECORDS FACILITY BRANCH 016. PLEASE DO NOT SEND DOCUMENTS CHARGED OUT THROUGH THE MAIL. REMOVAL OF ANY PAGE(S) FROM DOCUMENT FOR REPRODUCTION MUST BE REFERRED TO FILE PERSONNEL.

DEADLINE RETURN DATE

50-315  
ENVIRO

RECORDS

DUPLICATE DOCUMENT

1578 191

Entire document previously entered into system under:

ANO

7909260286

No. of pages:

20