

JUL 26 1979

POOR ORIGINAL

Dr. E. W. McCauley
Nuclear Test Engineering Division
Lawrence Livermore Laboratory
P.O. Box 808
Livermore, California 94550

Distribution

Subj

Circ

Chron

Branch RF

SF RF

LST CY

bcc w/o encls: ✓ S. Hanauer

F. Schroeder

R. P. Denise

W. Butler

J. Kudrick

C. Anderson

bcc w/encls: R. Cudlin

Dear Ed:

Please find enclosed:

- 1) A copy of the program letter that is now being officially processed and which explains the nature of your liaison work with JAERI on their MARK II containment research. Notice that \$69,000 was added by this program letter, making a total of \$119,000 for the combined GKSS and JAERI work.
- 2) Two JAERI reports and a copy of viewgraphs presented at a recent meeting attended by Dr. Tong. All this material pertains to JAERI's MARK II containment steam venting tests and all is marked proprietary.

Please arrange for translation of the two JAERI reports, making sure that their proprietary status is not jeopardized. Proprietary material must be clearly identified as such and could only be disseminated to NRC.

- 3) A copy of NRR's memo requesting establishment of liaison with JAERI and monitoring of MARK II containment research.

Sincerely,

Original Signed By

S. Fabric
S. Fabric, Chief
Analysis Development Branch
Division of Reactor Safety Research

Enclosures: as stated

1733 286

8001080 073

OFFICE	WRSR/ADB	WRSR/RST	WRSR			
SIGNATURE	S. Fabric/bts	Johnson/Tong	T. Murley			
DATE	7/9/79	7/9/79	7/25/79			

POOR ORIGINAL

2.5

7/24/79

A8

March II Owners Mtg
Obj: Project close-out of program
Pete Hedgecock from Owners Group (WPPSS)
11 Units 11-129 US - some foreign participants
Reactor Vessel high-loads (seismic!)

Lead Haddell Non-Lead all others

Shoreham

Zimmer

Letters address formally the tech concerns
\$32M so far March II program!

+ mods in plants

Events in past year (slide)

TMI - resources esp NRC

Generic vs plant-unique (slide)

Part Section C, E Slideshow

Plants designed, mostly built

Eg purchased, some installed

Today Hydro loads "like seismic"

Combinations of loads

Stress criteria

Functional Capability

added to MII program

related to hydro loads?

Impact on MIII plants

* S&RT - complications

Risk (to owners) of later Δ req

1733 287

POOR ORIGINAL

②

al Smith GE Slideshow

Program overview - CHANGED lots of slides
Also A-E for each plant large effort
Areas they are working on
Better (more precise) load definitions
Owners hope less conservative
Add'l

- 1. (NRC) More comp lateral downcomer loads
- * Anderson - some things not yet included
Get foreign data
Argument on use of these data in MTH Proj
So - better get data exp WPPSS / Tokai
- Block diag of tech programs
- ⑦ Modeling - "backups for WPPSS" ?
Dumb - Caorso tests

Plant - unique - identify
Build on GE principles (built?)
Some plants > GE envelope?
Role of model in quenches?
More work if true

NRC Q sets - ans nearly done

Wouldn't do testing cogeneration
GE - monitoring

March I? Owner group agrees? III too
Yes -

Bar Chart
Slips slips slips

"Generic" - GE tasks
Resources

1733 288

POOR ORIGINAL

Huge lists of tasks - generic

Need plant-by-plant list (later)

Sobon Response to N 0487
Long long list

Some counterproposals already in
Some coming in

Some questions - not yet
clear whether something coming in
(Color code & don't reproduce)

Big thing about SRSS

All dynamic loads

Seismic/SRV/LOCA

Whole industry position is
dependent on applicability
of SRSS to all dynamic loads
All Mark II & III

Paul - unique features

A-E's have had to develop methodology
couldn't wait for every generic item
to do plant designs

RESOURCES FOR THIS

Built on Pool T but no work underway
"No limit w/ quenching"

In-plant tests - head plants

wants to prepare future actions

Smith GE
7/24/79

AGENDA FOR MARK II
NRC MEETING
JULY 24, 1979 BETHESDA, MD.

9:00 AM - 12:00 NOON

- INTRODUCTION P. HEDGECOCK
- LICENSING BACKGROUND L. SOBON
- PROGRAM DEFINITION A. SMITH
- REMAINING PROGRAM TASK A. SMITH
 ACTIVITIES
- POSITION STATEMENTS REGARDING
 NRC CRITERIA
 - GENERIC L. SOBON
 - PLANT UNIQUE APPROACHES MK II REPRESENTATIVES

1:00 PM - 5:00 PM

- CLOSURE PROGRAM W. DAVIS
 - ACTIVITIES
 - DOCUMENTATION
 - SCHEDULES

1733 290

ARS/DH

7/79

AGENDA FOR MARK II
NRC MEETING
JULY 25, 1979 BETHESDA, MD.

9:00 AM - 12:00 NOON

- INDIVIDUAL PROGRAM TASK STATUS
 - TASK A.17 CONDENSATION GE
OSCILLATION TESTING
 - REVIEW OF MK II SUBMITTALS MK II REPRESENTATIVES
 - TASK C.9 WORLD TEST GE
MONITORING

1:00 PM - 4:00 PM

- NRC REVIEW STATUS & POSITIONS NRC PERSONNEL
 - SRSS
 - FUNCTIONAL CAPABILITY
 - IMPROVED CHUG LOAD DEFINITION
(TASK A.16)
 - MULTIVENT TEST PROGRAM PHASES I & II
(TASK A.11)
 - SUGGESTED ALTERNATIVES FOR:
 - WALL & FLOOR VENT CLEARING LOADS
 - ASYMMETRIC LOCA LOADS
 - LOAD CASE NO. 10

1733 291

ARS/DH

7/79

MARK II CONTAINMENT PROGRAM

TASK STRUCTURE SUMMARY

TOTAL NUMBER OF TASKS ————— \approx 101

<u>MARK II PLANT APPLICATION</u>	<u>% OF TOTAL TASKS</u>
LEAD PLANT SER	8
NON-LEAD PLANT	32
COMBINATION OF PLANT CATEGORIES	34
CONFIRMATORY	12
INFORMATIONAL	14
TOTAL	<hr/> 100%

JULY 1979 COMPLETION STATUS:
(BASED ON COST WEIGHTING)

● OVERALL PROGRAM

70%

1733 292

ARS/DH

7/79

MK II CONTAINMENT PROGRAM

☐ EFFORT COMPLETE
☐ EFFORT IN PROCESS

STEAM & CHUGGING
MAIN VENT LOADS

CONDENSATION
OSCILLATION
TESTS
A.17

4T TESTS
A.1

BOUNDING
LOADS
JUSTIFICATION
C.7

IMPROVED CHUG
LOAD DEFINITION
A.16

CHUGGING
ANAL. EVAL.
A.6

CHUGGING
PARAMETRIC
TESTS
A.7

SUBSCALE
MULTIVENT
TESTS
A.11

INCIDENT
WALL
PRESSURE

IMPACT DATA
AND MODEL
A.3 A.4

POOL SWELL
LOADS

4T TESTS
A.1

POOL SWELL
MODEL
A.2

EPRI TESTS
A.9

DDFR
C.1

PLANT
EVALUATION
BY DAR

LATERAL
LOADS

4T TESTS
A.1

DYNAMIC LATERAL
LOADS ANALYSIS
A.13

BOUNDING
LOADS
JUSTIFICATION
C.7

CONFIRMATORY
LATERAL LOADS
ANALYSIS
A.13 EXT.

POOR ORIGINAL

1733 293

ARS
7/79


MK II CONTAINMENT PROGRAM

☐ EFFORT COMPLETE
☐ EFFORT IN PROCESS


SRV RAMSHEAD
WALL LOADS

1733 294


SRV QUENCHER
WALL LOADS



MK II CONTAINMENT
SUBMERGED STRUCTURES PROGRAM



SUBMERGED STRUCTURES PROGRAM




☐ EFFORT COMPLETE
☐ EFFORT IN PROCESS

ARS
7/79

1733 296

SUBMERGED STRUCTURES PROGRAM

☐ EFFORT COMPLETE
☐ EFFORT IN PROCESS




ARS
7/79

1733 297

MK II CONTAINMENT PROGRAM

☐ EFFORT COMPLETE
☐ EFFORT IN PROCESS

MISCELLANEOUS ACTIVITIES




1733 298


ARS
7/79

MARK II GENERIC PROGRAM SCHEDULE


LOCA RELATED ACTIVITIES



S/RV RELATED ACTIVITIES



MISCELLANEOUS ACTIVITIES




1733
299

1733 300
MK II PROGRAM TASKS

TO BE COMPLETED

1733 300



MARK II CONTAINMENT - SUPPORTING PROGRAM
LOCA-RELATED TASKS

TASK NUMBER	ACTIVITY	ACTIVITY TYPE	TARGET COMPLETION	DOCUMENTATION	DATE DOC/SUBM	LFAD PLANT SER/ INTERMED PLANT
A.1	"4T" TEST PROGRAM	Phase I Test Report Phase I Appl Memo Phase II & III Test Rpt Application Memorandum	Completed Completed Completed Completed	NEDO/NEDE 13442-P-01 Application Memo NEDO/NEDE 13468-P NEDO/NEDE 23678-P	5/76 - 5/76 6/76 - 6/76 12/76 - 1/77 1/77 - 2/77	LP SER/IP LP SER/IP LP SER/IP LP SER/IP
A.2	POOL SWELL MODEL REPORT	Model Report	Completed	NEDO/NEDE 21544-P	12/76 - 2/77	LP SER/IP
A.3	IMPACT TESTS	PSTF 1/3 Scale Tests Mark I 1/12 Scale Tests	Completed Completed	NEDO/NEDE 13426-P NEDO/NEDE 20989-2P	8/75 - 9/75 9/75 - 11/75	LP SER/IP LP SER/IP
A.4	IMPACT MODEL	PSTF 1/3 Scale Tests Mark I 1/12 Scale Tests	Completed Completed	NEDO/NEDE 13426P NEDO/NEDE 20989-2P	8/75 - 9/75 9/75 - 11/75	LP SER/IP LP SER/IP
A.5	LOADS ON SUBMERGED STRUCTURES	LOCA/RH Air Bubble Model LOCA/RH Water Jet Model Ring Vortex Model Applications Methods Quenc. Air Bubble Model Appl. Memo. Supplement Quencher Air Bubble 1/4 Scaling Tests Data Eval. Steam Condensation Methods -	Completed Completed Completed 4Q 79 Completed 3Q 79 3Q 79 Complete 4Q 79 -	NEDO/NEDE 21471-P NEDO/NEDE 21472-P Letter Report Topical Report NEDO/NEDE 21730-P NEDO 21471 Supplement NEDE 21730 Supplement NEDE 23817-P Report Plant DAR's	9/77 - 1/78 9/77 - 1/78 5/79 - 5/79 12/77 - 1/78 9/78 - 12/78	LP SER/IP LP SER/IP LP/IP IP LP SER/IP IP Info Info LP SER/IP
A.6	CHUGGING ANALYSIS AND TESTING	Single Cell Report Multivalent Model 4T FSI Report	Completed Completed Completed	NEDO/NEDE 23703-P NEDO/NEDE 21669-P NEDO/NEDE 23710-P	9/77 - 11/77 2/78 - 3/78 4/78 - 3/78	LP SER IP LP SER
A.7	CHUGGING SINGLE VENT	CREARE Report	Completed	NEDO/NEDE 21851-P	6/78 - 7/78	Info.
A.9	ERPI TEST EVALUATION - EPRI 1/13 SCALE TESTS - EPRI SINGLE CELL TESTS	EPRI-4T Comparison 3D Tests Unit Cell Tests	Completed Completed 3Q 79	NEDO 21667 EPRI NP-441 EPRI Report	8/77 - 9/77 4/77 - --	LP SER* LP SER* Info
A.11	MULTIVENT SUBSCALE TESTING AND ANALYSIS	Preliminary MV Prog Plan MV Test Program Plan & Proc. - Phase I Phase I Test Report MV Test Prog Plan & Proc. - Phase II Phase II Test Report CONMAP Tests MIM Verification 1/10 Scale	Completed Completed 3Q 79 3Q 79 2Q 80 3Q 79 Completed	NEDO 23697 NEDO 23697 Rev 1 Report NEDO 23697, Rev. 1, Supp. 1 Report Report	12/77 - 1/78 1/79 - 4/79	LP SER/IP IP IP IP Info.
A.13	SINGLE VENT LATERAL LOADS	Dynamic Analysis Summary Report Summary Report (Extension)	Completed Completed 3Q 79	NEDO 24106-P NEDE 23806-P Report	3/78 - 7/78 10/78 - 11/78	IP IP
A.16	IMPROVED CHUGGING LOAD DEFINITION	Impulse Evaluation Improved Chug Load Defn.	Completed 3Q 79	Letter Report Report	6/78 - 7/78	LP SER* IP
A.17	STEAM CONDENSATION OSCILL.	4T C.O. Test	2Q80	Report		IP

CK:at/30E2
CK070979

POOR ORIGINAL

1733 301

MARK II CONTAINMENT - SUPPORTING PROGRAM
SRV - RELATED TASKS

TASK NUMBER	ACTIVITY	ACTIVITY TYPE	TARGET COMPLETION	DOCUMENTATION	DATE DOC/SUBM	LEAD PLANT SER/ INTERMED PLANT
B.1	QUENCHER EMPIRICAL MODEL	OFFER Model Supporting Data	Completed Completed	NEDO/NEDE 21061-P NEDO/NEDE 21078-P	9/76 - 9/76 5/75 - 7/75	IP IP
B.2	RAMSHEAD MODEL	OFFER Model Supporting Data Analysis	Completed Completed Completed	NEDO/NEDE 21061-P NEDO/NEDE 21062-P NEDO/NEDE 20942-P	9/76 - 9/76 7/75 - 10/75 5/75 - 7/75	LP SER LP SER LP SER
B.3	MONTICELLO IN-PLANT S/RV TESTS	Preliminary Test Rpt. Hydrodynamic Report	Completed Completed	NEDO/NEDE 21465-P NEDO/NEDE 21581-P	12/76 - 1/77 8/77 - 8/77	LP SER LP SER
B.5	S/RV QUENCHER IN-PLANT CAORSO TESTS	Test Plan Test Plan Addendum 1 Test Plan Addendum 2 Test Summary Test Report Test Report	Completed Completed Completed Completed Completed 1Q 80	NEDM 20988 Rev. 2 NEDM 20988 Rev. 2, Add 1 NEDM 20988 Rev. 2, Add 2 Letter Report NEDE-25100-P Report	12/76 - 3/77 10/77 - 3/78 4/78 - 7/78 3/79 - 3/79 5/79 - 6/79	IP IP IP IP IP IP
B.6	THERMAL MIXING MODEL	Analytical Model	Completed	NEDO/NEDE 23689-P	3/78 - 3/78	Info.
B.10	MONTICELLO FSI	Analysis of FSI	Completed	NEDO 23834	6/78 - 7/78	LP SER
B.11	OFFER RAMSHEAD MODEL TO MONTICELLO DATA	Data/Model Comparison	Completed	NSC-GEN 0394	9/77 - 10/77	LP SER
B.12	RAMSHEAD SRV METHODOLOGY SUMMARY	Analytical Methods	Completed	NEDO 24070	10/77 - 11/77	LP SER
B.14	QUENCHER EMPIRICAL MODEL UPDATE	Model Confirmation	1Q 80	Report		Info.

1733 302

POOR ORIGINAL

MARK II CONTAINMENT - SUPPORTING PROGRAM
MISCELLANEOUS TASKS

TASK NUMBER	ACTIVITY	ACTIVITY TYPE	TARGET COMPLETION	DOCUMENTATION	DATE DOC/SUBM	LEAD PLANT SER/ INTERMED PLANT
C.0	SUPPORTING PROGRAM	Supp Prog Rpt Supp Prog Rpt Rev. Supp Prog Rpt Rev.	Completed Completed 4Q 79	NEDO 21297 NEDO 21297 - Rev. 1 NEDO 21297 - Rev. 2	5/76 - 6/76 4/78 - 4/78	- - Info
C.1	DDFR REVISIONS	Revision 1 Revision 2 Revision 3	Completed Completed Completed	NEDO/NEDE 21061-P Rev. 1 NEDO/NEDE 21061-P Rev. 2 NEDO/NEDE 21061-P Rev. 3	9/75 - 4/76 9/76 - 9/76 6/78 - 6/78	- - -
C.3	NRC ROUND 1 QUESTIONS	DDFR Rev. 2 DDFR Rev. 2 Amendment 1 DDFR Rev. 3, Appendix A	Completed Completed Completed	NEDO/NEDE 21061-P Rev. 2 NEDO/NEDE 21061-P Rev. 2 Amend. 1 NEDO/NEDE 21061-P Rev. 3 Appendix A	9/76 - 9/76 12/76 - 2/77 6/78 - 5/79	LP SER*/IP LP SER*/IP LP SER*/IP
C.5	SRSS JUSTIFICATION	Interim Report SRSS Report SRSS Exec. Report SRSS Criteria Appl. SRSS Bases SRSS Justification Suppl.	Completed Completed Completed Completed Completed 3Q 79	(NEDE 24010) NEDO/NEDE 24010-P Summary Report NEDO/NEDE 24010-P Suppl. 1 NEDO/NEDE 24010-P Suppl. 2 Report	4/77 - 3/77 7/77 - 8/77 4/78 - 5/78 10/78 - 11/78 12/78 - 2/79	LP SER*/IP LP SER*/IP LP SER*/IP LP/IP LP/IP
C.6	NRC ROUND 2 QUESTIONS	DDFR Amendment 2 DDFR Amend 2, Suppl 1 DDFR Amend 2, Suppl 2 DDFR Rev. 3, Appendix A	Completed Completed Completed Completed	NEDO/NEDE 21061-P Rev. 2 Amend. 2 NEDO/NEDE 21061-P Rev.2 Amend.2 Suppl.1 NEDO/NEDE 21061-P Rev.2 Amend.2 Suppl.2 NEDO/NEDE 21061-P, Rev. 3 Appendix A	6/77 - 7/77 8/77 - 9/77 9/77 - 11/77 6/78 - 7/79	LP SER*/IP LP SER*/IP LP SER*/IP LP SER*/IP
C.7	JUSTIFICATION OF "4T" BOUNDING LOADS	Chugging Loads Justification	Complete Complete Complete Complete Complete Complete Complete	NEDO/NEDE 23617-P NEDO/NEDE 24013-P NEDO/NEDE 24014-P NEDO/NEDE 24015-P NEDO/NEDE 24016-P NEDO/NEDE 24017-P NEDO/NEDE 23627-P	7/77 - 8/77 6/77 - 8/77 6/77 - 8/77 6/77 - 8/77 6/77 - 8/77 6/77 - 8/77 6/77 - 8/77	LP SER/IP LP SER/IP LP SER/IP LP SER/IP LP SER/IP LP SER/IP LP SER/IP
C.8	S/RV AND CHUGGING FSI	Prestressed Concrete Reinforced Concrete Steel	Completed	NEDO/NEDE 21936-P	7/78-7/78	LP SER/IP
C.9	MONITOR WORLD TESTS	Monitor Tests	End of Program	None		
C.13	LOAD COMBINATIONS & FUNCTIONAL CAPABILITY CRITERIA	Criteria Justification	Completed	NEDO 21985	9/78 - 12/78	IP
C.14	NRC ROUND 3 QUESTIONS	Letter Report DDFR, Rev. 3, Appendix A	Completed	Letter Report NECO/NEDE 21061-P Rev. 3 Appendix A	6/78 - 6/78 6/78 - 5/79	LP SER*/IP LP SER*/IP
C.15	SUBMERGED STRUCTURE CRITERIA	NRC Question Responses	3Q 79	Letter Report		LP SER/IP

* Submitted in response to NRC question.

LP SER: Zimmer, LaSalle, Shoreham
IP: All Other Plants

CK:at/30E1
CK070979

1733 303

POOR ORIGINAL

MARK II PROGRAM
LICENSING BACKGROUND

ORIGINAL PRESSURE SUPPRESSION DESIGN BASIS

HUMBOLDT BAY LOCA TESTS	1958-1960
BODEGA BAY LOCA TESTS	1962-1963

NEW ERA OF TESTING STARTS

GE SMALL SCALE MARK III TESTS	1971
QUAD CITIES SRV TESTS (RAMSHEADS)	OCT 1972
KWU SRV TESTS (QUENCHERS)	1972-1974
MARVIKEN LOCA TESTS START	AUG 1973
GE MARK III PSTF TESTS START	NOV 1973

HYDRODYNAMIC LOADING CONDITIONS BEGIN TO BE DEFINED

FIRST RAMSHEAD SRV MODEL	APRIL 1973
PRELIM. MARK III POOL SWELL LOADS	APRIL 1974
PRELIM. MARK II SRV LOADS IDENTIFIED	DEC 1974
PRELIM. MARK II LOCA LOADS IDENTIFIED	JAN 1975
TWO MARK II's REPORT TO NRC	MARCH 7, 1975
NRC LETTERS REQUESTING LOCA INFORMATION	APRIL 17, 1975
NRC LETTERS REQUESTING SRV INFORMATION	APRIL 21, 1975
MARK I AND II OWNERS GROUPS FORM	MAY, 1975

1733 304

MARK II PROGRAM
LICENSING BACKGROUND

PROGRAM APPROACH

PHASE I --- DYNAMIC FORCING FUNCTION REPORT (DFFR)

DEFINES HYDRODYNAMIC LOADS FOR LOCA AND SRV,
PROVIDES ANALYTICAL TOOLS FOR PLANT UNIQUE LOAD
DEFINITION, AND LISTS STRUCTURAL CRITERIA TO BE
USED FOR PLANT UNIQUE DESIGN ANALYSIS.

PREPARED BY GE AND SARGENT AND LUNDY

SUBMITTED TO THE NRC OCTOBER 25, 1975

REVISIONS MADE AS REQUIRED TO REFLECT RESOLUTION
OF NRC REVIEW OF DFFR AND SUPPORTING PROGRAM

LJS
7/24/79

1733 305

MARK II PROGRAM
LICENSING BACKGROUND

PROGRAM APPROACH

PHASE II --- DESIGN ANALYSIS REPORT (DAR)

DOCUMENTS THE STURCTURAL ANALYSIS/DESIGN USING PLANT
UNIQUE HYDRODYNAMIC LOADS AND LOAD CRITERIA THAT
RESULT FROM APPLYING THE METHODOLOGY IN THE DFFR

PREPARED BY UTILITY AE

SUBMITTED TO NRC FEBRUARY THROUGH JUNE 1976

REVISIONS MADE AS REQUIRED TO REFLECT RESOLUTION
OF NRC REVIEW OR TO REFLECT CHANGES TO DFFR

1733 306

MARK II PROGRAM
LICENSING BACKGROUND

PROGRAM APPROACH

PHASE III --- SUPPORTING PROGRAM

PROVIDES TESTING AND ANALYSIS INFORMATION TO
DEMONSTRATE THE ADEQUACY OF DFFR METHODOLOGY

MANAGED BY GE

SUBMITTED TO THE NRC AS EACH TASK IS COMPLETED

1733 307

MARK II PROGRAM
LICENSING BACKGROUND

PROGRAM INTEGRATION MUST CONSIDER STATUS OF DESIGN/CONSTRUCTION

- ALTHOUGH PLANTS ARE AT VARIOUS STAGES OF CONSTRUCTION, ESSENTIALLY ALL EQUIPMENT IS FABRICATED AND MUCH OF IT ALREADY INSTALLED.
- LIKE SEISMIC LOADS, HYDRODYNAMIC LOADS AFFECT THE CONTAINMENT STRUCTURE AND ALL EQUIPMENT CONTAINED WITHIN IT.
- THUS, IN ADDITION TO THE HYDRODYNAMIC LOAD DEFINITION ITSELF, DYNAMIC LOAD COMBINATIONS, THE METHOD OF COMBINING THEM (ABS vs SRSS), AND THE ACCEPTANCE CRITERIA, BECOME EXTREMELY IMPORTANT IN ORDER TO ATTAIN A BALANCED DESIGN.
- ALTHOUGH FUNCTIONAL CAPABILITY IS REALLY A GENERIC NRC CONCERN THAT NEED NOT BE RESOLVED AS PART OF THE MARK II PROGRAM, AN EFFORT IS BEING MADE TO ADDRESS THIS ISSUE.
- BECAUSE OF ADVANCED STAGE OF CONSTRUCTION AND LICENSING REVIEW, ZIMMER, LA SALLE AND SHOREHAM FORM LEAD PLANT SUBGROUP IN MID 1977.
- BECAUSE OF GENERIC NSSS EQUIPMENT ADEQUACY EVALUATION NEEDS FOR MARK II AND III PLANTS, GE INITIATES SEPARATE DISCUSSIONS WITH NRC (MATTSON) IN EARLY 1978.
- SQRT ACTIVITIES AND SCHEDULE HAVE A HIGH POTENTIAL FOR FURTHER COMPLICATING MARK II PROGRAM CLOSURE.

1733 308

MARK II PROGRAM
LICENSING BACKGROUND

STRATEGY FOR LEAD MARK II PROJECTS

- ESTABLISH COMPREHENSIVE LEAD PLANT PROGRAM DEFINITION
- SEPARATE PROGRAM INTO BASIC AND CONFIRMATORY ACTIVITIES
- KEEP DFFR CURRENT WITH PROGRAM OUTPUT
- COMPLETE OR UPDATE DESIGN ANALYSIS REPORTS
- KEEP PRESSURE ON NRC REVIEW SCHEDULE

LEAD PLANT STATUS/OPEN ITEMS ARE TO BE DISCUSSED IN A SEPARATE MEETING

1733 309

MARK II PROGRAM
LICENSING BACKGROUND

KEY AREAS NEEDING NRC ATTENTION/RESOLUTION

SRSS - MARK II OWNER POSITIONS REGARDING NRC ACCEPTANCE CRITERIA ON LOAD DEFINITION ARE BASED ON APPROVAL OF SRSS FOR ALL DYNAMIC LOADS (LOCA, SEISMIC, & SRV). MARK II & III EQUIPMENT ADEQUACY ASSESSMENTS UTILIZE SRSS COMBINATION METHODOLOGY.

LOAD COMBINATIONS - LOAD CASE 10 IS A NEW NRC REQUIREMENT FOR EQUIPMENT ADEQUACY ASSESSMENTS WHICH TAKES AN ARBITRARY LOAD COMBINATION FOR DEMONSTRATING CONTAINMENT ASYMMETRIC LOCA LOAD CAPABILITIES & MAKES IT A MECHANISTIC COMBINATION NOT PREVIOUSLY CONSIDERED.

ACCEPTANCE CRITERIA - ARBITRARY NRC CLASSIFICATION OF THE OBE BY ITSELF & THE OBE WITH SRV'S AS EQUAL IS NOT APPROPRIATE CONSIDERING THAT LOADS ARE COMBINED AS THOUGH INDEPENDENT. OBE + SRV ALLOWABLE STRESS LIMITS, NUMBER OF SRV'S, & THE NEED FOR FATIGUE ANALYSIS (PREVIOUSLY RESOLVED) CREATING UNCERTAINTIES IN EQUIPMENT ADEQUACY ASSESSMENTS.

1733 310

LJS
7/24/79

NRC ACCEPTANCE CRITERIA
MARK II POOL DYNAMIC LOADS

LOAD	LEAD PLANT	LONG TERM PROGRAM
<u>LOCA</u>		
I.A	<u>SUBMERGED BOUNDARY VENT CLEARING LOAD</u> MARCH 20, 1979 LETTER. 24 PSI STATICALLY APPLIED TO SURFACES BELOW VENT EXIT (ATTENUATE TO 0 PSI AT POOL SURFACE) FOR PERIOD OF VENT CLEARING. ZIMMER AND LASALLE MEET NUREG-0487	MARCH 20, 1979 LETTER. 24 PSI STATICALLY APPLIED TO SURFACES BELOW VENT EXIT (ATTENUATE TO 0 PSI AT POOL SURFACE) FOR PERIOD OF VENT CLEARING.
I.B.1	<u>POOL SWELL ANALYTICAL MODEL</u> (a) ACCEPT NUREG 0487 (b) ACCEPT NUREG 0487 (SHOREHAM FEBRUARY 16, 1979 LETTER RE- EMPHASIZE RESPONSE TO QUESTION 020.68). (c) ACCEPT NUREG 0487 WITH VELOCITY VS. ELEVATION OBTAINED FROM PSAM. (d) ACCEPT NUREG 0487 (e) ACCEPT NUREG 0487 (f) ACCEPT NUREG 0487	(a) ACCEPT NUREG 0487 (b) APPROACH IN RESPONSE TO QUESTION 020.63 TO BE USED. (c) ACCEPT NUREG 0487 WITH VELOCITY VS. ELEVATION OBTAINED FROM PSAM. (d) ACCEPT NUREG 0487 (e) ACCEPT NUREG 0487 (f) ACCEPT NUREG 0487
I.B.2	<u>SUBMERGED BOUNDARY POOL SWELL LOAD</u> ACCEPT NUREG 0487	ACCEPT NUREG 0487
I.B.3	<u>POOL SWELL IMPACT LOAD</u> (a) ACCEPT NUREG 0487 (b) NOT APPLICABLE (NO LARGE STRUCTURES). (c) ACCEPT NUREG 0487 WITH VELOCITY VS. ELEVATION OBTAINED FROM PSAM.	(a) ACCEPT NUREG 0487 (b) NOT APPLICABLE (NO LARGE STRUCTURES). (c) ACCEPT NUREG 0487 WITH VELOCITY VS. ELEVATION OBTAINED FROM PSAM.

1733 311

NRC ACCEPTANCE CRITERIA
MARK II POOL DYNAMIC LOADS
(Continued)

LOAD	LEAD PLANT	LONG TERM PROGRAM
I.B.4	<u>WETWELL AIR COMPRESSION</u>	
(a)	ACCEPT NUREG 0487	(a) ACCEPT NUREG 0487
(b)	ACCEPT NUREG 0487	(b) ACCEPT NUREG 0487
I.B.5	<u>ASYMMETRIC LOADING</u>	
	MARCH 16, 1979 LETTER. 10% OF MAXIMUM BUBBLE PRESSURE STATICALLY APPLIED TO 1/2 OF THE SUBMERGED BOUNDARY WITH HYDROSTATIC PRESSURE.	MARCH 16, 1979 LETTER. 10% OF MAXIMUM BUBBLE PRESSURE STATICALLY APPLIED TO 1/2 OF THE SUBMERGED BOUNDARY WITH HYDROSTATIC PRESSURE.
I.C.1	<u>DOWNCOMER LATERAL LOADS</u>	
(a)	NUREG 0487 ACCEPTABLE FOR STATIC ANALYSIS.	(a) TASK A.13 SINGLE VENT DYNAMIC LATERAL LOAD TO BE USED.
(b)	ACCEPT NUREG 0487	(b) TASK A.13 MULTI-VENT DYNAMIC LATERAL LOAD TO BE USED.
I.C.2	<u>SUBMERGED BOUNDARY STEAM CONDENSATION LOADS</u>	
(a)	ACCEPT NUREG 0487	(a) ACCEPT NUREG 0487
(b)	ACCEPT NUREG 0487	(b) ACCEPT NUREG 0487 AS INTERIM. (ADDITIONAL FREQUENCY RANGES BEING EVALUATED) FINAL BASIS TO BE 4T C.O. TEST RESULTS.
(c)	ACCEPT NUREG 0487	(c) ACCEPT NUREG 0487 AS INTERIM. FINAL BASIS TO BE TASK A.16 LOAD IMPROVEMENT PLUS MULTI-VENT TEST RESULTS AS CONFIRMATION.
<u>SRV</u>		
II.A	<u>POOL TEMPERATURE LIMITS</u>	
(a)	ACCEPT NUREG 0487	(a) DOCUMENT WILL BE PREPARED USING ADDITIONAL PP&L TEST DATA TO SUPPORT NO (LOCAL) TEMPERATURE LIMIT FOR QUENCHERS.
		(b) NUREG-0487 NOT APPLICABLE BASED ON (a) ABOVE.
		(c) ACCEPT NUREG 0487.

NRC ACCEPTANCE CRITERIA
MARK II POOL DYNAMIC LOADS
(Continued)

LOAD	LEAD PLANT	LONG TERM PROGRAM
II.B	<u>AIR CLEARING LOADS</u>	
(a)	ACCEPT NUREG 0487	(a) T-QUENCHERS LOAD PREDICTIVE METHODS PRESENTED IN SUSQUEHANNA DAR, SECTION 4.1.3 X-QUENCHER LOAD DEFINITION BEING DEVELOPED BY BURNS & ROE BASED LARGELY ON CAORSO TEST DATA
(b)	LOAD CASE 5 IS NOT REALISTIC AND SHOULD NOT BE INCLUDED FOR EVALUATION. MULTIPLE VALVE CASES WILL BE ADDRESSED IN PLANT DARs.	(b) LOAD CASE 4 IS NOT INCLUDED FOR EVALUATION. IT IS BOUNDED BY CASE 1.a AND 1.b.
(c)	PLANT UNIQUE CLOSURE REPORTS DEFINE METHOD USED TO DEFINE BUBBLE FREQUENCY.	(c) T-QUENCHER BUBBLE FREQUENCY PRESENTED IN SUSQUEHANNA DAR, SECTION 4.1.3. X-QUENCHER BUBBLE FREQUENCY BEING DEVELOPED BY BURNS & ROE BASED LARGELY ON CAORSO TEST DATA.
II.C.1	<u>QUENCHER ARM LOADS</u>	
(a)	NUREG 0487 NOT APPLICABLE	(a) ACCEPT NUREG 0487
(b)	ACCEPT NUREG 0487	(b) T-QUENCHER ARM LOADS PRESENTED IN SUSQUEHANNA DAR, SECTION 4.1.2.5
II.C.2	<u>QUENCHER TIE-DOWN LOADS</u>	
(a)	NUREG 0487 NOT APPLICABLE	(a) ACCEPT NUREG 0487
(b)	ACCEPT NUREG 0487	(b) T-QUENCHER TIE-DOWN LOADS PRESENTED IN SUSQUEHANNA DAR, SECTION 4.1.2.5.

1733 313

NRC ACCEPTANCE CRITERIA
MARK II POOL DYNAMIC LOADS
(Continued)

LOAD	LEAD PLANT	LONG TERM PROGRAM
<u>SUBMERGED STRUCTURES</u>		
III.A	<u>WATER JET LOADS</u>	
1	WILL ADDRESS CRITERIA BY BY PROPOSING CORRECTED EQUATIONS IN 1.a AND 1.b, SUBMIT PRELIMINARY RING VORTEX MOD. AND SUPPORTING SUBSCALE BENCH MARK TEST.	1 RING VORTEX MODEL INCLUDING POTENTIAL FUNCTION FOR INDUCED FLOW BEING FINALIZED. MORE APPROPRIATE ACCELERATION DRAG CONSIDERATION TO BE IDENTIFIED.
2	ZONE OF INFLUENCE DEVELOPED BASED ON T-QUENCHER PROGRAM AND/OR QUENCHER WATER JET MODEL. NO SIGNIFICANT LOADS BEYOND 5 FT.	2 DATA FROM T-QUENCHER TEST PROGRAM PRESSURE TRANSDUCER P5.5, SHOWS NO WATER JET EFFECT (SUSQUEHANNA DAR, SECTION 8). NO SIGNIFICANT LOADS BEYOND 5FT ZONE OF INFLUENCE.
		3 NUREG-0487 X-QUENCHER CRITERIA ACCEPTED.
III.B	<u>AIR BUBBLE DRAG LOADS</u>	
1(a)	ACCEPT NUREG 0487 ADJUSTMENTS TO DRAG	1(a) ACCEPT NUREG 0487 ADJUSTMENTS TO DRAG
(b)	IDENTIFY MORE APPROPRIATE ACCELERATION DRAG COEFFICIENT TREATMENT THAN FACTOR OF 3.	(b) IDENTIFY MORE APPROPRIATE ACCELERATION DRAG COEFFICIENT TREATMENT THAN FACTOR OF 3.
(c)	DEMONSTRATE THAT ACCELERATION AT CENTER OF STRUCTURE IS TECHNICALLY CORRECT. DEMONSTRATE THAT ERROR RESULTING IN VELOCITY AT CENTER VS. MAXIMUM VELOCITY IS SMALL AND BOUNDED BY CONSERVATISM IN VELOCITY APPLIED. THUS SIMPLIFIED DFFR APPROACH IS ACCEPTABLE.	(c) DEMONSTRATE THAT ACCELERATION AT CENTER OF STRUCTURE IS TECHNICALLY CORRECT. DEMONSTRATE THAT ERROR RESULTING IN VELOCITY AT CENTER VS. MAXIMUM VELOCITY IS SMALL AND BOUNDED BY CONSERVATISM IN VELOCITY APPLIED. THUS SIMPLIFIED DFFR APPROACH IS ACCEPTABLE.

LJS

7/24/79

1733 314

NRC ACCEPTANCE CRITERIA
MARK II POOL DYNAMIC LOADS
(Continued)

LOAD	LEAD PLANT	LONG TERM PROGRAM
	(d) DEMONSTRATE THAT FACTOR (e) OF 4 IS NOT TECHNICALLY CORRECT (f) FOR STANDARD DRAG. REFER TO QUESTION RESPONSE TO 020.70. INTERFERENCE EFFECT ON ACCELERATION DRAG WILL BE ANALYZED ON A PLANT UNIQUE BASIS. (f) ACCEPT NUREG-0487 2(a) ACCEPT NUREG-0487 (b) FOR III.B.1(a) AND (c) THRU (f), SEE ABOVE. FOR III.B.1(b), IT WILL BE DEMONSTRATED THAT A FACTOR OF 3 FOR DRAG COEFFI- CIENTS IS NOT CORRECT FOR OSCIL- LATING BUBBLES AND THAT STANDARD DRAG LOADS ARE NEGLIGIBLE. 3 T-QUENCHER BUBBLE LOCATION AND SIZE ARE PLANT UNIQUE. AMPLI- TITUDE AND FREQUENCY ARE BASED ON PP&L PROGRAM, METHODOLOGY FROM NEDE-21471-P IS USED TO APPLY LOAD TO STRUCTURES.	(d) DEMONSTRATE THAT FACTOR (e) OF 4 IS NOT TECHNICALLY CORRECT (f) FOR STANDARD DRAG. REFER TO QUESTION RESPONSE TO 020.70. INTERFERENCE EFFECT ON ACCELERATION DRAG WILL BE ANALYZED ON A PLANT UNIQUE BASIS. (f) ACCEPT NUREG-0487 2(a) NOT APPLICABLE (NO RAMSHEADS) 3 T-QUENCHER METHODOLOGY PRESENTED IN SUSQUEHANNA, DAR 4.1.3. X-QUENCHER METHODOLOGY TO BE PRESENTED IN HANFORD 2 DAR.
III.C	<u>STEAM CONDENSATION LOADS</u>	
	ACCEPT NUREG-0487	PLANT UNIQUE METHODS BEING DEVELOPED.

LJS

1733 315

LJS

7/24/79

NRC ACCEPTANCE CRITERIA
MARK II LOAD COMBINATIONS FOR

NOTE: SRSS IS TECHNICALLY JUSTIFIED AND IS THE LICENSING BASIS.

LOAD COMBINATION	LEAD PLANT	LONG TERM PROGRAM
#1 $N+SRV_x$ TO B	ACCEPTABLE	ACCEPTABLE
#2 $N+SRV_x+OBE$ TO B	$N+SRV_{all}+OBE$ TO B USED. APPROVED GESSAR APPROACH USED FOR NSSS.	$N+SRV_2+OBE$ TO B AND $N+SRV_{all}+OBE$ TO C USED. SRV_2 IS ARBITRARY. APPROVED GESSAR APPROACH USED FOR NSSS. SEE RE- SPONSE TO QUESTION MEB-7b.
#3 $N+SRV_{all}+SSE$ TO C^4	ACCEPTABLE. WE RESERVE THE RIGHT TO USE THE RODABAUGH CRITERIA	RODABAUGH PAPER TO BE USED AS BASIS FOR ACCEPTANCE CRITERIA (i.e., C OR D).
#4 $N+SRV_{ads}+OBE+SBA$ TO C^4	ENVELOPED BY #5 AND #6	
#5 $N+SRV_{ads}+OBE+IBA$ TO C^4	ENVELOPED BY #6	
#6 $N+SRV_{ads}+SSE+IBA$ TO C^4	SAME AS POSITION FOR #3	SAME AS POSITION FOR #3.
#7 $N+SSE+DBA$ TO C^4	SAME AS POSITION FOR #3	SAME AS POSITION FOR #3. SEE RESPONSE TO QUESTION MEB-7a.
#8 N TO A	ACCEPTABLE	ACCEPTABLE
#9 $N+OBE$ TO B	ACCEPTABLE	ACCEPTABLE
#10 $N+SRV_1+SSE+DBA$ TO C^4	APPLIED TO CONTAINMENT ONLY (SEE M 020.22 & DFFR 5.2.4)	

1733 316

NRC ACCEPTANCE CRITERIA
OTHER MISCELLANEOUS POSITIONS

NRC POSITION	LEAD PLANT	LONG TERM PROGRAM
FUNCTIONAL CAPABILITY	ACCEPTABLE. WE RESERVE THE RIGHT TO USE THE RODABAUGH CRITERIA	DEMONSTRATION OF FUNCTIONAL CAPABILITY WILL BE BASED ON RODABAUGH CRITERIA.
MASS-ENERGY RELEASE FOR ANNULUS PRESSURIZATION	ACCEPTABLE TO ZIMMER AND LASALLE. SHOREHAM ASSUMES VERIFICATION OF MASS-ENERGY RELEASE RATE HAS BEEN SHOWN BY ZIMMER, LASALLE AND HATCH-2.	VERIFICATION OF MASS-ENERGY RELEASE RATE HAS BEEN SHOWN BE ZIMMER, LASALLE AND HATCH-2.
QUESTIONS SEB-2, MEB-5	15% PEAK BROADENING TO BE USED.	
SEB-3, MEB-5	CLOSELY SPACED MODES ARE COMBINED PER 1.92 WHERE REANALYSIS IS PERFORMED. NSSS SCOPE USES MODIFIED SUMMATION PER APPROVED GESSAR.	
MEB-1	ACCEPTABLE	
MEB-2	ACCEPTABLE	
MEB-6	ACCEPTABLE	
MEB-7a AND b	SEE LOAD COMBINATION TABLE FOR CASE #2 AND #7	
MEB-8	SEE FUNCTIONAL CAPABILITY DISCUSSION ABOVE AND LOAD COMBINATION AND ACCEPTANCE CRITERIA TABLE.	

1733 317

NRC ACCEPTANCE CRITERIA
MARK II POOL DYNAMIC LOADS

	<u>BAILLY</u>	<u>HANFORD</u>	<u>LIMERICK</u>	<u>NINE MILE PT.</u>	<u>SUSQUEHANNA</u>
LOCA					
I. A - VENT CLEARING	X			X	
I. B - POOL SWELL		X			
I. C - C. O. & CHUGGING		X			X
SRV					
II.A - TEMPERATURE LIMIT		X			
II.B - AIR CLEARING				X	
II.C - TIE DOWN	X			X	
SUBMERGED STRUCTURES					
III.A - JET					
III.B - AIR BUBBLE	X	X	X		X
III.C - STEAM COND.		X	X	X	X

LJS
7/24/79

1733 318

NRC ACCEPTANCE CRITERIA
MARK II POOL DYNAMIC LOADS

BAILLY (SARGENT & LUNDY)

- I.A - THE DESIGN MEETS NUREG 0487
- II.C.1b - T-QUENCHER ARM LOADS ARE GENERATED USING
SUBMERGED STRUCTURE METHODOLOGY SIMILAR TO LEAD
PLANTS.
- III.B.3 - T-QUENCHER AIR BUBBLE SUBMERGED STRUCTURE LOADS
ARE GENERATED USING METHODOLOGY SIMILAR TO LEAD
PLANTS.

1733 319

LJS
7/24/79

NRC ACCEPTANCE CRITERIA
MARK II POOL DYNAMIC LOADS

HANFORD (BURNS & ROE)

- I.B.3a - SMALL STRUCTURE POOL SWELL IMPACT LOADS ARE GENERATED PER DFFR, REV. 3
- I.B.3c - GRATING POOL SWELL IMPACT LOADS ARE GENERATED WITH DRAG FOR MAXIMUM POOL SWELL VELOCITY (FROM IDEL'CHIK) APPLIED ON GROSS AREA WITH DYNAMIC LOAD FACTOR OF 2.
- I.C.2c - THE SUBMERGED BOUNDARY CHUGGING LOAD IS GENERATED PER BURNS & ROE REPORT "CHUGGING LOADS - IMPROVED DEFINITION AND APPLICATION METHODOLOGY TO MARK II CONTAINMENTS TECHNICAL REPORT", JUNE 1979.
- II.A - NO LOCAL POOL TEMPERATURE LIMIT FOR X-QUENCHER OPERATION
- III.B.1 - THE LOCA AIR BUBBLE SUBMERGED STRUCTURE LOADS ARE GENERATED USING:
 - SOURCE - BASED ON PSAM (NEDE-21544-P) AND DFFR, REV. 3
 - FLOW - THREE DIMENSIONAL SOURCE FLOW IN EXACT CONTAINMENT GEOMETRY
 - DRAG - PER GENERIC POSITION

LJS
7/24/79

1733 320

NRC ACCEPTANCE CRITERIA
MARK II POOL DYNAMIC LOADS

HANFORD (BURNS & ROE) CONTINUED

- III.B.3 - THE X-QUENCHER AIR BUBBLE SUBMERGED STRUCTURE LOADS ARE GENERATED USING POTENTIAL FLOW SOLUTION WITH SOURCES/SINKS DISTRIBUTED TO MAXIMIZE INDUCED FLUID TRANSIENTS IN CONJUNCTION WITH SRV AIR CLEARING LOAD AND CAORSO DATA.
- III.C - THE STEAM CONDENSATION SUBMERGED STRUCTURE LOADS ARE GENERATED USING POTENTIAL FLOW SOLUTION WITH SOURCES/SINKS DISTRIBUTED TO MAXIMIZE INDUCED FLUID TRANSIENTS IN CONJUNCTION WITH APPROPRIATE SOURCE STRENGTHS, DRAG COEFFICIENTS AND INTERFERENCE EFFECTS.

1733 321

LJS
7/24/79

NRC ACCEPTANCE CRITERIA
MARK II POOL DYNAMIC LOADS

LIMERICK (BECHTEL)

III.B.1 - LOCA AIR BUBBLE SUBMERGED STRUCTURE LOADS ARE GENERATED BY USING NEDE-21471-P TO DETERMINE THE IDEALIZED (RAYLEIGH) BUBBLE WITH THE EXCEPTION THAT THE TIME DEPENDENT DRYWELL PRESSURE HISTORY WILL BE USED IN DEFINING THE BUBBLE PRESSURE. THIS IDEALIZED BUBBLE WILL BE USED AS THE SOURCE TERM IN A MODIFIED IWEGS/MARS CODE (DEVELOPED FOR TASK A.16) TO ESTABLISH ACCELERATION AND VELOCITY FLOW FIELDS. APPLICATION OF FLOW FIELDS WILL BE THE SAME AS LEAD PLANTS FOR ITEMS A. THROUGH F.

III.C - STEAM CONDENSATION SUBMERGED STRUCTURE LOADS ARE GENERATED BY APPLYING THE C. O. AND CHUGGING SOURCE AT THE VENT EXIT IN A MODIFIED IWEGS/MARS CODE (DEVELOPED FOR TASK A.16) TO ESTABLISH ACCELERATION AND VELOCITY FLOW FIELDS. APPLICATION OF FLOW FIELDS WILL BE MADE WITH APPROPRIATE DRAG COEFFICIENTS.

QUESTIONS MEB-5 AND SEB-3

CLOSELY SPACED MODES ARE COMBINED PER REG. GUIDE 1.92 EXCEPT FOR SEISMIC LOADS. SEISMIC REANALYSIS IS DONE PER ORIGINAL DESIGN BASIS.

LJS
7/24/79

1733 322

NRC ACCEPTANCE CRITERIA
MARK II POOL DYNAMIC LOADS

NINE MILE POINT (STONE & WEBSTER)

- I.A GENERIC LOAD PROFILE IS APPLIED
 DYNAMICALLY.
- II.B REFINEMENT OF METHODOLOGY CONSIDERING
 KARLSTEIN TEST DATA BEING CONSIDERED
- II.C REFINEMENT OF METHODOLOGY CONSIDERING
 KARLSTEIN TEST DATA BEING CONSIDERED
- III.C VARIOUS ALTERNATIVE METHODS FOR DEVELOPING
 THE FLOW FIELDS ARE BEING EVALUATED

1733 323

LJS
7/24/79

NRC ACCEPTANCE CRITERIA
MARK II POOL DYNAMIC LOADS

SUSQUEHANNA (BECHTEL)

- I.C.2 - STEAM CONDENSATION BOUNDARY LOADS
WILL BE SUPPORTED BY PP&L TEST AT
GKM-2
- III.B - LOCA BUBBLE SUBMERGED STRUCTURE LOADS
ARE GENERATED USING GREENS' FUNCTION
TO DETERMINE FLOW FIELDS.
- III.C - STEAM CONDENSATION SUBMERGED STRUCTURE
LOADS ARE GENERATED USING GREENS' FUNCTION
TO DETERMINE FLOW FIELDS.

QUESTIONS MEB-5 AND SEB-3

CLOSELY SPACED MODES ARE COMBINED PER
REG GUIDE 1.92 EXCEPT FOR SEISMIC LOADS.
SEISMIC REANALYSIS IS DONE PER ORIGINAL
DESIGN BASIS


LJS
7/24/79

1733 324

Mark II
7/24/79

26

POOR ORIGINAL



Typical Mark II Pressure Suppression Containment

1733 325

DOMESTIC MARK II UTILITIES AND PLANTS


UTILITY NAME	PLANT NAME
NORTHERN INDIANA PUBLIC SERVICE CO. CHESTERTON, INDIANA	BAILLY 1
WASHINGTON PUBLIC POWER SUPPLY SYSTEM RICHLAND, WASHINGTON	HANFORD 2
COMMONWEALTH EDISON COMPANY CHICAGO, ILLINOIS	LASALLE 1 AND 2
PHILADELPHIA ELECTRIC COMPANY PHILADELPHIA, PENNSYLVANIA	LIMERICK 1 AND 2
NIAGARA MOHAWK POWER COMPANY SYRACUSE, NEW YORK	NINE MILE POINT 2
LONG ISLAND LIGHTING COMPANY HICKSVILLE, NEW YORK	SHOREHAM
PENNSYLVANIA POWER AND LIGHT COMPANY ALLENTOWN, PENNSYLVANIA	SUSQUEHANNA 1 AND 2
CINCINNATI GAS AND ELECTRIC COMPANY CINCINNATI, OHIO	ZIMMER

1733 326

MARK II OWNERS' GROUP OBJECTIVES

- **TO SATISFACTORILY RESPOND TO THE EXPRESSED NRC CONCERNS RELATING TO DYNAMIC LOADS OCCASIONED BY LOCA AND SRV BLOWDOWN EVENTS**
- **TO POOL THE TALENTS OF THE OWNERS' ORGANIZATIONS, THEIR ARCHITECT-ENGINEERS, THE GENERAL ELECTRIC COMPANY AND SELECTED CONSULTANTS AND PRODUCE A RESPONSIVE, TECHNICALLY SOUND PROGRAM WHICH RESOLVES THE EXPRESSED CONCERNS**

MARK II OWNERS' ORGANIZATION



1733 328

MEETING BETWEEN NRC AND MARK II REPRESENTATIVES

JULY 24 AND 25, 1979

OBJECTIVES

- **To present a closure program for the technical concerns related to the non-Lead Mark II plants**
- **To indicate positions taken with respect to NUREG-0487 criteria**
- **To briefly describe non-generic approaches taken for non-Lead plants**
- **To elicit a response from the NRC concerning the program described by Mark II representatives**

WHAT HAS CHANGED SINCE THE LAST MARK II MEETING WITH THE NRC (SPRING 1978) ON A CLOSURE PLAN FOR THE NON-LEAD PLANTS?

- **NRC has issued NUREG-0487**
- **Owners have decided upon which quencher to use in all cases (7, T-quenchers and 1, X-quencher)**
- **Karlstein T-quenchers test completed**
- **Two in-plant SRV tests have been completed —CAORSO and TOKAI (both X-quenchers)**
- **Two full-scale condensation oscillation programs have been agreed to (GKM/PP&L and Mark II 4T)**
- **The scaled multivalent chugging test program (A.11) is approaching completion**
- **Three-Mile Island (TMI-2) happened**

WHY IS THERE NOT A TOTALLY GENERIC APPROACH?

- **The choice of quenchers is not unanimous — hence, both T and X-quencher programs exist**
- **Schedule pressures have caused many AEs to develop their own analytical procedures**
- **Plant-unique features tend to preclude the use of sweeping conservatisms which might facilitate a generic approach**