

Central file

ILLINOIS POWER COMPANY

U-0116

L08-80(01-04)-0

500 SOUTH 27TH STREET, DECATUR, ILLINOIS 62525

January 4, 1979

Mr. James G. Keppler  
Director, Region III  
Office of Inspection & Enforcement  
U.S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Dear Mr. Keppler:

Clinton Power Station Units 1 and 2  
Docket Nos. 50-461 and 50-462  
Construction Permit Nos. CPPR-137 & CPPR-138

This is in reply to your letter of November 8, 1979, whereby you forwarded Revision No. 2 to IE Bulletin No. 79-02. Our response to action items 1 through 4 of revision No. 1 was transmitted to you on July 5, 1979, by our letter U-0098, L08-79(07-05)-9. That response still applies to items 1 through 4, with the following clarifications:

Item 2. Our procedure for installing wedge type anchors was approved approximately 2 weeks ago. We have not yet used concrete anchors to support any category 1 piping.

Item 4. Our inspection criteria and procedure are in force. Any data resulting from their use will be available for inspection on the CPS site.

Item 5. Until anchors and procedures are approved, none will be used in concrete blocks. Testing is in progress toward the goal of qualifying specific expansion anchor bolts for use at CPS. When these are completed, we will report to you the results and our plans for using them.

1787 233

JAN 7 1980

8001220040

Mr. James G. Keppler


-2-

January 4, 1980

Item 6. Not applicable since we have not used any expansion anchors to support category 1 piping or equipment.

Items 7 & 8. Not applicable.

Sincerely,



G. E. Wuller  
Supervisor - Licensing  
Generation Engineering Department

CCW/jh

Enc.

cc: Director, Division of Reactor Construction Inspection  
Office of Inspection & Enforcement, USNRC

1787 234