



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION IV
611 RYAN PLAZA DRIVE, SUITE 1000
ARLINGTON, TEXAS 76012

TIC

February 20, 1980

In Reply Refer to:

RIV

Docket No. 50-498/Rpt. 79-20

50-499/Rpt. 79-20

Houston Lighting and Power Company
ATTN: Mr. E. A. Turner, Vice President
Power Plant Construction and
Technical Services

Post Office Box 1700
Houston, Texas 77001

Gentlemen:

Thank you for your letter of January 9, 1980, in response to our letter of December 12, 1979, and the attached Notice of Deviation. As a result of our review, we find that additional information is needed.

Specifically, your response should address recurrence control measures taken by construction concrete placement personnel to maintain unrestricted vertical drop of concrete within specifications.

You are requested to provide the additional information within twenty days of the receipt of this letter.

Should you have any questions concerning this matter, please contact this office.

Sincerely,

W. C. Seidle, Chief
Reactor Construction and
Engineering Support Branch

8003040220