NRC FORM 366 (7-77)

U. S. NUCLEAR REGULATORY COMMISSION

UPDATE REPORT--
PREVIOUS REPORT DATE 2-7-80

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | ILQAD2 (2) | 000-000-000 (3) | 4111111 (4) | (5)
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T
01 REPORT SOURCE L (6) | 05000265 (7) | 010880 (8) | 022580 (9)
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 While performing SBLC Relief Valve Setpoint Check, procedure QOS 1100-4, relief valve
03 RV 1105A actuated at 1600 psig and relief valve RV 1105B actuated at 1500 psig. The
04 Technical Specification 4.4.A.2 limit for SBLC relief valves is 1400-1490 psig. The
05 increased setpoints of the relief valves were still within the design pressure rating
06 of the SBLC piping. Subsequently the SBLC system was operable and would have
07 performed had the need arose.
08 80

09 SYSTEM CODE SH (11) | CAUSE CODE E (12) | CAUSE SUBCODE B (13) | COMPONENT CODE VALVEX (14) | COMP. SUBCODE X (15) | VALVE SUBCODE B (16)
7 8 9 10 11 12 18 19 20

(17) LER/RO REPORT NUMBER: EVENT YEAR 80 | — | SEQUENTIAL REPORT NO. 001 | / | OCCURRENCE CODE 03 | REPORT TYPE L | — | REVISION NO. 1
21 22 23 24 26 27 28 29 30 31 32

ACTION TAKEN E (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0000 | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. Y (24) | PRIME COMP. SUPPLIER N (25) | COMPONENT MANUFACTURER C715 (26)
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The cause is attributed to relief valve setpoint drift. Both valves were removed,
11 inspected, and rebuilt. The valves were retested in the system using procedure
12 QOS 1100-4. The RV 1105A valve corrected relief point was 1490 psig and the RV 1105B
13 valve corrected relief point was 1450 psig.
14 80

15 FACILITY STATUS H (28) | % POWER 000 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY B (31) | DISCOVERY DESCRIPTION (32) Surveillance Testing
7 8 9 10 12 13 44 45 46 80

16 ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA
7 8 9 10 11 44 45 80

17 PERSONNEL EXPOSURES NUMBER 000 (37) | TYPE Z (38) | DESCRIPTION (39) NA
7 8 9 11 12 13 80

18 PERSONNEL INJURIES NUMBER 000 (40) | DESCRIPTION (41) NA
7 8 9 11 12 80

19 LOSS OF OR DAMAGE TO FACILITY (43) TYPE Z (42) | DESCRIPTION NA
7 8 9 10 80

20 PUBLICITY ISSUED N (44) | DESCRIPTION (45) NA | NRC USE ONLY
7 8 9 10 68 69 80

NAME OF PREPARER J. Vahrenwald PHONE: 309-654-2241 ext. 195

8003170457

GPO 917-926