

**From:** [Alan Cebula](#)  
**To:** [Helvenston, Edward](#)  
**Subject:** [External\_Sender] Re: Minor clarification on October 7, 2019 letter  
**Date:** Tuesday, October 08, 2019 4:35:13 PM

---

Hi Ed,

Yes, that is a typographical error. Administrative operating restriction #2 should read:

"No reactor operation when the bulk pool temperature is above 50 C (122 F)."

The same correction has been made to the facility Condition/ Limit Log.

Thank you,

Alan

---

Alan T. Cebula, PhD, DABR, DABSNM, DABMP  
Nuclear Reactor Facility Manager  
Alan Levin Department of Mechanical and Nuclear Engineering  
Office Address: 112 Ward Hall  
Mailing Address: 3002 Rathbone Hall, 1701B Platt Street  
Kansas State University  
Manhattan, KS 66506  
o: 785-532-6657  
c: 352-672-7289  
f: 785-532-7057

---

**From:** Helvenston, Edward <Edward.Helvenston@nrc.gov>  
**Sent:** Tuesday, October 8, 2019 3:29 PM  
**To:** Alan Cebula <alanc@ksu.edu>  
**Subject:** Minor clarification on October 7, 2019 letter

Hi Alan,

In administrative operating restriction #2 in your October 7, 2019 letter, I noticed that the conversion for 50 degrees Celsius is given as 112 degrees Fahrenheit, which appears to be a typographical error. Could you please just confirm by response to this email that 50°C (122°F) was what was meant?

Thanks,  
Ed

**Ed Helvenston, U.S. NRC**  
Research and Test Reactor Licensing Branch (PRLB)

Division of Licensing Projects (DLP)  
Office of Nuclear Reactor Regulation (NRR)  
O-12C07  
(301) 415-4067