



October 18, 2019

NRC 2019-0037
TS 5.5.13
10 CFR 50.71(e)

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

Point Beach Nuclear Plant, Units 1 and 2
Dockets 50-266 and 50-301
Renewed License Nos. DPR-24 and DPR-27

Technical Specification Bases Change Summary

In accordance with the requirements of Technical Specification (TS) 5.5.13 and 10 CFR 50.71(e), NextEra Energy Point Beach, LLC (NextEra) is submitting a summary of changes made to the Point Beach Nuclear Plant TS Bases without prior NRC approval.

The enclosure contains the TS Bases change summary for the period April 1, 2018, through October 1, 2019. NextEra previously submitted the TS Bases change summary for January 1, 2016, through March 31, 2018 on May 2, 2018.

This letter contains no new commitments and no revisions to existing commitments.

If you have any questions or require additional information, please contact me at (920) 755-7854.

Sincerely,

NextEra Energy Point Beach, LLC

A handwritten signature in black ink, appearing to read "Eric Schultz". The signature is fluid and cursive, with a long horizontal stroke extending to the right.

Eric Schultz
Licensing Manager

Enclosure

cc: Administrator, Region III, USNRC
Project Manager, Point Beach Nuclear Plant, USNRC
Resident Inspector, Point Beach Nuclear Plant, USNRC

ENCLOSURE

**NEXTERA ENERGY POINT BEACH, LLC
POINT BEACH NUCLEAR PLANT, UNITS 1 AND 2**

**TECHNICAL SPECIFICATION (TS) BASES CHANGE SUMMARY FOR
April 1, 2018 – October 1, 2019**

Affected Section	Date of Change	Affected Page(s)	Summary
3.1.7	April 2018	B 3.1.7-2	Clarified the control room readouts, correct the wording from transmitter to transformer, corrected various editorial changes to make the paragraph grammatically correct
3.6.4	September 2018	B 3.6.4- 1	Corrected errors in the LOCA and steam line break containment response analyses
3.7.1	November 2018	B 3.7.1-6	Replaced ASME OM Code, Appendix I, Inservice Testing of Pressure Relief Devices in Light Water Reactor Power Plants with ASME OM Code Case OMN-17, Alternative Rules for Testing ASME Class 1 Pressure Relief/Safety Valves [and PWR Main Steam Safety Valves].
3.7.7	November 2018	B 3.7.7-2	Added a new paragraph to describe the new component cooling water cross-connects
3.8.6	November 2018	B 3.8.6-2	The changes to TSB 3.8.1 were made to align with surveillance frequency change. Surveillance Requirement (SR) 3.8.6 was changed from every 7 days to every 31 days. The Surveillance Test Interval change is controlled by TS 5.5.19 Surveillance Frequency Control Program.
3.7.7	April 2019	B 3.7.7-1	Removed blowdown evaporator from the background section. The blowdown evaporator was abandoned.
3.8.9	August 2019	B 3.8.9-7	Corrected the amendment numbers in the footer of page 7.