

METROPOLITAN EDISON COMPANY  
JERSEY CENTRAL POWER & LIGHT COMPANY

AND

PENNSYLVANIA ELECTRIC COMPANY  
THREE MILE ISLAND NUCLEAR STATION UNIT 1

---

Operating License No. DPR-50  
Docket No. 50-289  
Technical Specification Change Request No. 67


This Technical Specification Change Request is submitted in support of Licensee's request to change Appendix A to Operating License No. DPR-50 for Three Mile Island Nuclear Station Unit 1. As a part of this request, proposed replacement pages for Appendix A are also included.

METROPOLITAN EDISON COMPANY

By 

Vice President

Sworn and subscribed to me this 13<sup>th</sup> day of January, 1978.

  
Notary Public

NOTARY PUBLIC  
Reading, Berks County, Pa.  
My Commission Expires Nov. 19, 1979

1583 308

7911080 614

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

IN THE MATTER OF

DOCKET NO. 50-289  
LICENSE NO. DPR-50

METROPOLITAN EDISON COMPANY


This is to certify that a copy of Technical Specification Change Request No. 67 to Appendix A of the Operating License for Three Mile Island Nuclear Station Unit 1, has, on the date given below, been filed with the U. S. Nuclear Regulatory Commission and been served on the chief executives of Londonderry Township, Dauphin County, Pennsylvania and Dauphin County, Pennsylvania by deposit in the United States mail, addressed as follows:

Mr. Weldon B. Arehart  
Board of Supervisors of  
Londonderry Township  
R. D. #1, Geyers Church Road  
Middletown, Pennsylvania 17057

Mr. Harry B. Reese, Jr.  
Board of County Commissioners  
of Dauphin County  
Dauphin County Court House  
Harrisburg, Pennsylvania 17120

METROPOLITAN EDISON COMPANY

By

  
Vice President

Dated: January 13, 1978

1583 309

Three Mile Island Nuclear Station, Unit 1  
Operating License No. DPR-50  
Docket No. 50-289

Technical Specification Change Request #67

The licensee requests that the attached changed pages replace pages 6-12, 6-13, 6-14, and 6-18 of the existing Technical Specifications.

Reasons for Change Request

The Commission has concluded that much of the information now included in the Annual Operating Report (AOR) can be deleted and still meet the desired objectives. Therefore, the Commission requests that the requirements for the AOR be deleted from the Technical Specifications.

Safety Analysis Justifying the Change

This change request deletes the reporting requirements for the AOR and includes a section for the Monthly Operating Report. All required data concerning the operation of the unit will be supplied in the Monthly Operating Report. The change does not affect the operation or equipment of Unit 1. Therefore, (i) the probability of occurrence or the consequences of an accident or malfunction of equipment important to safety previously evaluated in the safety analysis report is not increased; (ii) the possibility of an accident or malfunction of a different type than any evaluated previously in the safety analysis report is not created; (iii) the margin of safety defined in the basis of any technical specification is not reduced.

1583 310

## 6.9 REPORTING REQUIREMENTS

In addition to the applicable reporting requirements of Title 10, Code of Federal Regulations, the following identified reports shall be submitted to the Director of the appropriate Regional Office of Inspection and Enforcement unless otherwise noted.

### 6.9.1 Routine Reports

- A. Startup Report. A summary report of plant startup and power escalation testing shall be submitted following (1) receipt of an operating license, (2) amendment to the license involving a planned increase in power level, (3) installation of fuel that has a different design or has been manufactured by a different fuel supplier, and (4) modifications that may have significantly altered the nuclear, thermal, or hydraulic performance of the plant. The report shall address each of the tests identified in the FSAR and shall in general include a description of the measured values of the operating conditions or characteristics obtained during the test program and a comparison of these values with design predictions and specifications. Any corrective actions that were required to obtain satisfactory operation shall also be described. Any additional specific details required in license conditions based on other commitments shall be included in this report.

Startup reports shall be submitted within (1) 90 days following completion of the startup test program, (2) 90 days following resumption or commencement of commercial power operation, or (3) 9 months following initial criticality, whichever is earliest. If the Startup Report does not cover all three events (i.e., initial criticality, completion of startup test program, and resumption or commencement of commercial power operation), supplementary reports shall be submitted at least every three months until all three events have been completed.

- B. Annual Reports. <sup>1</sup>/ Annual reports covering the activities of the unit as described below during the previous calendar year shall be submitted prior to March 1 of each year. The initial report shall be submitted prior to March 1 of the year following initial criticality. Reports required on an annual basis shall include:

1. A tabulation on an annual basis of the number of station, utility and other personnel (including contractors) receiving exposures greater than 100 mrem/yr and their associated man rem exposure according to work and job functions, <sup>2</sup>/ (e.g., reactor operations and surveillance, inservice inspection, routine maintenance, special maintenance (describe maintenance), waste processing, and refueling). The dose assignment to various duty functions may be estimates based on pocket dosimeter, TLD, or film badge measurements. Small exposures totalling less than 20% of the individual total dose need not be accounted for. In the aggregate, at least 80% of the total whole body dose received from external sources shall be assigned to specific major work functions.

1583 311

2. The following information on aircraft movements at the Harrisburg International Airport:
  - a. The total number of aircraft movements (takeoffs and landings) at the Harrisburg International Airport for the previous twelve-month period.
  - b. The total number of movements of aircraft larger than 200,000 pounds, based on a current percentage estimate provided by the airport manager.
- C. Monthly Operating Report. Routine reports of operating statistics and shutdown experience shall be submitted on a monthly basis to the Office of Inspection and Enforcement, U.S. Nuclear Regulatory Commission, Washington, D.C. 20555, with a copy to the Regional Office, no later than the fifteenth (15th) day of each month following the calendar month covered by the report.

6.9.2 Reportable Occurrences 3/

Reportable Occurrences, including corrective actions and measures to prevent recurrence, shall be reported to the NRC. Supplemental reports may be required to fully describe final resolution of an occurrence. In case of corrected or supplemental reports, reference shall be made to the original report date.

Delete Page 6-14

6.9 REPORTING REQUIREMENTS (cont'd)

6.9.3 Unique Reporting Requirements

- A. Special reports shall be submitted to the Director of the Regulatory Operations Regional Office within the time period specified for each report. These reports shall be submitted covering the activities identified below:

<u>Tests</u>	<u>Submittal Dates</u>
(1) Containment Structural Integrity Test	
(a) Tendon Surveillance Program	Within 3 months after performance of surveillance program.
(b) Ring Girder Inspection Program	Within 3 months after performance each inspection.
(2) Containment Integrated Leak Rate Test	Within 6 months after completion of test.
(3) Inservice Inspection Program	Within 6 months after five years of operation.

FOOTNOTES

1. A single submittal may be made for a multiple unit station. The submittal should combine those sections that are common to all units at the station.
2. This tabulation supplements the requirements of §20.407 of 10 CRF Part 20.
3. These reporting requirements apply only to Appendix A technical specifications.

1583 313