



# LONG ISLAND LIGHTING COMPANY

175 EAST OLD COUNTRY ROAD • HICKSVILLE, NEW YORK 11801

ANDREW W. WOFFORD  
VICE PRESIDENT

SNRC 449

November 19, 1979

Mr. Robert T. Carlson, Chief  
Reactor Construction & Engineering Support Branch  
U.S. Nuclear Regulatory Commission, Region I  
631 Park Avenue  
King of Prussia, Pennsylvania 19406

NRC Inspection No. 79-12  
Shoreham Nuclear Power Station - Unit No. 1  
Docket No. 50-322

Dear Mr. Carlson:

This letter responds to your letter of October 12, 1979, which forwarded the report of the inspection of activities authorized by NRC License No. CPPR-95, conducted by Messrs. Toth and Narrow of your office on August 13-16, 1979. The letter stated that it appeared that one of our activities was not conducted in full compliance with NRC requirements. The apparent noncompliance and our response follow:

Apparent Noncompliance with 10CFR50, Appendix B,  
Criterion V, and FSAR Paragraph 17.1.5B

Contrary to the above, on August 13, 1979, battery room ventilation control panels PNL-VC16, VC17 and VC18 were installed without approved engineering drawings.

### Corrective Action and Results

Failure to obtain approved mounting drawings for Panels PNL-VC16, VC17 and VC18 has been documented on a nonconformance report. Engineering evaluation of the nonconformance and completion of any necessary rework will be accomplished by January 1, 1980. Location drawings for the above panels are available at the construction site.

1791 176

8001280058.

Mr. Robert T. Carlson  
U.S. Nuclear Regulatory Commission, Region I

November 19, 1979  
Page 2

Final installation inspection of the panels had not been performed by Field Quality Control at the time of the NRC inspection. Since approved mounting drawings are required by FQC in order to perform their final inspection, this discrepancy would have been observed and corrected at that time.


Steps Taken to Prevent Recurrence

Responsible construction supervisory personnel have been advised of the NRC inspection finding, and specification requirements for panel mounting have been emphasized to them.

Date Full Compliance Will Be Achieved

Full compliance will be achieved by January 1, 1980. A final report will be submitted by January 31, 1980.

Very truly yours,



A. W. Wofford  
Vice President

1791 177

~~SECRET~~