



MISSISSIPPI POWER & LIGHT COMPANY
Helping Build Mississippi
 P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

PRODUCTION DEPARTMENT

January 16, 1980

Office of Inspection & Enforcement
 U. S. Nuclear Regulatory Commission
 Region II
 101 Marietta Street, N. W., Suite 3100
 Atlanta, Georgia 30303

ATTENTION: Mr. J. P. O'Reilly, Director

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
 File 0260/0266/15521/15525
 Interim Report No. 5
 PRD-79/05
 AECM-80/21

On February 23, 1979, Mississippi Power & Light Company notified Mr. W. B. Kenna of your office of a potential reportable deficiency at the Grand Gulf Nuclear Station construction site. The deficiency concerns improper drawings supplied by General Electric.

General Electric issued a Field Deviation Disposition Request (FDDR) calling for changes in wire and cable lists. Consequently all termination cabinet panels at the site are being reviewed against as-shipped drawings. We will submit the findings of their review as soon as GE provides the information. We expect to file a final report by March 31, 1980.

Yours truly,

L. F. Dale
 Nuclear Project Manager

POOR ORIGINAL

JDR/JRF:bsh

cc: Mr. N. L. Stampley
 Mr. R. B. McGehee
 Mr. T. B. Conner

Mr. Victor Stello, Jr., Director
 Division of Inspection & Enforcement
 U. S. Nuclear Regulatory Commission
 Washington, D. C. 20555

cc: Dr. D. C. Gibbs
 Mr. Adrian Zaccaria
 Mr. J. N. Ward
 Mr. D. M. Lake
 Mr. R. L. Scott
 Mr. W. L. Nail
 Mr. J. P. McGaughy
 Mr. T. E. Reaves
 Mr. C. K. McCoy
 Mr. J. W. Yelverton
 Mr. A. R. Smith
 File

THIS COPY FOR

3019
 SE
 1/0

1792 011

8001230144

S