

AUG 2 1963

Yankee Atomic Electric Company  
441 Stuart Street  
Boston 10, Massachusetts

Attention: Mr. Roger Coe  
Vice President

Gentlemen:

Attached is a copy of the Advisory Committee on Reactor Safeguards letter, dated July 18, 1963, regarding Yankee Atomic Electric Company's Proposed Change No. 36.

The Advisory Committee has concluded that the proposed Core III loading and operation up to full power with boric acid in the primary coolant may be carried out without undue hazard to the health and safety of the public.

We are proceeding to process our hazards analysis and authorization of Change No. 36.

Sincerely yours,

Original signed  
by Robert H. Bryan

Robert H. Bryan, Chief  
Research & Power Reactor Safety Branch  
Division of Licensing and Regulation

Attachment:  
As stated above

Distribution

- L. Kornblith - 2
- E. G. Cole
- M. D. Mason
- M. Gaske
- Document Room

- Formal
- Supplemental
- DL&R Reading
- RGPT&S Reading

OFFICE ▶	DL&R	BL&R			
SURNAME ▶	MGaske/dmf	RHEwan			
DATE ▶	7/31/63	7/2/63			

8011100 284

0