

Centrafilas

OCT 3 1978

Docket No. 50-254  
Docket No. 50-265

Commonwealth Edison Company  
ATTN: Mr. Byron Lee, Jr.  
Vice President  
P.O. Box 767  
Chicago, IL 60690

Gentlemen:

This acknowledges your letter dated September 1, 1978, informing us of the steps you have taken to correct the noncompliance identified in our letter dated August 10, 1978. With respect to infraction number 2, we are satisfied based on your described corrective action and followup telephone conversation that the reviews of new and temporary procedures will be conducted in accordance with your technical specifications.

We are aware of the level of review that was given to your procedures that we identified in our inspection report. The review process was not in compliance with technical specification requirements even though it has been in effect since 1975. We can offer no explanation for our not focusing on your temporary procedure review process except that we could not relate previous plant problems to your review practices. The recent error involving the lock-out of the core spray pump prompted our comprehensive inspection into this area and resulted in bringing this matter to your attention.

With respect to your disagreement to paragraph 3a of our inspection report, our statement was made with reference to the initial onsite review which is given to the original safety related procedure

7810110293

Mr. Byron Lee, Jr.

- 2 -

OCT 3 1978

and not given to a temporary procedure. We will review your corrective actions during future inspections.

Sincerely,

James G. Keppler  
Director

cc: Mr. N. Kalivianakis,  
Station Superintendent  
Central Files  
Reproduction Unit NRC 20b  
PDR  
Local FDR  
NSIC  
TIC  
Anthony Roisman, Esq.,  
Attorney  
Dean Hansell, Assistant  
Attorney General

OFFICE	RIII					
SURNAME	Jackw/ch	Knop	Fiorelli	Morelius	Keppler	
DATE	9/25/78			9/21/78	10/2/78	