U. S. NUCLEAR REGULATORY COMMISSION NRC FORM 366 . (7.77) . LICENSEE EVENT REPORT (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION) 10 CONTROL BLOCK: A L J M F 1 2 0 0 - 0 0 0 0 - 0 0 3 4 1 1 1 1 1 6 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 5 0 CON'T L 6 0 5 0 0 0 3 4 8 7 1 0 1 0 7 8 8 1 1 0 7 7 8 REPORT 0 1 SOURCE EVENT DATE DOCKET NUMBER EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10) On 10/10/78, a detailed review of data acquired during the performance of FNP-1-STP-256.11, 0 2 Response Time Testing, on 9/17/78, indicated a possible faulty component in the 1-2A 03 D/G output breaker control circuit which caused excessive delay in breaker closure. 0 4 The 1-2A D/G was then declared inoperable (at 1845 on 10/10/78) to investigate and 0 5 correct the problem. T/S 3.8.1.1 requires two separate and independent D/G sets to be 0 6 operable. The 1-2A D/G was returned to an operable status at 0845 on 10/11/78. T/S 0 7 3.8.1.1 action statement requirements were met. The healty and safety of the public 0 8 were not affected. COMP VALVE CAUSE CAUSE CODE COMPONENT CODE SUBCODE SUBCODE SUBCODE CODE Z (16) X (15 U (14) (13) S R E N E 0 9 REVISION OCCURRENCE REPORT SEQUENTIAL NO. CODE TYPE LER BO EVENT YEAR REPORT NO. 0 0 3 REPORT 7 5 8 01 NUMBER 32 PRIME COMP. COMPONENT NPRD-4 ATTACHMENT EFFECT ON PLANT SHUTDOWN METHOD ACTION FUTURE TAKEN ACTION HOURS (22) FORMOUB MANUFACTURER 0 9 A (25) 3 (26) Y (24) B 0 N (23) 0 0 0 (18) Z CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27) A fuse on the 125 V DC supply for starting excitation was found blown. This resulted 10 | in the 1-2A D/G coming up to voltage with residual magnetism only, causing the long voltage buildup time. The blown fuse was replaced and a satisfactory retest was 2 performed. The time required to reach rated speed and voltage for the remaining D/G's was verified during the performance of subsequent surveillance testing. 4 80 METHOD OF DISCOVERY OTHER STATUS DISCOVERY DESCRIPTION (32) FACILITY % POWER Review of surveillance data B (31) 1 0 0 29 NA E (28) 5 80 44 46 45 12 13 ACTIVITY CONTENT LOCATION OF RELEASE (36) AMOUNT OF ACTIVITY (35) RELEASED OF RELEASE NA Z 3 Z 34 NA 6 80 EXPOSIMIES DESCRIPTION (39) NUMBER TYPE 8/11/90 292 0 0 0 (37) Z (38) NA 7 80 PERSONNEL INJURIES DESCRIPTION (41) NUMBER 50 - 348 - 5 0 0 0 40 NA 80 11 LOSS OF OR DAMAGE TO FACILITY (43) TYPE DESCRIPTION Z (42) NA 9 10 NRC USE ONLY PUBLICITY DESCRIPTION (45) N (44) NA 0 68 69 80 10 (205) 800-5156