

Georgia Power Company
230 Peachtree Street
Post Office Box 4545
Atlanta, Georgia 30303
Telephone 404 522-6060

ATLANTA, GEORGIA

Power Supply Engineering and Services



Georgia Power

the southern electric system

78 DEC 7 12:24
December 5, 1978

United States Nuclear Regulatory Commission
Directorate of Inspection and Enforcement
Region II
101 Marietta Street, N.W.
Atlanta, Georgia 30303

REFERENCE:
IE: II: WBS
50-424/78-8
50-425/78-8
File: X7BG10

ATTENTION: Mr. C. E. Murphy

Gentlemen:

The Georgia Power Company wishes to submit the following information concerning the noncompliance discussed in your inspection report number 50-424/78-8 and 50-425/78-8.

The material noted by the noncompliance has been segregated as required.

Procedures GD-A-01, "Warehouse-Receipt, Storage, and Material Issue", and GD-T-01, "Nonconformance Control", will be revised to require segregation of nonconforming material when practicable.


Procedure MD-A-01, "Receipt & Storage of Mechanical Equipment," will be revised to require inspectors to review the hold tag log to assure that the hold tag status is reviewed prior to releasing equipment.

The Georgia Power Company is confident that the above actions will greatly improve the control of nonconforming items during the receipt and storage of material and equipment. Full compliance will be achieved by January 15, 1979.

The information contained in the inspection report is not considered to be proprietary.

Very truly yours,

781228 0069


R. W. Staffa

CWH:1b

xc: J. H. Miller, Jr.
W. E. Ehrensperger
F. G. Mitchell, Jr.
C. F. Whitmer
R. J. Kelly
D. E. Dutton

C. R. Miles, Jr.
D. L. McCrary
R. A. Thomas
J. A. Bailey
J. L. Leamon
H. A. Sindt