

APPENDIX A

NOTICE OF VIOLATION

Baltimore Gas and Electric Company

Docket No. 50-317

Based on the results of an NRC inspection conducted on August 27-30 and September 10-13, 1979, it appears that one of your activities was not conducted in full compliance with conditions of your NRC Facility License No. DPR-53, as indicated below. This item is an infraction.

Environmental Technical Specification, Section 2.2.1, states in part: "The pH of a representative sample of waste solution in the neutralization tank shall be measured prior to discharge. A representative sample of waste solution in the neutralization tank shall be analyzed for total dissolved solids using standard methods prior to discharge."

Environmental Technical Specification, Section 5.5, states in part: "The systems ... shall be operated in accordance with approved operating procedures." Calvert Cliffs Procedure 01-23D, Section II.A states in part: "Ensure ... drain valve to bay DW-199 (DW-367) is shut."

Contrary to the above, on September 11, 1979, Waste Neutralizing Tank 12 drain valve, DW-367, was left open and the solution used to regenerate the makeup water demineralizer was inadvertently discharged to the bay. Additionally, a sample for analysis was not taken prior to discharge.

8002280 246

~~000000~~