NRC FORM 366
(7-77)

POOR ORIGINAL

U.S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK [ ] (1)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

[0 1] [C A P S S 1] (2) [0 0 - 0 0 0 1 0 1 - 0 0] (3) [4] [1] [1] (4) [ ] (5)

LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CONT

[0 1] REPORT SOURCE [L] (6) [0 5 0 0 0 3 1 2] (7) [0 2 0 3 8 0] (8) [0 2 2 6 8 0] (9)

DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

[0 2] On 2-3-80 during a routine tour of the Reactor Building, a "U" bolt

[0 3] bracket was found missing on pipe support No. 1-C-26085-1. The support

[0 4] is for a 3/4" line utilized as an equalizing line between the DHR system

[0 5] piping and the core flood tanks in event of an overpressure condition

[0 6] in that portion of the system.

[0 7]

[0 8]

[0 9] SYSTEM CODE [S F] (11) — CAUSE CODE [X] (12) — CAUSE SUBCODE [X] (13) — COMPONENT CODE [S U P O R T] (14) — COMP. SUBCODE [X] (15) — VALVE SUBCODE [Z] (16)

(17) LER/RO REPORT NUMBER — EVENT YEAR [8 0] — SEQUENTIAL REPORT NO. [0 0 8] — OCCURRENCE CODE [0 3] — REPORT TYPE [L] — REVISION NO. [0]

ACTION TAKEN [B] (18) — FUTURE ACTION [Z] (19) — EFFECT ON PLANT [Z] (20) — SHUTDOWN METHOD [Z] (21) — HOURS (22) [0 0 0 0] — ATTACHMENT SUBMITTED [Y] (23) — NPRD-4 FORM SUB [Y] (24) — PRIME COMP. SUPPLIER [A] (25) — COMPONENT MANUFACTURER [B 2 0 9] (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

[1 0] Either through some maintenance evolution in the past or during construc-

[1 1] tion, the "U" bolt bracket was probably removed and not reinstalled. The

[1 2] "U" bolt bracket will be reinstalled prior to returning to power operation

[1 3] following the present refueling outage.

[1 4]

FACILITY STATUS [H] (28) — % POWER [0 0 0] (29) — OTHER STATUS (30) N/A — METHOD OF DISCOVERY [B] (31) — DISCOVERY DESCRIPTION (32) Routine Plant Tour

ACTIVITY RELEASED [Z] (33) — CONTENT OF RELEASE [Z] (34) — AMOUNT OF ACTIVITY (35) N/A — LOCATION OF RELEASE (36) N/A

PERSONNEL EXPOSURES — NUMBER [0 0 0] (37) — TYPE [Z] (38) — DESCRIPTION (39) N/A

PERSONNEL INJURIES — NUMBER [0 0 0] (40) — DESCRIPTION (41) N/A

LOSS OF OR DAMAGE TO FACILITY — TYPE [Z] (42) — DESCRIPTION N/A

PUBLICITY — ISSUED [Y] (43) — DESCRIPTION Local newspaper & wire 2/14/80.

NRC USE ONLY

NAME OF PREPARER R. W. Colombo — PHONE (916)452-3211

8003060 560