

Docket

Docket No. 50-344

Mr. Charles Goodwin, Jr.
Assistant Vice President
Portland General Electric Company
121 S.W. Salmon Street
Portland, Oregon 97204

CC: D Brinkman
P. Wagner

Dear Mr. Goodwin:

SUBJECT: INADVERTENT SAFETY INJECTION DURING COOLDOWN

The Division of Operating Reactors has completed a generic bounding review on this subject and concludes that no further licensing action is necessary at this time since it is likely that a facility could withstand more than fifty inadvertent ECCS actuations. We have concluded, however, that it would be prudent, should a facility experience more than twenty-five such injections, for you to consider a plant specific analysis for that facility which would identify more precisely the additional number of actuations that can be safely accommodated at that facility.

A copy of our Safety Evaluation Report is enclosed.

Sincerely,

A. Schwencer, Chief
Operating Reactors Branch #1
Division of Operating Reactors

Enclosure:
Safety Evaluation

cc: w/enclosure
See next page

POOR ORIGINAL

OFFICE	DOR:ORB1	DOR:ORB1			
SURNAME	CMT:raume	1:jbASchwencer			8008060633
DATE	12/13/79	12/13/79			