Docket Nos. 50-266 and 50-301

CC. D

Mr. Sol Burstein Executive Vice President Wisconsin Electric Power Company 231 West Michigan Street Milwaukee, Wisconsin 53201

Dear Mr. Burstein:

SUBJECT: INADVERTENT SAFETY INJECTION DURING COOLDOWN

The Division of Operating Reactors has completed a generic bounding review on this subject and concludes that no further licensing action is necessary at this time since it is likely that a facility could withstand more than fifty inadvertent ECCS actuations. We have concluded, however, that it would be prudent, should a facility experience more than twenty-five such injections, for you to consider a plant specific analysis for that facility which would identify more precisely the additional number of actuations that can be safely accommodated at that facility.

A copy of our Safety Evaluation Report is enclosed.

Sincerely,

Original signed by

A. Schwencer, Chief Operating Reactors Branch #1 Division of Operating Reactors

Enclosure: Safety Evaluation

cc: w/enclosure See next page

Λ.			8003060639		
arrest)	DOR : DANN	DOR STRET			
SURFIAME	CMTremmel1:	DOR STRET			
BATE	12/13/79	12/21/79			