




**ZION STATION RESTORATION PROJECT
FINAL STATUS SURVEY RELEASE RECORD**

**AUXILIARY BUILDING PENETRATIONS
SURVEY UNIT 05120**



PREPARED BY / DATE:  2019-09-01
Robert Massengill, Radiological Engineer

REVIEWED BY / DATE:  2019-09-01
Robert Decker, Radiological Engineer


APPROVED BY / DATE:  2019-09-01
David Wojtkowiak, C/LT Manager

TABLE OF CONTENTS

1. EXECUTIVE SUMMARY6

2. SURVEY UNIT DESCRIPTION7

3. CLASSIFICATION BASIS9

4. DATA QUALITY OBJECTIVES (DQO) 10

5. SURVEY DESIGN 14

6. SURVEY IMPLEMENTATION 18

7. SURVEY RESULTS20

8. QUALITY CONTROL24

9. INVESTIGATIONS AND RESULTS24

10. REMEDIATION AND RESULTS.....24

11. CHANGES FROM THE FINAL STATUS SURVEY PLAN24

12. DATA QUALITY ASSESSMENT (DQA).....24

13. ANOMALIES25

14. CONCLUSION.....25

15. REFERENCES26

16. ATTACHMENTS.....27

 ATTACHMENT 1 28

 ATTACHMENT 2 30

 ATTACHMENT 3 44

 ATTACHMENT 4 47

 ATTACHMENT 5 49

 ATTACHMENT 6 51

LIST OF TABLES

Table 1 - Dose Significant Radionuclides and Mixture.....	11
Table 2 - Base Case DCGLs for Penetrations (BcDCGL _{PN}) from LTP Chapter 5, Table 5-13 ...	13
Table 3 - Auxiliary Building Operational DCGLs for Penetrations (OpDCGL _{PN}) from LTP Chapter 5, Table 5-14	13
Table 4 - Auxiliary Building Surrogate Ratios	15
Table 5 - Survey Unit 05120 FSS Instrumentation and Action Levels	16
Table 6 – Investigation Levels	17
Table 7 - Systematic Static Locations for Hand-Held Survey	18
Table 8 - Auxiliary Building Penetrations Summary	22
Table 9 - Auxiliary Building Penetrations FSS Statistics Summary using Auxiliary Building BcDCGL _{PN}	23

LIST OF ACRONYMS AND ABBREVIATIONS

ALARA	As Low As Reasonably Achievable
AMCG	Average Member of the Critical Group
BFM	Basement Fill Model
DQA	Data Quality Assessment
DQO	Data Quality Objective
DCGL	Derived Concentration Guideline Level
EMC	Elevated Measurement Comparison
FOV	Field-of-View
FSS	Final Status Survey
IC	Insignificant Contributor
ID	Internal Diameter
LTP	License Termination Plan
MARSSIM	Multi-Agency Radiation Survey and Site Investigation Manual
MDC	Minimum Detectable Concentration
NaI	Sodium Iodide
QAPP	Quality Assurance Project Plan
OpDCGL	Operational Derived Concentration Guideline Level
QC	Quality Control
RE	Radiological Engineer
ROC	Radionuclides of Concern
SOF	Sum-of-Fraction
TSD	Technical Support Document
ZNPS	Zion Nuclear Power Station
ZSRP	Zion Station Restoration Project

1. EXECUTIVE SUMMARY

This Final Status Survey (FSS) Release Record for survey unit 05120, “Auxiliary Building Penetrations”, has been generated for the Zion Station Restoration Project (ZSRP) in accordance with ZionSolutions procedure ZS-LT-300-001-005, “*Final Status Survey Data Reporting*” (Reference 1) and satisfies the requirements of Section 5.11 of the “*Zion Station Restoration Project License Termination Plan*” (LTP) (Reference 2).

Two (2) Final Status Survey (FSS) sample plans (S1-05120A-F #1 and S1-05120A-F #2) were developed to perform this work in accordance with ZionSolutions procedure ZS-LT-300-001-001, “*Final Status Survey Package Development*” (Reference 3), the ZSRP LTP, and with guidance from NUREG-1575, “*Multi-Agency Radiation Survey and Site Investigation Manual*” (MARSSIM) (Reference 4).

Final Status Survey was performed to demonstrate that the concentrations of residual radioactivity on the interior surfaces of the penetrations were equal to or below site-specific Derived Concentration Guideline Levels (DCGL) corresponding to the dose criterion in 10 CFR 20.1402. Initially, the penetrations were segregated and classified in accordance with the type of system and system use. However, in a conservative measure to ensure that all accessible surfaces within each end-state penetration would be subjected to FSS, the classification of all penetrations was changed to Class 1.

Two (2) different survey approaches were used for FSS depending on the diameter, length and access to the penetrations. FSS measurements acquired under FSS sample plan #1, which was applicable to penetrations with an internal diameter (ID) less than 12 inches, consisted of a static measurement taken at 1-foot intervals inside the penetration using a sodium iodide (NaI), conservatively assuming a Field-of-View (FOV) of 1-foot for each measurement and thus providing 100% areal coverage of the accessible internal surfaces of the penetration.

FSS measurements acquired under FSS sample plan #2, which was applicable to penetrations with an ID greater than 12 inches, consisted of a 100% scan with a hand-held beta-gamma detector of the interior surface area of the penetration and at least one (1) 1-minute static gross beta-gamma measurement at a systematic location based on a triangular grid and a 1-minute static measurement at the location of the highest observed scan result in each penetration.

For the FSS of the Auxiliary Building Penetrations, sixty-six (66) measurements were obtained. LTP Chapter 6, section 6.4.5 states, “The dose from penetrations is summed with the dose from the wall and floor surfaces of both basements that the penetration interface.” Containment DCGLs are more limiting than the Auxiliary Building DCGLs. Consequently, the penetrations identified as interfacing between the Auxiliary Building

and the Unit 1 and Unit 2 Containments were addressed in the Release Records for Unit 1 and Unit 2 Containment Penetrations. In order to comply with the requirements of LTP Chapter 6, section 6.4.5, a dose of 1.468 mrem/yr will be added to the Auxiliary Building basement survey unit from penetrations that interfaced between the Auxiliary Building and Unit 1 Containment and a dose of 0.206 mrem/yr will be added to the Auxiliary Building basement survey unit from penetrations that interfaced between the Auxiliary Building and Unit 2 Containment. The Auxiliary Building penetrations addressed in this Release Record interfaced with the Turbine Building (via the “G” wall and Steam Tunnels). Consequently, the FSS design for penetrations that interfaced between the Auxiliary Building and the Turbine Building employed the DCGLs for the Auxiliary Building penetrations, which were the most limiting. However, the mean concentration for each Radionuclide-of-Concern (ROC) was also compared against the Base Case Penetration DCGLs ($BcDCGL_{PN}$) for the Turbine Building as well.

No single measurement taken in any penetration exceeded an Operational Sum of Fraction (OpSOF) of one (1) when compared against the Operational DCGLs ($OpDCGL_{PN}$) for Auxiliary Building Penetrations. When compared against the $BcDCGL_{PN}$ for the Auxiliary Building, the FSS results produced a mean Base Case SOF ($BcSOF$) for the survey unit of 0.002, which equates to a mean dose of 0.053 mrem/yr.

No penetration exceeded the Auxiliary Building $OpDCGL_{PN}$ or $BcDCGL_{PN}$. However, in accordance with LTP Chapter 5 section 5.5.5, two (2) of the penetrations required grouting as they had measurements with activity greater than the Turbine Building $OpDCGL$ for surfaces. Grouting of the two (2) penetrations was performed prior to backfill and there was no dose reduction attributed to the survey unit because of grouting.

2. SURVEY UNIT DESCRIPTION

In accordance with the definition of penetrations specified in LTP Chapter 5, section 5.5.5, “The end state will include embedded piping and penetrations. An embedded pipe is defined as a pipe that runs vertically through a concrete wall or horizontally through a concrete floor and is contained within a given building. A penetration is defined as a pipe (or remaining pipe sleeve, if the pipe is removed, or concrete, if the pipe and pipe sleeve is removed) that runs through a concrete wall and/or floor, between two buildings, and is open at the wall or floor surface of each building. A penetration could also be a pipe that runs through a concrete wall and/or floor and opens to a building on one end and the outside ground on the other end.”

A summary of the original End State lengths and surface areas for the Auxiliary Building Penetrations as depicted in ZionSolutions Technical Support Document (TSD) 14-016, “Description of Embedded Piping, Penetrations, and Buried Pipe to Remain in Zion End State” (Reference 5), Attachment F. Locations are shown in Attachment 1 of this Release Record.

The Auxiliary Building penetrations survey unit consists of one hundred five (105) penetrations that access the Auxiliary Building between the 542 foot, 560 foot and the 579 foot elevations. However, seventy-nine (79) of the 105 penetrations are identified as being both an Auxiliary Building and Containment Building penetration. Since the Containment DCGLs are more limiting than the Auxiliary Building DCGLs, the penetrations identified as being both Auxiliary and Containment were addressed in the Release Records for Unit 1 and Unit 2 Containment Penetrations.

The remaining twenty-six (26) penetrations that access the Auxiliary Building between the 542, 560 and the 579 foot elevations, but do not access the Containments, are A001-A025, and A034. These penetrations interface between the Auxiliary Building and the Turbine Building primarily through the “G” wall and through the north and south walls into the Unit 1 and Unit 2 Steam Tunnels.

In accordance with LTP Chapter 5, section 5.5.5, penetration survey units have total surface areas that are less than the area of the wall/floor surface survey unit that the penetrations interface. To eliminate the potential for activity levels in penetrations that could lead to releases greater than the adjacent basement walls and floors, the following remediation and grouting action levels were applied to measurements of surface activity in penetrations.

- If maximum activity exceeded the $BcDCGL_{PN}$ from LTP Chapter 5, Table 5-13 ($BcSOF > 1$), then remediation was performed.
- If the maximum activity in a penetration exceeded the most limiting $OpDCGL_B$ from LTP Chapter 5, Table 5-4 of the two basements where a penetrations interface ($OpSOF > 1$), but is below the $BcDCGL_{PN}$ from LTP Chapter 5, Table 5-13, then the penetration was remediated or grouted.
- If a penetration was remediated and the maximum activity continued to exceed the most limiting $OpDCGL_B$ from LTP Chapter 5, Table 5-4 of the two basements where a penetrations interface ($OpSOF > 1$), but was less than the $OpDCGL_{PN}$ (LTP Chapter 5, Table 5-14), then the penetration was grouted.
- If the maximum activity was below the surface $OpDCGL_B$ from LTP Chapter 5, Table 5-4, then grouting of the penetration was not required.

3. CLASSIFICATION BASIS

Survey unit 05120 was classified in accordance with *ZionSolutions* procedure ZS-LT-300-001-002, “*Survey Unit Classification*” (Reference 6).

The Auxiliary Building Penetrations were initially classified as Class 1, Class 2, or Class 3 based on historical assessment, exposure to radioactive materials and system use. As a conservative measure, the classifications of all Auxiliary Building Penetrations were changed to Class 1. Consequently, sufficient measurements were taken in all Auxiliary Building Penetrations to ensure 100% areal coverage of all accessible internal surfaces within the penetrations.

The Auxiliary Building housed numerous systems containing radioactively contaminated support systems. System leakage and maintenance activities over the operating life of the reactor resulted in the radiological contamination of most of the interior surfaces of the structures. Based on the building design basis and the operating history, all internal survey units in Auxiliary Building were assigned an initial classification of Class 1 in accordance with the “*Zion Station Historical Site Assessment*” (HSA) (Reference 7).

The Auxiliary Building penetrations housed numerous systems including the following:

- Service and primary water,
- Feed and demineralizer water,
- Fire protection,
- Vent and drain,
- Secondary sample,
- Waste disposal,
- Chemical addition,
- Vacuum control, and
- Condensate.

The location of the penetrations, their function, and the operational history of the Auxiliary Building to support the initial classifications are described in TSD 14-016.

In accordance with *ZionSolutions* TSD 14-013, “*Zion Auxiliary Building End State Estimated Concrete Volumes, Surface Areas, and Source Terms*” (Reference 8), there were seventeen (17) concrete core samples from the floors and three (3) cores from the walls that were obtained for analysis. The on-site gamma spectroscopy results for the sectioned cores from the 542 foot elevation initial characterization may be found in TSD 14-013. All radioactive systems and components were still located inside the building, consequently ambient radiation dose rates inside the Auxiliary Building prohibited the

direct assessment of penetrations or system interior surfaces by scanning or direct measurement.

As part of the survey unit turnover process, a Radiological Engineer (RE) performed the visual inspection and walk-down of the survey unit on March 27, 2018. The purpose of the walk-down was to assess the physical condition of the survey unit, evaluate access points and travel paths and identify potentially hazardous conditions and determine if the survey unit was acceptable for performing FSS.

The Auxiliary Building Penetrations were initially classified as Class 1, Class 2, or Class 3, based on historical assessment, exposure to radioactive materials and system use. Based upon completion of the Survey Unit Classification Basis for final classification, which included a review of the historical information, the results of the Characterization Survey data and completion of a final Survey Unit Classification Worksheet, the correct final classification of penetrations within the Auxiliary Building were validated. As a conservative measure, the classifications of all Auxiliary Building Penetrations were changed to Class 1. Consequently, sufficient measurements were taken in all Auxiliary Building Penetrations to ensure 100% areal coverage of all accessible internal surfaces within the penetrations.

4. DATA QUALITY OBJECTIVES (DQO)

Final Status Survey planning and design hinges on coherence with the DQO process to ensure, through compliance with explicitly defined inputs and boundaries, that the primary objective of the survey is satisfied. The DQO process is described in the ZSRP LTP Chapter 5, section 5.6.2 in accordance with MARSSIM. The appropriate design for a given survey was developed using the DQO process as outlined in Appendix D of MARSSIM.

The DQO process incorporated hypothesis testing and probabilistic sampling distributions to control decision errors during data analysis. Hypothesis testing is a process based on the scientific method that compares a baseline condition to an alternate condition. The baseline condition is technically known as the null hypothesis. Hypothesis testing rests on the premise that the null hypothesis is true and that sufficient evidence must be provided for rejection. In designing the survey plan, the underlying assumption, or null hypothesis was that residual activity in the survey unit exceeded the release criteria. Rejection of the null hypothesis would indicate that residual activity within the survey unit does not exceed the release criteria. Therefore, the survey unit would satisfy the primary objective of the FSS sample plan.

The primary objective of the FSS sample plan is to demonstrate that the level of residual radioactivity in the penetrations that comprised survey unit 05120 did not exceed the

release criteria specified in the LTP and that the potential dose from residual radioactivity is As Low As Reasonably Achievable (ALARA).

ZionSolutions TSD 11-001, “*Technical Support Document for Potential Radionuclides of Concern During the Decommissioning of the Zion Station*” (Reference 10) established the basis for an initial suite of potential ROC for the decommissioning of the Zion Nuclear Power Station (ZNPS). LTP Chapter 6, section 6.5.2 discusses the process used to derive the ROC for the decommissioning of ZNPS, including the elimination of insignificant dose contributors (IC) from the initial suite. Table 1 presents the ROC for the Auxiliary Building basement structural surfaces and the normalized fractions based on the radionuclide mixture.

Table 1 - Dose Significant Radionuclides and Mixture

Radionuclide	% of Total Activity (normalized)⁽¹⁾
Co-60	0.92
Ni-63	23.71
Sr-90	0.05
Cs-134	0.01
Cs-137	75.32

(1) Based on maximum percent of total activity from Table 20 of TSD 14-019, normalized to one for the dose significant radionuclides.

A fundamental precursor to survey design is to establish a relationship between the release criteria and some measurable quantity. This is done through the development of DCGLs. The DCGLs represent average levels of radioactivity above background levels and are presented in terms of surface or mass activity concentrations. Chapter 6 of the LTP describes in detail the modeling used to develop the DCGLs for penetrations.

The End State Basements are comprised of steel and/or concrete structures which will be covered by at least three feet of clean soil and physically altered to a condition which would not realistically allow the remaining structures, if excavated, to be occupied. The exposure pathways in the Basement Fill Model (BFM) are associated with residual radioactivity in floors and walls that is released through leaching into water contained in the interstitial spaces of the fill material. The BFM assumes that the inventory of residual radioactivity in a given building is released either instantly or over time by diffusion, depending on whether the activity is surficial or volumetric, respectively. The activity released into the fill water will adsorb into the clean fill, as a function of the radionuclide-specific distribution coefficients, resulting in equilibrium concentrations between the fill and the water. Consequently, the only potential exposure pathways after backfill,

assuming the ‘as-left’ geometry, are associated with the residual radioactivity in the water contained in the fill.

The final outputs of the BFM are the Penetration DCGLs, in units of pCi/m², which are calculated using the BFM Groundwater and BFM Drilling Spoils Dose Factors (LTP Chapter 6, Tables 6-24 and 6-25), LTP Equation 6-10 and the ratios in LTP Table 6-51. The BcDCGL_{PN} are radionuclide-specific concentrations that represent the 10 CFR 20.1402 dose criterion of 25 mrem/yr and are calculated for each ROC and each backfilled basement. The “unity rule” is applied when there is more than one ROC. The measurement results for each singular ROC present in the mixture are compared against their respective DCGL to derive a dose fraction.

The BcDCGL_{PN} for the unrestricted release of the Auxiliary Building penetrations are provided in Table 2. The IC dose percentage of 5% was used to adjust the Auxiliary Building Basement DCGL_{PN} to account for the dose from the eliminated IC radionuclides.

Each radionuclide-specific BcDCGL_{PN} is equivalent to the level of residual radioactivity (above background levels) that could, when considered independently, result in a Total Effective Dose Equivalent (TEDE) of 25 mrem/yr to an Average Member of the Critical Group (AMCG). To ensure that the summation of dose from each source term is 25 mrem/yr or less after all FSS is completed, the BcDCGL_{PN} are reduced based on an expected, or *a priori*, fraction of the 25 mrem/yr dose limit from each source term. The reduced DCGL_{PN}, or OpDCGL_{PN} can be related to the BcDCGL_{PN} as an expected fraction of dose based on an *a priori* assessment of what the expected dose should be based on the results of site characterization, process knowledge and the extent of planned remediation. The OpDCGL_{PN} is then used as the DCGL for the FSS design of the survey unit (calculation of surrogate DCGLs, investigations levels, etc.). Details of the OpDCGL_{PN} derived for each dose component and the basis for the applied *a priori* dose fractions are provided in ZionSolutions TSD 17-004, “Operational Derived Concentration Guideline Levels for Final Status Survey” (Reference 11).

Table 2 - Base Case DCGLs for Penetrations (BcDCGL_{PN}) from LTP Chapter 5, Table 5-13

Radionuclide	Auxiliary Building BcDCGL _{PN} (pCi/m ²)
Co-60	8.82E+07
Ni-63	6.79E+10
Sr-90	2.41E+07
Cs-134	3.28E+08
Cs-137	6.17E+08

The OpDCGL_{PN} for the unrestricted release of the Auxiliary Basement penetrations are provided in Table 3.

Table 3 - Auxiliary Building Operational DCGLs for Penetrations (OpDCGL_{PN}) from LTP Chapter 5, Table 5-14

Radionuclide	Operational DCGL (pCi/m ²)
Co-60	6.95E+06
Ni-63	5.35E+09
Sr-90	1.90E+06
Cs-134	2.58E+07
Cs-137	4.86E+07

Instrument DQOs included a verification of the ability of the survey instrument to detect the radiation(s) of interest relative to the OpDCGL_{PN}. Survey instrument response checks were required prior to issuance and after the instrument had been used. Control and accountability of survey instruments was required to assure the quality and prevent the loss of data. The minimum acceptable minimum detectable concentration (MDC) for measurements obtained using field instruments was 50 percent of the applicable OpDCGL_{PN}.

5. SURVEY DESIGN

The level of effort associated with planning a survey is based on the complexity of the survey and nature of the hazards. Guidance for preparing FSS plans is provided in procedure ZS-LT-300-001-001 “*Final Status Survey Package Development.*” The FSS plans for the survey of penetrations employed sample designs that combined hand-held scanning with static measurements and pipe detector survey methodologies.

The two (2) FSS sample plans for survey unit 05120, “Auxiliary Building Penetrations” includes FSS design and FSS results for the Auxiliary Building penetrations on the 542 foot, 560 foot and the 572 foot elevations. The survey method for large diameter penetrations (>12”) differs from smaller penetrations due to measurement sensitivity (i.e., MDCs) differences in the two size regimes. The larger penetrations were surveyed using a similar approach to traditional building surface surveys, whereas the smaller penetrations were surveyed with a single detector advanced through the length in 1-foot increments and centrally positioned. Sample plan #S1-05120A-F #1 addressed the survey of penetrations smaller than 12 inches in diameter (A002, A003, A005, A007-A013, A015, A017 and A019-A023) and sample plan #S1-05120A-F #2 addressed that survey of penetrations with a diameter greater than or equal to 12 inches in diameter (A001, A004, A014, A024 and A025).

Penetrations and buried pipe associated with the west wall of the Auxiliary Building (Unit 1 and Unit 2 Hot Pipe Chases at the 570 foot elevation and buried pipe associated with the SFP) have been physically removed and disposed of as radioactive waste. The penetrations that were removed in its entirety were A006, A016, A018, A029, A034, A037, A038, A039, A040, A041, A042, A043, A044, A046, A047, A048, A049, A050, A052, A053, A054, A055, A056, A057, A058, A059, A060, A061, A063, A064, A065, and A066.

There are twenty-two (22) penetrations that remain in Auxiliary Building that were not attributed to the Containments. The remaining penetrations are located primarily on the “G” Wall between the Auxiliary Building and the Turbine Building.

FSS of the remaining twenty-two (22) penetrations consisted of sixty-six (66) one-minute static measurements, either using a NaI detector or hand-held detector taken at 1-foot intervals throughout the length of the penetrations, providing 100% areal coverage of the pipe interior surface.

Section 5.1 of LTP Chapter 5 states that Co-60, Ni-63, Sr-90, Cs-134, and Cs-137 are the ROC. During FSS, concentrations for Hard-to-Detect (HTD) ROC Ni-63, and Sr-90 are inferred using a surrogate approach. Cs-137 is the principle surrogate radionuclide for Sr-90, and Co-60 is the principle surrogate radionuclide for Ni-63. The mean, maximum

and 95% Upper Confidence Level (UCL) of the surrogate ratios for concrete core samples taken in the Auxiliary Building basements were calculated in ZionSolutions TSD 14-019, “Radionuclides of Concern for Soil and Basement Fill Model Source Terms” (Reference 12) and are presented in Table 4 (reproduced from LTP Chapter 5, Table 5-12). The maximum ratios were used in the surrogate calculations during FSS.

Table 4 - Auxiliary Building Surrogate Ratios

Ratios	Auxiliary Building		
	Mean	Max	95%UCL
Ni-63/Co-60	44.143	180.450	154.632
Sr-90/Cs-137	0.001	0.002	0.002

For the FSS of survey unit 05120, the surrogate OpDCGL_{PN} for Co-60 and Cs-137 were computed based on the maximum ratios from Table 4.

The equation for calculating a surrogate DCGL is as follows:

Equation 1

$$Surrogate_{DCGL} = \frac{1}{\left[\left(\frac{1}{DCGL_{Sur}} \right) + \left(\frac{R_2}{DCGL_2} \right) + \left(\frac{R_3}{DCGL_3} \right) + \dots + \left(\frac{R_n}{DCGL_n} \right) \right]}$$

Where: $DCGL_{Sur}$ = Surrogate radionuclide DCGL

$DCGL_{2,3,\dots,n}$ = DCGL for radionuclides to be represented by the surrogate

R_n = Ratio of concentration (or nuclide mixture fraction) of radionuclide “n” to surrogate radionuclide

Using the OpDCGL_{PN} presented in Table 3 and the maximum ratios from Table 4, the following surrogate calculations were performed:

Equation 2

$$Surrogate_{DCGL(Cs-137)} = \frac{1}{\left[\left(\frac{1}{4.86E07_{(Cs-137)}} \right) + \left(\frac{0.002}{1.90E06_{(Sr-90)}} \right) \right]} = 4.62E07 \text{ pCi/m}^2$$

The surrogate OpDCGL_{PN} that was used for Cs-137 in this survey unit for direct comparison of sample results to demonstrate compliance is 4.62E+07 pCi/m².

Equation 3

$$Surrogate_{DCGL (Co-60)} = \frac{1}{\left[\left(\frac{1}{6.95E06_{(Co-60)}} \right) + \left(\frac{180.45}{5.35E09_{(Ni-63)}} \right) \right]} = 5.63E06 \text{ pCi/m}^2$$

The surrogate OpDCGL_{PN} that was used for Co-60 in this survey unit for direct comparison of sample results to demonstrate compliance is 5.63E+06 pCi/m².

The most limiting DCGL was determined to be Co-60 (5.63E+06 pCi/m²) or 1.25E+05 dpm/100 cm². This value was used as the action level for hand-held scan and static measurements and pipe detector static measurements in this survey unit. Action levels in counts per minute (cpm) for pipe detector surveys were calculated using the limiting Co-60 surrogate OpDCGL_{PN}, the effective area of detection for the various diameter penetrations, and the associated efficiency for each size penetration. The action levels in cpm for hand-held surveys were calculated using the limiting Co-60 OpDCGL_{PN} and the efficiency of the instrument/detector combination. Table 5 provides a summary of the instrumentation and action levels used for the FSS of the penetrations.

Table 5 - Survey Unit 05120 FSS Instrumentation and Action Levels

Survey Type	Instrument	Detector	Penetration Diameter (in)	Efficiency	Action Level (cpm)
Hand-held	Ludlum 2360	Ludlum 43-93	14-50	0.117 ⁽¹⁾	14,600
Pipe Detector	Ludlum 2350-1	Ludlum 44-157	6	0.012 ⁽²⁾	32,695
			8	0.009 ⁽²⁾	32,751
		Ludlum 44-162	10	0.018 ⁽²⁾	81,625
			12	0.016 ⁽²⁾	87,186
			23	0.0142 ⁽²⁾	148,131

(1) Efficiency determined using Tc-99 source. Derived instrument efficiency of 0.144 x source efficiency of 0.81 (NUREG-1507, Table 5.4) = 0.117 (total efficiency)

(2) Efficiency empirically derived using conformable Cs-137 source in various ID pipe jigs

For this Class 1 penetration survey unit, the “Investigation Levels” for area scanning and static measurement results are those levels specified in LTP Chapter 5, Table 5-25 and are reproduced below in Table 6.

Table 6 – Investigation Levels

Classification	Scan Investigation Levels	Direct Investigation Levels
Class 1	>Operational DCGL or >MDC _{scan} if MDC _{scan} is greater than Operational DCGL	>Operational DCGL

Two (2) survey methodologies were utilized for the FSS of the Auxiliary Building Penetrations, pipe detector survey or hand-held survey. This was due to the varying diameters and lengths of the penetrations. The survey designs for the FSS of Survey Unit 05120 using the different methodologies are detailed below.

The first sample plan required that measurements be collected with a pipe detector. Penetrations included in this plan were twelve (12) inches in diameter or smaller. Seventeen (17) of the twenty-two (22) total penetrations were included in the survey design for pipe detectors. Refer to Table 5 for the FSS instrumentation summary. The total length of the penetrations under the pipe detector methodology is 51 ft. (15.54 m) with a total interior surface area of 6.98 m². As a Class 1 survey unit, the survey design required a 100% areal coverage. For the survey of pipe or penetration internal surfaces that cannot be practically surveyed using a hand-held detector methodology, areal coverage is achieved by the “area of detection” for each static measurement taken. Scanning, in the traditional context, is not applicable to this type of survey. With a 1-foot area of detection, a 1-minute static measurement at 1-foot increments throughout the penetration length was sufficient to provide 100% areal coverage. For 51 feet of penetrations in the survey unit, at least fifty-one (51) measurements were required to satisfy the 100% coverage requirement.

Sample plan #2 required that measurements be collected with a hand-held detector. Penetrations included in sample plan #2 were larger than twelve (12) inches in diameter. Five (5) of the twenty-two (22) total penetrations were included in the survey design for hand-held detectors. Refer to Table 5 for the FSS instrumentation summary. The total length of the penetrations under the hand-held methodology is 15 ft. (4.572 m) with a total interior surface area of 8.90 m². For the survey of these larger diameter pipes, the survey design required 100% scan of the accessible interior surfaces of the penetration. In addition, a minimum of one 1-minute static measurement was acquired in each penetration at systematic locations based on a triangular grid, and at least one 1-minute static measurement was acquired in each penetration at the location of the highest scan result. Seventeen (17) static measurements (15 systematic and 2 QC) were acquired in the large diameter penetrations with the locations selected as denoted in Table 7 below.

Maps of the penetrations and measurement locations are provided in Attachment 1.

Table 7 - Systematic Static Locations for Hand-Held Survey

Measurement No.	Penetration No.	Inches into Penetration ⁽¹⁾
1	A001	12
2	A001	24
3	A001	36
4	A014	12
5	A014	24
6	A014	36
7	A014	36
8	A004	12
9	A004	24
10	A004	36
11	A024	12
12	A024	24
13	A024	36
14	A025	12
15	A025	24
16	A025	36
17	A025	36

(1) Static measurements were acquired on the bottom of the penetration circumference.

The implementation of quality control measures as referenced by LTP Chapter 5, section 5.9 and ZionSolutions ZS-LT-01, “*Quality Assurance Project Plan (for Characterization and FSS)*” (QAPP) (Reference 13) includes the collection of a duplicate measurement on 5% of the measurements taken with the locations selected at random. One (1) measurement out of every twenty (20) was required for QC compliance.

6. SURVEY IMPLEMENTATION

Survey instructions for this FSS were incorporated into and performed in accordance with FSS sample plans #S1-05120AF #1 and #2, which were developed in accordance with ZionSolutions procedure ZS-LT-300-001-001, “*Final Status Survey Package Development.*” The FSS unit was inspected and controlled in accordance with

ZionSolutions procedure ZS-LT-300-001-003, “*Isolation and Control for Final Status Survey*” (Reference 14).

Surveys of the Auxiliary Building Penetrations began on March 27, 2018 and concluded on March 28, 2018. The survey design estimated seven (7) working days to implement the FSS in parallel with any required decontamination and inspection activities. In reality, only two (2) working days were necessary to complete this work. Throughout these activities, briefings were conducted on a daily basis to discuss the expectations for job performance and to review the safety aspects of the job.

Visual inspections of the penetrations were performed prior to the start of the survey. Inspections were performed to ensure that the penetrations were relatively dry and free of debris.

For pipe detector surveys using a NaI detector, a background value was determined for the detector/instrument combination to be used prior to deployment. The background value was obtained at the location where the pre-use response check of the instrument was performed. The background value was primarily used to ensure that the detector had not become cross-contaminated by any previous use. Background was not subtracted from any measurement.

Daily, prior to and following use, each detector was subjected to an Operational Response Check in accordance with procedure ZS-LT-300-001-006, “*Radiation Surveys of Pipe Interiors Using Sodium/Cesium Iodide Detectors*” (Reference 15). The Daily Operational Response Check compared the background response to check source ranges established for normal background and detector source response. This check ensured that the detector was working properly.

Once the detector was determined to be fully functional, it was then deployed to the field for insertion into the targeted penetrations. A one-minute static measurement was acquired at each foot traversed into the penetrations. The detector output represented the gamma activity for each one-minute timed measurement in units of gross cpm. The gamma measurement value in units of cpm was then converted to units of dpm using the efficiency factor for the detector applicable to the diameter of the penetration surveyed.

Each measurement assumed a conservative “area of detection” for the NaI detector of one foot. This assumption is conservative because there is additional instrument response from contamination located in the pipe at distances outside of the “area of detection.” Consequently, the total activity from the measurement, in units of dpm, is adjusted for the total effective surface area commensurate with the penetration diameter and the assumed “area of detection,” resulting in measurement results in units of $\text{dpm}/100 \text{ cm}^2$. Using the appropriate conversion factors, the result is then converted to units of pCi/m^2 . This

measurement result represents a commensurate and conservative gamma surface activity for the one foot of pipe surface where the measurement was taken.

For the penetration surveys performed with hand-held detectors, a background value was determined for the detector/instrument combination as the average of five (5) ambient 1-minute static measurements. An Alarm Set Point was developed using the background value plus the Action Level dictated in Table 5.

The entire surface area (100%) of the interior surface area of the designated penetrations were scanned using either the Ludlum 2350-1 paired with a pipe detector or a Ludlum 2360 paired with a Ludlum 43-93 detector operated in the rate-meter mode and using audio response. The probe was positioned as close to the surface as possible and was moved at a scan speed of 2.0 inches per second.

Systematic 1-minute static measurements were acquired at the locations denoted in Table 6. Additionally, 1-minute static measurements were taken at the locations of highest scan result in each penetration. Using the established efficiencies (denoted in Table 5), the static measurement activities in cpm were converted to activities in dpm/100 cm² and then to pCi/m² using the appropriate conversion factor.

7. SURVEY RESULTS

After completion of the FSS measurements in the penetrations, the sample plan was reviewed to confirm the completeness of the survey and the survey data was validated in accordance with procedure ZS-LT-300-001-004, "*Final Status Survey Data Assessment*" (Reference 16). Data processing included converting measurement data into reporting units, validating instrument applicability and sensitivity, calculating relevant statistical quantities, and verification that all DQO have been met.

For measurements acquired with a NaI detector, the gross output of the measurement is converted to units of dpm by dividing by the efficiency. The effective FOV of the measurement is calculated based upon diameter of the pipe at a length of 1 foot. The result, following unit conversion, is a gross gamma measurement result in units of pCi/m².

For measurements acquired as a direct static measurement with a hand-held detector, the gross gamma output of the measurement is again converted to units of dpm by dividing by the efficiency. As the detector has an area of 100 cm², the units for the measurement are actually in units of dpm/100cm². Again, through unit conversion, units of dpm/100cm² are converted to units of pCi/m².

Using the mixture from Table 5-2 of LTP Chapter 5 (reproduced as Table 1 of this Release Record), the gross gamma result from each measurement is multiplied by the

normalized gamma mixture fractions for C-60, Cs-134 and Cs-137 to derive a radionuclide specific concentration for each gamma ROC. The HTD ROC concentrations for Ni-63 and Sr-90 were then inferred using the maximum surrogate ratios from LTP Chapter 5, Table 5-15 (reproduced as Table 4 of this Release Record). Each concentration for each measurement is then compared against the $OpDCGL_{PN}$ to produce an OpSOF for each ROC, which were when summed to derive an OpSOF for the measurement.

In accordance with LTP Chapter 5 section 5.5.5, penetration survey units also have total surface areas that are less than the area of the wall/floor surface survey unit that the penetrations interface. To eliminate the potential for activity levels in penetrations that could lead to releases greater than the adjacent basement walls and floors, the results are also compared against the $OpDCGL$ for surfaces from LTP Chapter 5, Table 5-4 of the two building that the penetration interfaces. In the case of the Auxiliary Building penetrations, the $OpDCGL_B$ for the Turbine Building are the most limiting. Two (2) of the penetrations required grouting as they had measurements with activity greater than the $OpDCGL_B$ for the Turbine Building. Grouting of the two (2) penetrations was performed prior to backfill and there was no dose reduction attributed to the survey unit because of grouting.

Table 8 provides the summary of Auxiliary Building penetrations, a summary of the FSS results, and whether the penetration required grouting. The complete tables containing the measurement results of all Auxiliary Building measurements that were taken are presented in Attachment 2. The measurement data collected passed the Sign Test. The results of the Sign Test are provided in Attachment 3. The statistical summary of the measurement data taken, when compared against the $BcDCGL_{PN}$ for Auxiliary Building penetrations are presented in Table 9.

FSS RELEASE RECORD
 AUXILIARY BUILDING PENETRATIONS
 SURVEY UNIT 05120



Table 8 - Auxiliary Building Penetrations Summary

Pen #	Description	Diameter (in)	Length (ft)	Area (m ²)	Measurement # ⁽²⁾			By Direct Scan	Max SOF			Requires Grouting
					OpDCGL _{PN}	BcDCGL _{PN}	OpDCGL _B ⁽¹⁾					
A001	Service Water	24	3	1.75	52	thru	54	X	0.001	0.001	0.305	No
A002	Feedwater	4.5	3	0.33	10	thru	12		0.012	0.003	0.848	No
A003	Secondary Sample	2.5	3	0.18	13	thru	15		0.033	0.000	0.021	No
A004	Service Water	24	3	1.75	58	thru	60	X	0.001	0.001	0.250	No
A005	Feedwater	4.5	3	0.33	31	thru	33		0.010	0.001	0.254	No
A007	Aux Vents & Drains	4.5	3	0.33	1	thru	3		0.010	0.001	0.311	No
A008	Aux Vents & Drains	4.5	3	0.33	4	thru	6		0.012	0.001	0.262	No
A009	Waste Disposal	3.5	3	0.26	7	thru	9		0.010	0.002	0.497	No
A010	Service Water	11	3	0.80	49	thru	51		0.020	0.022	7.078	No
A011	Waste Disposal	7	3	0.51	19	thru	21		0.279	0.001	0.346	Yes
A012	Chemical Feed	3.5	3	0.26	22	thru	24		0.014	0.001	0.421	No
A013	Primary Water	4.5	3	0.33	16	thru	18		0.017	0.000	0.020	No
A014	Service Water	20	3	1.46	55	thru	57	X	0.001	0.001	0.373	No
A015	Waste Disposal	6.5	3	0.47	28	thru	30		0.015	0.002	0.636	No
A017	Fire Protection	11	3	0.80	46	thru	48		0.025	0.001	0.256	No
A019	Primary Water	3.5	3	0.26	25	thru	27		0.010	0.001	0.296	No
A020	Vacuum Control	3.5	3	0.26	34	thru	36		0.012	0.001	0.330	No
A021	Demin Water	3.5	3	0.26	37	thru	39		0.013	0.001	0.298	No
A022	Line with Flange	4.5	3	0.33	40	thru	42		0.012	0.013	4.181	No
A023	Waste Disposal	6.5	3	0.47	43	thru	45		0.165	0.000	0.066	Yes
A024	Condensate	18	3	1.31	61	thru	63	X	0.003	0.000	0.018	No
A025	Supply Header	36	3	2.63	64	thru	66	X	0.001	0.001	0.305	No

(1) Compared against the OpDCGL_B for the Turbine Building from LTP Chapter 5, Table 5-4

(2) Measurement numbers correlates to Attachment 2, "Penetration Survey Data Assessment" Tables

The SOF for all sixty-six (66) measurements, based on the OpDCGL_{PN}, were less than one (1). The mean OpSOF for Auxiliary Building penetrations was 0.027. The maximum OpSOF for a measurement using OpDCGL_{PN} for penetrations was 0.279. The data collected passed the Sign Test.

Table 9 - Auxiliary Building Penetrations FSS Statistics Summary using Auxiliary Building BcDCGL_{PN}

Individual Measurement Metrics	
Total Number of Systematic Measurements	= 66
Number of Quality Control Measurements	= 5
Number of Judgmental/Investigational Measurements	= 0
Total Number of Measurements	= 71
Mean Systematic Measurement OpSOF	= 0.027
Max Individual Systematic Measurement OpSOF	= 0.279
Number of Systematic Measurements with OpSOF >1	= 0

Nuclide	Mean (pCi/m²)	Median (pCi/m²)	Max (pCi/m²)	Min (pCi/m²)	St Dev (pCi/m²)	BcDCGL_{PN} (pCi/m²)	Mean Nuclide BcSOF
Co-60	1.37E+04	5.47E+03	1.43E+05	2.71E+02	2.93E+04	8.82E+07	0.000
Ni-63	2.48E+06	9.87E+05	2.59E+07	4.88E+04	5.28E+06	6.79E+10	0.000
Sr-90	2.25E+03	8.95E+02	2.35E+04	4.43E+01	4.79E+03	2.41E+07	0.000
Cs-134	1.49E+02	5.94E+01	1.56E+03	2.94E+00	3.18E+02	3.28E+08	0.000
Cs-137	1.12E+06	4.48E+05	1.17E+07	2.22E+04	2.40E+06	6.17E+08	0.002

The mean BcSOF for Auxiliary Building penetrations (survey unit 05120), when compared against the BcDCGL_{PN} for Auxiliary Building penetrations is 0.002, which equates to a dose of 0.053 mrem/yr.

The SOF for two (2) measurements, when compared against the OpDCGL_B for the Turbine Building, were above one (1). In accordance with LTP Chapter 5 section 5.5.5, these two penetrations (A011 and A023) were grouted. No dose reduction was attributed to the survey unit because of grouting.

8. QUALITY CONTROL

In compliance with ZS-LT-01, replicate measurements were performed on 5% of the survey locations chosen at random. Five (5) replicate measurements were taken, which equates to 7.6% of the total number of measurements and satisfies the requirement. Using the acceptance criteria specified in section 4.1.2 of ZS-LT-01, there was acceptable agreement between the replicate readings and the original readings. Refer to Attachment 5 for quality control analysis results.

9. INVESTIGATIONS AND RESULTS

No investigations were performed during the performance or analyses of the FSS.

10. REMEDIATION AND RESULTS

No radiological remedial action as described by MARSSIM Section 5.4 was performed in this survey unit prior to or as a result of the FSS.

11. CHANGES FROM THE FINAL STATUS SURVEY PLAN

There were no addendums to the FSS plan.

12. DATA QUALITY ASSESSMENT (DQA)

The DQO sample design and data were reviewed in accordance with *ZionSolutions* procedure ZS-LT-300-001-004, “*Final Status Survey Data Assessment*” for completeness and consistency. Documentation was complete and legible. Surveys and sample collection were consistent with the DQOs and were sufficient to ensure that the survey unit was properly classified.

The analytical results of all samples were less than an OpSOF of one. Although MARSSIM states that the Sign Test need not be performed in the instance that no measurements surpass the DCGL, the test was conducted to demonstrate coherence to the statistical principles of the DQO process. The Sign Test was performed on the data and compared to the original assumptions of the DQOs. The evaluation of the Sign Test results clearly demonstrates that the survey unit passes the unrestricted release criteria, thus, the null hypothesis is rejected.

The preliminary data review consisted of calculating basic statistical quantities (e.g., mean, median, standard deviation). All data was considered valid including negative values, zeros, values reported below the MDC, and values with uncertainties greater than two standard deviations. The mean and median values for each ROC were well below

the respective $OpDCGL_{PN}$. Also, a retrospective power curve showed that a sufficient number of samples were collected to achieve the desired power. Therefore, the survey unit meets the unrestricted release criteria with adequate power as required by the DQOs.

The data for Co-60 and Cs-137 is represented graphically through a frequency plot and a quantile plot. All graphical representations are provided in Attachment 6.

13. ANOMALIES

No anomalies were observed during the performance or analyses of the survey.

14. CONCLUSION

Survey Unit 05120 has met the DQOs of the FSS plan. The ALARA criteria as specified in Chapter 4 of the LTP were achieved. The Elevated Measurement Comparison (EMC) is not applicable to structural surfaces.

All identified ROC were used for statistical testing to determine the adequacy of the survey unit for FSS. Evaluation of the data shows that none of the ROC concentration values exceed the $OpDCGL_{PN}$ for the Auxiliary Building or any investigational levels; therefore, in accordance with the LTP Section 5.10, the survey unit meets the release criterion.

The sample data passed the Sign Test. The null hypothesis was rejected. The Retrospective Power Curve showed that adequate power was achieved. The survey unit was properly classified as Class 1.

LTP Chapter 6, section 6.4.5 requires that the dose from a penetration be added to each basement that the penetration interfaces with. The penetrations in the Auxiliary Building interface with both Unit 1 and Unit 2 Containments and with the Turbine Building. The penetrations identified as interfacing between the Auxiliary Building and the Unit 1 and Unit 2 Containments were addressed in the Release Records for Unit 1 and Unit 2 Containment Penetrations. In order to comply with the requirements of LTP Chapter 6, section 6.4.5, a dose of 1.468 mrem/yr will be added to the Auxiliary Building basement survey unit from penetrations that interfaced between the Auxiliary Building and Unit 1 Containment and a dose of 0.206 mrem/yr will be added to the Auxiliary Building basement survey unit from penetrations that interfaced between the Auxiliary Building and Unit 2 Containment. The Auxiliary Building penetrations addressed in this Release Record interfaced with the Turbine Building (via the “G” wall and Steam Tunnels). Consequently, a dose value of 0.053 mrem/yr will also be added to the Auxiliary Building basement and the Turbine Building basement.

The null hypothesis was rejected. Therefore, in accordance with the LTP Section 5.10, survey unit 05120 meets the release criterion and is acceptable for unrestricted release.

15. REFERENCES

1. *ZionSolutions* procedure ZS-LT-300-001-005, Final Status Survey Data Reporting
2. Zion Station Restoration Project License Termination Plan
3. *ZionSolutions* procedure ZS-LT-300-001-001, Final Status Survey Package Development
4. NUREG-1575, Multi-Agency Radiation Survey and Site Investigation Manual
5. *ZionSolutions* TSD 14-016, Description of Embedded Piping, Penetrations, and Buried Pipe to Remain in Zion End State
6. *ZionSolutions* procedure ZS-LT-300-001-002, Survey Unit Classification
7. Zion Station Historical Site Assessment
8. *ZionSolutions* TSD 14-013, Zion Auxiliary Building End State Estimated Concrete Volumes, Surface Areas, and Source Terms
9. *ZionSolutions* procedure ZS-LT-300-001-002, Survey Unit Classification
10. *ZionSolutions* TSD 11-001, Technical Support Document for Potential Radionuclides of Concern During the Decommissioning of the Zion Station
11. *ZionSolutions* TSD 17-004, Operational Derived Concentration Guideline Levels for Final Status Survey
12. *ZionSolutions* TSD 14-019, Radionuclides of Concern for Soil and Basement Fill Model Source Terms
13. *ZionSolutions* ZS-LT-01, Quality Assurance Project Plan (for Characterization and FSS)
14. *ZionSolutions* procedure ZS-LT-300-001-003, Isolation and Control for Final Status Survey
15. *ZionSolutions* procedure ZS-LT-300-001-006, Radiation Surveys of Pipe Interiors Using Sodium/Cesium Iodide Detectors
16. *ZionSolutions* procedure ZS-LT-300-001-004, Final Status Survey Data Assessment

16. ATTACHMENTS

Attachment 1 – Figures and Maps

Attachment 2 – Measurement Data

Attachment 3 – Sign Test

Attachment 4 – QC Data


Attachment 5 – QC Measurement Assessments

Attachment 6 – Graphical Presentations

ATTACHMENT 1

FIGURES AND MAPS

Figure 1 – Overall Penetration Map



ATTACHMENT 2

MEASUREMENT DATA

Auxiliary Building Penetration Summary

MEASUREMENT ID		Co-60 (pCi/m ²)	Ni-63 (pCi/m ²)	Sr-90 (pCi/m ²)	Cs-134 (pCi/m ²)	Cs-137 (pCi/m ²)	OpSOF ⁽¹⁾
A007	Position#1	4.84E+03	8.74E+05	7.93E+02	5.27E+01	3.97E+05	0.0094
A007	Position#2	4.96E+03	8.96E+05	8.13E+02	5.40E+01	4.06E+05	0.0097
A007	Position#3	5.15E+03	9.30E+05	8.44E+02	5.60E+01	4.22E+05	0.0100
A008	Position#1	6.29E+03	1.14E+06	1.03E+03	6.84E+01	5.15E+05	0.0123
A008	Position#2	5.76E+03	1.04E+06	9.43E+02	6.26E+01	4.72E+05	0.0112
A008	Position#3	5.70E+03	1.03E+06	9.33E+02	6.20E+01	4.67E+05	0.0111
A009	Position#1	5.30E+03	9.56E+05	8.67E+02	5.76E+01	4.34E+05	0.0103
A009	Position#2	5.17E+03	9.32E+05	8.46E+02	5.61E+01	4.23E+05	0.0101
A009	Position#3	5.28E+03	9.54E+05	8.65E+02	5.74E+01	4.33E+05	0.0103
A002	Position#1	5.21E+03	9.41E+05	8.54E+02	5.67E+01	4.27E+05	0.0102
A002	Position#2	4.92E+03	8.87E+05	8.05E+02	5.34E+01	4.02E+05	0.0096
A002	Position#3	6.19E+03	1.12E+06	1.01E+03	6.72E+01	5.06E+05	0.0121
A003	Position#1	6.82E+03	1.23E+06	1.12E+03	7.41E+01	5.58E+05	0.0133
A003	Position#2	7.39E+03	1.33E+06	1.21E+03	8.03E+01	6.05E+05	0.0144
A003	Position#3	1.72E+04	3.10E+06	2.81E+03	1.87E+02	1.41E+06	0.0335
A013	Position#1	7.93E+03	1.43E+06	1.30E+03	8.62E+01	6.49E+05	0.0155
A013	Position#2	8.30E+03	1.50E+06	1.36E+03	9.02E+01	6.80E+05	0.0162
A013	Position#3	8.53E+03	1.54E+06	1.40E+03	9.27E+01	6.98E+05	0.0166
A011	Position#1	1.25E+05	2.25E+07	2.04E+04	1.35E+03	1.02E+07	0.2427
A011	Position#2	1.43E+05	2.59E+07	2.35E+04	1.56E+03	1.17E+07	0.2794
A011	Position#3	1.21E+05	2.18E+07	1.98E+04	1.31E+03	9.88E+06	0.2352
A012	Position#1	5.44E+03	9.81E+05	8.91E+02	5.91E+01	4.45E+05	0.0106
A012	Position#2	5.50E+03	9.92E+05	9.00E+02	5.98E+01	4.50E+05	0.0107
A012	Position#3	7.01E+03	1.26E+06	1.15E+03	7.62E+01	5.74E+05	0.0137
A019	Position#1	4.75E+03	8.57E+05	7.78E+02	5.16E+01	3.89E+05	0.0093

(1) Compared against the OpDCGL_{PN} for the Auxiliary Building from LTP Chapter 5, Table 5-14

Auxiliary Building Penetration Summary (continued)

MEASUREMENT ID		Co-60 (pCi/m ²)	Ni-63 (pCi/m ²)	Sr-90 (pCi/m ²)	Cs-134 (pCi/m ²)	Cs-137 (pCi/m ²)	OpSOF ⁽¹⁾
A019	Position#2	4.73E+03	8.53E+05	7.74E+02	5.14E+01	3.87E+05	0.0092
A019	Position#3	5.18E+03	9.34E+05	8.48E+02	5.63E+01	4.24E+05	0.0101
A015	Position#1	6.64E+03	1.20E+06	1.09E+03	7.22E+01	5.44E+05	0.0129
A015	Position#2	6.59E+03	1.19E+06	1.08E+03	7.16E+01	5.40E+05	0.0128
A015	Position#3	7.55E+03	1.36E+06	1.24E+03	8.21E+01	6.18E+05	0.0147
A005	Position#1	4.51E+03	8.14E+05	7.39E+02	4.90E+01	3.69E+05	0.0088
A005	Position#2	4.50E+03	8.12E+05	7.37E+02	4.89E+01	3.68E+05	0.0088
A005	Position#3	5.07E+03	9.15E+05	8.30E+02	5.51E+01	4.15E+05	0.0099
A020	Position#1	5.13E+03	9.26E+05	8.40E+02	5.58E+01	4.20E+05	0.0100
A020	Position#2	5.98E+03	1.08E+06	9.80E+02	6.51E+01	4.90E+05	0.0117
A020	Position#3	5.95E+03	1.07E+06	9.74E+02	6.47E+01	4.87E+05	0.0116
A021	Position#1	6.67E+03	1.20E+06	1.09E+03	7.25E+01	5.46E+05	0.0130
A021	Position#2	5.59E+03	1.01E+06	9.16E+02	6.08E+01	4.58E+05	0.0109
A021	Position#3	5.63E+03	1.02E+06	9.22E+02	6.12E+01	4.61E+05	0.0110
A022	Position#1	4.44E+03	8.01E+05	7.27E+02	4.83E+01	3.64E+05	0.0087
A022	Position#2	4.46E+03	8.06E+05	7.31E+02	4.85E+01	3.66E+05	0.0087
A022	Position#3	6.03E+03	1.09E+06	9.88E+02	6.56E+01	4.94E+05	0.0118
A023	Position#1	6.23E+04	1.12E+07	1.02E+04	6.77E+02	5.10E+06	0.1214
A023	Position#2	8.47E+04	1.53E+07	1.39E+04	9.20E+02	6.93E+06	0.1650
A023	Position#3	6.52E+04	1.18E+07	1.07E+04	7.09E+02	5.34E+06	0.1270
A017	Position#1	9.91E+03	1.79E+06	1.62E+03	1.08E+02	8.11E+05	0.0193
A017	Position#2	1.07E+04	1.93E+06	1.75E+03	1.16E+02	8.74E+05	0.0208
A017	Position#3	1.29E+04	2.32E+06	2.11E+03	1.40E+02	1.05E+06	0.0251
A010	Position#1	8.41E+03	1.52E+06	1.38E+03	9.14E+01	6.89E+05	0.0164
A010	Position#2	8.59E+03	1.55E+06	1.41E+03	9.33E+01	7.03E+05	0.0167

(1) Compared against the OpDCGL_{PN} for the Auxiliary Building from LTP Chapter 5, Table 5-14

Auxiliary Building Penetration Summary (continued)

MEASUREMENT ID		Co-60 (pCi/m ²)	Ni-63 (pCi/m ²)	Sr-90 (pCi/m ²)	Cs-134 (pCi/m ²)	Cs-137 (pCi/m ²)	OpSOF ⁽¹⁾
A010	Position#3	1.01E+04	1.82E+06	1.65E+03	1.10E+02	8.25E+05	0.0196
A001	Position #1	4.20E+02	7.59E+04	6.88E+01	4.57E+00	3.44E+04	0.0008
A001	Position #2	4.61E+02	8.33E+04	7.56E+01	5.02E+00	3.78E+04	0.0009
A001	Position #3	4.37E+02	7.89E+04	7.16E+01	4.75E+00	3.58E+04	0.0009
A014	Position #1	2.71E+02	4.88E+04	4.43E+01	2.94E+00	2.22E+04	0.0005
A014	Position #2	3.53E+02	6.36E+04	5.78E+01	3.83E+00	2.89E+04	0.0007
A014	Position #3	4.06E+02	7.32E+04	6.65E+01	4.41E+00	3.32E+04	0.0008
A004	Position #1	3.79E+02	6.84E+04	6.21E+01	4.12E+00	3.11E+04	0.0007
A004	Position #2	3.38E+02	6.10E+04	5.54E+01	3.68E+00	2.77E+04	0.0007
A004	Position #3	4.32E+02	7.80E+04	7.08E+01	4.70E+00	3.54E+04	0.0008
A024	Position #1	4.49E+02	8.11E+04	7.36E+01	4.88E+00	3.68E+04	0.0009
A024	Position #2	7.61E+02	1.37E+05	1.25E+02	8.27E+00	6.23E+04	0.0015
A024	Position #3	1.34E+03	2.42E+05	2.20E+02	1.46E+01	1.10E+05	0.0026
A025	Position #1	3.31E+02	5.97E+04	5.42E+01	3.60E+00	2.71E+04	0.0006
A025	Position #2	3.14E+02	5.67E+04	5.14E+01	3.41E+00	2.57E+04	0.0006
A025	Position #3	3.55E+02	6.41E+04	5.81E+01	3.86E+00	2.91E+04	0.0007

(1) Compared against the OpDCGL_{PN} for the Auxiliary Building from LTP Chapter 5, Table 5-14

Auxiliary Building Penetration Scan Measurements for Large Diameter Penetrations (>12 inches ID)

Instrument/ID	Cal. Due	Detector/ID	Cal. Due	Efficiency	Survey Date	Penetration	Reading (cpm)	Reading (dpm/100cm ²)	Reading (pCi/m ²)
2360/278576	1/27/2019	43-93/PR311187	1/27/2019	0.20	3/28/2018	A001	174	870	3.48E+04
2360/278576	1/27/2019	43-93/PR311187	1/27/2019	0.20	3/28/2018	A001	191	955	3.82E+04
2360/278576	1/27/2019	43-93/PR311187	1/27/2019	0.20	3/28/2018	A001	181	905	3.62E+04
2360/278576	1/27/2019	43-93/PR311187	1/27/2019	0.20	3/28/2018	A014	112	560	2.24E+04
2360/278576	1/27/2019	43-93/PR311187	1/27/2019	0.20	3/28/2018	A014	146	730	2.92E+04
2360/278576	1/27/2019	43-93/PR311187	1/27/2019	0.20	3/28/2018	A014	168	840	3.36E+04
2360/278576	1/27/2019	43-93/PR311187	1/27/2019	0.20	3/28/2018	A014 QC	145	725	2.90E+04
2360/278576	1/27/2019	43-93/PR311187	1/27/2019	0.20	3/28/2018	A004	157	785	3.14E+04
2360/278576	1/27/2019	43-93/PR311187	1/27/2019	0.20	3/28/2018	A004	140	700	2.80E+04
2360/278576	1/27/2019	43-93/PR311187	1/27/2019	0.20	3/28/2018	A004	179	895	3.58E+04
2360/278576	1/27/2019	43-93/PR311187	1/27/2019	0.20	3/28/2018	A024	186	930	3.72E+04
2360/278576	1/27/2019	43-93/PR311187	1/27/2019	0.20	3/28/2018	A024	315	1575	6.31E+04
2360/278576	1/27/2019	43-93/PR311187	1/27/2019	0.20	3/28/2018	A024	555	2775	1.11E+05
2360/278576	1/27/2019	43-93/PR311187	1/27/2019	0.20	3/28/2018	A025	137	685	2.74E+04
2360/278576	1/27/2019	43-93/PR311187	1/27/2019	0.20	3/28/2018	A025	130	650	2.60E+04
2360/278576	1/27/2019	43-93/PR311187	1/27/2019	0.20	3/28/2018	A025	147	735	2.94E+04
2360/278576	1/27/2019	43-93/PR311187	1/27/2019	0.20	3/28/2018	A025 QC	120	600	2.40E+04

Penetration Survey Data Assessment

No.	Sample ID	Feet into Pipe	Gamma Result (pCi/m ²)	ROC	Gamma Mixture/HTD Ratio	Activity per ROC (pCi/m ²)	Auxiliary OpDCGL _{PN} (pCi/m ²)	Auxiliary ROC OpSO _{FN}	Auxiliary Total OpSO _{FN}	Auxiliary BcDCGL _{PN} (pCi/m ²)	Auxiliary ROC BcSO _{FN}	Auxiliary Total BcSO _{FN}	Turbine OpDCGL _B (pCi/m ²)	Turbine ROC OpSO _B	Turbine Total OpSO _B
1	A007 Position#1	1	4.02E+05	Co-60	0.0121	4.84E+03	6.95E+06	0.0007	0.0094	8.82E+07	0.0001	0.0007	5.98E+06	0.0008	0.2392
				Ni-63	180	8.74E+05	5.35E+09	0.0002		6.79E+10	0.0000		1.85E+08	0.0047	
				Sr-90	0.002	7.93E+02	1.90E+06	0.0004		2.41E+07	0.0000		6.58E+04	0.0121	
				Cs-134	0.0001	5.27E+01	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0000	
				Cs-137	0.9878	3.97E+05	4.86E+07	0.0082		6.17E+08	0.0006		1.79E+06	0.2216	
2	A007 Position#2	2	4.11E+05	Co-60	0.0121	4.96E+03	6.95E+06	0.0007	0.0097	8.82E+07	0.0001	0.0008	5.98E+06	0.0008	0.2451
				Ni-63	180	8.96E+05	5.35E+09	0.0002		6.79E+10	0.0000		1.85E+08	0.0048	
				Sr-90	0.002	8.13E+02	1.90E+06	0.0004		2.41E+07	0.0000		6.58E+04	0.0124	
				Cs-134	0.0001	5.40E+01	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0000	
				Cs-137	0.9878	4.06E+05	4.86E+07	0.0084		6.17E+08	0.0007		1.79E+06	0.2270	
3	A007 Position#3	3	4.27E+05	Co-60	0.0121	5.15E+03	6.95E+06	0.0007	0.0100	8.82E+07	0.0001	0.0008	5.98E+06	0.0009	0.2545
				Ni-63	180	9.30E+05	5.35E+09	0.0002		6.79E+10	0.0000		1.85E+08	0.0050	
				Sr-90	0.002	8.44E+02	1.90E+06	0.0004		2.41E+07	0.0000		6.58E+04	0.0128	
				Cs-134	0.0001	5.60E+01	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0000	
				Cs-137	0.9878	4.22E+05	4.86E+07	0.0087		6.17E+08	0.0007		1.79E+06	0.2357	
4	A008 Position#1	1	5.22E+05	Co-60	0.0121	6.29E+03	6.95E+06	0.0009	0.0123	8.82E+07	0.0001	0.0010	5.98E+06	0.0011	0.3108
				Ni-63	180	1.14E+06	5.35E+09	0.0002		6.79E+10	0.0000		1.85E+08	0.0061	
				Sr-90	0.002	1.03E+03	1.90E+06	0.0005		2.41E+07	0.0000		6.58E+04	0.0157	
				Cs-134	0.0001	6.84E+01	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0001	
				Cs-137	0.9878	5.15E+05	4.86E+07	0.0106		6.17E+08	0.0008		1.79E+06	0.2878	
5	A008 Position#2	2	4.77E+05	Co-60	0.0121	5.76E+03	6.95E+06	0.0008	0.0112	8.82E+07	0.0001	0.0009	5.98E+06	0.0010	0.2844
				Ni-63	180	1.04E+06	5.35E+09	0.0002		6.79E+10	0.0000		1.85E+08	0.0056	
				Sr-90	0.002	9.43E+02	1.90E+06	0.0005		2.41E+07	0.0000		6.58E+04	0.0143	
				Cs-134	0.0001	6.26E+01	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0000	
				Cs-137	0.9878	4.72E+05	4.86E+07	0.0097		6.17E+08	0.0008		1.79E+06	0.2634	
6	A008 Position#3	3	4.72E+05	Co-60	0.0121	5.70E+03	6.95E+06	0.0008	0.0111	8.82E+07	0.0001	0.0009	5.98E+06	0.0010	0.2814
				Ni-63	180	1.03E+06	5.35E+09	0.0002		6.79E+10	0.0000		1.85E+08	0.0056	
				Sr-90	0.002	9.33E+02	1.90E+06	0.0005		2.41E+07	0.0000		6.58E+04	0.0142	
				Cs-134	0.0001	6.20E+01	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0000	
				Cs-137	0.9878	4.67E+05	4.86E+07	0.0096		6.17E+08	0.0008		1.79E+06	0.2607	
7	A009 Position#1	1	4.39E+05	Co-60	0.0121	5.30E+03	6.95E+06	0.0008	0.0103	8.82E+07	0.0001	0.0008	5.98E+06	0.0009	0.2615
				Ni-63	180	9.56E+05	5.35E+09	0.0002		6.79E+10	0.0000		1.85E+08	0.0052	
				Sr-90	0.002	8.67E+02	1.90E+06	0.0005		2.41E+07	0.0000		6.58E+04	0.0132	
				Cs-134	0.0001	5.76E+01	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0000	
				Cs-137	0.9878	4.34E+05	4.86E+07	0.0089		6.17E+08	0.0007		1.79E+06	0.2422	
8	A009 Position#2	2	4.28E+05	Co-60	0.0121	5.17E+03	6.95E+06	0.0007	0.0101	8.82E+07	0.0001	0.0008	5.98E+06	0.0009	0.2551
				Ni-63	180	9.32E+05	5.35E+09	0.0002		6.79E+10	0.0000		1.85E+08	0.0050	
				Sr-90	0.002	8.46E+02	1.90E+06	0.0004		2.41E+07	0.0000		6.58E+04	0.0129	
				Cs-134	0.0001	5.61E+01	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0000	
				Cs-137	0.9878	4.23E+05	4.86E+07	0.0087		6.17E+08	0.0007		1.79E+06	0.2363	

Penetration Survey Data Assessment (continued)

No.	Sample ID	Feet into Pipe	Gamma Result (pCi/m ²)	ROC	Gamma Mixture/HTD Ratio	Activity per ROC (pCi/m ²)	Auxiliary OpDCGL _{PN} (pCi/m ²)	Auxiliary ROC OpSOF _{PN}	Auxiliary Total OpSOF _{PN}	Auxiliary BcDCGL _{PN} (pCi/m ²)	Auxiliary ROC BcSOF _{PN}	Auxiliary Total BcSOF _{PN}	Turbine OpDCGL _B (pCi/m ²)	Turbine ROC OpSOF _B	Turbine Total OpSOF _B
9	A009 Position#3	3	4.38E+05	Co-60	0.0121	5.28E+03	6.95E+06	0.0008	0.0103	8.82E+07	0.0001	0.0008	5.98E+06	0.0009	0.2609
				Ni-63	180	9.54E+05	5.35E+09	0.0002		6.79E+10	0.0000		1.85E+08	0.0052	
				Sr-90	0.002	8.65E+02	1.90E+06	0.0005		2.41E+07	0.0000		6.58E+04	0.0131	
				Cs-134	0.0001	5.74E+01	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0000	
				Cs-137	0.9878	4.33E+05	4.86E+07	0.0089		6.17E+08	0.0007		1.79E+06	0.2417	
10	A002 Position#1	1	4.32E+05	Co-60	0.0121	5.21E+03	6.95E+06	0.0008	0.0102	8.82E+07	0.0001	0.0008	5.98E+06	0.0009	0.2574
				Ni-63	180	9.41E+05	5.35E+09	0.0002		6.79E+10	0.0000		1.85E+08	0.0051	
				Sr-90	0.002	8.54E+02	1.90E+06	0.0004		2.41E+07	0.0000		6.58E+04	0.0130	
				Cs-134	0.0001	5.67E+01	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0000	
				Cs-137	0.9878	4.27E+05	4.86E+07	0.0088		6.17E+08	0.0007		1.79E+06	0.2384	
11	A002 Position#2	2	4.07E+05	Co-60	0.0121	4.92E+03	6.95E+06	0.0007	0.0096	8.82E+07	0.0001	0.0008	5.98E+06	0.0008	0.2427
				Ni-63	180	8.87E+05	5.35E+09	0.0002		6.79E+10	0.0000		1.85E+08	0.0048	
				Sr-90	0.002	8.05E+02	1.90E+06	0.0004		2.41E+07	0.0000		6.58E+04	0.0122	
				Cs-134	0.0001	5.34E+01	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0000	
				Cs-137	0.9878	4.02E+05	4.86E+07	0.0083		6.17E+08	0.0007		1.79E+06	0.2248	
12	A002 Position#3	3	5.13E+05	Co-60	0.0121	6.19E+03	6.95E+06	0.0009	0.0121	8.82E+07	0.0001	0.0009	5.98E+06	0.0010	0.3055
				Ni-63	180	1.12E+06	5.35E+09	0.0002		6.79E+10	0.0000		1.85E+08	0.0060	
				Sr-90	0.002	1.01E+03	1.90E+06	0.0005		2.41E+07	0.0000		6.58E+04	0.0154	
				Cs-134	0.0001	6.72E+01	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0000	
				Cs-137	0.9878	5.06E+05	4.86E+07	0.0104		6.17E+08	0.0008		1.79E+06	0.2830	
13	A003 Position#1	1	5.65E+05	Co-60	0.0121	6.82E+03	6.95E+06	0.0010	0.0133	8.82E+07	0.0001	0.0010	5.98E+06	0.0011	0.3365
				Ni-63	180	1.23E+06	5.35E+09	0.0002		6.79E+10	0.0000		1.85E+08	0.0066	
				Sr-90	0.002	1.12E+03	1.90E+06	0.0006		2.41E+07	0.0000		6.58E+04	0.0170	
				Cs-134	0.0001	7.41E+01	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0001	
				Cs-137	0.9878	5.58E+05	4.86E+07	0.0115		6.17E+08	0.0009		1.79E+06	0.3117	
14	A003 Position#2	2	6.12E+05	Co-60	0.0121	7.39E+03	6.95E+06	0.0011	0.0144	8.82E+07	0.0001	0.0011	5.98E+06	0.0012	0.3647
				Ni-63	180	1.33E+06	5.35E+09	0.0002		6.79E+10	0.0000		1.85E+08	0.0072	
				Sr-90	0.002	1.21E+03	1.90E+06	0.0006		2.41E+07	0.0001		6.58E+04	0.0184	
				Cs-134	0.0001	8.03E+01	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0001	
				Cs-137	0.9878	6.05E+05	4.86E+07	0.0124		6.17E+08	0.0010		1.79E+06	0.3378	
15	A003 Position#3	3	1.42E+06	Co-60	0.0121	1.72E+04	6.95E+06	0.0025	0.0335	8.82E+07	0.0002	0.0026	5.98E+06	0.0029	0.8484
				Ni-63	180	3.10E+06	5.35E+09	0.0006		6.79E+10	0.0000		1.85E+08	0.0168	
				Sr-90	0.002	2.81E+03	1.90E+06	0.0015		2.41E+07	0.0001		6.58E+04	0.0428	
				Cs-134	0.0001	1.87E+02	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0001	
				Cs-137	0.9878	1.41E+06	4.86E+07	0.0289		6.17E+08	0.0023		1.79E+06	0.7859	

Penetration Survey Data Assessment (continued)

No.	Sample ID	Feet into Pipe	Gamma Result (pCi/m ²)	ROC	Gamma Mixture/HTD Ratio	Activity per ROC (pCi/m ²)	Auxiliary OpDCGL _{PN} (pCi/m ²)	Auxiliary ROC OpSOF _{PN}	Auxiliary Total OpSOF _{PN}	Auxiliary BcDCGL _{PN} (pCi/m ²)	Auxiliary ROC BcSOF _{PN}	Auxiliary Total BcSOF _{PN}	Turbine OpDCGL _B (pCi/m ²)	Turbine ROC OpSOF _B	Turbine Total OpSOF _B
16	A013 Position#1	1	6.57E+05	Co-60	0.0121	7.93E+03	6.95E+06	0.0011	0.0155	8.82E+07	0.0001	0.0012	5.98E+06	0.0013	0.3917
				Ni-63	180	1.43E+06	5.35E+09	0.0003		6.79E+10	0.0000		1.85E+08	0.0077	
				Sr-90	0.002	1.30E+03	1.90E+06	0.0007		2.41E+07	0.0001		6.58E+04	0.0197	
				Cs-134	0.0001	8.62E+01	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0001	
				Cs-137	0.9878	6.49E+05	4.86E+07	0.0134		6.17E+08	0.0011		1.79E+06	0.3628	
17	A013 Position#2	2	6.88E+05	Co-60	0.0121	8.30E+03	6.95E+06	0.0012	0.0162	8.82E+07	0.0001	0.0013	5.98E+06	0.0014	0.4098
				Ni-63	180	1.50E+06	5.35E+09	0.0003		6.79E+10	0.0000		1.85E+08	0.0081	
				Sr-90	0.002	1.36E+03	1.90E+06	0.0007		2.41E+07	0.0001		6.58E+04	0.0207	
				Cs-134	0.0001	9.02E+01	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0001	
				Cs-137	0.9878	6.80E+05	4.86E+07	0.0140		6.17E+08	0.0011		1.79E+06	0.3796	
18	A013 Position#3	3	7.07E+05	Co-60	0.0121	8.53E+03	6.95E+06	0.0012	0.0166	8.82E+07	0.0001	0.0013	5.98E+06	0.0014	0.4210
				Ni-63	180	1.54E+06	5.35E+09	0.0003		6.79E+10	0.0000		1.85E+08	0.0083	
				Sr-90	0.002	1.40E+03	1.90E+06	0.0007		2.41E+07	0.0001		6.58E+04	0.0212	
				Cs-134	0.0001	9.27E+01	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0001	
				Cs-137	0.9878	6.98E+05	4.86E+07	0.0144		6.17E+08	0.0011		1.79E+06	0.3900	
19	A011 Position#1	1	1.03E+07	Co-60	0.0121	1.25E+05	6.95E+06	0.0179	0.2427	8.82E+07	0.0014	0.0191	5.98E+06	0.0208	6.1494
				Ni-63	180	2.25E+07	5.35E+09	0.0042		6.79E+10	0.0003		1.85E+08	0.1215	
				Sr-90	0.002	2.04E+04	1.90E+06	0.0107		2.41E+07	0.0008		6.58E+04	0.3099	
				Cs-134	0.0001	1.35E+03	2.58E+07	0.0001		3.28E+08	0.0000		1.35E+06	0.0010	
				Cs-137	0.9878	1.02E+07	4.86E+07	0.2098		6.17E+08	0.0165		1.79E+06	5.6961	
20	A011 Position#2	2	1.19E+07	Co-60	0.0121	1.43E+05	6.95E+06	0.0206	0.2794	8.82E+07	0.0016	0.0220	5.98E+06	0.0240	7.0781
				Ni-63	180	2.59E+07	5.35E+09	0.0048		6.79E+10	0.0004		1.85E+08	0.1398	
				Sr-90	0.002	2.35E+04	1.90E+06	0.0124		2.41E+07	0.0010		6.58E+04	0.3567	
				Cs-134	0.0001	1.56E+03	2.58E+07	0.0001		3.28E+08	0.0000		1.35E+06	0.0012	
				Cs-137	0.9878	1.17E+07	4.86E+07	0.2415		6.17E+08	0.0190		1.79E+06	6.5564	
21	A011 Position#3	3	1.00E+07	Co-60	0.0121	1.21E+05	6.95E+06	0.0174	0.2352	8.82E+07	0.0014	0.0185	5.98E+06	0.0202	5.9582
				Ni-63	180	2.18E+07	5.35E+09	0.0041		6.79E+10	0.0003		1.85E+08	0.1177	
				Sr-90	0.002	1.98E+04	1.90E+06	0.0104		2.41E+07	0.0008		6.58E+04	0.3003	
				Cs-134	0.0001	1.31E+03	2.58E+07	0.0001		3.28E+08	0.0000		1.35E+06	0.0010	
				Cs-137	0.9878	9.88E+06	4.86E+07	0.2033		6.17E+08	0.0160		1.79E+06	5.5191	
22	A012 Position#1	1	4.51E+05	Co-60	0.0121	5.44E+03	6.95E+06	0.0008	0.0106	8.82E+07	0.0001	0.0008	5.98E+06	0.0009	0.2685
				Ni-63	180	9.81E+05	5.35E+09	0.0002		6.79E+10	0.0000		1.85E+08	0.0053	
				Sr-90	0.002	8.91E+02	1.90E+06	0.0005		2.41E+07	0.0000		6.58E+04	0.0135	
				Cs-134	0.0001	5.91E+01	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0000	
				Cs-137	0.9878	4.45E+05	4.86E+07	0.0092		6.17E+08	0.0007		1.79E+06	0.2487	

Penetration Survey Data Assessment (continued)

No.	Sample ID	Feet into Pipe	Gamma Result (pCi/m ²)	ROC	Gamma Mixture/HTD Ratio	Activity per ROC (pCi/m ²)	Auxiliary OpDCGL _{PN}	Auxiliary ROC OpSOF _{PN}	Auxiliary Total OpSOF _{PN}	Auxiliary BcDCGL _{PN} (pCi/m ²)	Auxiliary ROC BcSOF _{PN}	Auxiliary Total BcSOF _{PN}	Turbine OpDCGL _B (pCi/m ²)	Turbine ROC OpSOF _B	Turbine Total OpSOF _B
23	A012 Position#2	2	4.56E+05	Co-60	0.0121	5.50E+03	6.95E+06	0.0008	0.0107	8.82E+07	0.0001	0.0008	5.98E+06	0.0009	0.2715
				Ni-63	180	9.92E+05	5.35E+09	0.0002		6.79E+10	0.0000		1.85E+08	0.0054	
				Sr-90	0.002	9.00E+02	1.90E+06	0.0005		2.41E+07	0.0000		6.58E+04	0.0137	
				Cs-134	0.0001	5.98E+01	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0000	
				Cs-137	0.9878	4.50E+05	4.86E+07	0.0093		6.17E+08	0.0007		1.79E+06	0.2515	
24	A012 Position#3	3	5.81E+05	Co-60	0.0121	7.01E+03	6.95E+06	0.0010	0.0137	8.82E+07	0.0001	0.0011	5.98E+06	0.0012	0.3459
				Ni-63	180	1.26E+06	5.35E+09	0.0002		6.79E+10	0.0000		1.85E+08	0.0068	
				Sr-90	0.002	1.15E+03	1.90E+06	0.0006		2.41E+07	0.0000		6.58E+04	0.0174	
				Cs-134	0.0001	7.62E+01	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0001	
				Cs-137	0.9878	5.74E+05	4.86E+07	0.0118		6.17E+08	0.0009		1.79E+06	0.3204	
25	A019 Position#1	1	3.94E+05	Co-60	0.0121	4.75E+03	6.95E+06	0.0007	0.0093	8.82E+07	0.0001	0.0007	5.98E+06	0.0008	0.2345
				Ni-63	180	8.57E+05	5.35E+09	0.0002		6.79E+10	0.0000		1.85E+08	0.0046	
				Sr-90	0.002	7.78E+02	1.90E+06	0.0004		2.41E+07	0.0000		6.58E+04	0.0118	
				Cs-134	0.0001	5.16E+01	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0000	
				Cs-137	0.9878	3.89E+05	4.86E+07	0.0080		6.17E+08	0.0006		1.79E+06	0.2172	
26	A019 Position#2	2	3.92E+05	Co-60	0.0121	4.73E+03	6.95E+06	0.0007	0.0092	8.82E+07	0.0001	0.0007	5.98E+06	0.0008	0.2334
				Ni-63	180	8.53E+05	5.35E+09	0.0002		6.79E+10	0.0000		1.85E+08	0.0046	
				Sr-90	0.002	7.74E+02	1.90E+06	0.0004		2.41E+07	0.0000		6.58E+04	0.0118	
				Cs-134	0.0001	5.14E+01	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0000	
				Cs-137	0.9878	3.87E+05	4.86E+07	0.0080		6.17E+08	0.0006		1.79E+06	0.2162	
27	A019 Position#3	3	4.29E+05	Co-60	0.0121	5.18E+03	6.95E+06	0.0007	0.0101	8.82E+07	0.0001	0.0008	5.98E+06	0.0009	0.2556
				Ni-63	180	9.34E+05	5.35E+09	0.0002		6.79E+10	0.0000		1.85E+08	0.0050	
				Sr-90	0.002	8.48E+02	1.90E+06	0.0004		2.41E+07	0.0000		6.58E+04	0.0129	
				Cs-134	0.0001	5.63E+01	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0000	
				Cs-137	0.9878	4.24E+05	4.86E+07	0.0087		6.17E+08	0.0007		1.79E+06	0.2368	
28	A015 Position#1	1	5.50E+05	Co-60	0.0121	6.64E+03	6.95E+06	0.0010	0.0129	8.82E+07	0.0001	0.0010	5.98E+06	0.0011	0.3278
				Ni-63	180	1.20E+06	5.35E+09	0.0002		6.79E+10	0.0000		1.85E+08	0.0065	
				Sr-90	0.002	1.09E+03	1.90E+06	0.0006		2.41E+07	0.0000		6.58E+04	0.0165	
				Cs-134	0.0001	7.22E+01	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0001	
				Cs-137	0.9878	5.44E+05	4.86E+07	0.0112		6.17E+08	0.0009		1.79E+06	0.3037	
29	A015 Position#2	2	5.46E+05	Co-60	0.0121	6.59E+03	6.95E+06	0.0009	0.0128	8.82E+07	0.0001	0.0010	5.98E+06	0.0011	0.3255
				Ni-63	180	1.19E+06	5.35E+09	0.0002		6.79E+10	0.0000		1.85E+08	0.0064	
				Sr-90	0.002	1.08E+03	1.90E+06	0.0006		2.41E+07	0.0000		6.58E+04	0.0164	
				Cs-134	0.0001	7.16E+01	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0001	
				Cs-137	0.9878	5.40E+05	4.86E+07	0.0111		6.17E+08	0.0009		1.79E+06	0.3015	
30	A015 Position#3	3	6.26E+05	Co-60	0.0121	7.55E+03	6.95E+06	0.0011	0.0147	8.82E+07	0.0001	0.0012	5.98E+06	0.0013	0.3730
				Ni-63	180	1.36E+06	5.35E+09	0.0003		6.79E+10	0.0000		1.85E+08	0.0074	
				Sr-90	0.002	1.24E+03	1.90E+06	0.0007		2.41E+07	0.0001		6.58E+04	0.0188	
				Cs-134	0.0001	8.21E+01	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0001	
				Cs-137	0.9878	6.18E+05	4.86E+07	0.0127		6.17E+08	0.0010		1.79E+06	0.3455	

Penetration Survey Data Assessment (continued)

No.	Sample ID	Feet into Pipe	Gamma Result (pCi/m ²)	ROC	Gamma Mixture/HTD Ratio	Activity per ROC (pCi/m ²)	Auxiliary OpDCGL _{PN} (pCi/m ²)	Auxiliary ROC OpSOF _{PN}	Auxiliary Total OpSOF _{PN}	Auxiliary BcDCGL _{PN} (pCi/m ²)	Auxiliary ROC BcSOF _{PN}	Auxiliary Total BcSOF _{PN}	Turbine OpDCGL _B (pCi/m ²)	Turbine ROC OpSOF _B	Turbine Total OpSOF _B
31	A005 Position#1	1	3.74E+05	Co-60	0.0121	4.51E+03	6.95E+06	0.0006	0.0088	8.82E+07	0.0001	0.0007	5.98E+06	0.0008	0.2228
				Ni-63	180	8.14E+05	5.35E+09	0.0002		6.79E+10	0.0000		1.85E+08	0.0044	
				Sr-90	0.002	7.39E+02	1.90E+06	0.0004		2.41E+07	0.0000		6.58E+04	0.0112	
				Cs-134	0.0001	4.90E+01	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0000	
				Cs-137	0.9878	3.69E+05	4.86E+07	0.0076		6.17E+08	0.0006		1.79E+06	0.2064	
32	A005 Position#2	2	3.73E+05	Co-60	0.0121	4.50E+03	6.95E+06	0.0006	0.0088	8.82E+07	0.0001	0.0007	5.98E+06	0.0008	0.2222
				Ni-63	180	8.12E+05	5.35E+09	0.0002		6.79E+10	0.0000		1.85E+08	0.0044	
				Sr-90	0.002	7.37E+02	1.90E+06	0.0004		2.41E+07	0.0000		6.58E+04	0.0112	
				Cs-134	0.0001	4.89E+01	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0000	
				Cs-137	0.9878	3.68E+05	4.86E+07	0.0076		6.17E+08	0.0006		1.79E+06	0.2058	
33	A005 Position#3	3	4.20E+05	Co-60	0.0121	5.07E+03	6.95E+06	0.0007	0.0099	8.82E+07	0.0001	0.0008	5.98E+06	0.0008	0.2504
				Ni-63	180	9.15E+05	5.35E+09	0.0002		6.79E+10	0.0000		1.85E+08	0.0049	
				Sr-90	0.002	8.30E+02	1.90E+06	0.0004		2.41E+07	0.0000		6.58E+04	0.0126	
				Cs-134	0.0001	5.51E+01	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0000	
				Cs-137	0.9878	4.15E+05	4.86E+07	0.0085		6.17E+08	0.0007		1.79E+06	0.2319	
34	A020 Position#1	1	4.25E+05	Co-60	0.0121	5.13E+03	6.95E+06	0.0007	0.0100	8.82E+07	0.0001	0.0008	5.98E+06	0.0009	0.2533
				Ni-63	180	9.26E+05	5.35E+09	0.0002		6.79E+10	0.0000		1.85E+08	0.0050	
				Sr-90	0.002	8.40E+02	1.90E+06	0.0004		2.41E+07	0.0000		6.58E+04	0.0128	
				Cs-134	0.0001	5.58E+01	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0000	
				Cs-137	0.9878	4.20E+05	4.86E+07	0.0086		6.17E+08	0.0007		1.79E+06	0.2346	
35	A020 Position#2	2	4.96E+05	Co-60	0.0121	5.98E+03	6.95E+06	0.0009	0.0117	8.82E+07	0.0001	0.0009	5.98E+06	0.0010	0.2955
				Ni-63	180	1.08E+06	5.35E+09	0.0002		6.79E+10	0.0000		1.85E+08	0.0058	
				Sr-90	0.002	9.80E+02	1.90E+06	0.0005		2.41E+07	0.0000		6.58E+04	0.0149	
				Cs-134	0.0001	6.51E+01	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0000	
				Cs-137	0.9878	4.90E+05	4.86E+07	0.0101		6.17E+08	0.0008		1.79E+06	0.2737	
36	A020 Position#3	3	4.93E+05	Co-60	0.0121	5.95E+03	6.95E+06	0.0009	0.0116	8.82E+07	0.0001	0.0009	5.98E+06	0.0010	0.2937
				Ni-63	180	1.07E+06	5.35E+09	0.0002		6.79E+10	0.0000		1.85E+08	0.0058	
				Sr-90	0.002	9.74E+02	1.90E+06	0.0005		2.41E+07	0.0000		6.58E+04	0.0148	
				Cs-134	0.0001	6.47E+01	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0000	
				Cs-137	0.9878	4.87E+05	4.86E+07	0.0100		6.17E+08	0.0008		1.79E+06	0.2721	
37	A021 Position#1	1	5.53E+05	Co-60	0.0121	6.67E+03	6.95E+06	0.0010	0.0130	8.82E+07	0.0001	0.0010	5.98E+06	0.0011	0.3295
				Ni-63	180	1.20E+06	5.35E+09	0.0002		6.79E+10	0.0000		1.85E+08	0.0065	
				Sr-90	0.002	1.09E+03	1.90E+06	0.0006		2.41E+07	0.0000		6.58E+04	0.0166	
				Cs-134	0.0001	7.25E+01	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0001	
				Cs-137	0.9878	5.46E+05	4.86E+07	0.0112		6.17E+08	0.0009		1.79E+06	0.3052	
38	A021 Position#2	2	4.64E+05	Co-60	0.0121	5.59E+03	6.95E+06	0.0008	0.0109	8.82E+07	0.0001	0.0009	5.98E+06	0.0009	0.2762
				Ni-63	180	1.01E+06	5.35E+09	0.0002		6.79E+10	0.0000		1.85E+08	0.0055	
				Sr-90	0.002	9.16E+02	1.90E+06	0.0005		2.41E+07	0.0000		6.58E+04	0.0139	
				Cs-134	0.0001	6.08E+01	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0000	
				Cs-137	0.9878	4.58E+05	4.86E+07	0.0094		6.17E+08	0.0007		1.79E+06	0.2558	

Penetration Survey Data Assessment (continued)

No.	Sample ID	Feet into Pipe	Gamma Result (pCi/m ²)	ROC	Gamma Mixture/HTD Ratio	Activity per ROC (pCi/m ²)	Auxiliary OpDCGL _{PN} (pCi/m ²)	Auxiliary ROC OpSOF _{PN}	Auxiliary Total OpSOF _{PN}	Auxiliary BcDCGL _{PN} (pCi/m ²)	Auxiliary ROC BcSOF _{PN}	Auxiliary Total BcSOF _{PN}	Turbine OpDCGL _B (pCi/m ²)	Turbine ROC OpSOF _B	Turbine Total OpSOF _B
39	A021 Position#3	3	4.66E+05	Co-60	0.0121	5.63E+03	6.95E+06	0.0008	0.0110	8.82E+07	0.0001	0.0009	5.98E+06	0.0009	0.2779
				Ni-63	180	1.02E+06	5.35E+09	0.0002		6.79E+10	0.0000		1.85E+08	0.0055	
				Sr-90	0.002	9.22E+02	1.90E+06	0.0005		2.41E+07	0.0000		6.58E+04	0.0140	
				Cs-134	0.0001	6.12E+01	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0000	
				Cs-137	0.9878	4.61E+05	4.86E+07	0.0095		6.17E+08	0.0007		1.79E+06	0.2574	
40	A022 Position#1	1	3.68E+05	Co-60	0.0121	4.44E+03	6.95E+06	0.0006	0.0087	8.82E+07	0.0001	0.0007	5.98E+06	0.0007	0.2193
				Ni-63	180	8.01E+05	5.35E+09	0.0001		6.79E+10	0.0000		1.85E+08	0.0043	
				Sr-90	0.002	7.27E+02	1.90E+06	0.0004		2.41E+07	0.0000		6.58E+04	0.0111	
				Cs-134	0.0001	4.83E+01	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0000	
				Cs-137	0.9878	3.64E+05	4.86E+07	0.0075		6.17E+08	0.0006		1.79E+06	0.2031	
41	A022 Position#2	2	3.70E+05	Co-60	0.0121	4.46E+03	6.95E+06	0.0006	0.0087	8.82E+07	0.0001	0.0007	5.98E+06	0.0007	0.2205
				Ni-63	180	8.06E+05	5.35E+09	0.0002		6.79E+10	0.0000		1.85E+08	0.0044	
				Sr-90	0.002	7.31E+02	1.90E+06	0.0004		2.41E+07	0.0000		6.58E+04	0.0111	
				Cs-134	0.0001	4.85E+01	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0000	
				Cs-137	0.9878	3.66E+05	4.86E+07	0.0075		6.17E+08	0.0006		1.79E+06	0.2042	
42	A022 Position#3	3	5.00E+05	Co-60	0.0121	6.03E+03	6.95E+06	0.0009	0.0118	8.82E+07	0.0001	0.0009	5.98E+06	0.0010	0.2979
				Ni-63	180	1.09E+06	5.35E+09	0.0002		6.79E+10	0.0000		1.85E+08	0.0059	
				Sr-90	0.002	9.88E+02	1.90E+06	0.0005		2.41E+07	0.0000		6.58E+04	0.0150	
				Cs-134	0.0001	6.56E+01	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0000	
				Cs-137	0.9878	4.94E+05	4.86E+07	0.0102		6.17E+08	0.0008		1.79E+06	0.2759	
43	A023 Position#1	1	5.16E+06	Co-60	0.0121	6.23E+04	6.95E+06	0.0090	0.1214	8.82E+07	0.0007	0.0096	5.98E+06	0.0104	3.0764
				Ni-63	180	1.12E+07	5.35E+09	0.0021		6.79E+10	0.0002		1.85E+08	0.0608	
				Sr-90	0.002	1.02E+04	1.90E+06	0.0054		2.41E+07	0.0004		6.58E+04	0.1550	
				Cs-134	0.0001	6.77E+02	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0005	
				Cs-137	0.9878	5.10E+06	4.86E+07	0.1050		6.17E+08	0.0083		1.79E+06	2.8497	
44	A023 Position#2	2	7.02E+06	Co-60	0.0121	8.47E+04	6.95E+06	0.0122	0.1650	8.82E+07	0.0010	0.0130	5.98E+06	0.0142	4.1811
				Ni-63	180	1.53E+07	5.35E+09	0.0029		6.79E+10	0.0002		1.85E+08	0.0826	
				Sr-90	0.002	1.39E+04	1.90E+06	0.0073		2.41E+07	0.0006		6.58E+04	0.2107	
				Cs-134	0.0001	9.20E+02	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0007	
				Cs-137	0.9878	6.93E+06	4.86E+07	0.1426		6.17E+08	0.0112		1.79E+06	3.8729	
45	A023 Position#3	3	5.40E+06	Co-60	0.0121	6.52E+04	6.95E+06	0.0094	0.1270	8.82E+07	0.0007	0.0100	5.98E+06	0.0109	3.2190
				Ni-63	180	1.18E+07	5.35E+09	0.0022		6.79E+10	0.0002		1.85E+08	0.0636	
				Sr-90	0.002	1.07E+04	1.90E+06	0.0056		2.41E+07	0.0004		6.58E+04	0.1622	
				Cs-134	0.0001	7.09E+02	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0005	
				Cs-137	0.9878	5.34E+06	4.86E+07	0.1098		6.17E+08	0.0087		1.79E+06	2.9817	
46	A017 Position#1	1	8.21E+05	Co-60	0.0121	9.91E+03	6.95E+06	0.0014	0.0193	8.82E+07	0.0001	0.0015	5.98E+06	0.0017	0.4893
				Ni-63	180	1.79E+06	5.35E+09	0.0003		6.79E+10	0.0000		1.85E+08	0.0097	
				Sr-90	0.002	1.62E+03	1.90E+06	0.0009		2.41E+07	0.0001		6.58E+04	0.0247	
				Cs-134	0.0001	1.08E+02	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0001	
				Cs-137	0.9878	8.11E+05	4.86E+07	0.0167		6.17E+08	0.0013		1.79E+06	0.4533	

FSS RELEASE RECORD
 AUXILIARY BUILDING PENETRATIONS
 SURVEY UNIT 05120



Penetration Survey Data Assessment (continued)

No.	Sample ID	Feet into Pipe	Gamma Result (pCi/m ²)	ROC	Gamma Mixture/HTD Ratio	Activity per ROC (pCi/m ²)	Auxiliary OpDCGL _{PN} (pCi/m ²)	Auxiliary ROC OpSOF _{PN}	Auxiliary Total OpSOF _{PN}	Auxiliary BcDCGL _{PN} (pCi/m ²)	Auxiliary ROC BcSOF _{PN}	Auxiliary Total BcSOF _{PN}	Turbine OpDCGL _B (pCi/m ²)	Turbine ROC OpSOF _B	Turbine Total OpSOF _B
47	A017 Position#2	2	8.85E+05	Co-60	0.0121	1.07E+04	6.95E+06	0.0015	0.0208	8.82E+07	0.0001	0.0016	5.98E+06	0.0018	0.5272
				Ni-63	180	1.93E+06	5.35E+09	0.0004		6.79E+10	0.0000		1.85E+08	0.0104	
				Sr-90	0.002	1.75E+03	1.90E+06	0.0009		2.41E+07	0.0001		6.58E+04	0.0266	
				Cs-134	0.0001	1.16E+02	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0001	
				Cs-137	0.9878	8.74E+05	4.86E+07	0.0180		6.17E+08	0.0014		1.79E+06	0.4884	
48	A017 Position#3	3	1.07E+06	Co-60	0.0121	1.29E+04	6.95E+06	0.0019	0.0251	8.82E+07	0.0001	0.0020	5.98E+06	0.0022	0.6357
				Ni-63	180	2.32E+06	5.35E+09	0.0004		6.79E+10	0.0000		1.85E+08	0.0126	
				Sr-90	0.002	2.11E+03	1.90E+06	0.0011		2.41E+07	0.0001		6.58E+04	0.0320	
				Cs-134	0.0001	1.40E+02	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0001	
				Cs-137	0.9878	1.05E+06	4.86E+07	0.0217		6.17E+08	0.0017		1.79E+06	0.5889	
49	A010 Position#1	1	6.97E+05	Co-60	0.0121	8.41E+03	6.95E+06	0.0012	0.0164	8.82E+07	0.0001	0.0013	5.98E+06	0.0014	0.4153
				Ni-63	180	1.52E+06	5.35E+09	0.0003		6.79E+10	0.0000		1.85E+08	0.0082	
				Sr-90	0.002	1.38E+03	1.90E+06	0.0007		2.41E+07	0.0001		6.58E+04	0.0209	
				Cs-134	0.0001	9.14E+01	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0001	
				Cs-137	0.9878	6.89E+05	4.86E+07	0.0142		6.17E+08	0.0011		1.79E+06	0.3846	
50	A010 Position#2	2	7.12E+05	Co-60	0.0121	8.59E+03	6.95E+06	0.0012	0.0167	8.82E+07	0.0001	0.0013	5.98E+06	0.0014	0.4240
				Ni-63	180	1.55E+06	5.35E+09	0.0003		6.79E+10	0.0000		1.85E+08	0.0084	
				Sr-90	0.002	1.41E+03	1.90E+06	0.0007		2.41E+07	0.0001		6.58E+04	0.0214	
				Cs-134	0.0001	9.33E+01	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0001	
				Cs-137	0.9878	7.03E+05	4.86E+07	0.0145		6.17E+08	0.0011		1.79E+06	0.3928	
51	A010 Position#3	3	8.35E+05	Co-60	0.0121	1.01E+04	6.95E+06	0.0014	0.0196	8.82E+07	0.0001	0.0015	5.98E+06	0.0017	0.4975
				Ni-63	180	1.82E+06	5.35E+09	0.0003		6.79E+10	0.0000		1.85E+08	0.0098	
				Sr-90	0.002	1.65E+03	1.90E+06	0.0009		2.41E+07	0.0001		6.58E+04	0.0251	
				Cs-134	0.0001	1.10E+02	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0001	
				Cs-137	0.9878	8.25E+05	4.86E+07	0.0170		6.17E+08	0.0013		1.79E+06	0.4608	
52	A001 Position #1	3	3.48E+04	Co-60	0.0121	4.20E+02	6.95E+06	0.0001	0.0008	8.82E+07	0.0000	0.0001	5.98E+06	0.0001	0.0208
				Ni-63	180	7.59E+04	5.35E+09	0.0000		6.79E+10	0.0000		1.85E+08	0.0004	
				Sr-90	0.002	6.88E+01	1.90E+06	0.0000		2.41E+07	0.0000		6.58E+04	0.0010	
				Cs-134	0.0001	4.57E+00	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0000	
				Cs-137	0.9878	3.44E+04	4.86E+07	0.0007		6.17E+08	0.0001		1.79E+06	0.0192	
53	A001 Position #2	2	3.82E+04	Co-60	0.0121	4.61E+02	6.95E+06	0.0001	0.0009	8.82E+07	0.0000	0.0001	5.98E+06	0.0001	0.0228
				Ni-63	180	8.33E+04	5.35E+09	0.0000		6.79E+10	0.0000		1.85E+08	0.0005	
				Sr-90	0.002	7.56E+01	1.90E+06	0.0000		2.41E+07	0.0000		6.58E+04	0.0011	
				Cs-134	0.0001	5.02E+00	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0000	
				Cs-137	0.9878	3.78E+04	4.86E+07	0.0008		6.17E+08	0.0001		1.79E+06	0.0211	
54	A001 Position #3	1	3.62E+04	Co-60	0.0121	4.37E+02	6.95E+06	0.0001	0.0009	8.82E+07	0.0000	0.0001	5.98E+06	0.0001	0.0216
				Ni-63	180	7.89E+04	5.35E+09	0.0000		6.79E+10	0.0000		1.85E+08	0.0004	
				Sr-90	0.002	7.16E+01	1.90E+06	0.0000		2.41E+07	0.0000		6.58E+04	0.0011	
				Cs-134	0.0001	4.75E+00	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0000	
				Cs-137	0.9878	3.58E+04	4.86E+07	0.0007		6.17E+08	0.0001		1.79E+06	0.0200	

Penetration Survey Data Assessment (continued)

No.	Sample ID	Feet into Pipe	Gamma Result (pCi/m ²)	ROC	Gamma Mixture/HTD Ratio	Activity per ROC (pCi/m ²)	Auxiliary OpDCGL _{PN} (pCi/m ²)	Auxiliary ROC OpSOF _{PN}	Auxiliary Total OpSOF _{PN}	Auxiliary BcDCGL _{PN} (pCi/m ²)	Auxiliary ROC BcSOF _{PN}	Auxiliary Total BcSOF _{PN}	Turbine OpDCGL _B (pCi/m ²)	Turbine ROC OpSOF _B	Turbine Total OpSOF _B
55	A014 Position #1	3	2.24E+04	Co-60	0.0121	2.71E+02	6.95E+06	0.0000	0.0005	8.82E+07	0.0000	0.0000	5.98E+06	0.0000	0.0134
				Ni-63	180	4.88E+04	5.35E+09	0.0000		6.79E+10	0.0000		1.85E+08	0.0003	
				Sr-90	0.002	4.43E+01	1.90E+06	0.0000		2.41E+07	0.0000		6.58E+04	0.0007	
				Cs-134	0.0001	2.94E+00	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0000	
				Cs-137	0.9878	2.22E+04	4.86E+07	0.0005		6.17E+08	0.0000		1.79E+06	0.0124	
56	A014 Position #2	2	2.92E+04	Co-60	0.0121	3.53E+02	6.95E+06	0.0001	0.0007	8.82E+07	0.0000	0.0001	5.98E+06	0.0001	0.0174
				Ni-63	180	6.36E+04	5.35E+09	0.0000		6.79E+10	0.0000		1.85E+08	0.0003	
				Sr-90	0.002	5.78E+01	1.90E+06	0.0000		2.41E+07	0.0000		6.58E+04	0.0009	
				Cs-134	0.0001	3.83E+00	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0000	
				Cs-137	0.9878	2.89E+04	4.86E+07	0.0006		6.17E+08	0.0000		1.79E+06	0.0161	
57	A014 Position #3	1	3.36E+04	Co-60	0.0121	4.06E+02	6.95E+06	0.0001	0.0008	8.82E+07	0.0000	0.0001	5.98E+06	0.0001	0.0200
				Ni-63	180	7.32E+04	5.35E+09	0.0000		6.79E+10	0.0000		1.85E+08	0.0004	
				Sr-90	0.002	6.65E+01	1.90E+06	0.0000		2.41E+07	0.0000		6.58E+04	0.0010	
				Cs-134	0.0001	4.41E+00	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0000	
				Cs-137	0.9878	3.32E+04	4.86E+07	0.0007		6.17E+08	0.0001		1.79E+06	0.0186	
58	A004 Position #1	3	3.14E+04	Co-60	0.0121	3.79E+02	6.95E+06	0.0001	0.0007	8.82E+07	0.0000	0.0001	5.98E+06	0.0001	0.0187
				Ni-63	180	6.84E+04	5.35E+09	0.0000		6.79E+10	0.0000		1.85E+08	0.0004	
				Sr-90	0.002	6.21E+01	1.90E+06	0.0000		2.41E+07	0.0000		6.58E+04	0.0009	
				Cs-134	0.0001	4.12E+00	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0000	
				Cs-137	0.9878	3.11E+04	4.86E+07	0.0006		6.17E+08	0.0001		1.79E+06	0.0173	
59	A004 Position #2	2	2.80E+04	Co-60	0.0121	3.38E+02	6.95E+06	0.0000	0.0007	8.82E+07	0.0000	0.0001	5.98E+06	0.0001	0.0167
				Ni-63	180	6.10E+04	5.35E+09	0.0000		6.79E+10	0.0000		1.85E+08	0.0003	
				Sr-90	0.002	5.54E+01	1.90E+06	0.0000		2.41E+07	0.0000		6.58E+04	0.0008	
				Cs-134	0.0001	3.68E+00	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0000	
				Cs-137	0.9878	2.77E+04	4.86E+07	0.0006		6.17E+08	0.0000		1.79E+06	0.0155	
60	A004 Position #3	1	3.58E+04	Co-60	0.0121	4.32E+02	6.95E+06	0.0001	0.0008	8.82E+07	0.0000	0.0001	5.98E+06	0.0001	0.0214
				Ni-63	180	7.80E+04	5.35E+09	0.0000		6.79E+10	0.0000		1.85E+08	0.0004	
				Sr-90	0.002	7.08E+01	1.90E+06	0.0000		2.41E+07	0.0000		6.58E+04	0.0011	
				Cs-134	0.0001	4.70E+00	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0000	
				Cs-137	0.9878	3.54E+04	4.86E+07	0.0007		6.17E+08	0.0001		1.79E+06	0.0198	
61	A024 Position #1	3	3.72E+04	Co-60	0.0121	4.49E+02	6.95E+06	0.0001	0.0009	8.82E+07	0.0000	0.0001	5.98E+06	0.0001	0.0222
				Ni-63	180	8.11E+04	5.35E+09	0.0000		6.79E+10	0.0000		1.85E+08	0.0004	
				Sr-90	0.002	7.36E+01	1.90E+06	0.0000		2.41E+07	0.0000		6.58E+04	0.0011	
				Cs-134	0.0001	4.88E+00	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0000	
				Cs-137	0.9878	3.68E+04	4.86E+07	0.0008		6.17E+08	0.0001		1.79E+06	0.0206	
62	A024 Position #2	2	6.31E+04	Co-60	0.0121	7.61E+02	6.95E+06	0.0001	0.0015	8.82E+07	0.0000	0.0001	5.98E+06	0.0001	0.0376
				Ni-63	180	1.37E+05	5.35E+09	0.0000		6.79E+10	0.0000		1.85E+08	0.0007	
				Sr-90	0.002	1.25E+02	1.90E+06	0.0001		2.41E+07	0.0000		6.58E+04	0.0019	
				Cs-134	0.0001	8.27E+00	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0000	
				Cs-137	0.9878	6.23E+04	4.86E+07	0.0013		6.17E+08	0.0001		1.79E+06	0.0348	

Penetration Survey Data Assessment (continued)

No.	Sample ID	Feet into Pipe	Gamma Result (pCi/m ²)	ROC	Gamma Mixture/HTD Ratio	Activity per ROC (pCi/m ²)	Auxiliary OpDCGL _{PN} (pCi/m ²)	Auxiliary ROC OpSOF _{PN}	Auxiliary Total OpSOF _{PN}	Auxiliary BcDCGL _{PN} (pCi/m ²)	Auxiliary ROC BcSOF _{PN}	Auxiliary Total BcSOF _{PN}	Turbine OpDCGL _B (pCi/m ²)	Turbine ROC OpSOF _B	Turbine Total OpSOF _B
63	A024 Position #3	1	1.11E+05	Co-60	0.0121	1.34E+03	6.95E+06	0.0002	0.0026	8.82E+07	0.0000	0.0002	5.98E+06	0.0002	0.0662
				Ni-63	180	2.42E+05	5.35E+09	0.0000		6.79E+10	0.0000		1.85E+08	0.0013	
				Sr-90	0.002	2.20E+02	1.90E+06	0.0001		2.41E+07	0.0000		6.58E+04	0.0033	
				Cs-134	0.0001	1.46E+01	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0000	
				Cs-137	0.9878	1.10E+05	4.86E+07	0.0023		6.17E+08	0.0002		1.79E+06	0.0613	
64	A025 Position #1	3	2.74E+04	Co-60	0.0121	3.31E+02	6.95E+06	0.0000	0.0006	8.82E+07	0.0000	0.0001	5.98E+06	0.0001	0.0163
				Ni-63	180	5.97E+04	5.35E+09	0.0000		6.79E+10	0.0000		1.85E+08	0.0003	
				Sr-90	0.002	5.42E+01	1.90E+06	0.0000		2.41E+07	0.0000		6.58E+04	0.0008	
				Cs-134	0.0001	3.60E+00	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0000	
				Cs-137	0.9878	2.71E+04	4.86E+07	0.0006		6.17E+08	0.0000		1.79E+06	0.0151	
65	A025 Position #2	2	2.60E+04	Co-60	0.0121	3.14E+02	6.95E+06	0.0000	0.0006	8.82E+07	0.0000	0.0000	5.98E+06	0.0001	0.0155
				Ni-63	180	5.67E+04	5.35E+09	0.0000		6.79E+10	0.0000		1.85E+08	0.0003	
				Sr-90	0.002	5.14E+01	1.90E+06	0.0000		2.41E+07	0.0000		6.58E+04	0.0008	
				Cs-134	0.0001	3.41E+00	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0000	
				Cs-137	0.9878	2.57E+04	4.86E+07	0.0005		6.17E+08	0.0000		1.79E+06	0.0144	
66	A025 Position #3	1	2.94E+04	Co-60	0.0121	3.55E+02	6.95E+06	0.0001	0.0007	8.82E+07	0.0000	0.0001	5.98E+06	0.0001	0.0175
				Ni-63	180	6.41E+04	5.35E+09	0.0000		6.79E+10	0.0000		1.85E+08	0.0003	
				Sr-90	0.002	5.81E+01	1.90E+06	0.0000		2.41E+07	0.0000		6.58E+04	0.0009	
				Cs-134	0.0001	3.86E+00	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0000	
				Cs-137	0.9878	2.91E+04	4.86E+07	0.0006		6.17E+08	0.0000		1.79E+06	0.0162	

ATTACHMENT 3
SIGN TEST

Sign Test Auxiliary Building Basement Penetrations

Survey Area 05120 Description Auxiliary Building Basement
 Survey Unit S1-05120AF Description Penetrations
 Classification 1 Type I Error 0.05 # of Measurements 66

#	SOF (Ws)	1-Ws	Sign
1	0.0094	0.99	+1
2	0.0097	0.99	+1
3	0.0100	0.99	+1
4	0.0123	0.99	+1
5	0.0112	0.99	+1
6	0.0111	0.99	+1
7	0.0103	0.99	+1
8	0.0101	0.99	+1
9	0.0103	0.99	+1
10	0.0102	0.99	+1
11	0.0096	0.99	+1
12	0.0121	0.99	+1
13	0.0133	0.99	+1
14	0.0144	0.99	+1
15	0.0335	0.97	+1
16	0.0155	0.98	+1
17	0.0162	0.98	+1
18	0.0166	0.98	+1
19	0.2427	0.76	+1
20	0.2794	0.72	+1
21	0.2352	0.76	+1
22	0.0106	0.99	+1
23	0.0107	0.99	+1
24	0.0137	0.99	+1
25	0.0093	0.99	+1
26	0.0092	0.99	+1
27	0.0101	0.99	+1
28	0.0129	0.99	+1
29	0.0128	0.99	+1
30	0.0147	0.99	+1
31	0.0088	0.99	+1

#	SOF (Ws)	1-Ws	Sign
34	0.0100	0.99	+1
35	0.0117	0.99	+1
36	0.0116	0.99	+1
37	0.0130	0.99	+1
38	0.0109	0.99	+1
39	0.0110	0.99	+1
40	0.0087	0.99	+1
41	0.0087	0.99	+1
42	0.0118	0.99	+1
43	0.1214	0.88	+1
44	0.1650	0.83	+1
45	0.1270	0.87	+1
46	0.0193	0.98	+1
47	0.0208	0.98	+1
48	0.0251	0.97	+1
49	0.0164	0.98	+1
50	0.0167	0.98	+1
51	0.0196	0.98	+1
52	0.0008	1.00	+1
53	0.0009	1.00	+1
54	0.0009	1.00	+1
55	0.0005	1.00	+1
56	0.0007	1.00	+1
57	0.0008	1.00	+1
58	0.0007	1.00	+1
59	0.0007	1.00	+1
60	0.0008	1.00	+1
61	0.0009	1.00	+1
62	0.0015	1.00	+1
63	0.0026	0.99	+1
64	0.0006	1.00	+1

Sign Test (continued) Auxiliary Building Basement Penetrations

#	SOF (Ws)	1-Ws	Sign
32	0.0088	0.99	+1
33	0.0099	0.99	+1

#	SOF (Ws)	1-Ws	Sign
65	0.0006	1.00	+1
66	0.0007	1.00	+1

Number of Positive Differences (S+) = 66

Critical Value = 40

Survey Unit Meets the Acceptance Criteria

ATTACHMENT 4
QC DATA

FSS RELEASE RECORD
 AUXILIARY BUILDING PENETRATIONS
 SURVEY UNIT 05120



Penetration QC Survey Data

No.	Sample ID	Feet into Pipe	Gamma Result (pCi/m ²)	ROC	Gamma Mixture/HTD Ratio	Activity per ROC (pCi/m ²)	Auxiliary OpDCGL _{PN} (pCi/m ²)	Auxiliary ROC OpSOF _{PN}	Auxiliary Total OpSOF _{PN}	Auxiliary BcDCGL _{PN} (pCi/m ²)	Auxiliary ROC BcSOF _{PN}	Auxiliary Total BcSOF _{PN}	Turbine OpDCGL _B (pCi/m ²)	Turbine ROC OpSOF _B	Turbine Total OpSOF _B
54 QC	A014 Position #3	1	2.90E+04	Co-60	0.0121	3.50E+02	6.95E+06	0.0001	0.0007	8.82E+07	0.0000	0.0001	5.98E+06	0.0001	0.0173
				Ni-63	180	6.32E+04	5.35E+09	0.0000		6.79E+10	0.0000		1.85E+08	0.0003	
				Sr-90	0.002	5.74E+01	1.90E+06	0.0000		2.41E+07	0.0000		6.58E+04	0.0009	
				Cs-134	0.0001	3.81E+00	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0000	
				Cs-137	0.9878	2.87E+04	4.86E+07	0.0006		6.17E+08	0.0000		1.79E+06	0.0160	
66 QC	A025 Position #3	1	2.40E+04	Co-60	0.0121	2.90E+02	6.95E+06	0.0000	0.0006	8.82E+07	0.0000	0.0000	5.98E+06	0.0000	0.0143
				Ni-63	180	5.23E+04	5.35E+09	0.0000		6.79E+10	0.0000		1.85E+08	0.0003	
				Sr-90	0.002	4.75E+01	1.90E+06	0.0000		2.41E+07	0.0000		6.58E+04	0.0007	
				Cs-134	0.0001	3.15E+00	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0000	
				Cs-137	0.9878	2.37E+04	4.86E+07	0.0005		6.17E+08	0.0000		1.79E+06	0.0133	
38 QC	A021 Position #2	2	4.66E+05	Co-60	0.0121	5.62E+03	6.95E+06	0.0008	0.0109	8.82E+07	0.0001	0.0009	5.98E+06	0.0009	0.2773
				Ni-63	180	1.01E+06	5.35E+09	0.0002		6.79E+10	0.0000		1.85E+08	0.0055	
				Sr-90	0.002	9.20E+02	1.90E+06	0.0005		2.41E+07	0.0000		6.58E+04	0.0140	
				Cs-134	0.0001	6.11E+01	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0000	
				Cs-137	0.9878	4.60E+05	4.86E+07	0.0095		6.17E+08	0.0007		1.79E+06	0.2569	
10 QC	A002 Position #1	1	4.81E+05	Co-60	0.0121	5.81E+03	6.95E+06	0.0008	0.0113	8.82E+07	0.0001	0.0009	5.98E+06	0.0010	0.2867
				Ni-63	180	1.05E+06	5.35E+09	0.0002		6.79E+10	0.0000		1.85E+08	0.0057	
				Sr-90	0.002	9.51E+02	1.90E+06	0.0005		2.41E+07	0.0000		6.58E+04	0.0144	
				Cs-134	0.0001	6.31E+01	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0000	
				Cs-137	0.9878	4.75E+05	4.86E+07	0.0098		6.17E+08	0.0008		1.79E+06	0.2656	
50 QC	A010 Position #2	2	7.21E+05	Co-60	0.0121	8.71E+03	6.95E+06	0.0013	0.0170	8.82E+07	0.0001	0.0013	5.98E+06	0.0015	0.4298
				Ni-63	180	1.57E+06	5.35E+09	0.0003		6.79E+10	0.0000		1.85E+08	0.0085	
				Sr-90	0.002	1.43E+03	1.90E+06	0.0008		2.41E+07	0.0001		6.58E+04	0.0217	
				Cs-134	0.0001	9.46E+01	2.58E+07	0.0000		3.28E+08	0.0000		1.35E+06	0.0001	
				Cs-137	0.9878	7.13E+05	4.86E+07	0.0147		6.17E+08	0.0012		1.79E+06	0.3982	

**ATTACHMENT 5
QC MEASUREMENT
ASSESSMENTS**

Replicate Measurement Assessment

Survey Unit # 05120 Survey Unit Name Auxiliary Building Penetrationst
 Sample Plan # S1-05120A-F

Sample Description: Comparison of replicate gross-gamma measurements for QC from A002, position 1, A010, position 2, A014, position 3, A021, position 2 and A025 position 3.

STANDARD				DUPLICATE		
ID	ACTIVITY (pCi/m2)	+20% (pCi/m2)	-20% (pCi/m2)	ID	ACTIVITY (pCi/m2)	ACCEPTABLE (Y/N)
A014 Position 3	3.36E+04	4.04E+04	2.69E+04	A014 Position 3 QC	2.90E+04	Y
A025 Position 3	2.94E+04	3.53E+04	2.35E+04	A025 Position 3 QC	2.40E+04	Y
A021 Position 2	4.64E+05	5.56E+05	3.71E+05	A021 Position 2 QC	4.66E+05	Y
A002 Position 1	4.32E+05	5.18E+05	3.46E+05	A002 Position 1 QC	4.81E+05	Y
A010 Position 2	7.12E+05	8.54E+05	5.69E+05	A010 Position 2 QC	7.21E+05	Y
Comments/Corrective Actions: There was acceptable agreement between the standard measurement and the duplicate measurement. No further action is necessary.				The acceptance criteria for replicate static measurements and scan surveys is that the same conclusion is reached for each measurement. That is defined as $\pm 20\%$ of the standard		

ATTACHMENT 6


GRAPHICAL PRESENTATIONS

Quantile Plot for Co-60

Survey Unit: S1-05120A-F

Description: Aux Building Penetrations

Mean: 1.38E+04pCi/m²




Quantile Plot for Cs-137

Survey Unit: S1-05120A-F


Description: Aux Building Penetrations

Mean: 1.13E+06 pCi/m²



Histogram for Co-60


Survey Unit: S1-05120A-F
 Description: Aux Building Penetrations
 Mean: 1.38E+04 pCi/m²
 Median: 5.47E+03 pCi/m²
 ST Dev.: 2.92E+04
 Skew: 3.37E+00



Upper Value	Observation Frequency	Observation %
1.49E+04	59	89%
2.92E+04	1	2%
4.35E+04	0	0%
5.79E+04	0	0%
7.22E+04	3	5%
8.65E+04	0	0%
1.01E+05	0	0%
1.15E+05	0	0%
1.30E+05	2	3%
1.44E+05	1	2%
TOTAL	66	100%

Histogram for Cs-137

Survey Unit: S1-05120A-F
 Description: Aux Building Penetrations
 Mean: 1.13E+05 pCi/m²
 Median: 4.48E+05 pCi/m²
 ST Dev.: 2.39E+06
 Skew: 3.37E+00



Upper Value	Observation Frequency	Observation %
1.22E+06	59	89%
2.39E+06	1	2%
3.56E+06	0	0%
4.74E+06	0	0%
5.91E+06	2	3%
7.08E+06	1	2%
8.26E+06	0	0%
9.43E+06	0	0%
1.06E+07	2	3%
1.18E+07	1	2%
TOTAL	66	100%