

**CALCULATION OF RELEASES  
OF RADIOACTIVE MATERIALS  
IN GASEOUS AND LIQUID EFFLUENTS  
FROM BOILING WATER REACTORS  
(BWR-GALE CODE)**

**April 1976**



**Office of Standards Development  
U. S. Nuclear Regulatory Commission**

8001100 825

Available from  
National Technical Information Service  
Springfield, Virginia 22161  
Price: Printed Copy \$6.00 ; Microfiche \$2.25

Calculation of Releases of Radioactive Materials  
in Gaseous and Liquid Effluents From  
Boiling Water Reactors  
(BWR-GALE Code)

April 1976

Office of Standards Development  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

## TABLE OF CONTENTS

|  | <u>Page</u> |
|--|-------------|
| <u>CHAPTER 1. BWR-GALE CODE</u>  |             |
| 1.1 Introduction .....   | 1-1         |
| 1.2 Definitions .....  | 1-2         |
| 1.3 Gaseous Source Terms .....   | 1-4         |
| 1.4 Liquid Source Terms .....  | 1-4         |
| 1.5 Instructions for Completing BWR-GALE Code Input Data Cards .....                               | 1-5         |
| 1.5.1 Parameters Included in the BWR-GALE Code .....   | 1-5         |
| 1.5.2 Parameters Required for the BWR-GALE Code .....  | 1-8         |
| <u>CHAPTER 2. PRINCIPAL PARAMETERS USED IN BWR SOURCE TERM CALCULATIONS AND THEIR BASES</u>        |             |
| 2.1 Introduction .....   | 2-1         |
| 2.2 Principal Parameters and Their Bases .....   | 2-1         |
| 2.2.1 Thermal Power Level .....  | 2-1         |
| 2.2.2 Plant Capacity Factor .....  | 2-1         |
| 2.2.3 Radionuclide Concentrations in the Reactor Coolant.....                                      | 2-1         |
| 2.2.4 Gaseous Releases from Building Ventilation Systems.....                                      | 2-11        |
| 2.2.5 Iodine Input to the Main Condenser Offgas Treatment System.....                              | 2-19        |
| 2.2.6 Turbine Gland Sealing System Exhaust.....  | 2-19        |
| 2.2.7 Main Condenser Mechanical Vacuum Pump.....   | 2-27        |
| 2.2.8 Air Inleakage to the Main Condenser.....   | 2-28        |
| 2.2.9 Holdup Times for Charcoal Delay Systems.....   | 2-28        |
| 2.2.10 Decontamination Factors for Cryogenic Distillation.....                                     | 2-29        |
| 2.2.11 Decontamination Factor for the Charcoal Adsorbers and HEPA filters....                      | 2-29        |
| 2.2.12 Liquid Waste Inputs.....  | 2-32        |
| 2.2.13 Chemical Wastes from Regeneration of Condensate Demineralizers.....                         | 2-32        |
| 2.2.14 Detergent Waste.....  | 2-32        |
| 2.2.15 Tritium Releases.....   | 2-36        |
| 2.2.16 Decontamination Factors for Demineralizers.....   | 2-36        |
| 2.2.17 Decontamination Factors for Evaporators.....  | 2-38        |
| 2.2.18 Decontamination Factors for Reverse Osmosis.....  | 2-38        |
| 2.2.19 Guidelines for Calculating Liquid Waste Holdup Times.....                                   | 2-39        |
| 2.2.20 Adjustment to Liquid Radwaste Source Terms for Anticipated<br>Operational Occurrences ..... | 2-39        |
| 2.2.21 Guidelines for Rounding Off Numerical Values.....   | 2-42        |
| 2.2.22 Carbon-14 Releases.....   | 2-42        |
| 2.2.23 Argon-41 Releases.....  | 2-43        |
| <u>CHAPTER 3. INPUT FORMAT, SAMPLE PROBLEM, AND FORTRAN LISTING OF THE BWR-GALE CODE</u>           |             |
| 3.1 Introduction .....   | 3-1         |
| 3.2 Input Data Sheets .....  | 3-1         |
| 3.3 Sample Problem - Input and Output .....  | 3-4         |
| 3.4 Listing of BWR-GALE Code .....   | 3-11        |
| 3.4.1 Nuclear Data Library .....   | 3-11        |
| 3.4.2 Fortran Program Listing .....  | 3-11        |



TABLE OF CONTENTS (Cont'd)

|   | <u>Page</u> |
|---|-------------|
| <u>CHAPTER 4. DATA NEEDED FOR RADIOACTIVE SOURCE TERM CALCULATIONS FOR BOILING WATER REACTORS</u> |             |
| 4.1 General .....   | 4-1         |
| 4.2 Nuclear Steam Supply System.....  | 4-1         |
| 4.3 Reactor Coolant Cleanup System.....   | 4-1         |
| 4.4 Condensate Demineralizers.....  | 4-1         |
| 4.5 Liquid Waste Processing Systems.....  | 4-1         |
| 4.6 Main Condenser and Turbine Gland Seal Air Removal Systems.....                                | 4-2         |
| 4.7 Ventilation and Exhaust Systems.....  | 4-2         |
| <u>REFERENCES</u> .....   | R-1         |

LIST OF TABLES

| <u>Table</u> |  | <u>Page</u> |
|--------------|--|-------------|
| 1-1          | Releases from Building Ventilation Systems Prior to Treatment.....   | 1-6         |
| 1-2          | BWR Liquid Wastes .....  | 1-10        |
| 1-3          | Decontamination Factors for BWR Liquid Waste Treatment Systems .....   | 1-12        |
| 2-1          | Plant Capacity Factors at Operating BWRs .....   | 2-2         |
| 2-2          | Radionuclide Concentrations in Boiling Water Reactor Coolant and Main Steam.....   | 2-3         |
| 2-3          | Parameters Used to Describe the Reference Boiling Water Reactor.....   | 2-5         |
| 2-4          | Values Used in Determining Adjustment Factors for Boiling Water Reactors.....  | 2-6         |
| 2-5          | Adjustment Factors for Boiling Water Reactors.....   | 2-7         |
| 2-6          | Summary of Noble Gas Release Rates for Operating BWRs (1971-1972).....   | 2-12        |
| 2-7          | Summary of Noble Gas Release Rates for Operating BWRs (1973-1974).....   | 2-13        |
| 2-8          | Reactor Vessel Halogen Carryover Factors Observed at Operating BWRs.....   | 2-14        |
| 2-9          | Gaseous Releases from Ventilation Systems.....   | 2-15        |
| 2-10         | Annual Iodine-131 Releases from Reactor Building Ventilation Systems, Normal Operation.....                                  | 2-16        |
| 2-11         | Comparison Between Iodine-131 Releases from Reactor Building During Normal Operation and Releases During Plant Outages.....  | 2-16        |
| 2-12         | Annual Iodine-131 Releases from Turbine Building Ventilation Systems During Normal Operation.....                            | 2-17        |
| 2-13         | Comparison Between Iodine-131 Releases from Turbine Building During Normal Operation and Releases During Plant Outages.....  | 2-17        |
| 2-14         | Annual Iodine-131 Releases from Radwaste Building Ventilation Systems, Normal Operation.....                                 | 2-18        |
| 2-15         | Comparison Between Iodine-131 Releases from Radwaste Building During Normal Operation and Releases During Plant Outages..... | 2-18        |
| 2-16         | Releases of Noble Gases from the Reactor Building Ventilation System.....  | 2-20        |
| 2-17         | Releases of Noble Gases from the Turbine Building Ventilation System.....  | 2-20        |
| 2-18         | Releases of Noble Gases from the Radwaste Building Ventilation System.....   | 2-20        |
| 2-19         | Particulate Release Rates from Reactor Building Ventilation System, Normal Operation.....                                    | 2-21        |
| 2-20         | Particulate Release Rates from Reactor Building Ventilation System, Short-Term Shutdown (2 Days/Event).....                  | 2-21        |
| 2-21         | Particulate Release Rates from Reactor Building Ventilation System, Refueling Shutdown.....                                  | 2-22        |

LIST OF TABLES (Cont'd)

| <u>Table</u> |  | <u>Page</u> |
|--------------|--|-------------|
| 2-22         | Particulate Release Rates from Turbine Building Ventilation System, Normal Operation.....                                      | 2-22        |
| 2-23         | Particulate Release Rates from Turbine Building Ventilation System, Short-Term Shutdown.....                                   | 2-23        |
| 2-24         | Particulate Release Rates from Turbine Building Ventilation System, Refueling Shutdown.....                                    | 2-23        |
| 2-25         | Particulate Release Rate from Radwaste Building Ventilation System, Normal Operation.....                                      | 2-24        |
| 2-26         | Particulate Release Rate from Radwaste Building Ventilation System, Short-Term Shutdown.....                                   | 2-24        |
| 2-27         | Particulate Release Rate from Radwaste Building Ventilation System, Refueling Shutdown.....                                    | 2-25        |
| 2-28         | Iodine-131 Releases from the Main Condenser Air Ejectors.....  | 2-26        |
| 2-29         | Particulate Release Rate from Vermont Yankee Mechanical Vacuum Pump and Gland Exhaust Condenser Vent, Short-Term Shutdown..... | 2-27        |
| 2-30         | Particulate Release Rate from Vermont Yankee Vacuum Pump and Gland Exhaust Condenser Vent, Refueling Shutdown.....             | 2-27        |
| 2-31         | BWR Liquid Wastes.....   | 2-33        |
| 2-32         | Calculated Annual Release of Radioactive Materials in Untreated Detergent Waste from a BWR and PWR.....                        | 2-34        |
| 2-33         | Ginna Nuclear Power Station - Radionuclide Distribution of Detergent Waste....   | 2-35        |
| 2-34         | Tritium Release Data from Operating BWRs.....  | 2-37        |
| 2-35         | Reverse Osmosis Decontamination Factors, Ginna Station.....  | 2-40        |
| 2-36         | Reverse Osmosis Decontamination Factors, Point Beach.....  | 2-41        |
| 2-37         | Expected Reverse Osmosis Decontamination Factors for Specific Nuclides.....  | 2-41        |
| 2-38         | Frequency and Extent of Unplanned Liquid Radwaste Releases from Operating Plants.....  | 2-42        |

LIST OF FIGURES

| <u>Figure</u> |   | <u>Page</u> |
|---------------|---|-------------|
| 2-1           | Removal Paths for the Reference Boiling Water Reactor.....              | 2-8         |
| 2-2           | Krypton and Xenon K Values as a Function of Reciprocal Temperature..... | 2-30        |
| 2-3           | Effect of Moisture Content on the Dynamic Adsorption Coefficient.....   | 2-31        |
| 2-4           | Charcoal Moisture as a Function of Relative Humidity.....               | 2-31        |

## CHAPTER 1. BWR-GALE CODE

### 1.1 INTRODUCTION

The BWR-GALE (Boiling Water Reactor Gaseous and Liquid Effluents) Code is a computerized mathematical model for calculating the release of radioactive material in gaseous and liquid effluents from boiling water reactors (BWRs). The calculations are based on data generated from operating reactors, field tests, laboratory tests, and plant-specific design considerations incorporated to reduce the quantity of radioactive materials that may be released to the environment.

The average quantity of radioactive material released to the environment from a nuclear power reactor during normal operation is called the "source term," since it is the source or initial number used in calculating the environmental impact of radioactive releases. The calculations performed by the BWR-GALE Code are based on (1) standardized primary and secondary coolant activities derived from American Nuclear Society (ANS) 18.1 Working Group recommendations (Ref. 1), (2) release and transport mechanisms that result in the appearance of radioactive material in liquid and gaseous waste streams, and (3) plant-specific design features used to reduce the quantities of radioactive materials ultimately released to the environs.

In a BWR, water is converted to steam by heat from the fuel elements in the reactor. The steam expands through a turbine and then is condensed and returned to the reactor. The principal mechanisms that affect the concentrations of radioactive materials in the reactor coolant are (1) fission product leakage to the coolant from defects in the fuel cladding and fission product generation in tramp uranium, (2) corrosion products activated in the core, (3) radioactivity removed by the reactor coolant cleanup system, (4) radioactivity removed by the condensate demineralizers, (5) radioactivity removed through the steam-jet ejectors, and (6) radioactivity removed due to reactor coolant leakage. These mechanisms are described briefly in the following paragraphs.

Fission products enter the coolant as a result of defects in the fuel cladding and from the tramp uranium on the cladding surfaces, while corrosion products are activated in the reactor core. These impurities must be continuously removed from the reactor coolant to prevent damage to the fuel elements and other reactor components. The removal is accomplished in two ways: (1) after passing through the turbine, the condensed steam is processed through the condensate cleanup system (e.g., demineralizers) and returned to the reactor for reuse and (2) a side stream of reactor coolant is continuously withdrawn, processed through the reactor cleanup system (demineralizers), and returned to the reactor vessel. Both cleanup systems remove particulates and ionic impurities from the reactor coolant. The materials collected by the demineralizers are removed periodically by chemical regeneration or by replacement of resins. The liquid wastes are processed in the liquid waste treatment system, and the spent ion exchange resins are transferred to the solid waste treatment system and prepared for offsite shipment.

Radioactive gases are removed from the condensing steam in the main condenser by the steam-jet air ejectors. This source of gaseous waste is treated principally by delaying the release to permit radioactive decay. Alternative treatment methods include holdup lines, long-term holdup systems using charcoal delay systems, and cryogenic distillation.

Another potential release point of radioactive material is the exhaust from the turbine gland sealing system. A sidestream of primary steam flows through the turbine gland seal. The steam is condensed and returned to the condenser hotwell for reuse in the reactor. However, noble gases, activation gases, radioactive particulates, and iodine that remain in the gaseous phase must be vented. The treatment provided this source of gaseous waste is normally a two-minute holdup line that permits decay of the short-lived noble and activation gases before they are released to the environment. Clean steam (nonradioactive steam) may be used in place of primary steam to eliminate the gland seal as an activity release point.

Following plant shutdowns, mechanical vacuum pumps are used to reestablish the main condenser vacuum. In addition, the mechanical vacuum pumps may be used during plant shutdowns to maintain a slight condenser vacuum and thereby prevent outleakage of gases from the main condenser. If required to meet the design objectives of Appendix I, the effluent from the mechanical vacuum pump could be processed through charcoal adsorbers for removal of radioiodine prior to release.

In addition to the above release points, the BWR-GALE Code, the calculational model used for BWR source term calculations, considers releases from the turbine, containment, auxiliary, and radwaste buildings due to leakage from contaminated systems. Such leakage from systems containing main steam or reactor coolant may have an appreciable effect on the radioactive source term. Leakage may occur through valve stems, pump seals, and flanged connections. The amount of airborne radioactive material released is a function of reactor coolant temperature, pressure, and activity at the point where the leak occurs. Included with the leaking steam or coolant are noble gases, iodine, and particulates that are released directly to the building atmosphere. In some cases, leakage may be reduced by special design features such as vacuum leakoff drains or "clean" steam on the valve bonnets in addition to normal precautions such as backseating valves and using all-welded systems. Leakage can also be reduced by the use of closed leakoff drains and by increased maintenance.

Liquid waste sources include liquid streams used to sluice (transfer), backwash, regenerate, and rinse demineralizer resins; laundry waste water; personnel shower wastes; laboratory drain wastes; decontamination wastes; and water collected in equipment drains and floor drains.

This chapter provides a step-by-step explanation of the BWR-GALE Code and a description of the parameters that have been built into the Code for use with all BWR source term calculations. These parameters, which apply generically to all BWRs, have been incorporated into the Code to eliminate the need for their entry on input data cards. This chapter also describes the entries required to be entered on input data cards used by the Code. Explanations of the data required, along with acceptable means for calculating such data, are given for each input data card. Chapter 2 gives the principal source term parameters developed for use with the BWR-GALE Code and explains the bases for each parameter. Chapter 3 contains a sample data input sheet and a FORTRAN listing of the BWR-GALE Code. Chapter 4 lists the information needed to generate source terms that an applicant is required to submit with the application.

## 1.2 DEFINITIONS

The following definitions apply to terms used in this report:

Activation Gases: The gases (including oxygen, nitrogen, and argon) that become radioactive due to irradiation in the core.

Chemical Waste Stream: Normally liquids that contain relatively high concentrations of decontamination wastes or chemical compounds other than detergents. These liquids originate primarily from resin regenerants and laboratory waste.

Decontamination Factor (DF): The ratio of the initial amount of a nuclide in a stream (specified in terms of concentration or activity of radioactive materials) to the final amount of that nuclide in a stream following treatment by a given process.

Detergent Waste Stream: Liquids that contain detergent, soaps, or similar organic materials. These liquids consist principally of laundry, personnel shower, and equipment decontamination wastes and normally have a low radioactivity content.

Effective Full Power Days: The number of days a plant would have to operate at 100% licensed power to produce the integrated thermal power output during a calendar year; i.e.,

$$\text{Effective Full Power Days} = \frac{\text{Integrated Thermal Power}}{\text{Licensed Power Level}} = \frac{\sum P_i T_i}{P_{\text{total}}}$$

where

$P_i$  is the  $i$ th power level, in MWt;

$P_{\text{total}}$  is the license power level, in MWt; and

$T_i$  is the time of operation at power level  $i$ , in days.

Fission Product: A nuclide produced either by fission or by subsequent radioactive decay or neutron activation of the nuclides formed in the fission process.

Gaseous Effluent Stream: Processed gaseous waste containing radioactive materials resulting from the operation of a nuclear power reactor.

High-Purity Waste Stream: Liquids, normally of low conductivity, consisting primarily of liquid waste collected from building equipment drains, valve and pump seal leakoffs, demineralizer backwash, ultrasonic resin cleaning, and resin transfer. These liquids are normally reused as primary coolant makeup water after processing.

Liquid Effluent Stream: Processed liquid wastes containing radioactive materials resulting from the operation of a nuclear power reactor.

Low-Purity Waste Stream: Liquids, normally of high conductivity and not of primary quality, collected from building sumps, uncollected valve and pump seal leakoffs, miscellaneous vents, and floor drains.

Partition Coefficient (PC): The ratio of the concentration of a nuclide in the gas phase to the concentration of that nuclide in the liquid phase when the liquid and gas are at equilibrium.

Partition Factor (PF): The ratio of the quantity of a nuclide in the gas phase to the total quantity in both the liquid and gas phases when the liquid and gas are at equilibrium.

Plant Capacity Factor: The ratio of the average net power to the rated power capacity.

Radioactive Halogens: The isotopes of fluorine, chlorine, bromine, and iodine. The radioactive isotopes of iodine are the key isotopes considered in dose calculations.

Radioactive Noble Gases: The radioactive isotopes of helium, neon, argon, krypton, xenon, and radon, which are characterized by their chemical inactivity. The radioactive isotopes of krypton and xenon are the key elements considered in dose calculations.

Radioactive Release Rate: The average quantity of radioactive material released to the environment from a nuclear power reactor during normal operation including anticipated operational occurrences.

Reactor Coolant (Primary Coolant): The fluid circulated through the reactor to remove heat. In a BWR, the fluid allowed to boil in the reactor vessel to generate steam and power the turbine. The reactor coolant activity is considered to be constant over a range of power levels, coolant and cleanup flows, and reactor coolant volumes. The radionuclide distributions and concentrations for the reactor coolant and main steam are based on the values proposed in the ANS 18.1 (Ref. 1) Working Group draft standard for BWRs. Provisions are made in the BWR-GALE Code, in accordance with the recommendations of the draft standard, for adjusting reactor coolant concentrations should the plant be designed to parameters that are outside the ranges considered in the standard. The radionuclide concentrations used are representative of measured values based on the available data. The radionuclides are divided into the following categories:

1. Noble gases
2. Halogens (Br, I)
3. Cesium and Rubidium
4. Water activation products
5. Other nuclides (as listed in Table 2-2 of Chapter 2 of this document)

Regenerant Solutions Waste Stream: Liquids containing regeneration chemical compounds that originate from regeneration of the condensate demineralizer resins.

Source Term: The calculated average quantity of radioactive material released to the environment from a nuclear power reactor during normal operation including anticipated operational occurrences. The source term is the isotopic distribution of radioactive materials used in evaluating the impact of radioactive releases on the environment.

Tramp Uranium: The uranium present on the cladding of a fuel rod.



### 1.3 GASEOUS SOURCE TERMS

The following sources are considered in calculating the release of radioactive materials (noble gases, radioactive particulates, and iodine) in gaseous effluents from normal operation including anticipated operational occurrences:

1. Main condenser offgas system,
2. Turbine gland sealing system,
3. Mechanical vacuum pumps, and
4. Ventilation exhaust air from the containment, auxiliary, radwaste, and turbine buildings.

The releases of radioactive materials in ventilation exhaust air from buildings not covered in 4. above are calculated to be negligible when compared to the gaseous source term from the sources listed above and are therefore not considered individually in the source term calculations.

Calculations show that approximately 9.5 Ci/yr of carbon-14 will be released from a BWR. All carbon-14 releases are assumed to be in the form of a vapor from the main condenser evacuation system vent.

Argon-41 is formed in the drywell by neutron activation of stable, naturally occurring argon-40 in the drywell air. The argon-41 is released to the environment when the drywell is vented or purged. Based on releases reported by licensees in semiannual reports, it is expected that, independent of power level, approximately 25 Ci/yr of argon-41 will be released to the environment.

The releases of radioactive materials in gaseous effluents are based on measurements made at operating BWRs. The radioiodine, radioactive particulate, and noble gas release rates are specified in the BWR-GALE Code and are modified only as needed to reflect treatment processes. Gaseous releases for building ventilation exhaust systems and the main condenser offgas system are based on the average of actual measurements.

The BWR-GALE Code also calculates tritium releases through the ventilation exhaust systems. The annual quantity of tritium available for release is calculated using a functional relationship derived from measured liquid and vapor tritium releases at operating BWRs and considering the integrated thermal power output during the calendar year in which the releases occurred. This relationship expresses total tritium as a function of power output. The tritium releases through the ventilation exhaust systems are assumed to be the total tritium available for release minus the tritium calculated to be released through the liquid pathway. Except for tritium, the radioactivity released in ventilation air is considered to be independent of the power level. Releases from the mechanical vacuum pump are also considered to be independent of the power level.

Chapter 2 provides iodine and particulate decontamination factors for removal equipment and parameters for calculating holdup times for noble gases and for calculating tritium releases.

### 1.4 LIQUID SOURCE TERMS

The following sources are considered in calculating the release of radioactive materials in liquid effluents from normal operations including anticipated operational occurrences:

1. Processed liquid wastes from the high-purity waste system,
2. Processed liquid wastes from the low-purity waste system,
3. Processed liquid wastes from the chemical waste system,
4. Processed liquid regenerant wastes, and
5. Detergent wastes.

The radioactivity input to the liquid radwaste treatment system is based on flow rates of the liquid waste streams and their radioactivity levels, expressed as a fraction of the primary reactor coolant activity (PCA). The primary coolant activity (PCA) is based on the recommendations of the ANS 18.1 Working Group (Ref. 1), which considers a noble gas release rate of 60,000  $\mu$ Ci/sec after a 30-minute decay.



Radionuclide removal by the liquid radwaste treatment system is based on the following parameters:

1. Decay during collection and processing and
2. Removal by the proposed treatment systems, e.g., filtration, ion exchange, evaporation, reverse osmosis, and plateout.

For BWRs using a deep-bed condensate demineralizer, the inventory of radionuclides collected on the demineralizer resins is calculated by considering the flow rate of condensate at main steam activity that is processed through the demineralizers and radionuclide removal using the decontamination factors given in Chapter 2. The radioactivity content of the demineralizer regenerant solution is obtained by considering that all of the activity is removed from the resins at the interval dictated by the regeneration frequency.

Methods for calculating collection and processing times and the decontamination factors for radwaste treatment equipment are given in this chapter. The liquid radioactive source terms are adjusted to compensate for equipment downtime and anticipated operational occurrences.

For plants having an onsite laundry, a standard detergent source term, adjusted for the treatment provided, is added to the adjusted source term.

## 1.5 INSTRUCTIONS FOR COMPLETING BWR-GALE CODE INPUT DATA CARDS

### 1.5.1 PARAMETERS INCLUDED IN THE BWR-GALE CODE

The parameters listed below are built into the BWR-GALE Code since they are generally applicable to all BWR source term calculations and do not require entry on input data cards.

#### 1.5.1.1 Plant Capacity Factor

0.80 (292 effective full power days per year).

#### 1.5.1.2 Radionuclide Concentrations in the Reactor Coolant and Main Steam

See Chapter 2, Tables 2-2 through 2-5 of this document.

#### 1.5.1.3 Noble Gas, Iodine, and Particulate Releases From Building Ventilation Systems Prior to Treatment

See Table 1-1.

#### 1.5.1.4 Radioiodine Input Rate to Main Condenser Offgas System

5 Ci/yr per reactor downstream of main condenser air ejectors.

#### 1.5.1.5 Main Condenser Vacuum Pump Release

Xe-133 -- 2300 Ci/yr

Xe-135 -- 350 Ci/yr

I-131 -- 0.03 Ci/yr

#### 1.5.1.6 Charcoal Delay Systems

For a charcoal delay system used to treat the offgases from the main condenser air ejector, the BWR-GALE Code calculates the holdup times for Kr and Xe. Iodine releases from charcoal delay systems are negligible due to the large quantities of charcoal used in the system. The holdup times for noble gases are calculated by the Code using the following equation, and the data are entered on Cards 31-35.

$$T = 0.262 \frac{MK}{TO N}$$

TABLE 1-1  
RELEASES FROM BUILDING VENTILATION SYSTEMS PRIOR TO TREATMENT  
 (in Ci/yr per Reactor)

| <u>NUCLIDE</u> | <u>CONTAINMENT BUILDING</u> | <u>AUXILIARY BUILDING</u> | <u>TURBINE* BUILDING</u> | <u>RADWASTE BUILDING</u> |
|----------------|-----------------------------|---------------------------|--------------------------|--------------------------|
| Kr-83m         | **                          | **                        | **                       | **                       |
| Kr-85m         | 3                           | 3                         | 68                       | **                       |
| Kr-85          | **                          | **                        | **                       | **                       |
| Kr-87          | 3                           | 3                         | 190                      | **                       |
| Kr-88          | 3                           | 3                         | 230                      | **                       |
| Kr-89          | **                          | **                        | **                       | **                       |
| Xe-131m        | **                          | **                        | **                       | **                       |
| Xe-133m        | **                          | **                        | **                       | **                       |
| Xe-133         | 66                          | 66                        | 280                      | 10                       |
| Xe-135m        | 46                          | 46                        | 650                      | **                       |
| Xe-135         | 34                          | 34                        | 630                      | 45                       |
| Xe-137         | **                          | **                        | **                       | **                       |
| Xe-138         | 7                           | 7                         | 1440                     | **                       |
| I-131          | 0.17                        | 0.17                      | 0.19                     | 0.046                    |
| I-133          | 0.68                        | 0.68                      | 0.76                     | 0.18                     |
| Co-60          | 0.01                        | 0.01                      | 0.002                    | 0.09                     |
| Co-58          | 0.0006                      | 0.0006                    | 0.0006                   | 0.0045                   |
| Cr-51          | 0.0003                      | 0.0003                    | 0.013                    | 0.009                    |
| Mn-54          | 0.003                       | 0.003                     | 0.0006                   | 0.036                    |
| Fe-59          | 0.0004                      | 0.0004                    | 0.0005                   | 0.015                    |
| Zn-65          | 0.002                       | 0.002                     | 0.0002                   | 0.001                    |
| Zr-95          | 0.0004                      | 0.0004                    | 0.0001                   | 0.00005                  |
| Sr-89          | 0.00009                     | 0.00009                   | 0.006                    | 0.0005                   |
| Sr-90          | 0.000005                    | 0.000005                  | 0.00002                  | 0.0003                   |
| Sb-124         | 0.0002                      | 0.0002                    | 0.0003                   | 0.00005                  |
| Cs-134         | 0.004                       | 0.004                     | 0.0003                   | 0.0045                   |
| Cs-136         | 0.0003                      | 0.0003                    | 0.0005                   | 0.00045                  |
| Cs-137         | 0.005                       | 0.005                     | 0.0006                   | 0.009                    |
| Ba-140         | 0.0004                      | 0.0004                    | 0.011                    | 0.0001                   |
| Ce-141         | 0.0001                      | 0.0001                    | 0.0006                   | 0.0026                   |

\*For special design feature to control leakage from valves in lines 2-1/2 inches and larger, reduce the turbine building leakage rates by a factor of five.

\*\*Less than 1 Ci/yr per reactor for noble gases.

where

- K is the dynamic adsorption coefficient, in  $\text{cm}^3/\text{g}$ ,  
M is the mass of charcoal, in  $10^3$  lb,  
T is the holdup time, in hr, and  
10 N is the number of condenser shells times 10, in  $\text{ft}^3/\text{min}$  per shell.

#### 1.5.1.7 Cryogenic Distillation System

For a cryogenic distillation system, the BWR-GALE Code uses a partition factor (PF) of 0.0001 for Xe and I and a PF of 0.00025 for Kr to calculate Xe, I, and Kr losses during separation by distillation. The Xe, I, and Kr separated by distillation are considered to be released following 90-day holdup. The calculated releases are the sum total of the noble gases and iodine released from the overheads during distillation without holdup and the noble gases and iodine released following 90-day holdup.

#### 1.5.1.8 Decontamination Factors for Condensate Demineralizers

| <u>Demineralizer</u> | <u>Halogens</u> | <u>Cs, R<sub>2</sub></u> | <u>Other Nuclides</u> |
|----------------------|-----------------|--------------------------|-----------------------|
| Deep bed             | 10              | 2                        | 10                    |
| Powdex               | 10              | 2                        | 10                    |

Note: For a system using filter/demineralizers (Powdex), a zero is entered for regeneration frequency on Card 6, as explained later in Section 1.5.2.6.

#### 1.5.1.9 Detergent Wastes

The radionuclides listed in Table 2-32 of Chapter 2 are assumed to be released unless treatment is provided or laundry is not processed on site.

#### 1.5.1.10 Tritium Releases

Total tritium release equals 0.025 Ci/yr per Mwt. The quantity of tritium released through the liquid pathway is the calculated annual volumetric liquid release times 0.01  $\mu\text{Ci}/\text{ml}$  of tritium in liquid waste. The difference between the total release and liquid release is the amount considered to be released through the plant ventilation exhaust systems.

#### 1.5.1.11 Regeneration of Condensate Demineralizers

Flow rates and concentrations of radioactive materials routed to the liquid radwaste system from the chemical regeneration of the condensate demineralizers are based on the following parameters:

1. Liquid flow to the demineralizer is based on the radioactivity of the main steam.
2. All radionuclides removed from the condensate by the demineralizers are removed from the demineralizer resins during chemical regeneration. The regenerant waste radioactivity is adjusted for radionuclide decay during operation of the demineralizers.
3. The radioactivity in the regenerant wastes is adjusted for radionuclide decay on the resins during demineralizer operation.

#### 1.5.1.12 Adjustment to Liquid Radwaste Source Terms for Anticipated Operational Occurrences

1. The calculated source term is increased by 0.15 Ci/yr per reactor using the same isotopic distribution as for the calculated source term to account for anticipated occurrences such as operator errors resulting in unplanned releases.

2. Evaporators are assumed to be unavailable for two consecutive days per week for maintenance. If a two-day holdup capacity or an alternative evaporator is available, no adjustment is needed. If less than a two-day capacity is available, the waste excess is assumed to be handled as follows:

- a. High-Purity or Low-Purity Waste--Processed through an alternative system (if available) using a discharge fraction consistent with the lower purity system.
- b. Chemical Waste--Discharged to the environment to the extent holdup capacity or an alternative evaporator is not available.

#### 1.5.2 PARAMETERS REQUIRED FOR THE BWR-GALE CODE

The parameters described in the following sections must be entered on input data cards. Complete the cards designated below by "(SAR/ER)" from information given in the Safety Analysis and Environmental Reports. Complete the remaining cards (i.e., those not designated below as "(SAR/ER)" cards) using the principal source term parameters specified below and discussed in Chapter 2.

##### 1.5.2.1 Card 1: Name of Reactor (SAR/ER)

Enter in spaces 33-60 the name of the reactor.

##### 1.5.2.2 Card 2: Thermal Power Level (SAR/ER)

Enter in spaces 73-80 the maximum thermal power level (in MWt) evaluated for safety considerations in the Safety Analysis Report.

Note: Adjust all power-dependent parameters to this power level.

##### 1.5.2.3 Card 3: Total Steam Flow Rate (SAR/ER)

Enter in spaces 73-80 the total steam flow rate from the reactor (in  $10^6$  lb/hr).

##### 1.5.2.4 Card 4: Mass of Coolant in Reactor Vessel (SAR/ER)

Enter in spaces 73-80 the mass of water in the reactor vessel (in  $10^6$  lb).

##### 1.5.2.5 Card 5: Cleanup Demineralizer Flow (SAR/ER)

Enter in spaces 73-80 the primary coolant flow rate (in  $10^6$  lb/hr) through the reactor coolant cleanup system demineralizers.

##### 1.5.2.6 Card 6: Condensate Demineralizer Regeneration Time

For deep-bed condensate demineralizers, use a 3.5-day regeneration frequency. If ultrasonic resin cleaning is used, assume a 7-day regeneration frequency. Multiply the frequency by the number of demineralizers and enter the calculated number of days in spaces 73-80. For filter/demineralizers (Powdex), enter zeros in spaces 73-80.

##### 1.5.2.7 Card 7: Fraction of Feedwater Through Condensate Demineralizer (SAR/ER)

Enter in spaces 73-80 the fraction of feedwater processed through the condensate demineralizers.

##### 1.5.2.8 Card 8: Dilution Flow (SAR/ER)

Enter in spaces 73-80 the annual average flow rate of water ( $10^3$  gal/min) used to dilute liquid waste discharged to the environment.

##### 1.5.2.9 Cards 9-20: Liquid Radwaste Treatment System Input Parameters

Four liquid radwaste inlet streams are considered in the BWR-GALE Code:

1. High-Purity Waste, Cards 9-11
2. Low-Purity Waste, Cards 12-14
3. Chemical Waste, Cards 15-17
4. Regenerant Solutions Waste, Cards 18-20

Three input data cards are used to define the major parameters for each of the four waste streams. Essentially the same information is needed on the three input data cards used for each of the four streams. The instructions given in this section are applicable to all four waste streams, with the following exception: the inlet waste activity is not entered on Card 18 for the regenerant solutions wastes for systems using regenerable condensate demineralizers since that activity is calculated by the Code.

The entries required on the first card (9, 12, and 15) for the High-Purity, Low-Purity, and Chemical Waste Systems, respectively, are outlined below and described in more detail in Section 1.5.2.9.1.

1. Enter in spaces 18-41 the name of the waste inlet stream (e.g., high-purity wastes).
2. Enter in spaces 42-49 the flow rate (in gal/day) of the inlet stream.
3. Enter in spaces 57-61 the activity of the inlet stream expressed as a fraction of the primary coolant activity (PCA).

On the first card for the Regenerant Solutions Waste System (i.e., Card 18), enter in spaces 73-80 the flow rate of the regenerant solutions waste inlet stream.

The second card (10, 13, 16, and 19) for each waste stream contains the overall system decontamination factors for three categories of radionuclides, as follows:

1. Enter in spaces 21-28 the DF for iodine.
2. Enter in spaces 34-41 the DF for cesium and rubidium.
3. Enter in spaces 47-54 the DF for other nuclides.

The following entries are required on the third card (11, 14, 17, and 20) for each waste stream:

1. Enter in spaces 29-33 the waste collection time (in days) prior to processing.
2. Enter in spaces 48-53 the waste processing and discharge time (in days).
3. Enter in spaces 72-77 the average fraction of wastes to be discharged after processing.

The following sections explain in more detail the use of the parameters in this document and the information given in the SAR/ER to make the data entries in Cards 9-20 listed above.

#### 1.5.2.9.1 Liquid Waste Flow Rates and Activities (Cards 9, 12, 15, and 18)

Calculate flow rates and activities to complete the first card for each liquid radwaste inlet stream by using the waste volumes and activities given in Table 1-2. To the input flow rates given in the table, add expected flows and activities more specific to the plant design as given in the SAR/ER. The inlet streams should be combined to form the four principal waste streams (high-purity, low-purity, chemical wastes, and regenerant wastes) considered in this document. Calculate the primary coolant activity (PCA) of each of the four principal inlet streams by determining the weighted average activity of the composite stream entering the waste collection tanks. For example, if inlet streams A, B, and C enter the low-purity waste collector tank at average rates and PCA as listed below:

|          |                          |
|----------|--------------------------|
| Stream A | 1,000 gal/day at 0.01PCA |
| Stream B | 2,000 gal/day at 0.1PCA  |
| Stream C | 500 gal/day at 1.0PCA    |

the composite A, B, C activity would be calculated as follows:

$$\frac{(1000 \text{ gal/day})(0.01\text{PCA}) + (2000 \text{ gal/day})(0.1\text{PCA}) + (500 \text{ gal/day})(1.0\text{PCA})}{(1000 \text{ gal/day} + 2000 \text{ gal/day} + 500 \text{ gal/day})} = 0.2\text{PCA}$$

The entries on Card 12 for this example would then be: spaces 18-41, "Low-Purity Waste"; spaces 42-49, "3500"; spaces 57-61, "0.2."

TABLE 1-2  
BWR LIQUID WASTES

| SOURCE  | EXPECTED DAILY AVERAGE INPUT<br>FLOW RATE (in gal/day) |  | FRACTION OF THE<br>PRIMARY COOLANT<br>ACTIVITY<br>(PCA) |
|---|--|--|---|
|   | PLANT WITH<br>ULTRASONIC RESIN<br>CLEANER              | PLANT WITHOUT<br>ULTRASONIC RESIN<br>CLEANER |   |
| <u>Equipment Drains</u>                           |  |  |   |
| Drywell   | 3,400  | 3,400  | 1.00  |
| Containment, auxiliary<br>building, and fuel pool | 3,720  | 3,720  | 0.01  |
| Radwaste building                                 | 1,060  | 1,060  | 0.01  |
| Turbine building                                  | 2,960  | 2,960  | 0.01  |
| Ultrasonic resin cleaner                          | 15,000   | -  | 0.05  |
| Resin rinse                                       | 2,500  | 5,000  | 0.002   |
| Subtotal  | 28,640   | 16,140                                       | -   |
| <u>Floor Drains</u>                               |  |  |   |
| Drywell   | 700  | 700  | 1.00  |
| Containment, auxiliary<br>building, and fuel pool | 2,000  | 2,000  | 0.01  |
| Radwaste building                                 | 1,000  | 1,000  | 0.01  |
| Turbine building                                  | 2,000  | 2,000  | 0.01  |
| Subtotal  | 5,700  | 5,700  | -   |
| Cleanup phase separator<br>decant                 | 640  | 640  | 0.002   |
| Laundry drains                                    | 450  | 450  | *   |
| Lab drains  | 500  | 500  | 0.02  |
| Regenerants**                                     | 1,700  | 3,400  | ***   |
| Condensate demineralizer<br>backwash†             | -  | 8,100  | $2 \times 10^{-6}$                                      |
| Chemical lab waste                                | 100  | 100  | 0.02  |
| Total   | 37,730   | 26,930                                       |   |

\* Listed in BWR-GALE Code; see Table 2-32.

\*\* Deep-bed condensate demineralizers.

\*\*\* Calculated by BWR-GALE Code.

† Filter/demineralizer (Powdex) condensate demineralizers.

The input flows and activities are entered in units of gal/day and fraction of PCA, respectively.

1.5.2.9.2 Decontamination Factors for Equipment Used in the Liquid Radwaste Treatment System (Cards 10, 13, 16, and 19)

The decontamination factors (DFs) should be entered in the second card for each liquid radwaste inlet stream. The DFs represent the expected equipment performance averaged over the life of the plant, including downtime. The following factors are to be considered in calculating overall decontamination factors for the various systems.


1. DFs are categorized by one of the following types of radionuclides:
  - a. Halogens
  - b. Cs, Rb
  - c. Other nuclides

Note: A DF of 1 is assumed by the BWR-GALE Code for tritium. Noble gases and water activation products are not considered in the liquid code.

2. The system DF for each inlet stream is the product of the individual equipment DFs in each of the subsystems.
3. Equipment that is used optionally (as required) and not included in the normal flow scheme should not be considered in calculating the overall system DF.

Table 1-3 shows the decontamination factors to be used for BWR systems.

The following example illustrates the calculation of the decontamination factor for a low-purity waste treatment system: Assume that low-purity wastes are collected; processed through a filter, an evaporator, and a mixed-bed polishing demineralizer; and collected for sampling. If required to meet discharge criteria, the contents of the waste sample (test) tank are processed through a mixed-bed demineralizer for additional radionuclide removal. This example may be summarized graphically as:



Extracting from Table 1-3 gives the following values for the example:

|                | Filter | Evaporator      | Demineralizer 1 | Demineralizer 2 | Product         |
|----------------|--------|-----------------|-----------------|-----------------|-----------------|
| Halogens       | 1      | 10 <sup>3</sup> | 10              | 1               | 10 <sup>4</sup> |
| Cs, Rb         | 1      | 10 <sup>4</sup> | 10              | 1               | 10 <sup>5</sup> |
| Other Nuclides | 1      | 10 <sup>4</sup> | 10              | 1               | 10 <sup>5</sup> |

These values were obtained as follows:

- ° A DF of 1.0 was applied to all nuclides for the filter.
- ° A DF of 10<sup>3</sup> for halogens and 10<sup>4</sup> for Cs, Rb, and other nuclides was applied for the radwaste evaporator.
- ° A DF of 10 was applied for halogens, Cs, Rb, and other nuclides and for the evaporator condensate polishing demineralizer.
- ° A DF of 1 was applied to the second demineralizer since this demineralizer's use is optional and it is not used for normal operations.
- ° The product of the DFs was obtained by combining the first four columns for each radionuclide.



TABLE 1-3  
 DECONTAMINATION FACTORS FOR BWR LIQUID WASTE TREATMENT SYSTEMS

| TREATMENT SYSTEM                     | DECONTAMINATION FACTOR            |        |                      |
|--------------------------------------|-----------------------------------|--------|----------------------|
|                                      | Anion                             | Cs, Rb | Other Nuclides       |
| <u>Demineralizers</u>                |                                   |        |                      |
| Mixed-bed reactor<br>coolant cleanup | 10                                | 2      | 10                   |
| Condensate (deep bed)                | 10                                | 2      | 10                   |
| High-purity waste                    | 10 <sup>2</sup> (10)*             | 10(10) | 10 <sup>2</sup> (10) |
| Low-Purity Waste                     |                                   |        |                      |
| Mixed bed                            | 10 <sup>2</sup> (10)              | 2(10)  | 10 <sup>2</sup> (10) |
| Cation bed                           | 1(1)                              | 10(10) | 10 <sup>2</sup> (10) |
| Anion bed                            | 10 <sup>2</sup> (10)              | 1(1)   | 1(1)                 |
| Powdex (any system)                  | 10(10)                            | 2(10)  | 10(10)               |
| <u>Evaporators</u>                   | <u>All Nuclides Except Iodine</u> |        | <u>Iodine</u>        |
| Miscellaneous                        | 10 <sup>4</sup>                   |        | 10 <sup>3</sup>      |
| Detergent wastes                     | 10 <sup>2</sup>                   |        | 10 <sup>2</sup>      |
| <u>Reverse Osmosis</u>               | <u>All Nuclides</u>               |        |                      |
| Laundry wastes                       | 30                                |        |                      |
| Other liquid wastes                  | 10                                |        |                      |
| <u>Filters</u>                       | DF of 1.0 for all nuclides        |        |                      |

\* For an evaporator polishing demineralizer or for the second demineralizer in series, the DF is given in parentheses.



Thus in Card 10 the following would be entered: in spaces 21-28, "10,000"; in spaces 34-41, "100,000"; and in spaces 47-54, "100,000."

#### 1.5.2.9.3 Collection Time for Liquid Wastes (Cards 11, 14, 17, 20 -- Spaces 29-33)


Collection time prior to processing is based on the input flow calculated above. Where redundant tanks are provided, assume the collection tank to be filled to 80% capacity. If only one tank is provided, assume the tank to be filled to 40% capacity. For example, if flow from a 1,000-gal/day floor drain is collected in two 20,000-gallon tanks prior to processing, collection time would be calculated as follows:

$$\text{Collection time } (T_c) = \frac{(20,000 \text{ gal})(0.8)}{1,000 \text{ gal/day}} = 16 \text{ days}$$

Then, for this example, "16" should be entered in spaces 29-33 on Card 14.

#### 1.5.2.9.4 Processing and Discharge Time (Cards 11, 14, 17, 20 -- Spaces 48-53)

Decay during processing and discharge of liquid wastes is shown graphically as follows:



where

- A is the capacity of the initial tank in the flow scheme, in gal;
- B is the limiting process based on equipment flow capacity, dimensionless;
- C is the capacity of the final tank in the flow scheme prior to discharge, in gal;
- $R_b$  is the equipment flow capacity of process B, in gal/day;
- $R_c$  is the flow capacity of the Tank C discharge pump, in gal/day; and
- $R_o$  is the rate of flow of additional wastes inputs to Tank C, in gal/day.

$T_p$ , the process time credited for decay, is calculated as follows, in days:

$$T_p = \frac{0.8A}{R_b}$$

$T_d$ , the discharge time -- 50% credited for decay, is calculated as follows, in days:

$$T_d = \frac{0.8C}{R_c}$$

After performing the above two calculations, calculate whether credit may be taken for decay during processing by determining whether

$$0.8C > T_p R_b + R_o$$


If so, then

$$\text{Decay} = T_p + 0.5T_d$$

where "Decay" is the new processing and discharge time to be entered in spaces 48-53 of the third card for each input stream (Cards 11, 14, 17, and 20).

If, however,  $0.8 \leq T_p(R_b + R_o)$ ,  $T_p$  is used for the holdup time during processing, since Tank C may be discharged before Tank A has been completely processed. In this case, the  $T_p$  value should be entered in spaces 48-53 of the third card.

For example, for the following input waste stream:



Decay time during processing and discharge would be calculated as follows:

$$\text{Process Time } (T_p) = \frac{(0.8)(20,000 \text{ gal})}{(15 \text{ gal/min})(1440 \text{ min/day})} = 0.7 \text{ day}$$

$$\text{Discharge Time } (T_d) = \frac{(0.8)(40,000 \text{ gal})}{(10 \text{ gal/min})(1440 \text{ min/day})} = 3 \text{ days}$$

Then, checking for decay credit,  $0.8C/(R_b + R_0) = 1.45$  days, which is greater than  $T_p$ ; therefore, credit is taken for  $(T_p + 0.5T_d)$  or 2.2 days for processing and discharge. The input on spaces 48-53 to the Code is 2.2 days for processing and discharge time.

#### 1.5.2.9.5 Fraction of Wastes Discharged (Cards 11, 14, 17, and 20 -- Spaces 72-77)

The percent of the wastes discharged after processing may vary between 1% and 100% based on the capability of the system to process liquid waste during equipment downtime, waste volume surges, tritium control requirements, and tank surge capacity. A minimum value of 1% discharge for high-purity wastes and 10% discharge for other wastes is used when the radwaste system is designed for maximum waste recycle, the system capacity is sufficient to process wastes for reuse during equipment downtime and anticipated operational occurrences, and a discharge route is provided.

The BHR-GALE Code calculates the release of radioactive materials in liquid waste from the four inlet streams after processing. Releases included in each stream are:

1. High-Purity Waste - Combined releases from equipment drains and sumps.
2. Low-Purity Waste - Combined releases from floor drains and sumps.
3. Chemical Waste - Combined releases from laboratory and decontamination wastes and from demineralizer regenerant solutions according to the design of the condensate demineralizer system. If a filter/demineralizer (Powdex) system is used, the laboratory and decontamination wastes are combined with the low-purity waste or solidified in the solid waste system.
4. Detergent Waste System - Combined releases from laundry operations, equipment decontamination solutions, and personnel decontamination showers.

#### 1.5.2.10 Card 21: Gland Seal Steam Flow

Enter in spaces 73-80 of Card 21 the steam flow (in  $10^3$  lb/hr) to the turbine gland seal, as follows:

1. If main steam is used for the sealing steam, enter a flow rate 0.001 times the main steam flow entered previously on Card 3.
2. If clean (nonradioactive) steam from an auxiliary boiler is used for sealing steam, enter a zero in spaces 73-80.

1.5.2.11 Card 22: Mass of Steam in Reactor Vessel (SAR/ER)

Enter in spaces 73-80 the mass of steam in the reactor vessel (in  $10^6$  lb).

1.5.2.12 Card 23: Gland Seal Holdup Time (SAR/ER)

Enter in spaces 73-80 the design holdup (in hr) for gases vented from the gland seal condenser.

1.5.2.13 Card 24: Holdup Time for Condenser Air Ejector Offgas (SAR/ER)

Enter in spaces 73-80 the design holdup time (in hr) for offgases from the main condenser air ejector to be processed through the offgas treatment system, e.g., a 10-minute holdup time prior to cryogenic distillation.

1.5.2.14 Card 25: Containment Building Releases

1. If ventilation exhaust air is treated through charcoal adsorbers, enter YES in spaces 43-45. If no treatment is provided, leave spaces 43-45 blank.
2. If ventilation exhaust air is treated through HEPA filters, enter YES in spaces 52-54. If no treatment is provided, leave spaces 52-54 blank.

1.5.2.15 Card 26: Turbine Building Releases

1. If ventilation exhaust air is treated through charcoal adsorbers, enter YES in spaces 43-45. If no treatment is provided, leave spaces 43-45 blank.
2. If ventilation exhaust air is treated through HEPA filters, enter YES in spaces 52-54. If no treatment is provided, leave these spaces blank.
3. If "clean steam" or other acceptable special design features are provided on valves 2-1/2 inches and larger to reduce steam leakage, enter YES in spaces 68-70. If the above features are not provided, leave spaces 68-70 blank.

1.5.2.16 Card 27: Fraction of Iodine Released from Turbine Gland Seal Condenser Vent

1. Enter 1.0 in spaces 73-80 if the noncondensables are released from the turbine gland seal condenser without treatment or if clean steam is used.
2. Enter 0.1 in spaces 73-80 if, prior to release, the noncondensables are processed through charcoal adsorbers having a 90% efficiency.

1.5.2.17 Card 28: Fraction of Iodine Released from the Condenser Air Ejector Offgas Treatment System

1. Enter 1.0 in spaces 73-80 if the offgas is released without treatment.
2. Enter 0.1 in spaces 73-80 if, prior to release, the offgas is processed through a charcoal adsorber having a 90% efficiency.
3. Enter a zero in spaces 73-80 if the offgas is processed through a charcoal delay system.
4. Enter 1.0 in spaces 73-80 if the offgas is processed through a cryogenic distillation system (removal of iodine by the cryogenic distillation system is built into the Code - see Card 30).

1.5.2.18 Card 29: Auxiliary Building Releases

1. If ventilation exhaust air is treated through charcoal adsorbers, enter YES in spaces 43-45. If no treatment is provided, leave blank.

- If ventilation effluent is treated through HEPA filters, enter YES in spaces 52-54. If no treatment is provided, leave blank.

1.5.2.19 Card 30: Radwaste Building Releases

- If ventilation exhaust air is treated through charcoal adsorbers, enter YES in spaces 43-45. If no treatment is provided, leave blank.
- If ventilation exhaust air is treated through HEPA filters, enter YES in spaces 52-54. If no treatment is provided, leave blank.

1.5.2.20 Card 31: Condenser Air Ejector Offgas Treatment System (SAR/ER)

- Enter 1 in space 80 if charcoal delay system is used to treat the offgas from the condenser air ejector.
- Enter 2 in space 80 if the offgas from the condenser air ejector is processed by the cryogenic distillation.
- Enter a zero in space 80 if the offgas is not treated either through a charcoal delay system or by cryogenic distillation.

Note: Cards 31, 32, 33, and 34 are left blank if a charcoal delay system is not used to treat the offgases from the condenser air ejector. The blank cards are included in the card deck.

1.5.2.21 Card 32: Dynamic Adsorption Coefficient for Krypton

Enter in spaces 73-80 the dynamic adsorption coefficient for Kr based on the system design and the dynamic adsorption coefficients noted below.

|    | DYNAMIC ADSORPTION COEFFICIENT (cm <sup>3</sup> /g) |                                 |                                  |
|----|---|---------------------------------|----------------------------------|
|    | OPERATING 77°F<br>DEW POINT 45°F                    | OPERATING 77°F<br>DEW POINT 0°F | OPERATING 0°F<br>DEW POINT -20°F |
| Kr | 18.5  | 25                              | 105                              |

1.5.2.22 Card 33: Dynamic Adsorption Coefficient for Xenon

Enter in spaces 73-80 the dynamic adsorption coefficient for Xe based on the system design and dynamic adsorption coefficients noted below.

|    | DYNAMIC ADSORPTION COEFFICIENT (cm <sup>3</sup> /g) |                                 |                                  |
|----|---|---------------------------------|----------------------------------|
|    | OPERATING 77°F<br>DEW POINT 45°F                    | OPERATING 77°F<br>DEW POINT 0°F | OPERATING 0°F<br>DEW POINT -20°F |
| Xe | 330   | 440                             | 2410                             |

1.5.2.23 Card 34: Number of Main Condenser Shells (SAR/ER)

Enter in spaces 73-80 the number of shells in the main condenser.

1.5.2.24 Card 35: Mass of Charcoal in Charcoal Delay System (SAR/ER)

Enter in spaces 73-80 the mass of charcoal (in 10<sup>3</sup> lb) used in the charcoal delay system.

1.5.2.25 Card 36: Detergent Waste

- If the plant does not have an onsite laundry, enter a zero in spaces 73-80.
- If the plant has an onsite laundry and detergent wastes are released without treatment, enter 1.0 in spaces 73-80.
- If detergent wastes are treated prior to discharge, enter the fraction of radionuclides remaining after treatment (1/DF) in spaces 73-80. The parameters in Chapter 2 are used in determining the DF for the treatment applied to detergent waste.

CHAPTER 2. PRINCIPAL PARAMETERS USED  
IN BWR SOURCE TERM CALCULATIONS AND THEIR BASES

2.1 INTRODUCTION

The principal parameters used in source term calculations have been compiled to standardize the calculation of radioactive source terms. The source term is defined as the calculated average quantity of radioactive material released annually to the environment from a nuclear power reactor during normal operation, including anticipated operational occurrences. The parameters used in the calculations are the average values expected over the life of the plant. Normal operation includes anticipated operational occurrences that deviate from steady-state operation.

The following sections describe parameters used in the evaluation of radwaste treatment systems. The parameters have been derived from reactor operating experience where data were available. Where operating data were inconclusive or not available, information was drawn from laboratory and field tests and from engineering judgment. The bases for the source term parameters explain the reasons for choosing the numerical values listed. A list of references used in developing the parameters is also included.

The parameters in the BWR-GALE Code are updated as additional operating data become available. The source term parameters used are believed to provide a realistic assessment of reactor and radwaste system operation.

2.2 PRINCIPAL PARAMETERS AND THEIR BASES

2.2.1 THERMAL POWER LEVEL

2.2.1.1 Parameter

The maximum thermal power level (MWt) evaluated for safety considerations in the Safety Analysis Report.

2.2.1.2 Bases

The power level used in the source term BWR-GALE Code is the maximum power level evaluated for safety considerations in the Safety Analysis Report. Using this value, the evaluation of the radwaste management systems need not be repeated when the applicant applies for a stretch power license at a later date. Past experience indicates that most utilities request approval to operate at maximum power soon after reaching commercial operation.

2.2.2 PLANT CAPACITY FACTOR

2.2.2.1 Parameter

Plant capacity factor of 80%, i.e., 292 effective full power days.

2.2.2.2 Bases

The source term calculations are based on a plant capacity factor of 80% averaged over the 30-year operating life of the plant, i.e., the plant operates at 100% power 80% of the time. The plant capacity factors experienced at BWRs are listed in Table 2-1 for the period 1961 through 1974.

The average plant capacity factors listed indicate that the 80% factor assumed is higher than the average factors experienced. However, it is expected that the maintenance and refueling problems that have contributed to the low capacity factors will be overcome.

2.2.3 RADIONUCLIDE CONCENTRATIONS IN THE REACTOR COOLANT

2.2.3.1 Parameter

Table 2-2 lists the expected radionuclide concentrations in the reactor coolant and steam for BWRs with design parameters within the ranges listed in Table 2-3. Should any design parameter be outside the ranges in Table 2-3, adjust the concentrations in Table 2-2, using Tables 2-4 and 2-5. Figure 2-1 shows the graphical relationship of the design parameters.

TABLE 2-1  
PLANT CAPACITY FACTORS AT OPERATING BWRs\*  
 (in %)

| FACILITY          | INITIAL<br>CRITICALITY | 1968 | 1969 | 1970 | 1971 | 1972 | 1973 | 1974 |
|-------------------|------------------------|------|------|------|------|------|------|------|
| Dresden 1         | 10/15/59               | 52   | 48   | 78   | 35   | 61   | 40   | 21   |
| Big Rock Point    | 9/27/62                | 68   | 64   | 58   | 59   | 57   | 67   | 54   |
| Humboldt Bay      | 2/16/63                | 82   | 68   | 76   | 61   | 59   | 70   | 61   |
| Oyster Creek      | 5/3/69                 |      |      | 74   | 78   | 77   | 64   | 66   |
| Nine Mile Point 1 | 9/5/69                 |      |      |      | 63   | 62   | 68   | 63   |
| Dresden 2         | 1/7/70                 |      |      |      | 39   | 47   | 74   | 51   |
| Millstone 1       | 10/26/70               |      |      |      | 63   | 55   | 34   | 63   |
| Monticello        | 12/10/70               |      |      |      |      | 74   | 68   | 57   |
| Dresden 3         | 1/31/71                |      |      |      |      | 67   | 54   | 47   |
| Quad Cities 1     | 10/18/71               |      |      |      |      |      | 70   | 51   |
| Vermont Yankee    | 3/24/72                |      |      |      |      |      | 44   | 59   |
| Quad Cities 2     | 4/26/72                |      |      |      |      |      | 74   | 68   |
| Pilgrim 1         | 6/16/72                |      |      |      |      |      | 72   | 34   |
| Average           |                        | 67   | 60   | 72   | 57   | 62   | 61   | 53   |

2-2

\*From "U.S. Nuclear Power Reactors," Atomic Energy Commission, WASH-1203-68 to 73, Table 1, "Selected Operating Statistics." Plant capacity factors listed are for the calendar year(s) following a period of at least six months since initial criticality. Operating BWRs not included in the table are Browns Ferry 1 and Peach Bottom 2, which achieved criticality during CY-1973. The LaCrosse Nuclear Power Station was not included since it is not considered to be representative of current power reactors.

TABLE 2-2  
 RADIONUCLIDE CONCENTRATIONS  
 IN BOILING WATER REACTOR COOLANT AND MAIN STEAM\*  
 (in  $\mu\text{Ci/g}$ )

| <u>ISOTOPE</u>             | <u>REACTOR<br/>WATER</u> | <u>REACTOR<br/>STEAM</u> |
|----------------------------|--------------------------|--------------------------|
| <u>Noble Gases</u>         |                          |                          |
| Kr-83m                     |                          | 1.1(-3)**                |
| Kr-85m                     |                          | 1.9(-3)                  |
| Kr-85                      |                          | 6.0(-6)                  |
| Kr-87                      |                          | 6.6(-3)                  |
| Kr-88                      |                          | 6.6(-3)                  |
| Kr-89                      |                          | 4.1(-2)                  |
| Kr-90                      |                          | 9.0(-2)                  |
| Kr-91                      |                          | 1.1(-1)                  |
| Kr-92                      |                          | 1.1(-1)                  |
| Kr-93                      |                          | 2.9(-2)                  |
| Kr-94                      |                          | 7.2(-3)                  |
| Kr-95                      |                          | 6.6(-4)                  |
| Kr-97                      |                          | 4.4(-6)                  |
| Xe-131m                    |                          | 4.7(-6)                  |
| Xe-133m                    |                          | 9.0(-5)                  |
| Xe-133                     |                          | 2.6(-3)                  |
| Xe-135m                    |                          | 8.4(-3)                  |
| Xe-135                     |                          | 7.2(-3)                  |
| Xe-137                     |                          | 4.7(-2)                  |
| Xe-138                     |                          | 2.8(-2)                  |
| Xe-139                     |                          | 9.0(-2)                  |
| Xe-140                     |                          | 9.6(-2)                  |
| Xe-141                     |                          | 7.8(-2)                  |
| Xe-142                     |                          | 2.3(-2)                  |
| Xe-143                     |                          | 3.8(-3)                  |
| Xe-144                     |                          | 1.8(-4)                  |
| <u>Halogens</u>            |                          |                          |
| Br-83                      | 3(-3)                    | 6(-5)                    |
| Br-84                      | 5(-3)                    | 1(-4)                    |
| Br-85                      | 3(-3)                    | 6(-5)                    |
| I-131                      | 5(-3)                    | 1(-4)                    |
| I-132                      | 3(-2)                    | 6(-4)                    |
| I-133                      | 2(-2)                    | 4(-4)                    |
| I-134                      | 5(-2)                    | 1(-3)                    |
| I-135                      | 2(-2)                    | 4(-4)                    |
| <u>Cesium and Rubidium</u> |                          |                          |
| Rb-89                      | 5(-3)                    | 5(-6)                    |
| Cs-134                     | 3(-5)                    | 3(-8)                    |
| Cs-136                     | 2(-5)                    | 2(-8)                    |
| Cs-137                     | 7(-5)                    | 7(-8)                    |
| Cs-138                     | 1(-2)                    | 1(-5)                    |

\* The reactor water concentration is specified at the nozzle where reactor water leaves the reactor vessel. Similarly, the reactor steam concentration is specified at time 0.

\*\*  $1.1(-3) = 1.1 \times 10^{-3}$ .



TABLE 2-2 (Continued)

| <u>ISOTOPE</u>                   | <u>REACTOR<br/>WATER</u> | <u>REACTOR<br/>STEAM</u> |
|----------------------------------|--------------------------|--------------------------|
| <u>Water Activation Products</u> |                          |                          |
| N-13                             | 5(-2)                    | 7(-3)                    |
| N-16                             | 6(+1)                    | 5(+1)                    |
| N-17                             | 9(-3)                    | 2(-2)                    |
| O-19                             | 7(-1)                    | 2(-1)                    |
| F-18                             | 4(-3)                    | 4(-3)                    |
| <u>Tritium*</u>                  |                          |                          |
| H-3                              | 1(-2)                    | 1(-2)                    |
| <u>Other Nuclides</u>            |                          |                          |
| Na-24                            | 9(-3)                    | 9(-6)                    |
| P-32                             | 2(-4)                    | 2(-7)                    |
| Cr-51                            | 5(-3)                    | 5(-6)                    |
| Mn-54                            | 6(-5)                    | 6(-8)                    |
| Mn-56                            | 5(-2)                    | 5(-5)                    |
| Fe-55                            | 1(-3)                    | 1(-6)                    |
| Fe-59                            | 3(-5)                    | 3(-8)                    |
| Co-58                            | 2(-4)                    | 2(-7)                    |
| Co-60                            | 4(-4)                    | 4(-7)                    |
| Ni-63                            | 1(-6)                    | 1(-9)                    |
| Ni-65                            | 3(-4)                    | 3(-7)                    |
| Cu-64                            | 3(-2)                    | 3(-5)                    |
| Zn-65                            | 2(-4)                    | 2(-7)                    |
| Zn-69                            | 2(-3)                    | 2(-6)                    |
| Sr-89                            | 1(-4)                    | 1(-7)                    |
| Sr-90                            | 6(-6)                    | 6(-9)                    |
| Sr-91                            | 4(-3)                    | 4(-6)                    |
| Sr-92                            | 1(-2)                    | 1(-5)                    |
| Y-91                             | 4(-5)                    | 4(-8)                    |
| Y-92                             | 6(-3)                    | 6(-6)                    |
| Y-93                             | 4(-3)                    | 4(-6)                    |
| Zr-95                            | 7(-6)                    | 7(-9)                    |
| Zr-97                            | 5(-6)                    | 5(-9)                    |
| Nb-95                            | 7(-6)                    | 7(-9)                    |
| Nb-98                            | 4(-3)                    | 4(-6)                    |
| Mo-99                            | 2(-3)                    | 2(-6)                    |
| Tc-99m                           | 2(-2)                    | 2(-5)                    |
| Tc-101                           | 9(-2)                    | 9(-5)                    |
| Tc-104                           | 8(-2)                    | 8(-5)                    |
| Ru-103                           | 2(-5)                    | 2(-8)                    |
| Ru-105                           | 2(-3)                    | 2(-6)                    |
| Ru-106                           | 3(-6)                    | 3(-9)                    |
| Ag-110m                          | 1(-6)                    | 1(-9)                    |
| Te-129m                          | 4(-5)                    | 4(-8)                    |
| Te-131m                          | 1(-4)                    | 1(-7)                    |

\* Measured values increased to account for liquid recycle.



TABLE 2-2 (Continued)

| <u>ISOTOPES</u> | <u>REACTOR WATER</u> | <u>REACTOR STEAM</u> |
|-----------------|----------------------|----------------------|
| Te-132          | 1(-5)                | 1(-8)                |
| Ba-139          | 1(-2)                | 1(-5)                |
| Ba-140          | 4(-4)                | 4(-7)                |
| Ba-141          | 1(-2)                | 1(-5)                |
| Ba-142          | 6(-3)                | 6(-6)                |
| La-142          | 5(-3)                | 5(-6)                |
| Ce-141          | 3(-5)                | 3(-8)                |
| Ce-143          | 3(-5)                | 3(-8)                |
| Ce-144          | 3(-6)                | 3(-9)                |
| Pr-143          | 4(-5)                | 4(-8)                |
| Nd-147          | 3(-6)                | 3(-9)                |
| W-187           | 3(-4)                | 3(-7)                |
| Np-239          | 7(-3)                | 7(-6)                |

TABLE 2-3  
PARAMETERS USED TO DESCRIBE THE REFERENCE BOILING WATER REACTOR

| <u>PARAMETER</u>   | <u>SYMBOL</u> | <u>UNITS</u> | <u>NOMINAL VALUE</u> | <u>RANGE</u>   |                |
|--|---------------|--------------|----------------------|----------------|----------------|
|  |               |              |                      | <u>MAXIMUM</u> | <u>MINIMUM</u> |
| Thermal power  | P             | MWt          | 3400                 | 3800           | 3000           |
| Weight of water in the reactor vessel                          | WP            | lb           | 3.8(5)*              | 4.2(5)         | 3.4(5)         |
| Cleanup demineralizer flow rate                                | FA            | lb/hr        | 1.3(5)               | 1.5(5)         | 1.1(5)         |
| Steam flow rate  | FS            | lb/hr        | 1.5(7)               | 1.7(7)         | 1.3(7)         |
| Ratio of condensate demineralizer flow rate to steam flow rate | NC            | -            | 1.0                  | 1.0            | 0.8            |

\* 3.8(5) =  $3.8 \times 10^5$

TABLE 2-4  
VALUES USED IN DETERMINING ADJUSTMENT FACTORS FOR  
BOILING WATER REACTORS

| SYMBOL | DESCRIPTION   | NOBLE GASES | HALOGENS | Cs, Rb | WATER ACTIVATION PRODUCTS | TRITIUM | OTHER NUCLIDES |
|--------|---|-------------|----------|--------|---------------------------|---------|----------------|
| NA     | Fraction of material removed in the reactor water cleanup system              | 0.0         | 0.9      | 0.5    | 0.0                       | 0.0     | 0.9*           |
| NB     | Fraction of material removed by the condensate demineralizers                 | 0.0         | 0.9      | 0.5    | 0.0                       | 0.0     | 0.9*           |
| NS     | Ratio of concentration in reactor steam to the concentration in reactor water | **          | 0.02     | 0.001  | ***                       | 1.0     | 0.001          |
| R      | Removal rate from the reactor water (hr <sup>-1</sup> ) <sup>+</sup>          | **          | 1.0      | 0.19   | ***                       | ++      | 0.34           |

\* These represent effective removal terms and include other mechanisms such as plateout. Plateout would be applicable to nuclides such as Mo and corrosion products.

\*\* All noble gases released from the core are transported rapidly out of the reactor water to the reactor steam and are stripped from the system in the main condenser. Therefore the concentration in the reactor water is negligible and the steam concentration is approximately equivalent to the ratio of the release rate and the steam flow rate.

\*\*\* Water activation products exhibit varying chemical and physical properties in reactor coolant which are not well defined. However, most are stripped off as gases. They are not effectively removed by the demineralizers of the systems, but their concentrations are controlled by decay.

+ These values of R apply to the reference BWR whose parameters are given in Table 2-3 and have been used in developing Table 2-5. For BWRs not included in Table 2-3, the appropriate value for R may be determined by the following equation:

$$R = \frac{FA \cdot NA + NC \cdot FS \cdot NS \cdot NB}{WP} \text{ for halogens, Cs, Rb, and other nuclides}$$

where the symbols are defined in this table and Table 2-3. The values for R for noble gases and water activation products are not used in the adjustment factors of Table 2-5.

++ The tritium concentrations in the reactor water and the steam are expected to be equal. They are controlled by loss of water from the main coolant system by evaporation or leakage. The concentration is therefore given by the ratio of the appearance rate in the coolant, which is about 100 Ci/yr, and the total loss from the system.


TABLE 2-5  
ADJUSTMENT FACTORS FOR BOILING WATER REACTORS

| NUCLIDES                  | REACTOR WATER   | REACTOR STEAM   |
|---------------------------|---|---|
| Noble gases*              | 1.0   | 1.0   |
| Halogens**                | $\frac{P}{WP} \left( 110 \frac{lb}{Mwt} \right) \frac{1.0 + \lambda}{R + \lambda}$  | $\frac{P}{WP} \left( 110 \frac{lb}{Mwt} \right) \frac{1.0 + \lambda}{R + \lambda}$  |
| Cs, Rb                    | $\frac{P}{WP} \left( 110 \frac{lb}{Mwt} \right) \frac{0.19 + \lambda}{R + \lambda}$ | $\frac{P}{WP} \left( 110 \frac{lb}{Mwt} \right) \frac{0.19 + \lambda}{R + \lambda}$ |
| Water activation products | 1.0   | 1.0   |
| Tritium***                | 1.0   | 1.0   |
| Other nuclides            | $\frac{P}{WP} \left( 110 \frac{lb}{Mwt} \right) \frac{0.34 + \lambda}{R + \lambda}$ | $\frac{P}{WP} \left( 110 \frac{lb}{Mwt} \right) \frac{0.34 + \lambda}{R + \lambda}$ |

\*Assumes that the ratio of power to steam flow is essentially the same for all BWRs.

\*\* $\lambda$  is the isotope's decay constant ( $hr^{-1}$ ).

\*\*\*The tritium concentrations in the reactor water and the steam are expected to be equal. They are controlled by loss of water from the main coolant system by evaporation or leakage. The concentration is therefore given by the ratio of the appearance rate in the coolant, which is about 100 Ci/yr, and the total loss from the system.



\* SYMBOLS ARE DEFINED IN TABLES 2-3 AND 2-4

FIGURE 2-1  
REMOVAL PATHS FOR THE REFERENCE  
BOILING WATER REACTOR

### 2.2.3.2 Bases

The radionuclide concentrations, adjustment factors, and procedures for effecting adjustments are based on the values and methods proposed by the ANS 18.1 Working Group draft standard for boiling water reactor source terms (Ref. 1). The values in Table 2-2 provide a set of typical radionuclide concentrations in the reactor coolant and steam for reactor designs within the parameters specified in Table 2-3. The values in Table 2-2 were those judged by the ANS Working Group to be representative of radionuclide concentrations in a BWR over its lifetime based on the currently available data and models (Refs. 2 and 3). It is recognized that some systems will have design parameters that are outside the ranges specified in Table 2-3. For that reason a means of adjusting the concentrations to the actual design parameters has been provided in Tables 2-4 and 2-5. The adjustment factors in Tables 2-4 and 2-5 are based on the following expression:

$$C = \frac{S}{w(\lambda + R)k}$$

where

- C is the specific activity, in  $\mu\text{Ci/g}$ ;
- k is a conversion factor, 454 g/lb;
- R is the removal rate of the isotope from the system due to demineralization, leakage, etc., in  $\text{hr}^{-1}$ ;
- S is the rate of release to and/or production of the isotope in the system, in  $\mu\text{Ci/hr}$ ;
- w is the fluid weight, in lb; and
- $\lambda$  is the decay constant, in  $\text{hr}^{-1}$ .

The following sample calculations illustrate the method by which the BWR-GALE Code will adjust the radionuclide concentrations in Table 2-2. As indicated in Table 2-5, adjustment factors will be calculated only for halogens, Cs, Rb, and other nuclides.

As an example, the Barton Nuclear Station parameters compare with the range values in Table 2-3 as follows:

| Parameter                              | Barton Station Value | Range Values                          |
|--|----------------------|---------------------------------------|
| Thermal power level (Mwt)              | 3758                 | 3000-3800                             |
| Water weight in vessel (lb)            | $4.9 \times 10^5$    | $3.4 \times 10^5 - 4.2 \times 10^5$   |
| Cleanup demineralizer flow (lb/hr)     | $1.5 \times 10^5$    | $1.1 \times 10^5 - 1.5 \times 10^5$   |
| Steam flow rate (lb/hr)                | $15.4 \times 10^6$   | $13.0 \times 10^6 - 17.0 \times 10^6$ |
| Condensate demineralizer flow fraction | 0.75                 | 0.8 - 1.0                             |

Since in this example two of the parameters (water weight in vessel and condensate demineralizer flow fraction) are outside the range, adjusted values of the three types of radionuclide concentrations are calculated using the actual value of each parameter, as follows:

1. Halogens (I-131 is used as an example) -- Using the equation for halogens in Table 2-5, the adjustment factor A is calculated as follows:

$$A = \frac{P}{WP} (110) \frac{1.0 + \lambda}{R + \lambda} \quad (2-1)$$

where the terms in the equation are as defined in Tables 2-3 and 2-4.

In calculating A, the variable R is calculated first, using the equation given in Table 2-4:

$$R = \frac{FA \cdot NA + NC \cdot FS \cdot NS \cdot NB}{WP} \quad (2-2)$$

where the terms in the equation are as defined in Tables 2-3 and 2-4.

Using the Barton Station parameters given above and the halogen parameters given in Table 2-4 and substituting in Equation (2-1) gives

$$R = \frac{1.5 \times 10^5 \times 0.9 + 0.75 \times 15.4 \times 10^6 \times 0.02 \times 0.9}{4.9 \times 10^5} = 0.7$$

Then, using this value of R in Equation (2-1):

$$A = \frac{3758}{4.9 \times 10^5} (110) \frac{1.0 + 3.6 \times 10^{-3}}{0.7 + 3.6 \times 10^{-3}} = 1.2$$

The adjusted I-131 concentration

$$\begin{aligned} &= (\text{adjustment factor}) \times (\text{standard I-131 concentration}) \\ &= 1.2 \times 5 \times 10^{-3} \text{ } \mu\text{Ci/g} = 6.0 \times 10^{-3} \text{ } \mu\text{Ci/g} \end{aligned}$$

2. Cs, Rb (Cs-137 is used as an example) -- Using the equation for Cs and Rb in Table 2-5, the adjustment factor A is calculated as follows:

$$A = \frac{P}{WP} (110) \frac{0.19 + \lambda}{R + \lambda} \quad (2-3)$$

where the terms in the equation are as defined in Tables 2-3 and 2-4.

In calculating A, the variable R is calculated first, using Equation (2-2). The Cs and Rb parameters given in Table 2-4 and the Barton Station parameters are used in the equation.

$$R = \frac{1.5 \times 10^5 \times 0.5 + 0.75 \times 15.4 \times 10^6 \times 0.001 \times 0.5}{4.9 \times 10^5} = 0.17$$

Then, using this value of R in Equation (2-3) above:

$$A = \left( \frac{3758}{4.9 \times 10^5} \right) (110) \left( \frac{0.19 + 2.6 \times 10^{-6}}{0.17 + 2.6 \times 10^{-6}} \right) = 0.97$$

The adjusted Cs-137 concentration

$$\begin{aligned} &= (\text{adjustment factor}) \times (\text{standard Cs-137 concentration}) \\ &= 0.97 \times 7 \times 10^{-5} \text{ } \mu\text{Ci/g} = 6.8 \times 10^{-5} \text{ } \mu\text{Ci/g} \end{aligned}$$

3. Other Nuclides (Na-24 is used as an example) -- Using the equation for other nuclides in Table 2-5, the adjustment factor A is calculated as follows:

$$A = \frac{P}{WP} (110) \frac{0.34 + \lambda}{R + \lambda} \quad (2-4)$$

where the terms in the equation are as defined in Tables 2-3 and 2-4.

In calculating A, the variable R is calculated first, using Equation (2-2). The other nuclide parameters given in Table 2-4 and the Barton Station parameters are used in the equation:

$$R = \frac{1.5 \times 10^5 \times 0.9 + 0.75 \times 15.4 \times 10^6 \times 0.001 \times 0.9}{4.9 \times 10^5} = 0.3$$

Then, using this value of R in Equation (2-4):

$$A = \left( \frac{3758}{4.9 \times 10^5} \right) (110) \left( \frac{0.34 + 4.62 \times 10^{-2}}{0.3 + 4.62 \times 10^{-2}} \right) = 0.95$$

The adjusted concentration of Na-24

$$\begin{aligned} &= (\text{adjustment factor}) \times (\text{standard Na-24 concentration}) \\ &= 0.95 \times 9 \times 10^{-3} \text{ } \mu\text{Ci/g} = 8.6 \times 10^{-3} \text{ } \mu\text{Ci/g} \end{aligned}$$

The noble gas concentrations in Table 2-2 are based on an offgas release rate of 60,000  $\mu\text{Ci/sec}$  measured at a 30-minute decay. A summary of noble gas release rates from a number of operating BWRs in 1971-72 is given in Table 2-6 and a similar summary for 1973-74 is given in Table 2-7. The data in these tables are limited to measurements from BWRs larger than 1000 Mwt with more than one year of operating experience. The average of the noble gas release rates in Tables 2-6 and 2-7, based on the effective full power days of operation and normalized to 3400 Mwt, is 60,000  $\mu\text{Ci/sec}$ .

A carryover factor of 0.02 is used to calculate the halogen concentrations in the main steam in Table 2-2. This carryover factor is derived from data taken at operating reactors (Refs. 2, 3, 4, and 5) which are listed in Table 2-8. The average of the data in Table 2-8 is 0.018 for halogen (iodine) carryover.

The category "Other nuclides" includes Mo, Y, and Tc which are generally present in colloidal suspensions or as "crud." Although the actual removal mechanism for Y, Mo, and Tc is expected to be plateout or filtration, the quantitative effect of renewal is expected to be commensurate with the removal of ionic impurities by ion exchange (within the accuracy of the calculations) and consequently plateout of these nuclides is included in the parameters for ion exchange.

#### 2.2.4 GASEOUS RELEASES FROM BUILDING VENTILATION SYSTEMS

##### 2.2.4.1 Parameter

The noble gas, iodine, and radioactive particulate releases from ventilation systems for facilities with the BWR/6, Mark III containment design, prior to treatment, are shown in Table 2-9.

##### 2.2.4.2 Bases

The iodine-131 releases from building ventilation effluents are based on measurements made at operating reactors. The measurements were made during normal operation and during plant shutdowns. The data are given in Tables 2-10 through 2-15. These data show that the release rates during plant shutdown differ from the release rates during plant operation. The ratio of releases during shutdowns to releases during normal operations, assuming a plant capacity factor of 80%, is used to calculate annual releases that consider both normal operation and shutdown releases.

Table 2-13 gives the iodine-131 release rates during normal operation and during plant shutdowns for the Oyster Creek turbine building as 0.024  $\mu\text{Ci/sec}$  and 0.081  $\mu\text{Ci/sec}$ , respectively. Using an 80% plant capacity factor, the ratio of releases due to normal operation and shutdowns to the releases during normal operation only can be expressed as

$$\frac{(0.024 \text{ } \mu\text{Ci/sec})(0.8) + (0.081 \text{ } \mu\text{Ci/sec})(0.2)}{(0.024 \text{ } \mu\text{Ci/sec})(0.8)} = 1.8$$

Similarly, from Table 2-13 the ratio of releases due to normal operation and shutdowns to the releases during normal operation for Vermont Yankee is 1.7. Using the average of these ratios, the average annual turbine building releases during normal operation from Table 2-12 are normalized to obtain a total annual release as indicated below:

$$\frac{(1.8 + 1.7)}{2} (0.11 \text{ Ci/yr}) = 0.19 \text{ Ci/yr total I-131 released}$$

TABLE 2-6  
SUMMARY OF NOBLE GAS RELEASE RATES FOR  
OPERATING BWRs (1971-1972)

| REACTOR *        | NOMINAL POWER (Mwt) | HOLDUP TIME (min) | 1971 RELEASES  |                   |                   |                               | 1972 RELEASES  |                   |                   |                               |
|------------------|---------------------|-------------------|----------------|-------------------|-------------------|-------------------------------|----------------|-------------------|-------------------|-------------------------------|
|                  |                     |                   | EFPD ** (days) | NOBLE GAS (Ci/yr) | AVERAGE (μCi/sec) | AVERAGE AT 3400 Mwt (μCi/sec) | EFPD ** (days) | NOBLE GAS (Ci/yr) | AVERAGE (μCi/sec) | AVERAGE AT 3400 Mwt (μCi/sec) |
| Oyster Creek     | 1930                | 90                | 260            | 516,000           | 23,000            | 69,000                        | 280            | 866,000           | 36,000            | 120,000                       |
| Nine Mile Point  | 1850                | 60                | 210            | 253,000           | 14,000            | 36,000                        | 230            | 517,000           | 27,000            | 73,000                        |
| Millstone 1      | 2011                | 50                | 230            | 276,000           | 14,000            | 30,000                        | 200            | 721,000           | 42,000            | 88,000                        |
| Dresden 2, 3 *** | 5052                | 60                | ---            | ---               | ---               | ---                           | 420            | 431,000           | 35,000            | 35,000                        |
| Monticelio       | 1670                | 60                | ---            | ---               | ---               | ---                           | 270            | 565,000           | 25,000            | 76,000                        |
| Yearly Average   |                     |                   |                |                   |                   |                               | 45,000         |                   | 71,000            |                               |

\* Reactors smaller than 1000 Mwt (Big Rock Point, Dresden 1, Humboldt Bay, Lacrosse) are not included. Quad Cities 1 and 2, Vermont Yankee, and Pilgrim 1 were undergoing startup when this table was compiled and are not included.

\*\* Effective full power days of operation.

\*\*\* Dresden 2 and 3 are considered as two reactors.



TABLE 2-7  
SUMMARY OF NOBLE GAS RELEASE RATES FOR  
OPERATING BWRs (1973-1974)

| REACTOR*            | NOMINAL<br>POWER<br>(Mwt) | HOLDUP<br>TIME<br>(min) | 1973 RELEASES    |                      |                            |   | 1974 RELEASES    |                      |                            |   |
|---------------------|---------------------------|-------------------------|------------------|----------------------|----------------------------|---|------------------|----------------------|----------------------------|---|
|                     |                           |                         | EFPD**<br>(days) | NOBLE GAS<br>(Ci/yr) | AVERAGE<br>( $\mu$ Ci/sec) | AVERAGE<br>AT 3400 Mwt<br>( $\mu$ Ci/sec) | EFPD**<br>(days) | NOBLE GAS<br>(Ci/yr) | AVERAGE<br>( $\mu$ Ci/sec) | AVERAGE<br>AT 3400 Mwt<br>( $\mu$ Ci/sec) |
| Oyster Creek        | 1930                      | 90                      | 230              | 812,000              | 35,000                     | 120,000                                   | 240              | 280,000              | 14,000                     | 47,000                                    |
| Nine Mile Point 1   | 1850                      | 60                      | 250              | 872,000              | 40,000                     | 110,000                                   | 240              | 617,000              | 30,000                     | 75,000                                    |
| Millstone 1         | 2011                      | 50                      | 120              | 69,500               | 7,000                      | 21,000                                    | 230              | 912,000              | 46,000                     | 99,000                                    |
| Dresden 2, 3***     | 5054                      | 60                      | 440              | 875,000              | 46,000                     | 43,000                                    | 340              | 628,000              | 21,000                     | 20,000                                    |
| Monticello          | 1670                      | 60                      | 250              | 732,000              | 34,000                     | 95,000                                    | 220              | 1,490,000            | 78,000                     | 220,000                                   |
| Quad Cities 1, 2*** | 5022                      | 60                      | 510              | 903,000              | 41,000                     | 42,000                                    | 430              | 1,049,000            | 28,000                     | 26,000                                    |
| Vermont Yankee      | 1593                      | 60                      | 160              | 187,000              | 20,000                     | 63,000                                    | †                |                      |                            |   |
| Pilgrim 1           | 1998                      | 60                      | 270              | 230,000              | 10,000                     | 25,000                                    | 130              | 546,000              | 49,000                     | 126,000                                   |
| Yearly Average      |                           |                         |                  |                      |                            | 61,000                                    |                  |                      |                            | 73,000                                    |

\* Reactors smaller than 1000 Mwt (Big Rock Point, Dresden 1, Humboldt Bay, Lacrosse) are not included.  
Reactors undergoing startup (Browns Ferry 1, Cooper 1, Duane Arnold, Peach Bottom 2) are not included.

\*\* Effective full power days of operation.

\*\*\* Dresden 2, 3 and Quad Cities 1, 2 are both considered as two reactors.

† Vermont Yankee Nuclear Power Station was not included for CY-1974 because of insufficient data regarding effect of augmented offgas treatment system.

TABLE 2-8  
 REACTOR VESSEL HALOGEN CARRYOVER FACTORS\*  
 OBSERVED AT OPERATING BWRs

| REACTOR         | POWER LEVEL**<br>(Mwt) | METHOD***  | PARTITION<br>FACTOR | REFERENCE |
|-----------------|------------------------|------------|---------------------|-----------|
| Oyster Creek    | (1930)                 | Condensate | 0.018               | 3         |
|                 | (1930)                 | No cleanup | 0.018               | 3         |
|                 | 1830                   | Condensate | 0.019               | 2         |
|                 | 1830                   | Condensate | 0.021               | 2         |
|                 | 1330                   | No cleanup | 0.023               | 2         |
|                 | 1820                   | Condensate | 0.027               | 4         |
|                 | (1930)                 | Condensate | 0.023               | 4         |
|                 | (1930)                 | Condensate | 0.025               | 4         |
|                 | (1930)                 | No cleanup | 0.025               | 4         |
|                 | (1930)                 | No cleanup | 0.025               | 4         |
| Dresden 2       | 1830                   | Condensate | 0.022               | 5         |
|                 | 2210                   | Condensate | 0.016               | 5         |
|                 | 2210                   | Condensate | 0.017               | 5         |
|                 | 2400                   | Condensate | 0.019               | 2         |
|                 | 2400                   | No cleanup | 0.010               | 2         |
| Dresden 3       | 2100                   | Condensate | 0.022               | 2         |
|                 | 2100                   | No cleanup | 0.020               | 2         |
| Millstone       | (2011)                 | Condensate | 0.017               | 3         |
|                 | 2000                   | Condensate | 0.005               | 2         |
| Monticello      | 1670                   | Condensate | 0.003               | 2         |
|                 | 1670                   | No cleanup | 0.005               | 2         |
| Nine Mile Point | (1850)                 | Condensate | 0.02                | 3         |
|                 | (1850)                 | No cleanup | 0.02                | 3         |
| Quad Cities 1   | (2511)                 | Condensate | 0.012               | 2         |
|                 | (2511)                 | No cleanup | 0.013               | 2         |
| Average         |                        |            | 0.018               |           |

\* Based on iodine-131.

\*\* When test power level is not known, licensed power level is given in parentheses.

\*\*\* Condensate method - The calculated partition factors are based on the ratio of the iodine-131 concentration in the condensate to that in the reactor water.

No-cleanup method - The calculated partition factors are based on the change in the concentrations of iodine-131 in the reactor water with the cleanup system isolated compared to the concentration with the cleanup system in service.

TABLE 2-9  
 GASEOUS RELEASES FROM VENTILATION SYSTEMS  
 (in Ci/yr per reactor)

| NUCLIDE | CONTAINMENT BUILDING | AUXILIARY BUILDING | TURBINE* BUILDING | RADWASTE BUILDING |
|---------|----------------------|--------------------|-------------------|-------------------|
| Kr-83m  | **                   | **                 | **                | **                |
| Kr-85m  | 3                    | 3                  | 68                | **                |
| Kr-85   | **                   | **                 | **                | **                |
| Kr-87   | 3                    | 3                  | 190               | **                |
| Kr-88   | 3                    | 3                  | 230               | **                |
| Kr-89   | **                   | **                 | **                | **                |
| Xe-131m | **                   | **                 | **                | **                |
| Xe-133m | **                   | **                 | **                | **                |
| Xe-133  | 66                   | 66                 | 280               | 10                |
| Xe-135m | 46                   | 46                 | 650               | **                |
| Xe-135  | 34                   | 34                 | 630               | 45                |
| Xe-137  | **                   | **                 | **                | **                |
| Xe-138  | 7                    | 7                  | 1440              | **                |
| I-131   | 0.17                 | 0.17               | 0.19              | 0.046             |
| I-133   | 0.68                 | 0.68               | 0.76              | 0.18              |
| Co-60   | 0.01                 | 0.01               | 0.002             | 0.09              |
| Co-58   | 0.0006               | 0.0006             | 0.0006            | 0.0045            |
| Cr-51   | 0.0003               | 0.0003             | 0.013             | 0.009             |
| Mn-54   | 0.003                | 0.003              | 0.0006            | 0.036             |
| Fe-59   | 0.0004               | 0.0004             | 0.0005            | 0.015             |
| Zn-65   | 0.002                | 0.002              | 0.0002            | 0.001             |
| Zr-95   | 0.0004               | 0.0004             | 0.0001            | 0.00005           |
| Sr-89   | 0.00009              | 0.00009            | 0.006             | 0.0005            |
| Sr-90   | 0.000005             | 0.000005           | 0.00002           | 0.0003            |
| Sb-124  | 0.0002               | 0.0002             | 0.0003            | 0.00005           |
| Cs-134  | 0.004                | 0.004              | 0.0003            | 0.0045            |
| Cs-136  | 0.0003               | 0.0003             | 0.00005           | 0.00045           |
| Cs-137  | 0.005                | 0.005              | 0.0006            | 0.009             |
| Ba-140  | 0.0004               | 0.0004             | 0.011             | 0.0001            |
| Ce-141  | 0.0001               | 0.0001             | 0.0006            | 0.0026            |

\* Less than 1 Ci/yr per reactor.

\*\* For special design features to control leakage from valves in lines 2-1/2 inches and larger, reduce the turbine building leakage rates by a factor of 5.

TABLE 2-10  
ANNUAL IODINE-131 RELEASES FROM REACTOR BUILDING  
VENTILATION SYSTEMS, NORMAL OPERATION

| <u>FACILITY</u>   | <u>RELEASE (Ci/yr)*</u> | <u>REFERENCE</u> |
|-------------------|-------------------------|------------------|
| Vermont Yankee    | 0.12                    | 6                |
| Oyster Creek      | 0.072                   | 2                |
| Oyster Creek      | 0.04                    | 7                |
| Monticello        | 0.17                    | 2                |
| Dresden 2         | 0.096                   | 2                |
| Dresden 3         | 0.3                     | 2                |
| Millstone 1       | 0.03                    | 8                |
| Quad Cities 1     | 0.096                   | 9                |
| Nine Mile Point 1 | 0.096                   | 10               |
| Average           | 0.11                    |                  |

\* Annual release calculated from release rate ( $\mu\text{Ci}/\text{sec}$ ) based on 80% plant capacity factor.

TABLE 2-11  
COMPARISON BETWEEN IODINE-131 RELEASES FROM REACTOR  
BUILDING DURING NORMAL OPERATION AND RELEASES DURING PLANT OUTAGES

| <u>FACILITY</u> | <u>NORMAL OPERATION<br/>(<math>\mu\text{Ci}/\text{sec}</math>)</u> | <u>OUTAGES<br/>(<math>\mu\text{Ci}/\text{sec}</math>)</u> | <u>RATIO TOTAL RELEASES*<br/>TO NORMAL RELEASES</u> | <u>REFERENCE</u> |
|-----------------|--|---|---|------------------|
| Oyster Creek    | 0.0029   | 0.014**   | 2.6   | 2                |
| Vermont Yankee  | 0.0038   | 0.041   | 3.7   | 6                |

\* Ratio is based on normal releases occurring 80% of the year and releases during outages occurring 20% of the year.

\*\* Oyster Creek releases include measurements made during drywell purge which was assumed to occur 48 hr/yr.

TABLE 2-12  
ANNUAL IODINE-131 RELEASES FROM TURBINE BUILDING VENTILATION  
SYSTEMS DURING NORMAL OPERATION

| <u>FACILITY</u>   | <u>RELEASE (Ci/yr)*</u> | <u>REFERENCE</u> |
|-------------------|-------------------------|------------------|
| Vermont Yankee    | 0.041                   | 6                |
| Oyster Creek      | 0.61                    | 2                |
| Oyster Creek      | 0.073                   | 7                |
| Oyster Creek      | 0.023                   | 7                |
| Millstone 1       | 0.012                   | 8                |
| Monticello        | 0.13                    | 2                |
| Dresden 2         | 0.007                   | 2                |
| Dresden 3         | 0.015                   | 2                |
| Quad Cities 1     | 0.012                   | 9                |
| Nine Mile Point 1 | <u>0.14</u>             | 10               |
| Average           | 0.11                    |                  |

\* Annual release calculated from release rate ( $\mu\text{Ci}/\text{sec}$ ) based on 80% plant capacity factor.

TABLE 2-13  
COMPARISON BETWEEN IODINE-131 RELEASES FROM TURBINE BUILDING  
DURING NORMAL OPERATION AND RELEASES DURING PLANT OUTAGES

| <u>FACILITY</u> | <u>NORMAL OPERATION<br/>(<math>\mu\text{Ci}/\text{sec}</math>)</u> | <u>OUTAGES<br/>(<math>\mu\text{Ci}/\text{sec}</math>)</u> | <u>RATIO TOTAL RELEASES*<br/>TO NORMAL RELEASES</u> | <u>REFERENCE</u> |
|-----------------|--|---|---|------------------|
| Oyster Creek    | 0.024  | 0.081**   | 1.8   | 2                |
| Vermont Yankee  | 0.0013   | 0.0035  | 1.7   | 6                |

\* Ratio is based on normal releases occurring 80% of the year and releases during outages occurring 20% of the year.

\*\* Oyster Creek releases include measurements made during drywell purge which was assumed to occur 48 hr/yr.

TABLE 2-14  
ANNUAL IODINE-131 RELEASES FROM RADWASTE BUILDING VENTILATION  
SYSTEMS, NORMAL OPERATION

| <u>FACILITY</u>   | <u>RELEASE (Ci/yr)*</u> | <u>REFERENCE</u> |
|-------------------|-------------------------|------------------|
| Vermont Yankee    | 0.057                   | 6                |
| Oyster Creek      | 0.024                   | 2                |
| Oyster Creek      | 0.008                   | 7                |
| Nine Mile Point 1 | <u>0.008</u>            | 10               |
| Average           | 0.024                   |                  |

\* Annual release calculated from release rate ( $\mu\text{Ci}/\text{sec}$ ) based on 80% plant capacity factor.

TABLE 2-15  
COMPARISON BETWEEN IODINE-131 RELEASES FROM RADWASTE BUILDING  
DURING NORMAL OPERATION AND RELEASES DURING PLANT OUTAGES

| <u>FACILITY</u> | <u>NORMAL OPERATION<br/>(<math>\mu\text{Ci}/\text{sec}</math>)</u> | <u>OUTAGES<br/>(<math>\mu\text{Ci}/\text{sec}</math>)</u> | <u>RATIO TOTAL RELEASES*<br/>TO NORMAL RELEASES</u> | <u>REFERENCE</u> |
|-----------------|--|---|---|------------------|
| Oyster Creek    | 0.00086  | 0.0031**  | 1.9   | 2                |
| Vermont Yankee  | 0.0018   | 0.0066  | 1.9   | 6                |

\*Ratio is based on normal releases occurring 80% of the year and releases during outages occurring 20% of the year.

\*\* Oyster Creek releases include measurements made during drywell purge which was assumed to occur 48 hr/yr.

The same procedure was used for the radwaste and reactor buildings to obtain total annual iodine-131 releases of 0.046 Ci/yr and 0.34 Ci/yr, respectively. The reactor building releases are based on reactors with a BWR Mark I containment design. Equipment such as the reactor coolant cleanup pumps, residual heat removal system, and emergency core cooling systems have been placed in an auxiliary building in the BWR/6, Mark III containment design concept. Because of the potential for these systems to release radioactive materials from leakage during operation or testing, the Mark I reactor building releases have been assumed to be equally divided between the containment and auxiliary buildings for BWR/6, Mark III designs. The most significant leakage pathway in the turbine building is considered to be through valve stem packings. For this reason, the leakage rate is reduced by a factor of 5 if special design features are applied to reduce or collect leakage from valves in lines 2-1/2 inches in diameter and larger.

The noble gas release rates for building ventilation systems are the average of measurements made at Oyster Creek (Ref. 7) and Millstone Unit 1 (Ref. 8). These data are given in Tables 2-16 through 2-18. The noble gas release rates for the reactor building are equally divided between the containment and auxiliary buildings to reflect the BWR/6, Mark III design.

The radioactive particulate release rates for building ventilation systems are the average of measurements made at Vermont Yankee, Oyster Creek, Dresden 2 & 3, and Nine Mile Point (Refs. 11, 2, and 10). These data are given in Tables 2-21 through 2-27. The calculated annual release rates given above are based on an 80% plant capacity factor, i.e., 80% normal operation at 100% power and 20% plant downtime. To account for differences between release rates during shutdowns of long duration (greater than one week) and those for shorter shutdowns, the 20% downtime of 73 days was assumed to consist of 60 days of long-term shutdowns and 13 days of short-term shutdowns. The releases for normal operation were weighted to account for the operating and shutdown modes in a manner similar to that described previously for iodine releases. The particulate release rates in Tables 2-25 through 2-27 for the radwaste building were measured downstream of HEPA filters and were therefore normalized to upstream concentrations to obtain the radwaste building parameter above. A DF of 15, consistent with HEPA filter DF measurements at Nine Mile Point 1, was used in the normalization (Ref. 10). As described previously for noble gases and iodine, the particulate releases for the reactor building are equally divided between the containment and auxiliary buildings to reflect the BWR/6, Mark III containment design.

## 2.2.5 IODINE INPUT TO THE MAIN CONDENSER OFFGAS TREATMENT SYSTEM

### 2.2.5.1 Parameter

The iodine-131 input to the main condenser offgas treatment system, downstream of the air ejectors, is 5 Ci/yr.

### 2.2.5.2 Bases

Table 2-28 lists the measured iodine-131 releases and integrated thermal power outputs for BWRs with thermal ratings exceeding 1000 MWt, with more than one year of plant operation and without main condenser offgas treatment. The average ratio of the iodine-131 release in Ci/yr to the integrated thermal power in MWd for the years 1972, 1973, and 1974 is approximately  $5 \times 10^{-6}$  Ci/MWd per year. Based on a power rating of 3400 MWt and an 80% plant capacity factor, the iodine-131 release from the main condenser air ejector is approximately 5 Ci/yr.

## 2.2.6 TURBINE GLAND SEALING SYSTEM EXHAUST

### 2.2.6.1 Parameter

Use 0.1% of the main steam flow and assume 99% iodine removal due to radioiodine absorption by condensing steam in the turbine gland seal condenser. If clean steam is supplied to the gland seal, the radioiodine source term is negligible (less than  $10^{-4}$  Ci/yr). If sealing steam is supplied from a low-activity source, i.e., steam produced from demineralized condensate, consider the flow to be zero.

### 2.2.6.2 Bases

A design value of 0.1% of the main steam flow is used for the turbine gland seal steam flow (Ref. 12). A large fraction of the iodine is expected to be absorbed by the liquid phase during condensation of the gland seal steam. In the absence of radioiodine measurements, it is assumed that the gland seal condenser will remove approximately 99% of the iodine from the noncondensable stream due to iodine adsorption by the condensing water. It is further assumed that the iodine

TABLE 2-16  
 RELEASES OF NOBLE GASES FROM THE  
 REACTOR BUILDING VENTILATION SYSTEM  
 ( $\mu\text{Ci}/\text{sec}$ )

| NUCLIDE | MILLSTONE |          | OYSTER CREEK | AVERAGE |
|---------|-----------|----------|--------------|---------|
|         | 07/21/72  | 07/24/72 | 04/18/72     |         |
| Kr-85m  | 0.44      | 0.07     | NR           | 0.25    |
| Kr-87   | 0.29      | 0.19     | NR           | 0.24    |
| Kr-88   | 0.56      | 0.20     | 0.02         | 0.25    |
| Xe-133  | 0.67      | 0.36     | 15           | 5.3     |
| Xe-135m | 3.0       | 4.1      | NR           | 3.6     |
| Xe-135  | 3.1       | 2.9      | 2.1          | 2.7     |
| Xe-138  | 0.87      | NR       | 0.3          | 0.6     |

NR - Not reported.

TABLE 2-17  
 RELEASES OF NOBLE GASES FROM THE  
 TURBINE BUILDING VENTILATION SYSTEM  
 ( $\mu\text{Ci}/\text{sec}$ )

| NUCLIDE | MILLSTONE<br>(Ref. 7) | OYSTER CREEK<br>(Ref. 6) | AVERAGE |
|---------|-----------------------|--------------------------|---------|
| Kr-85m  | 2.7                   | NR                       | 2.7     |
| Kr-87   | 5.3                   | NR                       | 5.3     |
| Kr-88   | 8.2                   | 10                       | 9.1     |
| Xe-133  | 7.4                   | 12                       | 10      |
| Xe-135m | 29                    | 23                       | 26      |
| Xe-135  | 25                    | 25                       | 25      |
| Xe-138  | 63                    | 52                       | 58      |

NR - Not reported.

TABLE 2-18  
 RELEASES OF NOBLE GASES FROM THE  
 RADWASTE BUILDING VENTILATION SYSTEM  
 ( $\mu\text{Ci}/\text{sec}$ )

| NUCLIDE | MILLSTONE<br>(Ref. 7) | OYSTER CREEK<br>(Ref. 6) | AVERAGE |
|---------|-----------------------|--------------------------|---------|
| Xe-133  | 0.25                  | 0.56                     | 0.4     |
| Xe-135  | 2.0                   | 1.5                      | 1.8     |



TABLE 2-19  
 PARTICULATE RELEASE RATES FROM REACTOR BUILDING  
 VENTILATION SYSTEM, NORMAL OPERATION (Refs. 40, 2)  
 ( $10^{-6}$   $\mu$ Ci/sec)

| NUCLIDE | VERMONT YANKEE | OYSTER CREEK | AVERAGE |
|---------|----------------|--------------|---------|
| Co-60   | 30             | 930          | 480     |
| Co-58   | 4.6            | 56           | 30      |
| Cr-51   | 5              | 5.4          | 5.2     |
| Mn-54   | 21             | 370          | 196     |
| Fe-59   | 5              | 47           | 26      |
| Zn-65   | 35             | 11           | 23      |
| Zr-95   | 2              | NR           | 2       |
| Sr-89   | NA             | 6.8          | 6.8     |
| Sr-90   | NA             | 0.3          | 0.3     |
| Sb-124  | NR             | 11           | 11      |
| Cs-134  | 18             | 18           | 18      |
| Cs-136  | 13             | NR           | 13      |
| Cs-137  | 44             | 25           | 35      |
| Ba-140  | 25             | 1.8          | 13      |
| Ce-141  | NR             | 4.3          | 4.3     |

NA - Not analyzed.  
 NR - Not reported.

TABLE 2-20  
 PARTICULATE RELEASE RATES FROM REACTOR BUILDING  
 VENTILATION SYSTEM, SHORT-TERM SHUTDOWN (2 DAYS/EVENT) (REFS. 11, 2)  
 ( $10^{-6}$   $\mu$ Ci/sec)

| NUCLIDE | VERMONT YANKEE* | OYSTER CREEK | AVERAGE |
|---------|-----------------|--------------|---------|
| Co-60   | 104             | 8100         | 4100    |
| Co-58   | 71              | 37           | 54      |
| Cr-51   | 31              | 37           | 34      |
| Mn-54   | 131             | 23           | 77      |
| Fe-59   | 31              | 37           | 34      |
| Zn-65   | 57              | 19           | 38      |
| Zr-95   | 31              | NR           | 31      |
| Sr-89   | NA              | NA           | NA      |
| Sr-90   | NA              | NA           | NA      |
| Sb-124  | NR              | 37           | 37      |
| Cs-134  | 51              | 12000        | 6030    |
| Cs-136  | 33              | NR           | 33      |
| Cs-137  | 97              | 16000        | 8050    |
| Ba-140  | 12              | 780          | 396     |
| Ce-141  | NR              | 37           | 37      |

NA - Not analyzed.  
 NR - Not reported.

\* Initial drywell purge via SGTS not sampled.

TABLE 2-21  
 PARTICULATE RELEASE RATES FROM REACTOR BUILDING  
 VENTILATION SYSTEM, REFUELING SHUTDOWN (REFS. 11, 2)  
 ( $10^{-6}$   $\mu$ Ci/sec)

| NUCLIDE | VERMONT YANKEE | OYSTER CREEK | AVERAGE |
|---------|----------------|--------------|---------|
| Co-60   | 480            | 590          | 534     |
| Co-58   | 77             | 34           | 56      |
| Cr-51   | 120            | 43           | 81      |
| Mn-54   | 55             | 240          | 150     |
| Fe-59   | 21             | 6            | 14      |
| Zn-65   | 1500           | 2.7          | 770     |
| Zr-95   | 150            | NR           | 152     |
| Sr-89   | NA             | 2            | 2       |
| Sr-90   | NA             | 0.36         | 0.36    |
| Sb-124  | NR             | 14           | 14      |
| Cs-134  | 160            | 20           | 90      |
| Cs-136  | 39             | NR           | 39      |
| Cs-137  | 380            | 34           | 210     |
| Ba-140  | 27             | 2            | 14      |
| Ce-141  | NR             | 11           | 11      |

NA - Not analyzed.  
 NR - Not reported.

TABLE 2-22  
 PARTICULATE RELEASE RATES FROM TURBINE BUILDING  
 VENTILATION SYSTEM, NORMAL OPERATION (REFS. 11, 2)  
 ( $10^{-6}$   $\mu$ Ci/sec)

| NUCLIDE | VERMONT YANKEE | OYSTER CREEK | DRESDEN 2 | DRESDEN 3 | AVERAGE |
|---------|----------------|--------------|-----------|-----------|---------|
| Co-60   | 3.6            | 72           | 4.5       | 6.0       | 22      |
| Co-58   | 2.7            | 6.7          | NR        | 48        | 20      |
| Cr-51   | NR             | 840          | NR        | 160       | 500     |
| Mn-54   | 1.7            | 8.4          | NR        | 5         | 5       |
| Fe-59   | NR             | 6.7          | NR        | NR        | 6.7     |
| Zn-65   | NR             | 3.3          | NR        | NR        | 3.3     |
| Zr-95   | NR             | NR           | NR        | 4.0       | 4.0     |
| Sr-89   | NA             | 610          | 48        | 36        | 230     |
| Sr-90   | NA             | 1.3          | 0.3       | 0.25      | 0.6     |
| Sb-124  | NR             | 6.7          | NR        | NR        | 6.7     |
| Cs-134  | 2.9            | 15           | NR        | 3.0       | 7       |
| Cs-136  | NR             | NR           | NR        | NR        | *       |
| Cs-137  | 1.9            | 42           | 1.8       | 10        | 14      |
| Ba-140  | 133            | 1400         | 115       | 65        | 430     |
| Ce-141  | NR             | 42           | 5.5       | 5         | 18      |

NA - Not analyzed.  
 NR - Not reported.

\* Estimated to be less than  $1 \times 10^{-6}$   $\mu$ Ci/sec. A value of  $1 \times 10^{-6}$   $\mu$ Ci/sec was used to calculate annual release.

TABLE 2-23  
 PARTICULATE RELEASE RATES FROM TURBINE BUILDING  
 VENTILATION SYSTEM, SHORT-TERM SHUTDOWN (REFS. 11, 2)  
 ( $10^{-6}$   $\mu$ Ci/sec)

| NUCLIDE | VERMONT YANKEE | OYSTER CREEK | AVERAGE |
|---------|----------------|--------------|---------|
| Co-60   | 5.5            | 46           | 26      |
| Co-58   | 1.5            | 46           | 24      |
| Cr-51   | NR             | 46           | 46      |
| Mn-54   | 3.5            | 15           | 9.2     |
| Fe-59   | NR             | 46           | 46      |
| Zn-65   | NR             | 23           | 23      |
| Zr-95   | NR             | NR           | *       |
| Sr-89   | NA             | NA           | NA      |
| Sr-90   | NA             | NA           | NA      |
| Sb-124  | NR             | 46           | 46      |
| Cs-134  | 1.8            | 170          | 86      |
| Cs-136  | NR             | NR           | *       |
| Cs-137  | 4.5            | 240          | 120     |
| Ba-140  | 25             | 110          | 68      |
| Ce-141  | NR             | 46           | 46      |

NA - Not analyzed.

NR - Not reported.

\* Estimated to be less than  $10^{-6}$   $\mu$ Ci/sec. A value of  $1 \times 10^{-6}$   $\mu$ Ci/sec was used to calculate annual release.

TABLE 2-24  
 PARTICULATE RELEASE RATES FROM TURBINE BUILDING  
 VENTILATION SYSTEM, REFUELING SHUTDOWN (REFS. 11, 2)  
 ( $10^{-6}$   $\mu$ Ci/sec)

| NUCLIDE | VERMONT YANKEE | OYSTER CREEK | AVERAGE |
|---------|----------------|--------------|---------|
| Co-60   | 3.5            | 490          | 250     |
| Co-58   | 1              | 29           | 15      |
| Cr-51   | NR             | 72           | 72      |
| Mn-54   | 1              | 180          | 90      |
| Fe-59   | NR             | 49           | 49      |
| Zn-65   | NR             | 11           | 11      |
| Zr-95   | NR             | NR           | *       |
| Sr-89   | NA             | 2.5          | 2.5     |
| Sr-90   | NA             | 0.25         | 0.25    |
| Sb-124  | NR             | 9.5          | 9.5     |
| Cs-134  | 2.5            | 26           | 14      |
| Cs-136  | NR             | NR           | *       |
| Cs-137  | 5              | 57           | 31      |
| Ba-140  | 3.6            | 3.4          | 3.5     |
| Ce-141  | NR             | 20           | 20      |

NA - Not analyzed.

NR - Not reported.

\* Estimated to be less than  $10^{-6}$   $\mu$ Ci/sec. A value of  $1 \times 10^{-6}$   $\mu$ Ci/sec was used to calculate annual release.

TABLE 2-25  
 PARTICULATE RELEASE RATE\* FROM RADWASTE BUILDING  
 VENTILATION SYSTEM, NORMAL OPERATION (REFS. 11, 2, 8)  
 ( $10^{-6}$   $\mu$ Ci/sec)

| NUCLIDE | VERMONT<br>YANKEE | OYSTER<br>CREEK | NINE MILE<br>POINT | AVERAGE |
|---------|-------------------|-----------------|--------------------|---------|
| Co-60   | 0.7               | 55              | 83 **              | 46      |
| Co-58   | 0.64              | 1.5             | 2.0 **             | 1.4     |
| Cr-51   | NR                | 5.3             | NR **              | 5.3     |
| Mn-54   | 0.43              | 14              | 8.7 **             | 7.7     |
| Fe-59   | NR                | 0.72            | NR                 | 0.72    |
| Zn-65   | 1                 | 0.63            | NR                 | 0.82    |
| Zr-95   | NR                | NR              | NR                 | ***     |
| Sr-89   | NA                | 0.72            | NR                 | 0.72    |
| Sr-90   | NA                | 0.72            | NR                 | 0.72    |
| Sb-124  | NR                | NR              | NR *               | ***     |
| Cs-134  | 0.8               | 3               | 33                 | 12      |
| Cs-136  | 1                 | NR              | NR                 | 1       |
| Cs-137  | 1.9               | 6.8             | 57                 | 22      |
| Ba-140  | 3.7               | NR              | NR                 | 3.7     |
| Ce-141  | NR                | 0.72            | NR                 | 0.72    |

NR - Not reported.  
 NA - Not analyzed.

\* Downstream of HEPA filters.

\*\* Calculated based on known filter inlet activity concentration using DF of 15.

\*\*\* Estimated to be less than  $1 \times 10^{-6}$   $\mu$ Ci/sec. A value of  $1 \times 10^{-6}$  was used to calculate annual release.

TABLE 2-26  
 PARTICULATE RELEASE RATE\* FROM RADWASTE BUILDING  
 VENTILATION SYSTEM, SHORT-TERM SHUTDOWN (REFS. 11, 2)  
 ( $10^{-6}$   $\mu$ Ci/sec)

| NUCLIDE | VERMONT YANKEE | OYSTER CREEK | AVERAGE |
|---------|----------------|--------------|---------|
| Co-60   | 1.1            | 68           | 35      |
| Co-58   | 0.95           | 7.2          | 4.1     |
| Cr-51   | NR             | 7.2          | 7.2     |
| Mn-54   | 0.64           | 19           | 9.8     |
| Fe-59   | NR             | 7.2          | 7.2     |
| Zn-65   | 1              | 4.3          | 2.7     |
| Zr-95   | NR             | NR           | **      |
| Sr-89   | NA             | NA           | NA      |
| Sr-90   | NA             | NA           | NA      |
| Sb-124  | NR             | NR           | **      |
| Cs-134  | 1.3            | 7.2          | 4.3     |
| Cs-136  | 1.1            | NR           | 1.1     |
| Cs-137  | 8.6            | 7.2          | 8.0     |
| Ba-140  | 0.92           | NR           | 0.92    |
| Ce-141  | NR             | 7.2          | 7.2     |

NA - Not analyzed.  
 NR - Not reported.

\* Downstream of HEPA filters.

\*\* Estimated to be less than  $10^{-6}$   $\mu$ Ci/sec. A value of  $1 \times 10^{-6}$   $\mu$ Ci/sec was used to calculate annual release.

TABLE 2-27  
 PARTICULATE RELEASE RATE\* FROM RADWASTE BUILDING  
 VENTILATION SYSTEM, REFUELING SHUTDOWN (REFS. 11, 2)  
 ( $10^{-6}$   $\mu$ Ci/sec)

| NUCLIDE | VERMONT YANKEE | OYSTER CREEK | AVERAGE |
|---------|----------------|--------------|---------|
| Co-60   | 0.8            | 1850         | 920     |
| Co-58   | 0.6            | 114          | 57      |
| Cr-51   | NR             | 92           | 92      |
| Mn-54   | 0.6            | 860          | 430     |
| Fe-59   | NR             | 250          | 250     |
| Zn-65   | 1              | 29           | 15      |
| Zr-95   | NR             | NR           | **      |
| Sr-89   | NA             | 1.8          | 1.8     |
| Sr-90   | NA             | 0.08         | 0.08    |
| Sb-124  | NR             | NR           | **      |
| Cs-134  | 1              | 15           | 8       |
| Cs-136  | 1              | NR           | 1       |
| Cs-137  | 3.9            | 34           | 19      |
| Ba-140  | 1.1            | NR           | 1.1     |
| Ce-141  | NR             | 29           | 29      |

NR - Not reported.

NA - Not analyzed.

\* Downstream of HEPA filters

\*\* Estimated to be less than  $10^{-6}$   $\mu$ Ci/sec. A value of  $1 \times 10^{-6}$   $\mu$ Ci/sec was used to calculate annual release.

TABLE 2-28  
 IODINE-131 RELEASES FROM THE MAIN CONDENSER AIR EJECTORS\*

| FACILITY           | 1972                         |  |                              | 1973                         |  |                              | 1974                         |  |                              |
|--------------------|------------------------------|--|------------------------------|------------------------------|--|------------------------------|------------------------------|--|------------------------------|
|                    | IODINE<br>RELEASE<br>(Ci/yr) | INTEGRATED<br>THERMAL POWER<br>(10 <sup>6</sup> MWd) | Ci/yr<br>10 <sup>6</sup> MWd | IODINE<br>RELEASE<br>(Ci/yr) | INTEGRATED<br>THERMAL POWER<br>(10 <sup>6</sup> MWd) | Ci/yr<br>10 <sup>6</sup> MWd | IODINE<br>RELEASE<br>(Ci/yr) | INTEGRATED<br>THERMAL POWER<br>(10 <sup>6</sup> MWd) | Ci/yr<br>10 <sup>6</sup> MWd |
| Oyster Creek       | 6.3                          | 0.542  | 12.0                         | 6.7                          | 0.453  | 14.0                         | 3.3                          | 0.46   | 7.2                          |
| Nine Mile Point 1  | 0.89                         | 0.417  | 2.0                          | 1.9                          | 0.457  | 4.4                          | 0.7                          | 0.43   | 1.7                          |
| Millstone 1        | 1.2                          | 0.404  | 3.0                          | 0.15                         | 0.248  | 0.6                          | 0.29                         | 0.47   | 0.6                          |
| Dresden 2, 3**     | 5.1                          | 1.05   | 4.6                          | 9.8                          | 1.18   | 8.3                          | 4.0                          | 0.91   | 4.4                          |
| Monticello         | 0.58                         | 0.454  | 1.3                          | 1.2                          | 0.413  | 2.9                          | 5.7                          | 0.34   | 17.0                         |
| Pilgrim 1          |                              |  | ***                          | 0.46                         | 0.523  | 0.9                          | 1.4                          | 0.25   | 5.8                          |
| Quad Cities 1, 2** |                              |  | ***                          | 5.5                          | 1.32   | 4.2                          | 8.2                          | 1.09   | 7.5                          |
| Average            |                              |  | 4.5                          |                              |  | 5.4                          |                              |  | 6.2                          |

Combined average for 1972, 1973, 1974 --  $5.4 \times 10^{-6} \frac{\text{Ci/yr}}{\text{MWd}}$

\* Data from semiannual operating for 1972, 1973, 1974 for facilities listed.

\*\* Two-unit plants with a single stack.

\*\*\* Not included in 1972 average because plants had not achieved a full year of operation.

source term is negligible when clean steam (nonradioactive steam from an auxiliary steam supply system) is used for the gland seal. Because of noble gas removal in the main condenser, iodine removal by the condensate demineralizers, and partitioning in the boiler, steam produced from demineralized condensate is considered to be clean steam. Data in Tables 2-29 and 2-30 show the release of radioactive particulates from the turbine gland seal to be negligible.

TABLE 2-29  
PARTICULATE RELEASE RATE FROM VERMONT YANKEE MECHANICAL  
VACUUM PUMP AND GLAND EXHAUST CONDENSER VENT,  
SHORT-TERM SHUTDOWN

| (10 <sup>-6</sup> $\mu$ Ci/sec) |              |
|---------------------------------|--------------|
| NUCLIDE                         | RELEASE RATE |
| Cs-134                          | 1.2          |
| Cs-136                          | 1.1          |
| Cs-137                          | 4.9          |
| Ba-140                          | 2.9          |

TABLE 2-30  
PARTICULATE RELEASE RATE FROM VERMONT YANKEE VACUUM PUMP AND  
GLAND EXHAUST CONDENSER VENT, REFUELING SHUTDOWN

| (10 <sup>-6</sup> $\mu$ Ci/sec) |              |
|---------------------------------|--------------|
| NUCLIDE                         | RELEASE RATE |
| Cs-134                          | 0.45         |
| Cs-136                          | 0.13         |
| Cs-137                          | 1.0          |
| Ba-140                          | 1.6          |

## 2.2.7 MAIN CONDENSER MECHANICAL VACUUM PUMP

### 2.2.7.1 Parameter

|        |                        |
|--------|------------------------|
| Xe-133 | 2300 Ci/yr per reactor |
| Xe-135 | 350 Ci/yr per reactor  |
| I-131  | 0.03 Ci/yr per reactor |

### 2.2.7.2 Bases

The release values for Xe-133 and Xe-135 were derived from Dresden 1 operating data (Ref. 13). These data indicate that approximately 580 Ci of Xe-133 and 85 Ci of Xe-135 were released with the Dresden 1 mechanical vacuum pump effluent when establishing main condenser vacuum following a plant shutdown. At the point in the fuel cycle where the data were taken, the reactor was operating at an offgas rate of approximately 60,000  $\mu$ Ci/sec.

The release value for iodine-131 was derived from operating data taken at Vermont Yankee (Ref. 6). These data indicate that the release rate for iodine-131 due to mechanical vacuum pump operation during plant startup was approximately 0.09  $\mu$ Ci/sec. Information from reactor operators indicates that the mechanical vacuum pumps are operated periodically during plant shutdowns to maintain a slight condenser vacuum and prevent leakage from the condenser to the turbine building. A total of 24 hours of vacuum pump operation per shutdown was assumed for purposes of calculating iodine releases. The annual release estimates for noble gases and iodine-131 are based on four shutdowns per year. Data in Tables 2-29 and 2-30 show the release of radioactive particulates from the mechanical vacuum pump to be negligible.

## 2.2.8 AIR INLEAKAGE TO THE MAIN CONDENSER

### 2.2.8.1 Parameter

10 ft<sup>3</sup>/min air leakage for each condenser shell of the main condenser.

### 2.2.8.2 Bases

Air leakage to the main condenser is a function of the number of condenser shells and of the station housekeeping performed to reduce leakage and maintain low leakage levels. Operating data for leakage vary widely. For example, Oyster Creek and Dresden 2 air leakage measurements during early operation indicated that leakage rates were 4 to 250 ft<sup>3</sup>/min. Yet, Dresden 1 leakage during full-power operation has been measured to be approximately 3 ft<sup>3</sup>/min.

A large amount of air leakage data has been evaluated for TVA power plants, where leakage measurements have been recorded for several years. Air leakage measurements for six TVA plants, representing more than 40 years of cumulative experience, indicate leakage rates ranging from 4 to 12 ft<sup>3</sup>/min per condenser shell.

An air leakage rate of 10 ft<sup>3</sup>/min per condenser shell is assumed for nuclear power plants under normal operating conditions, including anticipated operational occurrences, averaged over the life of the plant.

## 2.2.9 HOLDUP TIMES FOR CHARCOAL DELAY SYSTEMS

### 2.2.9.1 Parameter

$$T = 0.26 MK/10 N$$

where

K is the dynamic adsorption coefficient, in cm<sup>3</sup>/g (see chart below);

M is the mass of charcoal adsorber, in thousands of pounds;

T is the holdup time, in hours; and

10 N is the number of shells in main condenser times 10 ft<sup>3</sup>/min leakage per shell.

Dynamic adsorption coefficients (in cm<sup>3</sup>/g) are as follows:

|                | OPERATING 77°F<br>DEW POINT 45°F | OPERATING 77°F<br>DEW POINT 0°F | OPERATING 0°F<br>DEW POINT -20°F |
|----------------|----------------------------------|---------------------------------|----------------------------------|
| K <sub>R</sub> | 18.5                             | 25                              | 105                              |
| X <sub>e</sub> | 330                              | 440                             | 2410                             |

### 2.2.9.2 Bases

Charcoal delay systems are evaluated using the above equation and dynamic adsorption coefficients.  $T = MK/10 N$  is a standard equation for the calculation of delay times in charcoal adsorption systems (Ref. 14). The dynamic adsorption coefficients (K values) for X<sub>e</sub> and K<sub>R</sub> are dependent on operating temperature and moisture content (Refs. 15 and 16) in the charcoal, as indicated by the values in the above parameter. The K values represent a composite of data from operating reactor charcoal delay systems (Refs. 17 and 18) and reports concerning charcoal adsorption systems (Refs. 14, 15, 16, 18, 19, 20, and 21).

The factors influencing the selection of values are

- Operational data from KRB\* (K<sub>R</sub> = 29, K<sub>Xe</sub> = 260-430) (Ref. 17) and from KWL\*\* (K<sub>R</sub> = 30, K<sub>Xe</sub> = 50)

\* Kernkraftwerk RWE - Bayernwerk GmbH.

\*\* Kernkraftwerk Lingen GmbH.



2. The effect of temperature on the dynamic adsorption coefficients, indicated in Figure 2-2 (Ref. 15).
3. The effect of moisture on the dynamic adsorption coefficients, shown in Figure 2-3. The affinity of charcoal for moisture, shown in Figure 2-4.
4. The variation in K values between researchers and between the types of charcoal used in these systems (Refs. 15, 22, and 23). Because of the variation in K values based on different types of charcoal and the data reported, average values taken from KRB and KWL data shown in Figure 2-2 are used.

The coefficient 0.26 adjusts the units and was calculated as follows:

$$T(\text{hr}) = \frac{M(10^3 \text{ lb}) K(\text{cm}^3/\text{g})(454 \text{ g/lb})(3.53 \times 10^{-5} \text{ ft}^3/\text{cm}^3)}{(10 \text{ ft}^3/\text{min-shell})(N \text{ shells})(60 \text{ min/hr})}$$

$$T = 0.26 \frac{MK}{10 N}$$

## 2.2.10 DECONTAMINATION FACTORS FOR CRYOGENIC DISTILLATION

### 2.2.10.1 Parameter

| <u>NUCLIDES</u> | <u>DECONTAMINATION FACTOR</u> |
|-----------------|-------------------------------|
| I, Xe           | $1 \times 10^4$               |
| Kr              | $4 \times 10^3$               |

The holdup times are calculated on the basis of gas residence time in the system prior to release.

### 2.2.10.2 Bases

A DF of  $10^4$  for iodine and xenon and a DF of  $4 \times 10^3$  for krypton are used for a cryogenic distillation system. The values are based on data submitted in Amendment 11 to the PSAR for the Hope Creek Nuclear Generating Station, Units 1 and 2 (Ref. 24), which were derived from a proprietary report (Ref. 25) of Air Products and Chemical, Inc. The PSAR states that a maximum of 0.025% Kr (DF =  $4 \times 10^3$ ) and 0.01% Xe (DF =  $10^4$ ) will escape from the system. These decontamination factors are considered reasonable.

## 2.2.11 DECONTAMINATION FACTOR FOR THE CHARCOAL ADSORBERS AND HEPA FILTERS

### 2.2.11.1 Parameter

Use a nominal DF of 10 for iodine removal by charcoal adsorbers subject to applicant's commitment to provide data to support charcoal bed depth for removal efficiency used. Use a DF of 100 for particulate removal by HEPA filtration.

### 2.2.11.2 Bases

Only very limited data are available concerning the removal of iodine at trace concentrations ( $10^{-12} \mu\text{Ci}/\text{cm}^3$ ). The majority of the available data concerning iodine adsorption on activated carbon is addressed toward iodine concentrations that are orders of magnitude higher than the levels of concern in source term evaluations for normal operations.

The iodine removal efficiency of activated carbon varies greatly, even between carbon in the same lot (Ref. 23). This lack of consistency makes the comparison of reported data difficult. The difficulty is compounded by sampling and measurement problems encountered when working with the low iodine concentrations involved. Accordingly, useful information concerning the adsorption of trace quantities of iodine is limited (Ref. 26). In addition, when iodine is present in low concentrations, impurities in the carrier gas may be adsorbed by the charcoal causing competition between the iodine and impurities. Over long periods of time (i.e., several months), such impurities may saturate (poison) the adsorber (Ref. 27), thereby decreasing the apparent iodine adsorption coefficient (Ref. 26) and shortening the time before iodine breakthrough. Channeling through the charcoal bed via passages caused by poor initial bed packing or by settling during use will also decrease adsorber efficiency.




FIGURE 2-2  
 KRYPTON AND XENON K VALUES AS A FUNCTION  
 OF RECIPROCAL TEMPERATURE




FIGURE 2-3  
EFFECT OF MOISTURE CONTENT ON THE  
DYNAMIC ADSORPTION COEFFICIENT




FIGURE 2-4  
CHARCOAL MOISTURE AS A FUNCTION  
OF RELATIVE HUMIDITY

Data being developed for iodine removal at trace levels may be used by applicants to substantiate the iodine removal efficiencies. The DF of 100 for HEPA filters is consistent with expected particulate removal efficiencies under normal operating conditions.

The DF assigned the charcoal adsorbers and HEPA filters considers in-place leak testing to be conducted before use and routinely thereafter, as recommended in ANSI Standard N510, "Testing of Nuclear Air Cleaning Systems" (Ref. 28).

## 2.2.12 LIQUID WASTE INPUTS

### 2.2.12.1 Parameter

The flow rates listed in Table 2-31 are used as inputs to the liquid radwaste treatment system. Flows that cannot be standardized are added to those listed in Table 2-31 to fit an individual application. Disposition of liquid streams to the appropriate collection tanks is based on the applicant's intended method of processing.

### 2.2.12.2 Bases

The liquid waste inputs are based on the values proposed by the ANS 52.3 Working Group draft standard for boiling water reactor liquid radwaste system (Ref. 29). Activity inputs are based on the reactor coolant concentrations proposed by ANS 18.1 Working Group draft standard (Ref. 1) boiling water reactor source terms given in Parameter 2.2.3. The values given are those that were judged to be representative for a typical BWR design.

## 2.2.13 CHEMICAL WASTES FROM REGENERATION OF CONDENSATE DEMINERALIZERS

### 2.2.13.1 Parameter

1. Liquid flows to demineralizer at main steam activity.
2. All nuclides removed from the reactor coolant by the demineralizers are removed from the resins during regeneration.
3. Use a regeneration cycle of 3.5 days times the number of demineralizers. (For systems using ultrasonic resin cleaning, use 7 days times the number of demineralizers.)

### 2.2.13.2 Bases

Operating data from Dresden 2 and 3 indicate that one condensate demineralizer regeneration occurs every 3.5 days (Ref. 30).

All material exchanged or filtered out by the resins between regenerations is contained in the regenerant waste streams; therefore, each regeneration will have approximately the same effectiveness (i.e., each regeneration removes all material collected since the previous regeneration, leaving a constant quantity of material on the resins after regeneration). Regeneration cycles are normally controlled by particulate buildup on resin beds, resulting in high pressure drops across the bed. If ultrasonic resin cleaning is used to remove insolubles between regenerations, the effective bed life between regenerations will be approximately doubled based on preliminary operating data from Dresden and Pilgrim 1 (Refs. 31 and 32).

## 2.2.14 DETERGENT WASTE

### 2.2.14.1 Parameter

For plants with an onsite laundry, use 450 gal/day per reactor of detergent waste and the radionuclide distribution given in Table 2-32 for untreated detergent wastes. The quantities shown in Table 2-32 are added to the adjusted liquid source term. They are reduced for any treatment provided using the appropriate decontamination factors.

### 2.2.14.2 Bases

In the evaluation of liquid radwaste treatment systems, it is assumed that detergent wastes (laundry drains, personnel and equipment decontamination drains, and cask cleaning drains) will total approximately 450 gal/day per reactor. The radionuclide distribution given in Table 2-32 is based on data from Ginna given in Table 2-33.

TABLE 2-31  
BWR LIQUID WASTES

| SOURCE  | FLOW RATE<br>(gal/day)                    |  | FRACTION OF<br>PRIMARY COOLANT<br>ACTIVITY<br>(PCA) |
|---|---|--|---|
|   | PLANT WITH<br>ULTRASONIC RESIN<br>CLEANER | PLANT WITHOUT<br>ULTRASONIC RESIN<br>CLEANER |   |
| <u>Equipment Drains</u>                           |   |  |   |
| Drywell   | 3,400                                     | 3,400  | 1   |
| Containment, auxiliary<br>building, and fuel pool | 3,720                                     | 3,720  | 0.01  |
| Radwaste building                                 | 1,060                                     | 1,060  | 0.01  |
| Turbine building                                  | 2,960                                     | 2,960  | 0.01  |
| Ultrasonic resin cleaner*                         | 15,000                                    | -  | 0.05  |
| Resin rinse                                       | 2,500                                     | 5,000  | 0.002   |
| Subtotal  | 28,640                                    | 16,140                                       | -   |
| <u>Floor Drains</u>                               |   |  |   |
| Drywell   | 700                                       | 700  | 1   |
| Containment, auxiliary<br>building, and fuel pool | 2,000                                     | 2,000  | 0.01  |
| Radwaste building                                 | 1,000                                     | 1,000  | 0.01  |
| Turbine building                                  | 2,000                                     | 2,000  | 0.01  |
| Subtotal  | 5,700                                     | 5,700  | -   |
| <u>Other</u>                                      |   |  |   |
| Cleanup phase separator decant                    | 640                                       | 640  | 0.002   |
| Laundry drains                                    | 450                                       | 450  | **  |
| Lab drains  | 500                                       | 500  | 0.02  |
| Regenerants*                                      | 1,700                                     | 3,400  | ***   |
| Condensate backwash <sup>+</sup>                  | -   | 8,100  | $2 \times 10^{-6}$                                  |
| Chemical lab waste                                | 100                                       | 100  | 0.02  |
| Total   | 37,730                                    | 26,930                                       |   |

- \* - Deep-bed condensate demineralizers.  
 \*\* - Listed in BWR-GALE Code, see Table 2-32.  
 \*\*\* - Calculated by BWR-GALE Code.  
 + - Filter/demineralizer (Powdex) condensate demineralizer.

TABLE 2-32  
 CALCULATED ANNUAL RELEASE OF RADIOACTIVE MATERIALS IN  
 UNTREATED DETERGENT WASTE FROM A BWR AND PWR

| <u>NUCLIDE</u> | <u>Ci/yr</u> |
|----------------|--------------|
| Mn-54          | 0.001        |
| Co-58          | 0.004        |
| Co-60          | 0.009        |
| Zr-95          | 0.0014       |
| Nb-95          | 0.002        |
| Ru-103         | 0.00014      |
| Ru-106         | 0.0024       |
| Ag-110m        | 0.00044      |
| I-131          | 0.0006       |
| Cs-134         | 0.013        |
| Cs-137         | 0.024        |
| Cs-144         | <u>0.005</u> |
| Total          | 0.06         |

TABLE 2-33  
GINNA NUCLEAR POWER STATION  
RADIONUCLIDE DISTRIBUTION OF DETERGENT WASTE  
FOR PERIOD OCTOBER 1972 - JULY 1973 (Ref. 33)

| NUCLIDE               | 10/26/72       | 11/26/72       | 1/01/73       | 2/01/73       | 3/01/73       | 4/01/73       | 5/01/73       | 6/01/73       | 7/01/73       | MONTHLY<br>AVG. | MAX.   | MIN.  |
|-----------------------|----------------|----------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|-----------------|--------|-------|
|                       | to<br>11/25/72 | to<br>12/31/72 | to<br>1/31/73 | to<br>2/28/73 | to<br>3/31/73 | to<br>4/30/73 | to<br>5/31/73 | to<br>6/30/73 | to<br>7/31/73 |                 |        |       |
| Cs-137                | 2.93           | 0.87           | 0.31          | 1.02          | 1.59          | 12.8          | 0.55          | 0.48          | 1.58          | 2.46            | 12.8   | 0.31  |
| Cs-134                | 2.04           | 0.48           | 0.19          | 0.53          | 0.82          | 7.0           | 0.26          | 0.21          | 0.60          | 1.35            | 7.0    | 0.19  |
| Co-60                 | 1.04           | 1.04           | 0.24          | 0.92          | 0.86          | 2.1           | 0.23          | 0.16          | 1.54          | 0.90            | 2.1    | 0.16  |
| Co-58                 | 0.82           | 0.74           | 0.10          | 0.17          | 1.32          | 0.43          | 0.08          | 0.02          | 0.03          | 0.47            | 1.3    | 0.02  |
| Mn-54                 | -              | 0.21           | 0.05          | 0.12          | 0.11          | 0.25          | 0.06          | -             | 0.15          | 0               | 0.25   | 0.05  |
| Zr-95                 | 0.59           | 0.25           | 0.07          | 0.09          | 0.10          | 0.17          | -             | -             | -             | 0.14            | 0.59   | 0.07  |
| Nb-95                 | 0.49           | 0.39           | 0.09          | 0.16          | 0.17          | 0.35          | 0.06          | -             | 0.11          | 0.20            | 0.49   | 0.06  |
| I-131                 | -              | -              | -             | -             | -             | -             | -             | -             | 0.06          | 0.06            | 0.06   | -     |
| Ce-144                | 1.05           | 0.76           | 0.17          | 0.55          | 0.43          | 1.50          | 0.26          | 0.08          | 0.41          | 0.53            | 1.50   | 0.08  |
| Ce-141                | -              | -              | 0.01          | -             | -             | -             | -             | -             | -             | 0.001           | 0.01   | -     |
| Ru-106                | 1.91           | -              | 0.30          | -             | -             | -             | -             | -             | -             | 0.25            | 1.9    | 0.30  |
| Ru-103                | -              | -              | 0.02          | 0.019         | 0.09          | -             | -             | -             | -             | 0.014           | 0.09   | 0.23  |
| Ag-110m               | -              | -              | 0.08          | 0.02          | 0.07          | 0.23          | -             | -             | -             | 0.05            | 0.23   | 0.02  |
| Cr-51                 | -              | -              | -             | -             | -             | -             | -             | -             | -             | -               | -      | -     |
| Mo-99                 | -              | -              | -             | 0.005         | -             | -             | -             | -             | -             | 0.005           | 0.005  | -     |
| Total                 | 10.9           | 4.7            | 1.6           | 3.4           | 5.6           | 24.8          | 1.5           | 0.9           | 4.5           | 6.4             | 24.8   | 0.94  |
| Monthly<br>Flow (gal) | 24,380         | 6,770          | 1,800         | 10,680        | 10,290        | 8,620         | 5,220         | 3,400         | 5,200         | 8,420           | 24,380 | 1,800 |
| Daily<br>Flow (gal)   | -              | -              | -             | -             | -             | -             | -             | -             | -             | 280             | 810    | 60    |

2-35

## 2.2.15 TRITIUM RELEASES

### 2.2.15.1 Parameter

The total tritium release through liquid and vapor pathways is 0.025 Ci/yr per Mwt. The quantity of tritium released through the liquid pathway is based on the calculated volume of liquid released with a tritium concentration of 0.01 uCi/cm<sup>3</sup> up to a maximum of 50% of the total quantity of tritium calculated to be available for release. The remainder of the tritium produced is assumed to be released as a vapor from the plant vent.

### 2.2.15.2 Bases

Table 2-34 lists the measured liquid and gaseous tritium releases from BWRs for 1972, 1973, and 1974. Based on the total tritium release for each facility, the integrated thermal power produced during the year, and a plant capacity factor of 80%, the total annual release is approximately 0.025 Ci/Mwt through the combined liquid and vapor pathways.

The tritium can be released either in liquid wastes or as a vapor with ventilation effluents, the relative amounts being dependent on liquid recycle practices. The tritium concentration assumed for the liquid releases is based on the tritium concentration given in Table 2-2 and is the value recommended by the ANS 18.1 Working Group for BWR source term calculations. This value is based on a review of tritium concentrations in BWR liquid streams (Ref. 1). This evaluation assumes steady-state conditions; i.e., the tritium inventory in the plant remains constant and the tritium entering the reactor water is released through the liquid and vapor pathways.

## 2.2.16 DECONTAMINATION FACTORS FOR DEMINERALIZERS

### 2.2.16.1 Parameter

The following are the expected decontamination factors (DFs) for demineralizers used on process or radwaste streams.

| DEMINERALIZER TYPE                              | DECONTAMINATION FACTORS* |        |                      |
|---|--------------------------|--------|----------------------|
|   | ANION                    | Cs, Rb | OTHER<br>NUCLIDES    |
| <u>Mixed Bed (H<sup>+</sup> OH<sup>-</sup>)</u> |                          |        |                      |
| Reactor coolant                                 | 10                       | 2      | 10                   |
| Condensate                                      | 10                       | 2      | 10                   |
| Clean waste                                     | 10 <sup>2</sup> (10)     | 10(10) | 10 <sup>2</sup> (10) |
| Dirty waste (floor drains)                      | 10 <sup>2</sup> (10)     | 2(10)  | 10 <sup>2</sup> (10) |
| <u>Cation Bed (H<sup>+</sup>)</u>               |                          |        |                      |
| Dirty waste                                     | 1(1)                     | 10(10) | 10 <sup>2</sup> (10) |
| Powdex (any system)                             | 10(10)                   | 2(10)  | 10(10)               |

\* For an evaporator polishing demineralizer or for the second demineralizer in series, the DF is given in the parentheses.

### 2.2.16.2 Bases

The DFs for demineralizers used in the evaluation of liquid waste treatment systems are derived from the findings of a generic review in the nuclear industry by ORNL (Ref. 34). This reference contains operating and theoretical data that provide a basis for the numerical values assigned. The information contained in this report was projected to obtain a performance value expected over an extended period of operation. It was also considered that attempts to extend the service life of the resin will reduce the DFs below those expected under controlled operating conditions.



TABLE 2-34  
TRITIUM RELEASE DATA FROM OPERATING BWRs\*

| REACTOR NAME     | POWER (Mwt) | STARTUP DATE | NUCLEAR THERMAL OUTPUT (10 <sup>6</sup> Mwdt) |      |      | TRITIUM RELEASED (Ci/yr) |                  |      |        |      |       | RATIO OF TOTAL TRITIUM RELEASED (Ci/yr-Mwt at 80% capacity) |       |       |
|------------------|-------------|--------------|---|------|------|--------------------------|------------------|------|--------|------|-------|---|-------|-------|
|                  |             |              | 1972  | 1973 | 1974 | GASEOUS                  |                  |      | LIQUID |      |       | 1972  | 1973  | 1974  |
|                  |             |              |   |      |      | 1972                     | 1973             | 1974 | 1972   | 1973 | 1974  |   |       |       |
| Dresden 1        | 700         | 1959         | 0.16  | 0.10 | 0.05 | **                       | **               | **   | 43     | 18.5 | 18.8  | 0.078   | 0.054 | 0.11  |
| Oyster Creek     | 1930        | 1969         | 0.54  | 0.45 | 0.46 | 0.8                      | 0.4              | 0.4  | 62     | 36.6 | 14.1  | 0.034   | 0.024 | 0.009 |
| Nine Mile Point  | 1850        | 1969         | 0.42  | 0.46 | 0.44 | 18                       | 26.8             | **   | 28     | 46.5 | 18.7  | 0.032   | 0.047 | 0.012 |
| Dresden 2, 3     | 2577        | 1970/71      | 1.04  | 1.18 | 0.91 | 31                       | 10               | 11   | 26     | 26   | 22.6  | 0.016   | 0.009 | 0.011 |
| Millstone 1      | 2011        | 1970         | 0.40  | 0.25 | 0.47 | 4.2                      | 1.7              | 2.8  | 21     | 3.7  | 24.1  | 0.018   | 0.006 | 0.017 |
| Monticello       | 1670        | 1970         | 0.46  | 0.41 | 0.37 | 12                       | **               | **   | ***    | ***  | ***   | 0.008   | -     | -     |
| Vermont Yankee   | 1593        | 1972         | 0.06  | 0.18 | 0.34 | †                        | 1.0              | 0.9  | †      | 0.2  | **    | -   | 0.002 | 0.001 |
| Quad Cities 1, 2 | 2511        | 1971/72      | 0.52  | 1.32 | 1.09 | 4.7                      | 34 <sup>††</sup> | 29   | 4.7    | 24.5 | 34    | 0.005   | 0.013 | 0.017 |
| Pilgrim 1        | 1998        | 1972         | 0.11  | 0.53 | 0.25 | **                       | 14               | 8    | 4.2    | 0.4  | 10.5  | 0.011   | 0.008 | 0.022 |
| Average          |             |              |   |      |      |                          |                  |      |        |      | 0.025 | 0.020   | 0.025 |       |

\* Data from semiannual reports of reactors listed.

\*\* No reported data.

\*\*\* No measurement made.

† Prior to first core refueling.

†† Measured only during the July-December 1973 period.

The following operating conditions were factored into the evaluation of demineralizer performance:

1. In general, the DF for waste treatment systems will vary with the quality of the water to be treated, increasing with increasing activity. Normally, when two demineralizers are used in series, the first demineralizer will have a higher DF than the second. However, the data in Reference 34 indicate that Cs and Rb will be more strongly exchanged in the second demineralizer in series than in the first, since the concentration of preferentially exchanged competing nuclides is reduced.

2. As indicated in Reference 34, compounds of Y, Mo, and Tc form colloidal particles that tend to plate out on solid surfaces. Mechanisms such as plateout on the relatively large surface area provided by demineralizer resin lead to removal of these nuclides to the degree stated above. An analysis of effluent release data indicates that these nuclides, although present in the primary coolant, are normally undetectable in the effluent streams.

## 2.2.17 DECONTAMINATION FACTORS FOR EVAPORATORS

### 2.2.17.1 Parameter

|  | <u>ALL NUCLIDES<br/>EXCEPT IODINE</u> | <u>IODINE</u> |
|--|---------------------------------------|---------------|
| Miscellaneous radwaste evaporator        | $10^4$                                | $10^3$        |
| Separate evaporator for detergent wastes | $10^2$                                | $10^2$        |

### 2.2.17.2 Bases

The decontamination factors for evaporators are derived from the findings of a generic review by ORNL of evaporators used in the nuclear industry (Ref. 35). The principal conclusions reached in the report are

1. Decontamination factors of  $10^4$  can be expected for nonvolatile radioactive nuclides in a single-stage evaporator.
2. Decontamination factors for iodine are a factor of 10 less than the DFs for nonvolatile nuclides.
3. Decontamination factors for wastes containing detergents that tend to foam are a factor of 10 to 100 lower than DFs expected for nonfoaming wastes.

These conclusions have been extended to take into account the following factors:

1. For nonvolatile nuclides in a nonfoaming solution, a DF of  $10^4$  is used.
2. If an evaporator is used for detergent wastes, the DF for the evaporator is reduced to 100 to reflect carryover due to foaming, which will reduce the DF.

## 2.2.18 DECONTAMINATION FACTORS FOR REVERSE OSMOSIS

### 2.2.18.1 Parameter

Overall DF of 30 for laundry wastes and DF of 10 for other liquid radwastes.

### 2.2.18.2 Bases

Reverse osmosis processes are generally run as semibatch processes. The concentrated stream rejected by the membrane is recycled until a desired fraction of the batch is processed through the membrane. The ratio of the volume processed through the membrane to the inlet batch volume is the percent recovery. The DF normally specified for the process is the ratio of nuclide concentrations in the concentrated liquor stream to the concentrations in the effluent stream. This ratio is termed as the membrane DF. For source term calculations, the system DF should be used. The system DF is the ratio of the nuclide concentrations in the feed stream to those in the effluent stream. The relationship between the system DF and the membrane DF is nonlinear and is a function of the percent recovery. This relationship can be expressed as follows:

$$DF_s = \frac{F}{1 - [1 - F]^{1/DF_m}}$$

where

$DF_m$  is the membrane DF;

$DF_s$  is the system DF; and

F is the ratio of effluent volume to inlet volume (percent recovery).

Tables 2-35 through 2-37 give membrane DFs derived from operating data at Point Beach and Ginna (Refs. 36, 37, 38, and 39) and laboratory data on simulated radwaste liquids (Refs. 40 and 41). These data indicate that the overall membrane DF is approximately 100. The percent recovery for liquid radwaste processes using reverse osmosis is expected to be approximately 95%, i.e., 5% concentrated liquor. Using these values in the above equation, the system DF is approximately 30.

$$DF_s = \frac{0.95}{1 - (1 - .95)^{1/100}} = 30$$

The data used were derived mainly from tests on laundry wastes. The DF for other plant wastes, e.g., floor drain wastes, is expected to be lower because of the higher concentrations of iodine and cesium isotopes. As indicated by the data in Tables 2-35 and 2-37, the membrane DF for these isotopes is lower than the average membrane DF used in the evaluation for laundry waste.

#### 2.2.19 GUIDELINES FOR CALCULATING LIQUID WASTE HOLDUP TIMES

The radioactive-decay holdup times applied to the input waste streams are calculated using the following parameters:

1. The collection time for an 80% volume change in the tank, based on the liquid waste flow rates from the source (above values).
2. The total time liquid remains in the system for processing, based on the flow rate through the limiting process step.
3. One-half the time required to empty the final liquid waste sample (test) tank to the environment. This value is based on the maximum rate of the discharge pumps and the nominal tank volume.

The calculated values in 1. and the total of 2. and 3. are used as inputs to the computer code.

#### 2.2.20 ADJUSTMENT TO LIQUID RADWASTE SOURCE TERMS FOR ANTICIPATED OPERATIONAL OCCURRENCES

##### 2.2.20.1 Parameter

1. Increase the calculated source term by 0.15 Ci/yr per reactor using the same isotopic distribution as for the calculated source term to account for anticipated operational occurrences such as operator errors that result in unplanned releases.

2. Assume evaporators to be unavailable for two consecutive days per week for maintenance. If a 2-day holdup capacity or an alternative evaporator is available, no adjustment is needed. If less than a 2-day capacity is available, assume the waste excess is handled as follows:

- a. High-purity or low-purity waste - Processed through an alternative system (if available) using a discharge fraction consistent with the lower purity system.
- b. Chemical Waste - Discharged to the environment to the extent holdup capacity or an alternative evaporator is unavailable.

##### 2.2.20.2 Bases

Reactor operating data over a 2-1/2-year period (January 1973 through June 1975, representing 102 reactor years of operation) were evaluated to determine the frequency and extent of

TABLE 2-35  
 REVERSE OSMOSIS DECONTAMINATION FACTORS, GINNA STATION (REF. 36)

| NUCLIDE                          | CONCENTRATE ACTIVITY<br>( $\mu\text{Ci}/\text{cm}^3$ ) | PRODUCT ACTIVITY<br>( $\mu\text{Ci}/\text{cm}^3$ ) | MEMBRANE DF |
|----------------------------------|--|--|-------------|
| Ce-144                           | $2.88 \times 10^{-4}$                                  | $<2.2 \times 10^{-7}$                              | 1200        |
| Co-58                            | $8.55 \times 10^{-5}$                                  | $<3.4 \times 10^{-8}$                              | 1600        |
| Ru-103                           | $5.83 \times 10^{-5}$                                  | $<5.5 \times 10^{-8}$                              | 1100        |
| Cs-137                           | $4.09 \times 10^{-4}$                                  | $6.6 \times 10^{-6}$                               | 60          |
| Cs-134                           | $2.02 \times 10^{-4}$                                  | $3.2 \times 10^{-6}$                               | 60          |
| Nb-95                            | $5.35 \times 10^{-5}$                                  | $<5.3 \times 10^{-8}$                              | 1000        |
| Zr-95                            | $2.36 \times 10^{-5}$                                  | $<3.7 \times 10^{-8}$                              | 640         |
| Mn-54                            | $8.82 \times 10^{-5}$                                  | $<3.4 \times 10^{-8}$                              | 2600        |
| Co-60                            | $9.62 \times 10^{-4}$                                  | $<8.1 \times 10^{-8}$                              | 12,000      |
| Total isotopic                   | $2.15 \times 10^{-3}$                                  | $9.8 \times 10^{-6}$                               | 220         |
| Gross $\beta$                    | $1.63 \times 10^{-3}$                                  | $1.86 \times 10^{-5}$                              | 88          |
| Total isotopic -<br>Weak $\beta$ | $1.93 \times 10^{-3}$                                  | $9.8 \times 10^{-6}$                               | <u>192</u>  |
| Average*                         |  |  | 200         |

\*The average DF is calculated from the average of the reciprocals of the isotopic DFs.

TABLE 2-36  
 REVERSE OSMOSIS DECONTAMINATION FACTORS, POINT BEACH (REF. 39)

| DATE    | TIME | FEED ACTIVITY<br>( $\mu\text{Ci/ml}$ ) | PRODUCT ACTIVITY<br>( $\mu\text{Ci/ml}$ ) | MEMBRANE<br>DF |
|---------|------|--|---|----------------|
| 6/14/71 | 0840 | $1.1 \times 10^{-5}$                   | $6.8 \times 10^{-7}$                      | 16             |
|         | 1225 | $6.3 \times 10^{-5}$                   | $4.2 \times 10^{-7}$                      | 150            |
|         | 1530 | $8.8 \times 10^{-5}$                   | $3.2 \times 10^{-7}$                      | 280            |
| 6/15/71 | 1030 | $2.7 \times 10^{-4}$                   | $3.1 \times 10^{-6}$                      | 87             |
|         | 1315 | $1.0 \times 10^{-4}$                   | $1.7 \times 10^{-6}$                      | 59             |
|         | 1440 | $1.3 \times 10^{-4}$                   | $1.1 \times 10^{-7}$                      | 1200           |
|         | 1510 | $1.6 \times 10^{-4}$                   | $1.1 \times 10^{-7}$                      | 1500           |
|         | 1530 | $1.8 \times 10^{-4}$                   | $5.7 \times 10^{-7}$                      | 320            |
| Average |      |  |   | 160            |

TABLE 2-37  
 EXPECTED REVERSE OSMOSIS DECONTAMINATION FACTORS  
 FOR SPECIFIC NUCLIDES (REF. 41)

| NUCLIDE                         | CONCENTRATE ACTIVITY<br>( $\mu\text{Ci/ml}$ ) | PRODUCT ACTIVITY<br>( $\mu\text{Ci/ml}$ ) | MEMBRANE<br>DF |
|---------------------------------|---|---|----------------|
| Co-60                           | $2.5 \times 10^{-4}$                          | $5 \times 10^{-7}$                        | 500            |
| Mo-99                           | $3.8 \times 10^{-2}$                          | $1 \times 10^{-3}$                        | 40             |
| I-131, 132,<br>133, 134,<br>135 | $1.2 \times 10^{-1}$                          | $4 \times 10^{-3}$                        | 30             |
| Cs-134, 137                     | $4.3 \times 10^{-2}$                          | $2 \times 10^{-4}$                        | 200            |

unplanned liquid release. During the period evaluated, 27 unplanned liquid releases occurred, 12 due to personnel errors, 7 due to component failures, and the remainder due to miscellaneous causes such as procedural errors and design errors. Table 2-38 summarizes the findings of this evaluation. These findings indicate that approximately 0.15 Ci/yr per reactor is expected to occur as unplanned releases. The tanks most likely to be released are the low-level sample (test) tanks, and therefore the calculated liquid source term radionuclide distribution is applied to the releases.

TABLE 2-38  
FREQUENCY AND EXTENT OF UNPLANNED LIQUID RADWASTE  
RELEASES FROM OPERATING PLANTS

| <u>UNPLANNED LIQUID RELEASES</u>   | <u>FREQUENCY/VOLUME</u> |
|--|-------------------------|
| Total number   | 27                      |
| Approximate activity (Ci)  | 14.0                    |
| Approximate volume (gal)   | $2.0 \times 10^5$       |
| Fraction of cumulative occurrence per reactor year (releases/reactor year) | 0.3                     |
| Activity per release (Ci/release)  | 0.5                     |
| Activity release per reactor year (Ci/reactor year)                        | 0.14                    |
| Volume of release per reactor year (gal/reactor year)                      | $2.0 \times 10^3$       |

Operating experience has shown the availability for evaporators in waste treatment systems to be in the range of 60 to 80%. Unavailability is attributed to scaling, fouling of surfaces, instrumentation failures, corrosion, and occasional upsets resulting in high carryovers requiring system cleaning. A value of two consecutive days unavailability per week was chosen as being representative of operating experience. For systems having sufficient tank capacity to collect and hold wastes during the assumed 2-day/week outage, no adjustments are required for the source term. If less capacity is available, the difference between the waste expected during two days of normal operation and the available holdup capacity is assumed to follow an alternative route for processing. Since processing through an alternative route implies mixing of wastes having different purities and different dispositions after treatment, it is assumed that the fraction of waste discharged following processing will be that normally assumed for the less pure of the two waste streams combined.

Since chemical and regenerant wastes are not amenable to processes other than evaporation, it is assumed that unless an alternative evaporation route is available, chemical and regenerant wastes in excess of the storage capacity are discharged without treatment.

#### 2.2.21 GUIDELINES FOR ROUNDING OFF NUMERICAL VALUES

In calculating the estimated annual release of radioactive materials in liquid and gaseous wastes, round off all numerical values to two significant figures.

#### 2.2.22 CARBON-14 RELEASES

##### 2.2.22.1 Parameter

The annual quantity of carbon-14 released from a boiling water reactor is 9.5 Ci/yr. It is assumed that the carbon-14 reacts with oxygen in the reactor water and behaves like a noble gas fission product; thus all carbon-14 produced will be released through the main condenser offgas system.

#### 2.2.22.2 Bases

The principal source of carbon-14 is the thermal neutron reaction with oxygen-17 in the reactor coolant. The production rate of carbon-14 from oxygen-17 is given by the equation:

$$Q = N_o \sigma_o \phi m t p s \quad (\text{Ci/yr})$$

where

- m is the  $3.9 \times 10^4$  kg, mass of water in reactor core;
- $N_o$  is the  $1.3 \times 10^{22}$  atoms O-17/kg natural water;
- p is the 0.08, plant capacity factor;
- s is the  $1.03 \times 10^{-22}$  Ci/atom, specific activity for C-14;
- t is the  $3.15 \times 10^7$  sec/yr, maximum irradiation time per year;
- $\sigma_o$  is the  $2.4 \times 10^{-25}$  cm<sup>2</sup>, thermal neutron cross section for O-17; and
- $\phi$  is the  $3 \times 10^{13}$  neutrons/cm<sup>2</sup>-sec, average thermal neutron flux.

Based on the above parameters,  $Q = 9.5$  Ci/yr.

Carbon-14 can also be produced by neutron activation of nitrogen-14 dissolved in the reactor coolant and present in air in the drywell. These sources contribute a small fraction of a curie per year to the annual production of carbon-14 due to the low concentration of nitrogen-14 in the reactor coolant (less than 1 ppm by weight), and the low neutron flux in the drywell (approximately  $4 \times 10^8$  neutrons/cm<sup>2</sup>-sec).

The annual release of 9.5 Ci of carbon-14 is in good agreement with measurements at Nine Mile Point 1 reported by Kunz et al. (Ref. 42), who found that 8 curies per year of carbon-14 were released, principally in the form of CO<sub>2</sub>.

#### 2.2.23 ARGON-41 RELEASES

##### 2.2.23.1 Parameter

The annual quantity of argon-41 released from a boiling water reactor is 25 Ci/yr. The argon-41 is released to the environment via the containment vent when the drywell is vented or purged.

##### 2.2.23.2 Bases

Argon-41 is formed by neutron activation of stable naturally occurring argon-40 in the drywell air surrounding the reactor vessel. The argon-41 is released to the environment when the drywell is vented or purged. BWRs that have a common stack for the release from the main condenser offgas system and the containment purge do not report argon-41 releases because the argon-41 is a small fraction of the total release from the stack. Monticello reported that 50 curies of argon-41 were released in 1973 and that the isotope was not detected in effluents in 1974. Browns Ferry 1 reported 19.2 curies of argon-41 released in 1974. Based on these data, the argon-41 release is estimated to be 25 curies per year.

CHAPTER 3. INPUT FORMAT, SAMPLE PROBLEM, AND  
FORTRAN LISTING OF THE BWR-GALE CODE

3.1 INTRODUCTION

This chapter contains additional information for using the BWR-GALE Code. Chapter 1 of this report described the entries required to be entered on input data cards, and Section 3.2 of this chapter contains sample input data sheets to orient the user in making the entries described in Chapter 1.

Section 3.3 of this chapter contains a listing of the input data cards for a sample problem and the resultant output for that sample problem. Section 3.4 contains a discussion of the nuclear data library used and a FORTRAN listing of the BWR-GALE Code.

3.2 INPUT DATA SHEETS

The following pages show (1) the form in which data should be entered on input data sheets and (2) a sample completed sheet.



IBM

FORTRAN Coding Form

GX28-7327-6 U/M 050\*\*  
Printed in U.S.A.

|            |                          |      |           |                       |         |  |  |  |  |  |                      |        |
|------------|--------------------------|------|-----------|-----------------------|---------|--|--|--|--|--|----------------------|--------|
| PROGRAMMER | Input Data BWR-GALE Code | DATE | July 1975 | PUNCHING INSTRUCTIONS | GRAPHIC |  |  |  |  |  | PAGE                 | 1 of 2 |
|            |                          |      |           |                       | PUNCH   |  |  |  |  |  | CARD SELECTED NUMBER |        |

3-2

| CARD    | STATEMENT NUMBER | COLUMN | FORTRAN STATEMENT |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |       |     | IDENTIFICATION |  |
|---------|------------------|--------|-------------------|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|-------|-----|----------------|--|
|         |                  |        |                   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |       |     | SEQUENCE       |  |
| CARD 1  |                  |        | NAME              | NAME OF REACTOR [ ]                                  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  | TYPE= | BWR |                |  |
| CARD 2  |                  |        | POWER             | THERMAL POWER LEVEL (MEGAWATTS)                      |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  | [ ]   |     |                |  |
| CARD 3  |                  |        | GTD               | TOTAL STEAM FLOW (MILLION LBS/HR)                    |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  | [ ]   |     |                |  |
| CARD 4  |                  |        | WLIQ              | MASS OF WATER IN REACTOR VESSEL (MILLION LBS)        |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  | [ ]   |     |                |  |
| CARD 5  |                  |        | GDE               | CLEAN-UP DEMINERALIZER FLOW (MILLION LBS/HR)         |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  | [ ]   |     |                |  |
| CARD 6  |                  |        | REGEN             | CONDENSATE DEMINERALIZER REGENERATION TIME (DAYS)    |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  | [ ]   |     |                |  |
| CARD 7  |                  |        | FECDM             | FRACTION FEEDWATER THROUGH CONDENSATE DEMIN          |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  | [ ]   |     |                |  |
| CARD 8  |                  |        | DILUT             | RADWASTE DILUTION FLOW (THOUSAND GPM)                |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  | [ ]   |     |                |  |
| CARD 9  |                  |        |                   | HIGH PURITY WASTE INPUT [ ] GPD AT [ ] PCA           |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |       |     |                |  |
| CARD 10 |                  |        |                   | DFI=[ ] DFCS=[ ] DFO = [ ]                           |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |       |     |                |  |
| CARD 11 |                  |        |                   | COLLECTION [ ] DAYS PROCESS [ ] DAYS FRACT DISCH [ ] |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |       |     |                |  |
| CARD 12 |                  |        |                   | LOW PURITY WASTE INPUT [ ] GPD AT [ ] PCA            |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |       |     |                |  |
| CARD 13 |                  |        |                   | DFI=[ ] DFCS = [ ] DFO = [ ]                         |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |       |     |                |  |
| CARD 14 |                  |        |                   | COLLECTION [ ] DAYS PROCESS [ ] DAYS FRACT DISCH [ ] |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |       |     |                |  |
| CARD 15 |                  |        |                   | CHEMICAL WASTE INPUT [ ] GPD AT [ ] PCA              |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |       |     |                |  |
| CARD 16 |                  |        |                   | DFI=[ ] DFCS = [ ] DFO = [ ]                         |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |       |     |                |  |
| CARD 17 |                  |        |                   | COLLECTION [ ] DAYS PROCESS [ ] DAYS FRACT DISCH [ ] |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |       |     |                |  |
| CARD 18 |                  |        |                   | REGENERANT SOLTNS WASTE INPUT - GPD                  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  | [ ]   |     |                |  |
| CARD 19 |                  |        |                   | DFI=[ ] DFCS = [ ] DFO = [ ]                         |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |       |     |                |  |
| CARD 20 |                  |        |                   | COLLECTION [ ] DAYS PROCESS [ ] DAYS FRACT DISCH [ ] |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |       |     |                |  |
| CARD 21 |                  |        | GGS               | GLAND SEAL STEAM FLOW (THOUSAND LBS/HR)              |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  | [ ]   |     |                |  |
| CARD 22 |                  |        | WSTE              | MASS OF STEAM IN REACTOR VESSEL (MILLION LBS)        |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  | [ ]   |     |                |  |
| CARD 23 |                  |        | TIM3              | GLAND SEAL HOLD UP TIME (HOURS)                      |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  | [ ]   |     |                |  |
| CARD 24 |                  |        | TIM4              | AIR EJECTOR OFFGAS HOLD UP TIME (HOURS)              |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  | [ ]   |     |                |  |

\*A standard card form, IBM electric 886137, is available for punching statements from this form. \*\*Number of forms per pad may vary slightly.



### 3.3 SAMPLE PROBLEM - INPUT AND OUTPUT

The following pages show printouts of the input and output for a sample problem using the BWR-GALE Code.

| CARD    | NAME   | NAME OF REACTOR  | SAMPLE RFR CASE | TYPE = | BAR   |
|---------|--------|--|-----------------|--------|-------|
| CARD 2  | PWRTH  | THERMAL POWER LEVEL (MEGAWATTS)                              |                 |        | 3000. |
| CARD 3  | GTO    | TOTAL STEAM FLOW (MILLION LBS/HR)                            |                 |        | 15.   |
| CARD 4  | KLIG   | MASS OF WATER IN REACTOR VESSEL (MILLION LBS)                |                 |        | 0.38  |
| CARD 5  | GDE    | CLEAN-UP DEMINERALIZER FLOW (MILLION LBS/HR)                 |                 |        | 0.15  |
| CARD 6  | REGENT | CONDENSATE DEMINERALIZER REGENERATION TIME (DAYS)            |                 |        | 56.   |
| CARD 7  | FFCDM  | FRACTION FEED WATER THROUGH CONDENSATE DEMIN                 |                 |        | 1.    |
| CARD 8  | MLUT   | RADWASTE DILUTION FLOW (THOUSAND GPM)                        |                 |        | 3.    |
| CARD 9  |        | HIGH PURITY WASTE INPUT 28500. GPD AT .15 PCA                |                 |        |       |
| CARD 10 |        | DFI= 1.0E03DFCS= 1.0E02DFD = 1.0E03                          |                 |        |       |
| CARD 11 |        | COLLECTION 1. DAYS PROCESS .07 DAYS FRACT DISCH              |                 |        | 0.01  |
| CARD 12 |        | LOW PURITY WASTE INPUT 5700. GPD AT .15                      |                 |        |       |
| CARD 13 |        | DFI= 1.0E03DFCS= 1.0E04DFD = 1.0E04                          |                 |        |       |
| CARD 14 |        | COLLECTION 3.1 DAYS PROCESS .6 DAYS FRACT DISCH              |                 |        | 1.    |
| CARD 15 |        | CHEMICAL WASTE INPUT 600. GPD AT .02 PCA                     |                 |        |       |
| CARD 16 |        | DFI= 1.0E03DFCS= 1.0E04DFD = 1.0E04                          |                 |        |       |
| CARD 17 |        | COLLECTION 3.1 DAYS PROCESS .6 DAYS FRACT DISCH              |                 |        | 1.    |
| CARD 18 |        | REGENERATION SOLVNS INPUT GPD                                |                 |        | 1700. |
| CARD 19 |        | DFI= 1.0E03DFCS= 1.0E05DFD = 1.0E05                          |                 |        |       |
| CARD 20 |        | COLLECTION 9.4 DAYS PROCESS .44 DAYS FRACT DISCH             |                 |        | 0.1   |
| CARD 21 | GGS    | GLAND SEAL STEAM FLOW (THOUSAND LBS/HR)                      |                 |        | 0.0   |
| CARD 22 | WSTE   | MASS OF STEAM IN REACTOR VESSEL (MILLION LBS)                |                 |        | .021  |
| CARD 23 | TIM3   | GLAND SEAL HOLDUP TIME (HOURS)                               |                 |        |       |
| CARD 24 | TIM4   | AIR EJECTOR OFFGAS HOLDUP TIME (HOURS)                       |                 |        | .167  |
| CARD 25 |        | CONTAINMENT BLDG CHARCOAL?YES HEPA?YES                       |                 |        |       |
| CARD 26 |        | TURBINE BLDG CHARCOAL? HEPA? CLEAN STEAM?YES                 |                 |        |       |
| CARD 27 | FTL3   | GLAND SEAL VENT, IDLINE PF                                   |                 |        | 1.0   |
| CARD 28 | FTL4   | AIR EJECTOR OFFGAS TOTINE PF                                 |                 |        |       |
| CARD 29 |        | AUXILIARY BLDG CHARCOAL? HEPA?                               |                 |        |       |
| CARD 30 |        | RADWASTE BLDG CHARCOAL? HEPA?YES                             |                 |        |       |
| CARD 31 | KCHAR  | CHARCOAL DELAY SYSTEM DENO. 1=YES, 2=CRYOGENIC DISTILL       |                 |        | 1     |
| CARD 32 | KKR    | KRYPTON DYNAMIC ADSORPTION COEFFICIENT (CM <sup>3</sup> /GM) |                 |        | 105.  |
| CARD 33 | KXE    | XENON DYNAMIC ADSORPTION COEFFICIENT (CM <sup>3</sup> /GM)   |                 |        | 2410. |
| CARD 34 | KND    | NUMBER OF MAIN CONDENSER SHELLS                              |                 |        | 3.    |
| CARD 35 | KMASS  | MASS OF CHARCOAL (THOUSAND LBS)                              |                 |        | 98.   |
| CARD 36 | PFLAUN | DETERGENT WASTE DECONTAMINATION FACTOR                       |                 |        | 1.0   |

THERMAL POWER LEVEL (MEGAWATTS) 3400.00000  
 PLANT CAPACITY FACTOR 0.80  
 TOTAL STEAM FLOW (MILLION LBS/HR) 15.00000  
 MASS WATER IN REACTOR VESSEL (MILLION LBS) 0.38000  
 CLIP DEMINERALIZER FLOW (MILLION LBS/HR) 0.13000  
 CONDENSATE DEMINERALIZER REGENERATION TIME (DAYS) 56.00000  
 FRACTION FEED WATER THROUGH CONDENSATE DEMIN 1.00000  
 RADWASTE DILUTION FLOW (THOUSAND GPM) 3.00000

SAMPLE BWR CASE

| STREAM            | FLOW RATE (GAL/DAY) | FRACTION OF PCA DISCHARGED | FRACTION COLLECTED | COLLECTION TIME (DAYS) | DECAY TIME (DAYS) | DECONTAMINATION FACTORS    |
|-------------------|---------------------|----------------------------|--------------------|------------------------|-------------------|----------------------------|
|                   |                     |                            |                    |                        |                   | I CS OTHERS                |
| HIGH PURITY WASTE | 2.85E 04            | 0.150                      | 0.010              | 1.000                  | 0.070             | 1.00E 03 1.00E 02 1.00E 03 |
| LOW PURITY WASTE  | 5.70E 03            | 0.130                      | 1.000              | 3.100                  | 0.600             | 1.00E 03 1.00E 04 1.00E 04 |
| CHEMICAL WASTE    | 6.00E 02            | 0.020                      | 1.000              | 3.100                  | 0.600             | 1.00E 03 1.00E 04 1.00E 04 |
| REGENERANT SOLS   | 1.70E 03            | 0.100                      | 0.100              | 9.400                  | 0.440             | 1.00E 04 1.00E 05 1.00E 05 |

GASEOUS WASTE INPUTS

GLAND SEAL STEAM FLOW (THOUSAND LBS/HR) 0.0  
 MASS OF STEAM IN REACTOR VESSEL (MILLION LBS) 0.02100  
 GLAND SEAL HOLDUP TIME (HOURS) 0.0  
 AIR EJECTOR OFFGAS HOLDUP TIME (HOURS) 0.16700  
 CONTAINMENT BLDG IODINE RELEASE FRACTION 0.10000  
 PARTICULATE RELEASE FRACTION 0.01000  
 TURBINE BLDG IODINE RELEASE FRACTION 1.00000  
 PARTICULATE RELEASE FRACTION 0.20000  
 GLAND SEAL VENT, IODINE PF 0.0  
 AIR EJECTOR OFFGAS IODINE PF 0.0  
 AUXILIARY BLDG IODINE RELEASE FRACTION 1.00000  
 PARTICULATE RELEASE FRACTION 1.00000  
 RADWASTE BLDG IODINE RELEASE FRACTION 1.00000  
 PARTICULATE RELEASE FRACTION 0.01000  
 THERE IS A CHARCOAL DELAY SYSTEM  
 KRYPTON HOLDUP TIME (DAYS) 1.85500  
 XENON HOLDUP TIME (DAYS) 92.57663  
 KRYPTON DYNAMIC ADSORPTION COEFFICIENT (CM3/GM) 105.00000  
 XENON DYNAMIC ADSORPTION COEFFICIENT (CM3/GM) 2410.00000  
 NUMBER OF MAIN CONDENSER SHELLS 3.00000  
 MASS OF CHARCOAL (THOUSAND LBS) 48.00000

SAMPLE BHR CASE

GASEOUS RELEASE RATE  
(CURIES PER YEAR)

| NUCLIDE                 | COOLANT CONC.<br>(MICROCURIERS/G) | CONTAINMENT<br>BLDG. | TURBINE<br>BLDG. | AUXILIARY<br>BLDG. | RADWASTE<br>BLDG. | GLAND<br>SEAL | AIR<br>EJECTOR | MECH VAC<br>PUMP | TOTAL   |
|-------------------------|-----------------------------------|----------------------|------------------|--------------------|-------------------|---------------|----------------|------------------|---------|
| KR-83M                  | 1,100E+03                         | 0,0                  | 0,0              | 0,0                | 0,0               | 0,0           | 0,0            | 0,0              | 0,0     |
| KR-85M                  | 1,900E+03                         | 3,0E 00              | 1,4E 01          | 3,0E 00            | 0,0               | 0,0           | 8,0E 01        | 0,0              | 1,0E 02 |
| KR-85                   | 6,000E+06                         | 0,0                  | 0,0              | 0,0                | 0,0               | 0,0           | 2,9E 02        | 0,0              | 2,9E 02 |
| KR-87                   | 6,600E+03                         | 3,0E 00              | 2,6E 01          | 3,0E 00            | 0,0               | 0,0           | 0,0            | 0,0              | 3,2E 01 |
| KR-88                   | 6,600E+03                         | 3,0E 00              | 4,6E 01          | 3,0E 00            | 0,0               | 0,0           | 5,0E 00        | 0,0              | 5,7E 01 |
| KR-89                   | 4,100E+02                         | 0,0                  | 0,0              | 0,0                | 0,0               | 0,0           | 0,0            | 0,0              | 0,0     |
| XE-131M                 | 4,700E+06                         | 0,0                  | 0,0              | 0,0                | 0,0               | 0,0           | 1,8E 01        | 0,0              | 1,8E 01 |
| XE-133M                 | 9,000E+05                         | 0,0                  | 0,0              | 0,0                | 0,0               | 0,0           | 0,0            | 0,0              | 0,0     |
| XE-133                  | 2,600E+03                         | 6,6E 01              | 5,0E 01          | 6,6E 01            | 1,0E 01           | 0,0           | 4,6E 02        | 2,3E 03          | 3,0E 03 |
| XE-135M                 | 8,400E+04                         | 4,6E 01              | 1,3E 02          | 4,6E 01            | 0,0               | 0,0           | 0,0            | 0,0              | 2,2E 02 |
| XE-135                  | 7,200E+03                         | 3,4E 01              | 1,3E 02          | 3,4E 01            | 4,5E 01           | 0,0           | 0,0            | 3,5E 02          | 5,9E 02 |
| XE-137                  | 4,700E+02                         | 0,0                  | 0,0              | 0,0                | 0,0               | 0,0           | 0,0            | 0,0              | 0,0     |
| XE-138                  | 2,800E+02                         | 7,0E 00              | 2,9E 02          | 7,0E 00            | 0,0               | 0,0           | 0,0            | 0,0              | 3,0E 02 |
| TOTAL NOBLE GASES       |                                   |                      |                  |                    |                   |               |                |                  |         |
| I-131                   | 5,000E+03                         | 1,7E+02              | 3,8E+02          | 1,7E+01            | 5,9E+02           | 0,0           | 0,0            | 3,0E+02          | 3,0E+01 |
| I-133                   | 2,000E+02                         | 6,8E+02              | 1,5E+01          | 6,8E+01            | 1,8E+01           | 0,0           | 0,0            | 0,0              | 1,1E 00 |
| TRITIUM GASEOUS RELEASE |                                   |                      |                  |                    |                   |               |                |                  |         |

43 CURIES/YR

0,0 APPEARING IN THE TABLE INDICATES RELEASE IS LESS THAN 1,0 CI/YR FOR NOBLE GAS, 0,0001 CI/YR FOR I

SAMPLE BWR CASE

AIRBORNE PARTICULATE RELEASE RATE

(CURIES PER YEAR)

| NUCLIDE | CONTAINMENT<br>BLDG. | TURBINE<br>BLDG. | AUXILIARY<br>BLDG. | RADWASTE<br>BLDG. | MECH VAC.<br>PUMP | TOTAL   |
|---------|----------------------|------------------|--------------------|-------------------|-------------------|---------|
| CR-51   | 3.0E+06              | 4.6E+03          | 3.0E+04            | 9.0E+05           | 0.0               | 3.0E+03 |
| MN-54   | 3.0E+05              | 1.2E+04          | 3.0E+03            | 3.0E+04           | 0.0               | 3.0E+03 |
| FE-59   | 4.0E+06              | 1.0E+04          | 4.0E+04            | 1.5E+04           | 0.0               | 6.5E+04 |
| CO-58   | 6.0E+06              | 1.2E+04          | 6.0E+04            | 4.5E+05           | 0.0               | 7.7E+04 |
| CO-60   | 1.0E+04              | 4.0E+04          | 1.0E+02            | 9.0E+04           | 0.0               | 1.1E+02 |
| ZN-65   | 2.0E+05              | 4.0E+05          | 2.0E+03            | 1.5E+05           | 0.0               | 2.1E+03 |
| SR-89   | 9.0E+07              | 1.2E+03          | 9.0E+05            | 4.5E+06           | 0.0               | 1.5E+03 |
| SR-90   | 5.0E+08              | 4.0E+06          | 5.0E+06            | 3.0E+06           | 0.0               | 1.2E+05 |
| ZR-95   | 4.0E+06              | 2.0E+05          | 4.0E+04            | 5.0E+07           | 0.0               | 4.2E+04 |
| SB-124  | 2.0E+06              | 6.0E+05          | 2.0E+04            | 5.0E+07           | 0.0               | 2.6E+04 |
| CS-134  | 4.0E+05              | 6.0E+05          | 4.0E+03            | 4.5E+05           | 3.0E+06           | 4.1E+03 |
| CS-136  | 3.0E+06              | 1.0E+05          | 3.0E+04            | 4.5E+06           | 2.0E+06           | 3.2E+04 |
| CS-137  | 5.5E+05              | 1.2E+04          | 5.5E+03            | 9.0E+05           | 1.0E+05           | 5.6E+03 |
| BK-140  | 4.0E+06              | 2.2E+03          | 4.0E+04            | 1.0E+06           | 1.1E+05           | 2.6E+03 |
| CE-141  | 1.0E+06              | 1.2E+04          | 1.0E+04            | 2.6E+05           | 0.0               | 2.5E+04 |



LIQUID EFFLUENTS

SAMPLE BWR CASE

| NUCLIDE | HAZ-LIFE<br>(DAYS) | CORROSION<br>AND<br>ACTIVATION PRODUCTS | CONCENTRATION                          |                                       |                      | ANNUAL RELEASES TO DISCHARGE CANAL |         |         | ADJUSTED<br>TOTAL<br>(CI/YR) | DETERGENT<br>WASTES<br>(CI/YR) | TOTAL<br>(CI/YR) |
|---------|--------------------|---|--|---------------------------------------|----------------------|------------------------------------|---------|---------|------------------------------|--------------------------------|------------------|
|         |                    |   | IN PRIMARY<br>COOLANT<br>(MICRO CI/ML) | HIGH PURITY<br>LOI PURITY<br>(CURIES) | CHEMICAL<br>(CURIES) | TOTAL LWS<br>(CURIES)              |         |         |                              |                                |                  |
| NA 24   | 6.25E-01           |   | 0.00030                                | 0.00013                               | 0.00000              | 0.00043                            | 0.00310 | 0.0     | 0.00310                      |                                |                  |
| P 32    | 1.35E-01           |   | 0.00001                                | 0.00002                               | 0.00000              | 0.00003                            | 0.00024 | 0.0     | 0.00024                      |                                |                  |
| CR 51   | 2.78E-01           |   | 0.00029                                | 0.00049                               | 0.00000              | 0.00077                            | 0.00680 | 0.0     | 0.00680                      |                                |                  |
| MN 54   | 3.03E-02           |   | 0.00000                                | 0.00001                               | 0.00000              | 0.00001                            | 0.00110 | 0.00100 | 0.00110                      |                                |                  |
| FE 55   | 1.07E-01           |   | 0.00029                                | 0.00001                               | 0.00000              | 0.00030                            | 0.00214 | 0.0     | 0.00210                      |                                |                  |
| FE 59   | 9.50E-02           |   | 0.00006                                | 0.00010                               | 0.00008              | 0.00024                            | 0.00170 | 0.0     | 0.00170                      |                                |                  |
| CO 58   | 4.50E-01           |   | 0.00000                                | 0.00000                               | 0.00000              | 0.00001                            | 0.00004 | 0.0     | 0.00004                      |                                |                  |
| CO 60   | 7.13E-01           |   | 0.00001                                | 0.00002                               | 0.00001              | 0.00004                            | 0.00031 | 0.00400 | 0.00430                      |                                |                  |
| NI 65   | 1.92E-03           |   | 0.00002                                | 0.00003                               | 0.00000              | 0.00010                            | 0.00058 | 0.00870 | 0.00940                      |                                |                  |
| CU 64   | 3.02E-04           |   | 0.00000                                | 0.00000                               | 0.00000              | 0.00000                            | 0.00001 | 0.0     | 0.00001                      |                                |                  |
| CU 64   | 3.02E-01           |   | 0.00000                                | 0.00034                               | 0.00001              | 0.00126                            | 0.00900 | 0.0     | 0.00900                      |                                |                  |
| ZN 65   | 2.45E-02           |   | 0.00001                                | 0.00002                               | 0.00001              | 0.00005                            | 0.00033 | 0.0     | 0.00033                      |                                |                  |
| ZN 69M  | 5.75E-01           |   | 0.00006                                | 0.00003                               | 0.00000              | 0.00009                            | 0.00064 | 0.0     | 0.00064                      |                                |                  |
| ZN 69   | 3.44E-02           |   | 0.00007                                | 0.00003                               | 0.00000              | 0.00009                            | 0.00068 | 0.0     | 0.00068                      |                                |                  |
| ZR 95   | 4.50E-01           |   | 0.0                                    | 0.0                                   | 0.0                  | 0.0                                | 0.0140  | 0.00140 | 0.0140                       |                                |                  |
| NB 95   | 3.50E-01           |   | 0.0                                    | 0.0                                   | 0.0                  | 0.0                                | 0.00200 | 0.00200 | 0.00200                      |                                |                  |
| X187    | 9.46E-01           |   | 0.00001                                | 0.00001                               | 0.00000              | 0.00002                            | 0.00015 | 0.0     | 0.00015                      |                                |                  |
| NP239   | 2.35E-00           |   | 0.00035                                | 0.00039                               | 0.00001              | 0.00075                            | 0.00539 | 0.0     | 0.00540                      |                                |                  |

| FISSION PRODUCTS | HAZ-LIFE<br>(DAYS) | CORROSION<br>AND<br>ACTIVATION PRODUCTS | CONCENTRATION                          |                                       |                      | ANNUAL RELEASES TO DISCHARGE CANAL |         |         | ADJUSTED<br>TOTAL<br>(CI/YR) | DETERGENT<br>WASTES<br>(CI/YR) | TOTAL<br>(CI/YR) |
|------------------|--------------------|---|--|---------------------------------------|----------------------|------------------------------------|---------|---------|------------------------------|--------------------------------|------------------|
|                  |                    |   | IN PRIMARY<br>COOLANT<br>(MICRO CI/ML) | HIGH PURITY<br>LOI PURITY<br>(CURIES) | CHEMICAL<br>(CURIES) | TOTAL LWS<br>(CURIES)              |         |         |                              |                                |                  |
| SR 83            | 1.00E-01           |   | 0.00002                                | 0.00000                               | 0.00000              | 0.00002                            | 0.00013 | 0.0     | 0.00013                      |                                |                  |
| SR 89            | 5.20E-01           |   | 0.00001                                | 0.00001                               | 0.00000              | 0.00002                            | 0.00015 | 0.0     | 0.00015                      |                                |                  |
| SR 91            | 4.03E-01           |   | 0.00010                                | 0.00003                               | 0.00000              | 0.00013                            | 0.00092 | 0.0     | 0.00092                      |                                |                  |
| Y 91M            | 3.17E-02           |   | 0.00006                                | 0.00002                               | 0.00000              | 0.00008                            | 0.00058 | 0.0     | 0.00058                      |                                |                  |
| Y 91             | 5.68E-01           |   | 0.00000                                | 0.00000                               | 0.00000              | 0.00000                            | 0.00010 | 0.0     | 0.00010                      |                                |                  |
| SR 92            | 1.13E-01           |   | 0.00006                                | 0.00000                               | 0.00000              | 0.00006                            | 0.00046 | 0.0     | 0.00046                      |                                |                  |
| Y 92             | 1.13E-01           |   | 0.00014                                | 0.00001                               | 0.00000              | 0.00015                            | 0.00111 | 0.0     | 0.00110                      |                                |                  |
| Y 93             | 4.25E-01           |   | 0.00010                                | 0.00003                               | 0.00000              | 0.00014                            | 0.00097 | 0.0     | 0.00097                      |                                |                  |
| ZR 95            | 4.50E-01           |   | 0.00000                                | 0.00000                               | 0.00000              | 0.00000                            | 0.00001 | 0.0     | 0.00001                      |                                |                  |
| NB 95            | 3.50E-01           |   | 0.00000                                | 0.00000                               | 0.00000              | 0.00000                            | 0.00001 | 0.0     | 0.00001                      |                                |                  |
| NB 98            | 3.54E-02           |   | 0.00000                                | 0.00000                               | 0.00000              | 0.00000                            | 0.00002 | 0.0     | 0.00002                      |                                |                  |
| MO 99            | 2.79E-00           |   | 0.00010                                | 0.00012                               | 0.00000              | 0.00023                            | 0.00164 | 0.0     | 0.00160                      |                                |                  |
| TC 99M           | 2.50E-01           |   | 0.00040                                | 0.00016                               | 0.00000              | 0.00056                            | 0.00401 | 0.0     | 0.00400                      |                                |                  |
| RU103            | 3.06E-01           |   | 0.00000                                | 0.00000                               | 0.00000              | 0.00000                            | 0.00003 | 0.00014 | 0.00017                      |                                |                  |
| RH104M           | 3.06E-02           |   | 0.00000                                | 0.00000                               | 0.00000              | 0.00000                            | 0.00003 | 0.0     | 0.00003                      |                                |                  |
| TC109            | 1.25E-02           |   | 0.00000                                | 0.00000                               | 0.00000              | 0.00000                            | 0.00001 | 0.0     | 0.00001                      |                                |                  |
| RU105            | 1.65E-01           |   | 0.00002                                | 0.00000                               | 0.00000              | 0.00003                            | 0.00018 | 0.0     | 0.00018                      |                                |                  |
| RH105M           | 5.21E-04           |   | 0.00001                                | 0.00000                               | 0.00000              | 0.00001                            | 0.00018 | 0.0     | 0.00018                      |                                |                  |
| RU106            | 1.50E-00           |   | 0.00001                                | 0.00001                               | 0.00000              | 0.00002                            | 0.00015 | 0.0     | 0.00015                      |                                |                  |
| AG106M           | 3.47E-02           |   | 0.00000                                | 0.00000                               | 0.00000              | 0.00000                            | 0.00240 | 0.00240 | 0.00240                      |                                |                  |
| TE120M           | 2.53E-02           |   | 0.00000                                | 0.00000                               | 0.00000              | 0.00000                            | 0.00000 | 0.00044 | 0.00044                      |                                |                  |
| TE129            | 3.40E-01           |   | 0.00000                                | 0.00000                               | 0.00000              | 0.00001                            | 0.00006 | 0.0     | 0.00006                      |                                |                  |
| TE131M           | 4.79E-02           |   | 0.00000                                | 0.00000                               | 0.00000              | 0.00001                            | 0.00004 | 0.0     | 0.00004                      |                                |                  |
| I131             | 1.25E-00           |   | 0.00000                                | 0.00000                               | 0.00000              | 0.00001                            | 0.00006 | 0.0     | 0.00006                      |                                |                  |
| I132             | 6.05E-00           |   | 0.00028                                | 0.00427                               | 0.00000              | 0.01139                            | 0.08138 | 0.00006 | 0.08100                      |                                |                  |
| I133             | 9.58E-02           |   | 0.00015                                | 0.00002                               | 0.00000              | 0.00017                            | 0.00120 | 0.0     | 0.00120                      |                                |                  |
| I134             | 9.75E-01           |   | 0.00078                                | 0.00474                               | 0.00000              | 0.00550                            | 0.03998 | 0.0     | 0.04000                      |                                |                  |
| CS134            | 3.47E-02           |   | 0.00006                                | 0.00000                               | 0.00000              | 0.00006                            | 0.00042 | 0.0     | 0.00042                      |                                |                  |
| I135             | 7.49E-02           |   | 0.00002                                | 0.00000                               | 0.00000              | 0.00002                            | 0.00016 | 0.01300 | 0.01300                      |                                |                  |
| I135             | 2.79E-01           |   | 0.00037                                | 0.00060                               | 0.00001              | 0.00098                            | 0.00699 | 0.0     | 0.00700                      |                                |                  |
| CS136            | 1.30E-01           |   | 0.00001                                | 0.00000                               | 0.00000              | 0.00001                            | 0.00010 | 0.0     | 0.00010                      |                                |                  |



LIQUID EFFLUENTS (CONTINUED)

SAMPLE BWR CASE

| NUCLIDE                | HALF-LIFE (DAYS) | CONCENTRATION IN PRIMARY COOLANT (MICRO CI/ML) | ANNUAL RELEASES TO DISCHARGE CANAL |                     |                   | TOTAL LRS (CURIES) | ADJUSTED TOTAL (CI/YR) | DETERGENT WASTES (CI/YR) | TOTAL (CI/YR) |
|------------------------|------------------|--|------------------------------------|---------------------|-------------------|--------------------|------------------------|--------------------------|---------------|
|                        |                  |  | HIGH PURITY (CURIES)               | LOW PURITY (CURIES) | CHEMICAL (CURIES) |                    |                        |                          |               |
| CS137                  | 1.10E 04         | 7.00E-05                                       | 0.00004                            | 0.00001             | 0.00000           | 0.00005            | 0.00037                | 0.02400                  | 0.02400       |
| BA137M                 | 1.77E-03         | 0.0  | 0.00004                            | 0.00001             | 0.00000           | 0.00005            | 0.00035                | 0.0                      | 0.00035       |
| CS138                  | 2.24E-02         | 1.00E-02                                       | 0.00002                            | 0.00000             | 0.00000           | 0.00002            | 0.00016                | 0.0                      | 0.00016       |
| BA139                  | 5.76E-02         | 1.00E-02                                       | 0.00002                            | 0.00000             | 0.00000           | 0.00002            | 0.00015                | 0.0                      | 0.00015       |
| BA140                  | 1.26E 01         | 4.00E-04                                       | 0.00002                            | 0.00004             | 0.00001           | 0.00007            | 0.00047                | 0.0                      | 0.00047       |
| LA140                  | 1.67E 00         | 0.0  | 0.00000                            | 0.00002             | 0.00001           | 0.00003            | 0.00023                | 0.0                      | 0.00023       |
| LA141                  | 1.62E-01         | 0.0  | 0.00001                            | 0.00000             | 0.00000           | 0.00001            | 0.00006                | 0.0                      | 0.00006       |
| CE141                  | 3.24E 01         | 3.00E-05                                       | 0.00000                            | 0.00000             | 0.00000           | 0.00001            | 0.00005                | 0.0                      | 0.00005       |
| LA142                  | 6.39E-02         | 5.00E-03                                       | 0.00001                            | 0.00000             | 0.00000           | 0.00001            | 0.00011                | 0.0                      | 0.00011       |
| CE143                  | 1.35E 00         | 3.00E-05                                       | 0.00000                            | 0.00000             | 0.00000           | 0.00000            | 0.00002                | 0.0                      | 0.00002       |
| PR143                  | 1.37E 01         | 4.00E-05                                       | 0.00000                            | 0.00000             | 0.00000           | 0.00001            | 0.00005                | 0.0                      | 0.00005       |
| CE144                  | 2.88E 02         | 3.00E-06                                       | 0.00000                            | 0.00000             | 0.00000           | 0.00000            | 0.00000                | 0.00520                  | 0.00520       |
| ALL OTHERS             |                  | 1.19E-01                                       | 0.00001                            | 0.00000             | 0.00000           | 0.00001            | 0.00007                | 0.0                      | 0.00007       |
| TOTAL (EXCEPT TRITIUM) |                  | 5.31E-01                                       | 0.00534                            | 0.01178             | 0.00730           | 0.02441            | 0.17441                | 0.06234                  | 0.24000       |

92 CURIES PER YEAR

TRITIUM RELEASE

### 3.4 LISTING OF BWR-GALE CODE

#### 3.4.1 NUCLEAR DATA LIBRARY

Calculation of the releases of radioactive materials in liquid effluents using the GALE Code requires a library of nuclear data available on magnetic tape from the Division of ADP Support, USNRC (301)492-7713. For convenience, the tape consists of five files, written in card image form. The contents of the five files are:

1. File 1: A FORTRAN listing of the liquid effluent code.
2. File 2: Nuclear data library for corrosion and activation products for use with the liquid effluent code.
3. File 3: Nuclear data library for fuel materials and their transmutation products for use with the liquid effluent code.
4. File 4: Nuclear data library for fission products for use with the liquid effluent code.
5. File 5: A FORTRAN listing of the gaseous effluent code.

The tape is written in the following format:

DCB = (RECFM = FB, LRECL = 80, BLKSIZE = 3200)

Use of the tape requires two data cards in addition to those described above containing the plant parameters. For a low enrichment uranium-235 oxide-fueled light water reactor, these cards should always contain the following data:

| <u>CARD</u> | <u>COLUMN</u> | <u>INPUT DATA</u>           |
|-------------|---------------|-----------------------------|
| 1           | 1-72          | Title                       |
| 1           | 75            | The value 2                 |
| 2           | 1-10          | The value 0.632             |
| 2           | 11-20         | The value 0.333             |
| 2           | 21-30         | The value 2.0               |
| 2           | 31-40         | The value 1.0E-25           |
| 2           | 41-46         | The date (month, day, year) |
| 2           | 48            | The value 1                 |
| 2           | 50            | The value 0                 |
| 2           | 52            | The value 0                 |

A description of the information contained in the nuclear data library can be found in the report ORNL-4628, "ORIGEN - The ORNL Isotope Generation and Depletion Code," dated May 1973.

#### 3.4.2 FORTRAN PROGRAM LISTING

The remainder of this chapter provides the program listing for the BWR-GALE Code.

```

C   GALE CODE FOR CALCULATING GASEOUS EFFLUENTS FROM LANS. MODIFIED 00000010
C   JULY 1975 TO IMPLEMENT APPENDIX I TO 10 CFR PART 50. REACTOR 00000020
C   WATER CONCENTRATIONS CALCULATED USING METHODS OF DRAFT STANDARD 00000030
C   ANS 237 (RADIOACTIVE MATERIALS IN PRINCIPAL FLUID STREAMS OF 00000040
C   LIGHT WATER COOLED NUCLEAR POWER PLANTS; DRAFT DATED MAY 20, 1974)00000050
REAL*8 NUCLID(20)/ 1 KH=85H KR=85H KR=85S KH=87 KR=88 KR=8900000060
1  XE=131H XE=133H XE=133 XE=135H XE=135 XE=137 XE=138 I=131 00000070
2  I=133 00000080
REAL*8 BPART(15)/1 CH=51 H=54 FE=59 CO=58 CO=60 ZR=65 00000090
1  SR=89 SR=90 ZR=95 SR=124 CS=134 CS=136 CS=137 HA=140 00000100
2E=141 1/ 00000110
REAL*8 PPART(8)/1 MN=54 FE=59 CO=58 CO=60 SR=89 SR=90 00000120
1CS=134 CS=137 1/ 00000130
COMMON NSIG,NSIG 00000140
DIMENSION ACUNT(20),CHCP(20),CBSP(20),ASHTRC(20),ASHINS(20) 00000150
DIMENSION ASHIM(20),CONCL(20),CONCP(20),CONCS(20),DECLIN(20) 00000160
DIMENSION DECFM(20),EXS(20),EXR(20),EXC(20),NAME(8) 00000170
DIMENSION EJT(20),SGL(20),THL(20),CHL(20),RADBL(20),AXBL(20) 00000180
DIMENSION VPR(20),BVUG(20),TOT(20),X0(20),X1(20),X2(20),X3(20) 00000190
DIMENSION CHB(20),AXHB(20),TBB(20),RADDB(20) 00000200
DIMENSION X4(20),X5(20),KORD(14),KARD(5),KORD(4) 00000210
DIMENSION PCBH(15),PAXBH(15),PTBH(15),PRRHH(15),PVPR(15),PTOTH(15) 00000220
DIMENSION PCHL(15),PTHL(15),PAXBL(15),PRRHL(15),PVPL(15) 00000230
DIMENSION PCBP(8),PAXBP(8),PGKS(8),PTOTR(8),PGAL(8),PCBCP(8), 00000240
1PCBSP(8),PRCUNT(8) 00000250
DIMENSION CTRUD(20) 00000260
C   KH CONTAINS COOLANT CONCENTRATIONS FOR HARTS. THE FOLLOWING 00000270
C   ISOTOPES (WITH THEIR CONCENTRATIONS IN UCI/GM) ARE NOT 00000280
C   CONSIDERED SIGNIFICANT IN EFFLUENT CALCULATIONS;HR=90,,09; 00000290
C   KH=91,,11;KR=92,,11;KH=93,,029;KH=94,,0072;KR=95,,6,6E=4;KH=97, 00000300
C   4,4E=6;XE=139,,09;XE=140,,090;XE=141,,078;XE=142,,023;XE=143, 00000310
C   ,0038;XE=144,1,8E=4. 00000320
DIMENSION XB(20) 00000330
C   XP1 CONTAINS PRIMARY COOLANT CONCENTRATIONS FOR PWR,S. XP2 00000340
C   CONTAINS SECONDARY COOLANT CONCENTRATIONS FOR PWR,S 00000350
DIMENSION XP1(20),XP2(13) 00000360
DATA XB/1,1E=3,1,9E=3,6,0E=6,6,6E=3,6,6E=3,4,1E=2,4,7E=6,9,0E=5, 00000370
1 2,6E=3,8,4E=4,7,2E=3,4,7E=2,2,6E=2,5,0E=3,2,0E=2,5*0./ 00000380
DATA XP1/.021,,11,,15,,06,,2,5E=3,, 1,22,1E,,.013,,35,9E=3,,044, 00000390
1,27,,38,5*0./ 00000400
DATA XP2/5,8E=9,3,1E=8,4,2E=8,1,0E=8,5,5E=8,1,4E=9,5,1E=8,6,2E=8, 00000410
15,0E=6,3,6E=9,9,7E=8,2,5E=9,1,2E=8/ 00000420
DATA DECFM/1,035E=04,4,375E=05,2,040E=09,1,520E=04,6,660E=05, 00000430
1 3,632E=03,6,800E=07,3,548E=06,1,520E=06,7,357E=04, 00000440
2 2,090E=05,3,024E=03,6,800E=04,9,970E=07,9,170E=06, 00000450
3 0,000E=00,0,000E=00,0,000E=00,0,000E=00,0,000E=00/ 00000460
DATA CHB/0,,3,0,0,,3,0,3,,3*0,,66,,46,,34,,0,,7,,17,,66,5*0./ 00000470
DATA AXHB/0,,3,0,0,,3,0,3,,3*0,,66,,46,,34,,0,,7,,17,,66,5*0./ 00000480
DATA TBB/0,,68,,0,,130,,250,,3*0,,250,,650,,630,,0,,1440,,19, 00000490
1,76,5*0./ 00000500
DATA RADDB/8*0,,10,,0,,45,,0,,0,,05,,18,5*0./ 00000510
DATA VPR/8*0,,2300,,0,,350,,2*0,,03,6*0./ 00000520
DATA PCBH/3,3,,4,,6,10,,2,,09,,005,,4,,2,4,,3,5,5,,4,,17 00000530
DATA PAXBH/3,3,,4,,6,10,,2,,09,,005,,4,,2,4,,3,5,5,,4,,17 00000540
DATA PTBH/13,,0,,5,,6,2,,2,6,,02,1,,3,,3,,05,,6,11,,6/ 00000550
DATA PRRHH/9,,30,,15,,4,5,90,,1,5,,45,,3,,05,,05,4,5,,45,9,,1,2,6 00000560
1/ 00000561
DATA PVPR/10*0,,.003,,002,,01,,011,6./ 00000570
DATA PCBP/22,,7,5,75,,34,,1,7,,3,22,,38./ 00000580
DATA PAXBP/18,,6,60,,27,,1,3,,24,18,,30./ 00000590

```

|  |          |
|--|----------|
| DATA PGS/4,5,1,5,7,,33,,06,4,5,7,5/  | 00000600 |
| DATA YES/YES/  | 00000610 |
| DATA NTRY,NTER/0,0/,P-W/1 P-R/1,B-H/1 B-W/1                                      | 00000620 |
| REAL KKR,KXE,KNU,KHASS   | 00000630 |
| 50 FORMAT(20A4)  | 00000640 |
| 51 FORMAT(16X,'PLANT CAPACITY FACTOR',T74,'0,B0')                                | 00000650 |
| 52 FORMAT(32X,B44,12X,A4)  | 00000660 |
| 53 FORMAT(16X,13A4,A2,F10,5)   | 00000670 |
| 54 FORMAT(16X,'PERCENT FUEL WITH CLADDING DEFECTS',T74,F6,5)                     | 00000680 |
| 55 FORMAT(15X,A44,A2,8X,F8,0,7X,F5,3)  | 00000690 |
| 56 FORMAT(20X,F8,0,2(5X,F8,0))   | 00000700 |
| 57 FORMAT(27X,F6,2,14X,F6,2,18X,F6,2)  | 00000710 |
| 58 FORMAT (30X,'FRACTION FRACTION COLLECTION DECAY',T6X,'STREAM                  | 00000720 |
| 1 FLOW RATE OF PCA DISCHARGED TIME TIME',5X,' DECONTAMINATI                      | 00000730 |
| 2INATION FACTORS',T20X,'(GAL/DAY)',23X,'(DAYS) (DAYS)',7X,                       | 00000740 |
| 3'I',8X,'CS',8X,'OTHERS')  | 00000750 |
| 59 FORMAT(2X,A44,A2,1PE9,2,1X,4(0PF8,3,2X),3(1PE9,2,1X))                         | 00000760 |
| 60 FORMAT(79X,I1)  | 00000770 |
| 61 FORMAT(16X,'THERE IS A CRYOGENIC DISTILLATION COLUMN',T20X,'IODINE            | 00000780 |
| 1AND XENON DECONTAMINATION FACTOR',T70,'10000',T20X,'KRYPTON DECONT              | 00000790 |
| 2AMINATION FACTOR',T71,'4000',T20X,'KRYPTON AND XENON HOLDUP TIME                | 00000800 |
| 3(DAYS)',T73,'90,')  | 00000810 |
| 62 FORMAT(16X,'THERE IS NO CHARCOAL DELAY SYSTEM')                               | 00000820 |
| 63 FORMAT(16X,'THERE IS A CHARCOAL DELAY SYSTEM',T20X,'KRYPTON HOLDUP            | 00000830 |
| 1TIME (DAYS)',T72,F9,5/20X,'XENON HOLDUP TIME (DAYS)',T72,F9,5/                  | 00000840 |
| 220X,'KRYPTON DYNAMIC ADSORPTION COEFFICIENT (CM <sup>3</sup> /GM)',T72,F9,5/    | 00000850 |
| 320X,'XENON DYNAMIC ADSORPTION COEFFICIENT (CM <sup>3</sup> /GM)',T71,F10,5/20X, | 00000860 |
| 4'NUMBER OF MAIN CONDENSER SHELLS',T72,F9,5/20X,'MASS OF CHARCOAL                | 00000870 |
| 5(THOUSAND LBS)',T72,F9,5)   | 00000880 |
| 64 FORMAT(36X,F8,4,35X,I1)   | 00000890 |
| 65 FORMAT (16X,'FRACTION IODINE PASSING CONDENSATE DEMINERALIZER',               | 00000900 |
| T71,F10,5)   | 00000910 |
| 66 FORMAT(16X,'BLOWDOWN RATE (THOUSAND LBS/HR)',25X,F8,4)                        | 00000920 |
| 67 FORMAT(16X,'FLOW RATE THROUGH GAS STRIPPER (GPM)',20X,F8,4)                   | 00000930 |
| 68 FORMAT(70X,F10,5)   | 00000940 |
| 69 FORMAT(2X,'BLOWDOWN',10X,1PE9,2,14X,0PF5,3,2X,2(F8,3,2X),                     | 00000950 |
| 13(1PE9,2,1X))   | 00000960 |
| 70 FORMAT(2X,'UNTREATED BLOWDOWN',1PE9,2,11X,' 1.000 0.0                         | 00000970 |
| 10.0 1.00E 00 1.00E 00 1.00E 00')  | 00000980 |
| 71 FORMAT(2X,'REGENERANT SOLS ',1PE9,2,14X,0PF5,3,2X,2(F8,3,2X),                 | 00000990 |
| 13(1PE9,2,1X))   | 00010000 |
| 72 FORMAT(16X,'PRIMARY COOLANT LEAK TO AUXILIARY BUG (LB/DAY)',T72,              | 00010010 |
| 1'160,')   | 00010020 |
| 73 FORMAT(16X,'FREQUENCY OF PRIMARY COOLANT DEGASSING (TIMES/YR)',T74            | 00010030 |
| 1,'2,)/16X,'PRIMARY TO SECONDARY LEAK RATE (LB/DAY)',T72,'100,')                 | 00010040 |
| 74 FORMAT(16X,'THERE IS A KIDNEY FILTER',T20X,'CONTAINMENT ATMOSPHERE            | 00010050 |
| 1CLEANUP RATE (THOUSAND CFM)',T71,F10,5/20X,'PURGE TIME OF CONTAINM              | 00010060 |
| 2ENT (HOURS)',T71,F10,5)   | 00010070 |
| 75 FORMAT(16X,'THERE IS NOT A KIDNEY FILTER')                                    | 00010080 |
| 76 FORMAT(16X,'THERE IS NOT A CONDENSATE DEMINERALIZER')                         | 00010090 |
| 77 FORMAT(16X,'FRACTION IODINE BYPASSING CONDENSATE DEMINERALIZER',              | 00011000 |
| T7X,T72,F9,5)  | 00011010 |
| 900 FORMAT(16X,'IODINE PARTITION FACTOR (GAS/LIQUID) IN STEAM GENERATOR          | 001120   |
| 1R ',F4,2)   | 001130   |
| 901 FORMAT(16X,'THERE IS A CRYOGENIC OFFGAS SYSTEM',T20X,'IODINE AND XE          | 00011400 |
| 1NON DECONTAMINATION FACTOR',T70,'10000',T20X,'KRYPTON DECONTAMINAT              | 00011500 |
| 2ION FACTOR',T71,'4000,')  | 00011600 |
| 902 FORMAT(16X,'THERE IS NOT A CRYOGENIC OFFGAS SYSTEM')                         | 00011700 |
| 903 FORMAT(16X,16A4)   | 00011800 |
| 904 FORMAT (/,' LIQUID WASTE INPUTS')  | 00011900 |
| 905 FORMAT (/,' GASEOUS WASTE INPUTS')   | 00012000 |



```

READ(50,56)DFIDK,DFCSK,DFDK
READ(50,57)TU,TSTORD,DFDU
WRITE(51,59)KARD,DFFLK,DKKA,DKFU,TU,TSTORD,DFIDK,DFCSK,DFDK
READ(50,55)KARD,CHKFR,CYA
READ(50,56)DFICK,DFCSK,DFDK
READ(50,57)TCR,TSTORR,DFDU
WRITE(51,59)KARD,CHKFR,CYA,DFDU,TCR,TSTORR,DFICK,DFCSK,DFDK
READ(50,66)RGKFR
READ(50,56)DFIRG,DFCSG,DFRG
READ(50,57)TRG,TSTORR,DFDU
WRITE(51,71)RGKFR,DFDU,TRG,TSTORR,DFIRG,DFCSG,DFRG

```

HEAD DATA FOR BAR GAS CODE

```

WRITE(51,905)
READ(50,53)KORD,GG5
WRITE(51,53)KORD,GG5
READ(50,53)KORD,KSTE
WRITE(51,53)KORD,KSTE
READ(50,53)KORD,TIM3
WRITE(51,53)KORD,TIM3
READ(50,53)KORD,TIM4
WRITE(51,53)KORD,TIM4
HEPA1=1.0
FIL1=1.0
HEPA2=1.0
FIL2=1.0
HEPA5=1.0
FIL5=1.0
HEPA6=1.0
FIL6=1.0
CSRF=1.0
READ(50,925)KORD,CHCH,CHHEPA
IF(CHCH,EQ,YES)FIL1=0.1
IF(CHHEPA,EQ,YES)HEPA1=0.01
WRITE(51,926)KORD,FIL1,HEPA1
READ(50,927)KORD,TRCH,TRHEPA,TRCS
IF(TRCH,EQ,YES)FIL2=0.1
IF(TRHEPA,EQ,YES)HEPA2=0.01
IF(TRCS,EQ,YES)CSRF=0.2
WRITE(51,928)KORD,FIL2,HEPA2,CSRF
READ(50,53)KORD,FIL3
WRITE(51,53)KORD,FIL3
READ(50,53)KORD,FIL4
WRITE(51,53)KORD,FIL4
READ(50,925)KORD,AXCH,AXHEPA
IF(AXCH,EQ,YES)FIL5=0.1
IF(AXHEPA,EQ,YES)HEPA5=0.01
WRITE(51,926)KORD,FIL5,HEPA5
READ(50,925)KORD,RKCH,RKHEPA
IF(RKCH,EQ,YES)FIL6=0.1
IF(RKHEPA,EQ,YES)HEPA6=0.01
WRITE(51,926)KORD,FIL6,HEPA6
READ(50,60)KCHAR
READ(50,53)KORD,KKY
READ(50,53)KORD,KKE
READ(50,53)KORD,KKU
READ(50,53)KORD,KKAB5
IF(KCHAR,EQ,0) GO TO 90
IF(KCHAR,EQ,1) GO TO 91
WRITE(51,61)

```

```

00001820
00001830
00001840
00001850
00001860
00001870
00001880
00001890
00001900
00001910
00001920
00001930
00001940
00001950
00001960
00001970
00001980
00001990
00002000
00002010
00002020
00002030
00002040
00002050
00002060
00002070
00002080
00002090
00002100
00002110
00002120
00002130
00002140
00002150
00002160
00002170
00002180
00002190
00002200
00002210
00002220
00002230
00002240
00002250
00002260
00002270
00002280
00002290
00002300
00002310
00002320
00002330
00002340
00002350
00002360
00002370
00002380
00002390
00002400
00002410
00002420

```

C  
C  
C

3-16

```

      CHT11=90,
      CHT12=90,
      GO TO 92
90  WRITE(51,62)
      CHT11=0,
      CHT12=0,
      GO TO 92
91  F=10,*KNU
      CHT11=(0,53*KKHASS*KKK)/(F*24,*2,)
      CHT12=(0,53*KKHASS*KKK)/(F*24,*2,)
      WRITE(51,63)CHT11,CHT12,KKH,XXE,PHU,KNASS
92  CONTINUE
      COW=0,02
      P3=0,01
      READ(50,53)  NORD,PFLAUN
      IF(PFLAUN.LE,0,0)  WRITE(51,907)
C
C  CONVERSION OF UNITS
C
      GTU=GTU*1000000,
      GDE=GDE*1000000,
      GGS=GGS*1000,
      KLIW=LIW*1000000,
      KSTE=STE*1000000,
      WRITE(51,908)
      WRITE(51,903)NA=E
      WRITE(51,214)
214  FORMAT(1H0,131H-----)
      1-----
      2-----)
      WRITE(51,235)
235  FORMAT(1H0,63X,'GASEOUS RELEASE RATE'/1H0,63X,'(CURIES PER YEAR)'/1H0,63X,
11H0,16X,'CONSTANT CONC./1,5X,'CONTAINMENT/1,5X,'TURBINE/1,4X,'AUXILIARY/1,4X,
2Y',3X,'RADWASTE/1,5X,'GLAND/1,7X,'AIR/1,6X,'TECH VAC/1,4X,'ROCC/1,4X,
3,3X,'(NICHOCCHIESY/6)'/6X,'BLDG,1,7X,'BLDG,1,7X,'BLDG,1,6X,'BLDG,1,
6BX,'REAL/1,5X,'EJECTOR/1,7X,'PUMP/1,1X,'TOTAL')
      WRITE(51,214)
C  TRITON IS THE B-H TRITIUM EQUILANT CONCENTRATION IN UCI/GM
      TRITPR=.025*POATH
      TRITCU=.01
      TLH=1,362*(C+FO+C+PLH+O+FO+O+FLW+CHFO*(C+FR+1800,))
      TRITRL=TRITCU*TLH
      IF(TRITRL.GT,0,5*TRITPR)TRITRL=0,5*TRITPR
      TRITRG=TRITPR-TRITRL
      DIV=10,*(INT(4LOG10(TRITRG)))+1
      IDIV=DIV
      ITHIG=INT((TRITRG/DIV+0,5)*10IV)
      IOT=1
      IF(ABS(PDATH=3400),GT,400,1) GO TO 210
      IF(ABS(ALIW=3,8E5),GT,0,4001E5)GO TO 210
      IF(ABS(GDE=1,3E5),GT,0,2001E5)GO TO 210
      IF(ABS(GTU=1,8E7),GT,0,2001E7)GO TO 210
      IF(ABS(FFCDM=0,9),GT,0,1001)GO TO 210
      GO TO 211
210  RHAL2=(GGS*0,9+FFCDM*GTU*0,018)/LIW
      IOT=2
211  CONTINUE
      DUSI=1,15
      DECUH(I)=DECUH(I)*3600,
      EX3(I)=DECUH(I)*T1=3
      IF(EX3(I),GT,75,0)EX3(I)=75,

```

```

00002450
00002460
00002450
00002460
00002470
00002480
00002490
00002500
00002510
00002520
00002530
00002540
00002550
00002560
00002570
00002580
00002590
00002600
00002610
00002620
00002630
00002640
00002650
00002660
00002670
00002680
00002690
00002700
00002710
00002720
00002730
00002740
00002750
00002760
00002770
00002780
00002790
00002800
00002810
00002820
00002830
00002840
00002850
00002860
00002870
00002880
00002890
00002900
00002910
00002920
00002930
00002940
00002950
00002960
00002970
00002980
00002990
00003000
00003010
00003020
00003030

```



```

EX4(I)=DECOH(I)*TIM4
IF(EX4(I),GT,75.)EX4(I)=75,
IF(I,GT,13)GO TO 2000
X1(I)=XH(I)
CBL(I)=CBB(I)
AXBL(I)=AXB(I)
TBL(I)=TBB(I)*CSHF
HAUBL(I)=HADBB(I)
SGL(I)=GGS*X1(I)*EXP(=EX3(I))*3.977*UPFRA
EXC(I)=DECOH(I)*CHT1*24,
IF(I,GT,6)EXC(I)=DECOH(I)*CHT2*24,
IF(EXC(I),GT,75.)EXC(I)=75,
DFCR=0,0
IF(KCHAR,EG,2) DFCR=0,00025
IF(KCHAR,EG,2,AND,I,GT,6) DFCR=0,0001
EJT(I)=GT0*X1(I)*EXP(=EX4(I))*(DFCR+EXP(=EXC(I)))*3.977*UPFRA
GO TO 2001
2000 CONTINUE
IF(IOT,EG,1)GO TO 2002
XR(I)=XB(I)*(111,76*PDATH/HLIG)*(1,015*DECOH(I)/HAL2 +DECOH(I))
2002 X1(I)=XH(I)*C014
CBL(I)=CBB(I)*FIL1
AXBL(I)=AXB(I)*FIL5
TBL(I)=TBB(I)*FIL2*CSHF
HAUBL(I)=HADBB(I)*FIL6
SGL(I)=GGS*X1(I)*P3*FIL3*EXP(=EX3(I))*3.977*UPFRA
EXC(I)=0,
IF(KCHAR,EG,2)EXC(I)=DECOH(I)*CHT1*24,
IF(EXC(I),GT,75.)EXC(I)=75,
IF(KCHAR,EG,2) DFCR=0,00010
EJT(I)=5,0*EXP(=EX4(I))*(DFCR+EXP(=EXC(I)))*FIL4
IF(I,EG,15) EJT(15)=EJT(15)*XB(15)/XR(14)
2001 TEST=1,
IF(I,GT,13) TEST=0,0001
IF(SGL(I),LE,TEST) SGL(I)=0,0
IF(EJT(I),LE,TEST) EJT(I)=0,0
5 CONTINUE
NSIG=1
NSIG=15
CALL SIGF2(TBL)
CALL SIGF2(SGL)
CALL SIGF2(EJT)
DO 2003 I=1,15
TOT(I)=AXB(I)+TBL(I)+SGL(I)+EJT(I)+CBL(I)+HAUBL(I)+VPR(I)
2003 CONTINUE
CALL SIGF2(TOT)
GASTOT=0,0
DO 2004 I=1,13
WRITE(51,230)NUCLID(I),XB(I),CBL(I),TBL(I),AXB(I),HAUBL(I),
1 SGL(I),EJT(I),VPR(I),TOT(I)
GASTOT=GASTOT+TOT(I)
2004 CONTINUE
230 FORMAT(1H0,4X,48,5X,1PE9,3,6X,1PE7,1,1X,6(4X,1PE7,1,1X),7X,1PE7,1)
DIV=10,**(INT(ALOG10(GASTOT))-1)
GASTOT=AINT(GASTOT/DIV+0,5)*DIV
WRITE(51,232) GASTOT
232 FORMAT(1H0,5X,'TOTAL NUHLE GASES', 99X,1PE7,1)
DO 2006 I=14,15
WRITE(51,230)NUCLID(I),XB(I),CBL(I),TBL(I),AXB(I),HAUBL(I),
1 SGL(I),EJT(I),VPR(I),TOT(I)
2006 CONTINUE

```

```

00003040
00003050
00003060
00003070
00003080
00003090
00003100
00003110
00003120
00003130
00003140
00003150
00003160
00003170
00003180
00003190
00003200
00003210
00003220
00003230
00003240
00003250
00003260
00003270
00003280
00003290
00003300
00003310
00003320
00003330
00003340
00003350
00003360
00003370
00003380
00003390
00003400
00003410
00003420
00003430
00003440
00003450
00003460
00003470
00003480
00003490
00003500
00003510
00003520
00003530
00003540
00003550
00003560
00003570
00003580
00003590
00003600
00003610
00003620
00003630
00003640

```



```

WRITE(51,215) ITRITG 00003650
215 FORMAT(1H0,5A,'TRITIUM GASEOUS RELEASE',12X,14,' COUNES/YR') 00003660
WRITE(51,214) 00003670
WRITE(51,251) 00003680
231 FORMAT(1H0,'0.0 APPEARING IN THE TABLE INDICATES RELEASE IS LESS 00003690
1 THAN 1.0 CI/YR FOR NOBLE GAS, 0.0001 CI/YR FOR I') 00003700
b CONTINUE 00003710
WRITE (51,906) 00003720
WRITE (51,903)NAME 00003730
WRITE (51,214) 00003740
WRITE (51,245) 00003750
245 FORMAT (1H0,4X,'AIRBORNE PARTICULATE RELEASE RATE'/1H0,5X,'(CURIO0003760
IES PER YEAR)'/1H0,3X,'CONTINENT',3A,'TUMHINE',X,'AUXILIARY',4X0003770
2,'HAUASTE' 'ECH' VAG,'/1',4X,'NUCLIDE',2X,'BLDG',1,7X,'BLDG',1,7X,0003780
3'BLDG',1,8X,'BLDG',1,8X,'PUM',1,10X,'TOTAL') 00003790
WRITE (51,214) 00003800
DO 250 I=1,15 00003810
PCBL(I)=PCBL(I)/1E3*HEPA1 00003820
PTBL(I)=PTBL(I)/1E3*HEPA2*CSHF 00003830
PVPL(I)=PVPL(I)/1E3 00003840
PAXBL(I)=PAXBL(I)/1E3*HEPA5 00003850
PRRBL(I)=PRRBL(I)/1E3*HEPA6 00003860
PTUTB(I)=PCBL(I)+PTBL(I)+PAXBL(I)+PRRBL(I)+PVPL(I) 00003870
250 CONTINUE 00003880
NSIG#2 00003890
NSIG#15 00003900
CALL SIGF2(PTUTB) 00003910
DO 253 I=1,15 00003920
WRITE (51,920) @PART(I),PCBL(I),PTBL(I),PAXBL(I),PRRBL(I),PVPL(I), 00003930
1PTUTB(I) 00003940
253 CONTINUE 00003950
WRITE (51,214) 00003960
GO TO 80 00003970
00003980
00003990
00004000
C THIS SECTION TREATS PAK RELEASES 00004010
C 00004020
1003 READ(50,53)WORD,PU=TH 00004030
WRITE(51,53)WORD,PU=TH 00004040
UPFR#0,80 00004050
WRITE(51,51) 00004060
READ(50,53)WORD,PRIVOL 00004070
WRITE(51,53)WORD,PRIVOL 00004080
600 PEN#0,12 00004090
WRITE(51,54)PEN 00004100
HEAD(50,53)WORD,DEM1FL 00004110
WRITE(51,53)WORD,DEM1FL 00004120
HEAD(50,53)WORD,CRFLR 00004130
WRITE(51,53)WORD,CRFLR 00004140
HEAD(50,53)WORD,GEN 00004150
WRITE(51,53)WORD,GEN 00004160
HEAD(50,53)WORD,TUSTFL 00004170
WRITE(51,53)WORD,TUSTFL 00004180
HEAD(50,53)WORD,WST 00004190
WRITE(51,53)WORD,WST 00004200
HEAD(50,53)WORD,WLI 00004210
WRITE(51,53)WORD,WLI 00004220
WLI#GEN*LI 00004230
HEAD(50,53)WORD,TMSC 00004240
WRITE(51,53)WORD,TMSC 00004250
HEAD(50,64)TBD,*FRNT
WRITE(51,66)THG

```

3-18

```

IF(FNRT,EW,0) GO TO 801
FNRTSC=0.9
WRITE (51,910)
GO TO 802
801 WRITE (51,911)
FNRTSC=1.0
802 CONTINUE
READ(50,53)WORD,REGENT
WRITE(51,53)WORD,REGENT
C
C READ DATA FOR PAR LIQUID CODE
C
READ(50,53)WORD,FFCDM
WRITE(51,53)WORD,FFCDM
READ(50,53)WORD,DILUT
WRITE(51,53)WORD,DILUT
READ(50,912)WORD,SBLDR
C=WORD
READ(50,56)DFICH,DFCSCH,DFC
READ(50,57)TC,TSTORC,CAF0
WRITE(51,904)
WRITE(51,58)
WRITE(51,59)WORD,SBLDR,CHA,CAF0,TC,TSTORC,DFICH,DFCSCH,DFC
READ(50,55)WORD,EDFLX,EDA
READ(50,56)DFIE0,DFCE0,DFE0
READ(50,57)TE,TS,EDF0
WRITE(51,59)WORD,EDFLX,EDA,EDF0,TE,TS,DFIE0,DFCE0,DFE0
READ(50,55)WORD,DNFLX,DA
READ(50,56)DFID0,DFCS0,DFD0
READ(50,57)TD,TSTOR0,DAF0
WRITE(51,59)WORD,DNFLX,DA,DAF0,TD,TSTOR0,DFID0,DFCS0,DFD0
READ(50,55)WORD,DNFL2,D2
READ(50,56)DFI02,DFCS02,DFD02
READ(50,57)T2,TSTOR2,DAF2
WRITE(51,59)WORD,DNFL2,D2,DAF2,T2,TSTOR2,DFI02,DFCS02,DFD02
READ(50,68)RGFR
READ(50,56)DFIRG,DFCSRG,DFRG
READ(50,57)TRG,TSTORR,RGFR
IF(TRD,EW,0.0) GO TO 800
BDFR=TB0*1.0E3*ROTFR/0.3476
WRITE(51,69)BDFR,CAF0,TC,TSTORC,DFICH,DFCSCH,DFC
BDFR=TB0*1.0E3*RB(1.-ROTFR)/0.3476
WRITE(51,70)BDFR
IF(FFCDM,EW,0.0)GO TO 801
800 CONTINUE
IF(REGENT,EW,0.0) GO TO 802
WRITE(51,71)RGFRN,RGFR,TRG,TSTORR,DFIRG,DFCSRG,DFRG
GO TO 801
802 RGFR=0.0
WRITE(51,71)RGFRN,RGFR,TRG,TSTORR,DFIRG,DFCSRG,DFRG
801 CONTINUE
C
C READ DATA FOR PAR GAS CODE
C
WRITE(51,905)
READ(50,60)KGTRNT
IF(KGTRNT,EW,0) GO TO 8001
GTR=([DENIFL=SELDR/1440.]/DENIFL

```

```

00004260
00004270
00004280
00004290
00004300
00004310
00004320
00004330
00004340
00004350
00004360
00004370
00004380
00004390
00004400
00004410
00004420
00004430
00004440
00004450
00004460
00004470
00004480
00004490
00004500
00004510
00004520
00004530
00004540
00004550
00004560
00004570
00004580
00004590
00004600
00004610
00004620
00004630
00004640
00004650
00004660
00004670
00004680
00004690
00004700
00004710
00004720
00004730
00004740
00004750
00004760
00004770
00004780
00004790
00004800
00004810
00004820
00004830
00004840
00004850
00004860

```

|      |                                      |          |
|------|--------------------------------------|----------|
|      | IF(KGTRH, EQ, 2) GO TO 8803          | 00004870 |
|      | WRITE (51, 909)                      | 00004880 |
|      | GO TO 8802                           | 00004890 |
| 8803 | GTRH=0.25*GTRH                       | 00004900 |
|      | WRITE (51, 900)                      | 00004910 |
|      | GO TO 8802                           | 00004920 |
| 8801 | GTRH=0.0                             | 00004930 |
|      | WRITE (51, 908)                      | 00004940 |
| 8802 | BRRHNGTRH=DEMTPL*(SHLDH*EDFLH)/1440. | 00004950 |
|      | WRITE (51, 87)BRRH                   | 00004960 |
|      | READ(50, 53)HORD, TAU1               | 00004970 |
|      | WRITE(51, 53)HORD, TAU1              | 00004980 |
|      | READ(50, 53)HORD, TAU2               | 00004990 |
|      | WRITE(51, 53)HORD, TAU2              | 00005000 |
|      | READ(50, 53)HORD, TAU3               | 00005010 |
|      | WRITE(51, 53)HORD, TAU3              | 00005020 |
|      | AUXLR=100.                           | 00005030 |
|      | WRITE (51, 72)                       | 00005040 |
|      | PCLPF=0.0075                         | 00005050 |
|      | WRITE (51, 93)PCLPF                  | 00005060 |
|      | GKHEPA=1.0                           | 00005070 |
|      | FRIAB=1.0                            | 00005080 |
|      | AXHEPA=1.0                           | 00005090 |
|      | FPPF=1.0                             | 00005100 |
|      | CSHEPA=1.0                           | 00005110 |
|      | FPPFN=1.0                            | 00005120 |
|      | CNHEPA=1.0                           | 00005130 |
|      | READ(50, 932)HORD, GKHT              | 00005140 |
|      | IF(GKHT, EQ, YES)GKHEPA=0.01         | 00005150 |
|      | WRITE(51, 933)HORD, GKHEPA           | 00005160 |
|      | READ(50, 934)HARD, AXCH, AXHT        | 00005170 |
|      | IF(AXCH, EQ, YES)FRIAB=0.1           | 00005180 |
|      | IF(AXHT, EQ, YES)AXHEPA=0.01         | 00005190 |
|      | WRITE(51, 935)HARD, FRIAB, AXHEPA    | 00005200 |
|      | FAUX=PCLPF*FRIAB                     | 00005210 |
|      | READ(50, 53)HORD, CONVUL             | 00005220 |
|      | WRITE(51, 53)HORD, CONVUL            | 00005230 |
|      | E=2.0                                | 00005240 |
|      | GENL=100.                            | 00005250 |
|      | CLFHG=0.01                           | 00005260 |
|      | CLFI=0.00001                         | 00005270 |
|      | WRITE(51, 73)                        | 00005280 |
|      | READ(50, 53)HORD, CFM                | 00005290 |
|      | PURTIM=10.                           | 00005300 |
|      | IF(CFM, EQ, 0.0)GO TO 803            | 00005310 |
|      | KID=1                                | 00005320 |
|      | WRITE(51, 74)CFM, PURTIM             | 00005330 |
|      | GO TO 804                            | 00005340 |
| 803  | KID=0                                | 00005350 |
|      | WRITE(51, 75)                        | 00005360 |
| 804  | CONTINUE                             | 00005370 |
|      | IF(FFCDM, GT, 0.0)GO TO 805          | 00005380 |
|      | WRITE(51, 76)                        | 00005390 |
|      | GO TO 806                            | 00005400 |
| 805  | FIBCD=1.0-FFCDM                      | 00005410 |
|      | WRITE(51, 77)FIBCD                   | 00005420 |
| 806  | CONTINUE                             | 00005430 |
|      | IF(TBU, EQ, 0.0) GO TO 809           | 00005440 |
|      | CUN=0.01                             | 00005450 |
|      | WRITE(51, 900)CUN                    | 00005460 |
|      | GO TO 810                            | 00005470 |

```

809 CON#1,0 00005480
WRITE(51,900)CON 00005490
810 CONTINUE 00005500
READ(50,936)WARD,CSCH,CSHT,ENPU 00005510
IF(CSCH,EQ,YES)FFFP#0,1 00005520
IF(CSHT,EQ,YES)CSHEPA#0,01 00005530
EN#4,0+ENPU 00005540
WRITE(51,937)EN 00005550
WRITE(51,935)WARD,FFFP,CSHEPA 00005560
FFFP#FFFP 00005570
READ(50,913)WARD,PNOV1,CNCH,CNHT 00005580
IF(CNCH,EQ,YES)FFFP#0,1 00005590
IF(CNHT,EQ,YES)CNHEPA#0,01 00005600
IF(PNOV1,LT,1.0) GO TO 8811 00005610
WRITE(51,914)WARD,PNOV1,WARD,FFFP,CNHEPA 00005620
GO TO 8812 00005630
8811 WRITE(51,938) 00005640
8812 CONTINUE 00005650
FFFP#FFFPN 00005660
TBLK#1700, 00005670
WRITE(51,930)TBLK 00005680
READ(50,53)WORD,FVN 00005690
WRITE(51,53)WORD,FVN 00005700
READ(50,53)WORD,FEJP 00005710
WRITE(51,53)WORD,FEJP 00005720
FEJ#FEJP*0.15 00005730
KCRYU#0,0 00005740
IF(KCRYU,EQ,0,0) GO TO 811 00005750
WRITE(51,901) 00005760
GO TO 812 00005770
811 WRITE(51,902) 00005780
812 CONTINUE 00005790
READ(50,53) WORD,PFLAUN 00005800
IF(PFLAUN,LE,0,0) WRITE(51,907) 00005810
CONVERSION OF UNITS 00005820
TOSTFL#TUSTFL*1000000, 00005830
WST#WST*1000, 00005840
WLI#WLI*1000, 00005850
CONVDL#CONVDL*1000000, 00005860
CFM#CFM*1000, 00005870
THD#THD*1E3 00005880
PRIVOL#PRIVOL*1E3 00005890
DEM1FL#DEM1FL*500,53 00005900
SHLDR#SHLDR*,3476 00005910
EDFLR#EDFLR*,3476 00005920
D#FLR#D#FLR*,3476 00005930
D#FL2#D#FL2*,3476 00005940
CBFLR#CBFLR*500,53 00005950
H3RPR#0,4*PU*TH 00005960
H3COP# IS THE PARTITION PRIMARY COOLANT CONCENTRATION IN UC17G 00005970
H3COP#1,0 00005980
TPLRP#SHLDR#CWA#CWFU+EDFLR#EDA#EDFU+D#FLR#DWA#WFU+D#FL2#U-2#D#F2 00005990
H3RLP#TPLRP#H3COP-3,977 00006000
IF(H3RLP,GT,0,5#H3RPR)H3RLP#0,5#H3RPR 00006010
H3RLG#H3RPR#H3RLP 00006020
DIV#10,*(INT(ALOG10(H3RLG))=1) 00006030
IDIV#DIV 00006040
IN'RLG#INT(H3RLG/DIV*10,5)*IDIV 00006050
IF(TAUS,EQ,0,)TAUS#0.01 00006060

```

3-21

C  
C  
C

C

```

SRB#SRB#500.53          0000090
PR#365,7TAU3            0000100
T1#3,1557E7/ENALPRA    0000110
T3#3,1557E+07/PE       0000120
T4#TAU1#86400,         0000130
T5#TAU2#86400,         0000140
DO 845 I#1,15           0000150
845 DECON(I)=DECON(I)*3600, 0000160
DO 850 I#1,15           0000170
850 CONCP(I)=XP1(I)     0000180
IF(ABS(PDATH#3400),GT,400,1)GO TO 855 0000190
IF(ABS(PHIVOL#5,5E5),GT,,5001E5) GO TO 855 0000200
IF(ABS(DE#1FL#3,7E4),GT,,5001E4) GO TO 855 0000210
IF(ABS(SBLDR#625,.)GT,375,1) GO TO 855 0000220
IF(ABS(CHFLR#3750,.)GT,3750,1) GO TO 855 0000230
IF(KGTR#T,GT,0) GO TO 855 0000240
GO TO 861               0000250
855 AFPTEG#1,0          0000260
RNG2#(SBLDR+DE#1FL* GTR)/PHIVOL 0000270
RHAL2#(DE#1FL*0,9+0,1*SBLDR)/PHIVOL 0000280
RK2G#161,76*PDATH/PHIVOL 0000290
DO 860 I#1,15           0000300
IF(I,GT,13) GO TO 858 0000310
CONCP(I)=CONCP(I)*RK2G#T,00091+DECON(I))/(RNG2+DECON(I)) 0000320
GO TO 860               0000330
858 CONCP(I)=CONCP(I)*RK2G#(,06064+DECON(I))/(RHAL2+DECON(I)) 0000340
860 CONTINUE           0000350
861 CONTINUE           0000360
IF(THU,EG,0,0)GO TO 880 0000370
IF(FPCOM,LE,0,0)GO TO 870 0000380
P#TYPE#1,0             0000390
DO 865 I#1,15           0000400
865 CONCS(I)=XF2(I)    0000410
CONCS(14)#6,6E#6      0000420
CONCS(15)#6,4E#6      0000430
R#STAR#,5617          0000440
IF(AFPTEG,EG,1,0) GO TO 890 0000450
IF(ABS(XLI#4,5E5),GT,,5001E5) GO TO 890 0000460
IF(ABS(TUSTFL#1,5E7),GT,,2001E7) GO TO 890 0000470
IF(ABS(THU#7,5E4),GT,2,5001E4) GO TO 890 0000480
IF(ABS(FPCOM#,65),GT,,1001) GO TO 890 0000490
GO TO 896              0000500
870 P#TYPE#2,0         0000510
DO 875 I#1,13           0000520
875 CONCS(I)=XF2(I)    0000530
CONCS(14)#1,1E#4      0000540
CONCS(15)#6,5E#5      0000550
R#STAR#,02            0000560
IF(AFPTEG,EG,1,0) GO TO 890 0000570
IF(ABS(XLI#4,5E5),GT,,5001E5) GO TO 890 0000580
IF(ABS(TUSTFL#1,5E7),GT,,2001E7) GO TO 890 0000590
IF(ABS(THU#9E3),GT,1,001E3) GO TO 890 0000600
IF(ABS(FPCOM#,005),GT,,005001) GO TO 890 0000610
GO TO 896              0000620
880 P#TYPE#3,0         0000630
DO 885 I#1,13           0000640
885 CONCS(I)=XF2(I)    0000650
CONCS(14)#1,3E#7      0000660
CONCS(15)#1,6E#7      0000670
IF(AFPTEG,EG,1,0)GO TO 890 0000680
IF(ABS(TUSTFL#1,5E7),GT,,2001E7) GO TO 890 0000690

```

```

IF(4BB(FFCOM=.65.GT.,100)) GO TO 890
GO TO 896
890 RHAL3=(TBD*PWRISC+.9*CON*JUSTEL*FFCOM)/XLI
DO M95 I=1,15
IF(I.GT.,13)GO TO 892
CONCS(I)=CONCS(I)*1.5E7/10STEL*TCUNCP(I)/XPI(I)
GO TO 895
892 KATM=3.7
IF(PATYPE,EN,3.0)GO TO 893
CONCS(I)=CONCS(I)*(4.5E5/XLI)*(INSTAN+DECOR(I))/RHAL3+DECOR(I)*
1(CUNCP(I)/XPI(I))
GO TO 895
893 CONCS(I)=CONCS(I)*(8.77E6/COLI*RHAL3)*(CUNCP(I)/XPI(I))
895 CONTINUE
896 PNOV=PNOV1/CUNYVL*60.

C
C THIS PART OF PROGRAM IS FOR KILOB GASES
C
C RYU=0.0
C D07I=1,15
C X2(I)=(DECOR(I)+PNOV/3600.)*T1
C IF (X2(I).GT.,75.) X2(I)=75.
C X3(I) = DECOR(I) * T3
C IF(X3(I).GT.,75.) X3(I) = 75.

C
C X4(I) = DECOR(I) * T4
C IF(X4(I).GT.,75.) X4(I) = 75.

C
C X5(I) = DECOR(I) * T5
C XDK=X5(I)
C IF(X5(I).GT.,75.) X5(I) = 75.
C XCRYU=DECOR(I)*600.
C IF(XCRYU.GT.,75.) XCRYU=75.

C
C IF(I.GT.,15)GO TO 1030

C
C IF(I.GT.,6) XDK=X4(I)
C IF(XCRYU,EN,1) CRYU=2.5E-4
C IF(I.GT.,6.AND.XCRYU,EN,1) CRYU=1.0E-4
C CTRPO(I)=(CUNCP(I)*PRIVOL*CLFNG)/DECOR(I)+PNOV)*1.692E-5
C ACUNT(I)=CTPRU(I)*(1.-EXP(-X2(I)))
C ASHIM(I)=(CUNCP(I)*SRB)/DECOR(I)*4.54E-4*(1.-EXP(-X3(I)))
C AXBL(I)=CUNCP(I)*AXLH*.1657*DPFKA
C CBPC(I)= EN * PNOV * (CTPRU(I)*T1/3600.+CTPRU(I)*(EXP(-X2(I))-1.)
1/DECOR(I)+PNOV)
C CBSP(I)=EN*ACUNT(I)
C CHL(I)=CBPC(I)+CBSP(I)
C ASHMC(I)=PE*ASHIM(I)*(EXP(-XDK)+CRYU*EXP(-XCRYU))*DPFKA
C ASHINS(I)=EM*CUNCP(I)*PRIVOL*4.54E-4*(EXP(-XDK)+CRYU*EXP(-XCRYU))
C EJT(I)=CONCS(I)*JUSTEL*3.977*DPFKA
C TBL(I)=CONCS(I)*THL*.3,977*DPFKA
C BVUG(I)=0.0
C TEST=1.0
C IF(CBL(I).LT.,TEST)CHL(I)=0.0
C IF(ASHINS(I).LT.,TEST)ASHINS(I)=0.0
C IF(ASHMC(I).LT.,TEST)ASHMC(I)=0.0
C IF(EJT(I).LT.,TEST)EJT(I)=0.0
C IF(TBL(I).LT.,TEST)TBL(I)=0.0
C IF(AXBL(I).LT.,TEST)AXBL(I)=0.0
C GO TO 1031

C
C THIS PART OF PROGRAM IS FOR IODINE

```

00006700  
00006710  
00006720  
00006730  
00006740  
00006750  
00006760  
00006770  
00006780  
00006790  
00006800  
00006810  
00006820  
00006830  
00006840  
00006850  
00006860  
00006870  
00006880  
00006890  
00006900  
00006910  
00006920  
00006930  
00006940  
00006950  
00006960  
00006970  
00006980  
00006990  
00007000  
00007010  
00007020  
00007030  
00007040  
00007050  
00007060  
00007070  
00007080  
00007090  
00007100  
00007110  
00007120  
00007130  
00007140  
00007150  
00007160  
00007170  
00007180  
00007190  
00007200  
00007210  
00007220  
00007230  
00007240  
00007250  
00007260  
00007270  
00007280  
00007290  
00007300

```

C
1030 CTPRO(I)=(CONCP(I)*PRIVOL*CLF1)/Z(DECOR(I)+PROV)*1.892E-5      00007310
ACUNT(I)=CTPRO(I)*1.0E+01*(1.0-EXP(-X2(I)))                          00007320
AXBL(I)=CONCP(I)*AUXLR*.1657*UPFNA*FAUX                             00007330
ASHIMC(I)=0.0                                                         00007340
ASHIMS(I)=0.0                                                         00007350
CHCP(I)= EN * PAVV * (CTPRO(I)*11/3600.0+CTPRO(I)*(EXP(-X2(I))-1.0) 00007360
1/(DECOR(I)+PROV))*UPFNA                                             00007370
CHSP(I)=EN*ACUNT(I)*UPFNA                                           00007380
CHL(I)=CHCP(I)+CHSP(I)                                              00007390
FVI=0.05                                                              00007400
EJT(I)=CONCP(I)*GENL*FVI*FEJ*.1657*UPFNA                            00007410
TBL(I)=CONCS(I)*CON*THL*.3,977*UPFNA                                00007420
BVUG(I)=CONCS(I)*THU*FV*.3,977*UPFNA                                00007430
IF(KID,ER,0) GO TO 4002                                              00007440
DLAK=((CF*.57,7CONV/L)+DECOR(I))                                    00007450
EXX2=DLAK*PURTIM                                                     00007460
IF(EXX2.GT.75.)EXX2=75.                                             00007470
EXPF=EXP(-EXX2)                                                       00007480
EXPC=1.-EXPF                                                           00007490
ELSS=UPFNA*CONCP(I)*PRIVOL*CLF1*1.892E-5/DLAK*EXPC                00007500
CHL(I)=CHSP(I)*EXPF+ELSS*EN*CHCP(I)*(1.-PURTIM/(3760.*UPFNA/EN)) 00007510
4002 TEST=0.0001                                                      00007520
IF(CHL(I).LT.TEST)CHL(I)=0.0                                         00007530
IF(EJT(I).LT.TEST)EJT(I)=0.0                                         00007540
IF(BVUG(I).LT.TEST)BVUG(I)=0.0                                       00007550
IF(TBL(I).LT.TEST)TBL(I)=0.0                                         00007560
IF(AXBL(I).LT.TEST)AXBL(I)=0.0                                       00007570
C
1031 CONTINUE                                                         00007580
C
7 CONTINUE                                                            00007590
MSIG=1                                                                 00007600
NSIG=15                                                                00007610
CALL SIGF2(CHL)                                                         00007620
CALL SIGF2(ASHIMS)                                                      00007630
CALL SIGF2(ASHIMC)                                                      00007640
CALL SIGF2(EJT)                                                         00007650
CALL SIGF2(BVUG)                                                         00007660
CALL SIGF2(TBL)                                                         00007670
CALL SIGF2(AXHL)                                                         00007680
DO 1035 I=1,15                                                         00007690
TOT(I)=CHL(I)+EJT(I)+TBL(I)+AXBL(I)+BVUG(I)+ASHIMC(I)+ASHIMS(I)    00007700
1035 CONTINUE                                                         00007710
CALL SIGF2(TOT)                                                         00007720
WRITE(51,906)                                                           00007730
WRITE(51,903)NAME                                                       00007740
WRITE(51,1051)                                                           00007750
1051 FORMAT(1H0,67X,'GASEOUS RELEASE RATE = CURIES PER  AIR')      00007760
WRITE(51,1052)                                                           00007770
1052 FORMAT(1H0,11X,'PRIMARY',4X,'SECONDARY',7X,'GAS STRIPPING',11X, 00007780
1'BUILDING VENTILATION'/12X,'COOLANT',5X,'COOLANT',5X,2(' '),        00007790
24X,30(' '),5X,'BLOWDOWN AIR EJECTOR TOTAL'/10X,'(MICROCI/GH)'(M00007800
3ICRUCI/GH SHUTDOWN CONTINUOUS REACTOR AUXILIARY TURBINE00007810
4 VENT OFFGAS EXHAUST')                                               00007820
WRITE(51,1053)                                                           00007830
1053 FORMAT(1H0,'-----')                                           00007840
1-----' )                                                            00007850
2-----' )                                                            00007860
1054 FORMAT('0 ',A8,2(2X,1PE10,3),6(3X,1PE8,1,1X))                  00007870
GASTOT=0.0                                                             00007880
00007890
00007900
00007910

```



```

DO 490 I=1,13
WRITE(51,1054)NUCLID(I),CONCP(I),CONCS(I),ASHIMS(I),ASHIMC(I),
1CHL(I),AXBL(I),TBL(I),BYUG(I),EJT(I),TOT(I)
GASTOT=GASTOT+TOT(I)
490 CONTINUE
DIV=10,*(INT(ALOG10(GASTOT))=1)
GASTOT=A[INT(GASTOT/DIV+0.5)*DIV
WRITE(51,1055) GASTOT
1055 FORMAT(1H0,' TOTAL NUBLE GASES',10I1,1PEB,1)
DO 492 I=14,15
WRITE(51,1054)NUCLID(I),CONCP(I),CONCS(I),ASHIMS(I),ASHIMC(I),
1CHL(I),AXBL(I),TBL(I),BYUG(I),EJT(I),TOT(I)
492 CONTINUE
WRITE(51,215)IM3RLG
WRITE(51,1053)
WRITE(51,231)
WRITE(51,906)
WRITE(51,903)NAME
WRITE(51,1060)
WRITE(51,1061)
WRITE(51,1053)
1060 FORMAT(1H0,54X,'AIRBORNE PARTICULATE RELEASE RATE=COUBES PER YEAR'
1)
1061 FORMAT(1H0,36X,'WASTE GAS',16X,'BUILDING VENTILATION'/2X,'NUCLIDE'
1,28X,'SYSTEM',14X,'REACTOR AUXILIARY',15X,'TOTAL')
WH=8760,*UPFRA/EN
DO 1070 I=1,8
PRCONT(I)=PCBCP(I)/(1E3*8760,*UPFRA)
IF(PNOV.GT,0.0) GO TO 1067
PCBCP(I)=0
PCBSP(I)=EN*PRCONT(I)*GH*CSHEPA
GO TO 1068
1067 PCBCP(I)=(EN*(WH*PRCONT(I)-PRCONT(I)/PNOV*(1.-EXP(-PNOV*WH))))
1*CNHEPA
PCBSP(I)=(EN*(PRCONT(I)/PNOV*(1.-EXP(-PNOV*GH))))*CSHEPA
1068 PCHL(I)=PCBCP(I)+PCBSP(I)
PAXBL(I)=PAXBP(I)/1E3*AXHEPA
PGHL(I)=PGHS(I)/1E3*GNHEPA
IF (KID.EQ,0) GO TO 1070
PDLAX=CFX*41.6/CONVUL
PEXX2=PDLAX*PURTIM
IF(PEXX2.GT,75,) PEXX2=75.
PEXPF=EXP(-PEXX2)
PEXPC=1.-PEXPF
PELSS=PRCONT(I)/PDLAX*PEXPC*CSHEPA
PCHL(I)=PCBSP(I)*PEXPF+PELSS*F+PCBCP(I)*(1.-PURTIM/(8760.*UPFRAZE
1N))
1070 CONTINUE
NSIG=2
NSIG=8
CALL SIGF2(PCHL)
DO 1075 I=1,8
PTOTP(I)=PCHL(I)+PAXBL(I)+PGHL(I)
1075 CONTINUE
CALL SIGF2(PTOTP)
DO 1076 I=1,8
WRITE(51,1062)PPAHT(I),PGHL(I),PCHL(I),PAXBL(I),PTOTP(I)
1076 CONTINUE
1062 FORMAT(1H0,46,28X,1PEB,1,11X,1PEB,1,4X,1PEB,1,16X,1PEB,1)
WRITE(51,1053)
GO TO 80

```

3-25

00007920  
00007930  
00007940  
00007950  
00007960  
00007970  
00007980  
00007990  
00008000  
00008010  
00008020  
00008030  
00008040  
00008050  
00008060  
00008070  
00008080  
00008090  
00008100  
00008110  
00008120  
00008130  
00008140  
00008150  
00008160  
00008170  
00008180  
00008190  
00008200  
00008210  
00008220  
00008230  
00008240  
00008250  
00008260  
00008270  
00008280  
00008290  
00008300  
00008310  
00008320  
00008330  
00008340  
00008350  
00008360  
00008370  
00008380  
00008390  
00008400  
00008410  
00008420  
00008430  
00008440  
00008450  
00008460  
00008470  
00008480  
00008490  
00008500  
00008510  
00008520



|    |   |          |
|----|---|----------|
|    | END   | 00008530 |
|    | SUBROUTINE SIGHZ(RLPT)                      | 00008540 |
|    | COMMON NSIG,NSIG                            | 00008550 |
|    | DIMENSION RLPT(NSIG)                        | 00008560 |
|    | IF (NSIG,EW,2) GO TO 30                     | 00008570 |
|    | DO 20 I=1,NSIG                              | 00008580 |
|    | IF (RLPT(I),EW,0,0) GO TO 20                | 00008590 |
|    | IF (I,GT,13) GO TO 10                       | 00008600 |
| C  | THIS PART OF SUBROUTINE IS FOR NOBLE GASES  | 00008610 |
|    | DIV=10,**(INT(ALOG10(RLPT(I))))+1)          | 00008620 |
|    | IF (RLPT(I),LT,10.) DIV=1.00                | 00008630 |
|    | RLPT(I)=AINT(RLPT(I)/DIV+0.5)*DIV           | 00008640 |
|    | GO TO 20                                    | 00008650 |
| C  | THIS PART OF SUBROUTINE IS FOR IODINE       | 00008660 |
| 10 | CONTINUE                                    | 00008670 |
|    | ISUR=2                                      | 00008680 |
|    | IF (RLPT(I),GT,1,0) ISUR=1                  | 00008690 |
|    | DIV=10,**(INT(ALOG10(RLPT(I))))+ISUR)       | 00008700 |
|    | RLPT(I)=AINT(RLPT(I)/DIV+0.5)*DIV           | 00008710 |
| 20 | CONTINUE                                    | 00008720 |
| 30 | CONTINUE                                    | 00008730 |
| C  | THIS PART OF SUBROUTINE IS FOR PARTICULATES | 00008740 |
|    | DO 50 I=1,NSIG                              | 00008750 |
|    | IF (RLPT(I),EW,0,) GO TO 50                 | 00008760 |
|    | DIV=10,**(INT(ALOG10(RLPT(I))))+2)          | 00008770 |
|    | RLPT(I)=AINT(RLPT(I)/DIV+0.5)*DIV           | 00008780 |
| 50 | CONTINUE                                    | 00008790 |
|    | RETURN                                      | 00008800 |
|    | END   | 00008810 |

```

C   GALE CODE FOR CALCULATING LIQUID EFFLUENTS FROM L-WRS. MODIFIED 00000010
C   JULY 1975 TO IMPLEMENT APPENDIX I TO 10 CFR PART 50, REACTOR 00000020
C   WATER CONCENTRATIONS CALCULATED USING METHODS OF DRAFT STANDARD 00000030
C   AND 237 TRADIDACTIVE MATERIALS IN PRINCIPAL FLUID STREAMS OF 00000040
C   LIGHT WATER COOLED NUCLEAR POWER PLANTS' DRAFT DATED MAY 20, 1974 00000050
C   MODIFIED EDITION OF ORIGEN PROGRAM TO COMPUTE EFFLUENTS FROM RWR 00000060
C   AND RWR RADWASTE SYSTEMS 00000070
C   00000080
C   LOGICAL DISCHG,PIWRIT 00000090
C   INTEGER*2 LOC,NONO,KD 00000100
C   REAL*4 LETDKN,NOGEN 00000110
C   REAL*4 LETDKA 00000120
C   REAL KKR,KXE,KNO,KHASS 00000130
C   INTEGER*2 NAME(3) 00000140
C   COMMON/ATRIX/4(2500),LOC(2500),NONO(800),KD(800) 00000150
C   COMMON/FLUX/FLUX(10),HNN,HOOT,INDEX,IXN,AXN,ERR,NOBLND,-ZERO 00000160
C   COMMON/PROCS/ NPROS,PRATE(8),NUPROSR, NZPHUS(R,20),PR(800) 00000170
C   COMMON/EQ/XZER(800),YZH(800),XTEMP(800),XNEW(10,800), 00000180
C   H(800),DI(800) 00000190
C   COMMON/FLUXN/1(20),PDWER(10),TDCAP(800),FISS(100),DIS(800),ILITE, 00000200
C   1 FACT,TFP,ITOT,-OK,INPT 00000210
C   COMMON/OUT/NUCL(800),TITLE(20),W(800),FG(800),CUTOFF(7), 00000220
C   1 PDH,HUMNUP,FLUXB,HSTAR,ALPHAN(100),SPONE(100),ARUND(500), 00000230
C   2 BASIS(10),TCNST,TUNIT 00000240
C   COMMON/CONC/PCONC(800),DWCINC(800),CWCNC(800),CMCNC(800), 00000250
C   1 SCON(800),RIW(800) 00000260
C   COMMON/COOL/REACTR,PHI,TYPE,PCVIL,LETDKN,NDRAS,SCVOL,STAVOL,NOGEN 00000270
C   1 ,NPURGE,NVESPG,SHLUR,GASOLA,STLKR,HLWDXN,EJCTR,XLKRAI, 00000280
C   2 GASLKR,CONDLR,IFRDRK,DFCSO, NZMRD, NZCRD, NE, PF, 00000290
C   3 STMR,PFEP,HEF,FRDM,DFMBS,CHFLR,DFI,DFCS,DF, 00000300
C   4 EDFLR,DFIED,DFCSO,DFED,D*FLR,DFIDW,DFCSO,DFDK,BILUT 00000310
C   5 ,SRA,EDA,DNA,C*FLR,C*FR,CXA,CYA,DFCH,DFIC,DFCSH, 00000320
C   6 DFC,DFIC,DFCSH,MHOLD,MHOLDX,MHOLDY,MHOLDZ 00000330
C   7 ,HOTFR,DFIR,DFCSH,DFR,MHOLD,REGENT, 00000340
C   8 SHFD,DFND,DFY,EDFD,DFMDE,DFYED,D*FD,DFMD,DFYD, 00000350
C   9 DFMRD,DFYD,CFD,DFMDC,DFYD,CFD,DFNUC,DFYD 00000360
C   A ,TS,TE,TD,TB,TC,ICH,TSTOR, TSTUR, TSTORR, T*SC,D*FL2,D*2,D*F2, 00000370
C   B T2,TSTOR2,DFID2,DFCS2,DFMD2,DFY2,DFD2,PFLAIN 00000380
C   COMMON/PCOOL/PGFR,DFIRG,DFCSG,DFRG,TRG,TSTORR,HGFD 00000390
C   COMMON/BDTES/RFART 00000400
C   COMMON /CONC/RCONC(800) 00000410
C   COMMON/CONC/PACONC(800),SCUTV(800),SCUTP(800),SCOT(800) 00000420
C   DIMENSION WORD13(4),WORD15(4),WORD18(5),WORD23(6),WORD28(7), 00000430
C   1 WORD33(9),WORD10(3),WORD8(2),WORD40(10) 00000440
C   DIMENSION REACTR(7),NZMRD(26),NZCRD(26) 00000450
C   DIMENSION FACT(10),XCONP(20),INUCL(20) 00000460
C   DATA YES/YES1/ 00000470
C   RCONC CONTAINS PRIMARY COOLANT CONCENTRATIONS FOR RWR'S. THE 00000480
C   FOLLOWING ISOTOPES (WITH THEIR CONCENTRATIONS IN UCI/GR) ARE 00000490
C   ALSO PRESENT IN THE PRIMARY COOLANT BUT ARE NOT CONSIDERED 00000500
C   SIGNIFICANT IN EFFLUENT CALCULATIONS IN=13,,05 IN=16,AD IN=17,,009; 00000510
C   D=19,,7;F=18,,004, 00000520
C   PACONC CONTAINS PRIMARY COOLANT CONCENTRATIONS FOR PWR'S. SCUTV, 00000530
C   SCUTP, AND SCOT CONTAIN SECONDARY COOLANT CONCENTRATIONS FOR 00000540
C   PLANTS WITH U-TURE STEAM GENERATORS AND VOLATILE SECONDARY CHEM- 00000550
C   ISTRY; FOR PLANTS WITH U-TURE STEAM GENERATORS AND PHOSPHATE 00000560
C   SECONDARY CHEMISTRY; AND FOR PLANTS WITH ONCE-THROUGH STEAM 00000570
C   GENERATORS, RESPECTIVELY. 00000580
C   DATA NTRY,NTER/0,0/,PWR1/ PWR1/,RWR1/ RWR1/ 00000590
C   00000600

```

C READ NUCLEAR DATA AND CONSTRUCT TRANSITION MATRIX

C 10 CALL NUDATA(NLINE)

C 20 DO 20 I=1,ITOT  
NMO(I)=NMO(I)+NMO(I)\*I

C 30 KD(I)=KD(I)+NMO(I)-1

C 40 DISCHG=.FALSE.

C 50 RWRITE=.FALSE.

C 60 XTR=0

C 70 INCK=0

C 80 LXR=0.0

C 90 PXR=0.0

C 100 BUR=0.0

C 110 BOTP=1.0

C 120 QX=0.001

C 130 AX=ALOG(QX)

C 140 NEBITOT

C 150 TCONSYSTEM=0.0

C 160 FDR=0.0

C 170 TMS=0.0

C 180 TSS=0.0

C 190 T2=0.0

C 200 YSTR2=0.0

C 210 O=FL2=0.0

C 220 O=2=0.0

C 230 O=2=0.0

C 240 DO 40 J=1,ROO

C 250 PCO=C(J)=0.0

C 260 D=CINC(J)=0.0

C 270 SCUN(J)=0.0

C 280 RIV(J)=0.0

C 290 C=CNC(C(J))=0.0

C 300 C=CNC(C(J))=0.0

C 310 XZ(C(J))=0.0

C 40 CONTINUE

C READ DESCRIPTION OF REACTOR AND RADWASTE TREATMENT PLANT

C DIMENSION MOR56(14)

C PRINT 9026

C READ 9010,REACTR,TYPE

C PRINT 9010,REACTR,TYPE

C READ 9011,MOR56,PCV1

C PRINT 9011,MOR56,PCV1

C PFM=0

C PRINT 9027

C IF TYPE EQ BUR) GO TO 50

C READ DATA FOR PER LIQUID CODE

C READ 9022,MOR56,PCVOL

C PRINT 9022,MOR56,PCVOL

C FAIL=0.12

C PRINT 9028,FAIL

C READ 9012,MOR56,LETD=K

C PRINT 9012,MOR56,LETD=K

C READ 9012,MOR56,CHFLR

C PRINT 9012,MOR56,CHFLR

C READ 9011,MOR56,MOR56

C PRINT 9011,MOR56,MOR56

C READ 9022,MOR56,STPER

00000410  
00000420  
00000430  
00000440  
00000450  
00000460  
00000470  
00000480  
00000490  
00000700  
00000710  
00000720  
00000730  
00000740  
00000750  
00000760  
00000770  
00000780  
00000790  
00000800  
00000810  
00000820  
00000830  
00000840  
00000850  
00000860  
00000870  
00000880  
00000890  
00000900  
00000910  
00000920  
00000930  
00000940  
00000950  
00000960  
00000970  
00000980  
00000990  
0001000  
0001010  
0001020  
0001030  
0001040  
0001050  
0001060  
0001070  
0001080  
0001090  
0001100  
0001110  
0001120  
0001130  
0001140  
0001150  
0001160  
0001170  
0001180  
0001190  
0001200  
0001210

|      |  |          |
|------|--|----------|
|      | PRINT 9022,WORD56,STMR                                       | 00001220 |
|      | READ 9022,WORD56,*ST   | 00001230 |
|      | PRINT 9022,WORD56,*ST  | 00001240 |
|      | READ 9022,WORD56,*LI   | 00001250 |
|      | PRINT 9022,WORD56,*LI  | 00001260 |
|      | SCVOL#NOGEN**LI  | 00001270 |
|      | PRINT 9029,SCVOL   | 00001280 |
|      | READ 9011,WORD56,TMSC  | 00001290 |
|      | PRINT 9011,WORD56,TMSC                                       | 00001300 |
|      | READ 9055,RLWDWN,*FNRT                                       | 00001310 |
|      | PRINT 9051,RLWDWN  | 00001320 |
|      | FNRT**FNRT   | 00001330 |
|      | IF(FNRT.GT.1.0) FNRT#1.0                                     | 00001340 |
|      | PRINT 9041   | 00001350 |
|      | READ 9012,WORD56,REGENT                                      | 00001360 |
|      | PRINT 9012,WORD56,REGENT                                     | 00001370 |
|      | IF(RLWDWN.FW.0.0) GO TO 41                                   | 00001380 |
|      | FPEF#0.001   | 00001390 |
|      | HEF#0.01   | 00001400 |
|      | PRINT 9030,FPEF,HEF  | 00001410 |
|      | GO TO 44   | 00001420 |
| 41   | FPEF#1.0   | 00001430 |
|      | HEF#1.0  | 00001440 |
|      | PRINT 9030,FPEF,HEF  | 00001450 |
| 44   | CONTINUE   | 00001460 |
|      | READ 9020,WORD56,FFCDM                                       | 00001470 |
|      | PRINT 9020,WORD56,FFCDM                                      | 00001480 |
|      | IF(FFCDM.LT.0.001)GO TO 4444                                 | 00001490 |
|      | DFCH#10.0  | 00001500 |
|      | DFCHCS#2.0   | 00001510 |
|      | GO TO 4445   | 00001520 |
| 4444 | DFCH#1.0   | 00001530 |
|      | DFCHCS#1.0   | 00001540 |
| 4445 | CONTINUE   | 00001550 |
|      | READ 9011,WORD56,DILUT                                       | 00001560 |
|      | PRINT 9011,WORD56,DILUT                                      | 00001570 |
|      | READ 9056,WORD18,SBLDM                                       | 00001580 |
|      | C#A#1.0  | 00001590 |
|      | READ 9014,DFICH,DFCSC#,DFC#                                  | 00001600 |
|      | READ 9015,TC,TSTORC,C#FD                                     | 00001610 |
|      | PRINT 9045   | 00001620 |
|      | PRINT 9016   | 00001630 |
|      | PRINT 9017,WORD18,SBLDR,C#A,C#FD,TC,TSTORC,DFICH,DFCSC#,DFC# | 00001640 |
|      | READ 9013,WORD18,EDFLR,*WORD8,EDA                            | 00001650 |
|      | READ 9014,DFIED,DFCSED,DFED                                  | 00001660 |
|      | READ 9015,TE,TS,EDFD   | 00001670 |
|      | PRINT 9017,WORD18,EDFLR,EDA,EDFD,TE,TS,DFIED,DFCSED,DFED     | 00001680 |
|      | READ 9013,WORD18,D*FLR,D*4,D*4                               | 00001690 |
|      | READ 9014,DFID#,DFCSD#,DFD#                                  | 00001700 |
|      | READ 9015,TD,TSTORD,D*FD                                     | 00001710 |
|      | PRINT 9017,WORD18,D*FLR,D*4,D*4,TD,TSTORD,DFID#,DFCSD#,DFD#  | 00001720 |
|      | READ 9013,WORD18,D*FL2,*WORD8,D*2                            | 00001730 |
|      | READ 9014,DFID2,DFCS02,DFD2                                  | 00001740 |
|      | READ 9015,T2,TSTOR2,D*F2                                     | 00001750 |
|      | PRINT 9017,WORD18,D*FL2,D*2,D*F2,T2,TSTOR2,DFID2,DFCS02,DFD2 | 00001760 |
|      | READ 9037,HDTRF  | 00001770 |
|      | READ 9014,DFICH,DFCSC#,DFC#                                  | 00001780 |
|      | READ 9015,TC#,TSTOR#,C#FD                                    | 00001790 |
|      | READ 9037,RGWFR  | 00001800 |
|      | READ 9014,DFIRG,DFCSR#,DFW#                                  | 00001810 |
|      | READ 9015,TRG,TSTOR#,RGFD                                    | 00001820 |

C  
C  
C

05-3

```

IF (HLWDKN, EQ, 0, 0) GO TO 45
RDFR=HLWDKN*1E3*HDFR/0.3476
PRINT 9034, HDFR, CMFD, TCM, TSTORR, DFICM, DFCSCH, DFCH
RDFR=HLWDKN*1.0E3*AH8(1,=HDFR)/0.3476
PRINT 9035, HDFR
IF (FFCDM, EQ, 0, 0) GO TO 46
45 CONTINUE
IF (REGENT, EQ, 0, 0) GO TO 47
PRINT 9038, RG*FR, RGFD, THG, TSTORR, DFIRG, DFCSRG, DFRG
GO TO 46
47 RG*FR=0.0
PRINT 9038, RG*FR, RGFD, THG, TSTORR, DFIRG, DFCSRG, DFRG
46 CONTINUE
IF (==H1, EQ, 0) GO TO 4446
FNRTSI=1.0-1.0/(DFCH*DFCH)
FNRTSI=1.0-1.0/(DFICH*DFCH)
FNRTSC=1.0-1.0/(DFCSCH*DFCHCS)
GO TO 4447
4446 FNRTSI=1.0
FNRTSI=1.0
FNRTSC=1.0
4447 CONTINUE
READ DATA FOR MWR GAS CODE
PRINT 9046
READ 9021, XGTRNT
IF (XGTRNT, EQ, 0) PRINT 9053
IF (XGTRNT, EQ, 1) PRINT 9052
IF (XGTRNT, EQ, 2) PRINT 9075
READ 9012, *DR056, TAU1
PRINT 9012, *DR056, TAU1
READ 9012, *DR056, TAU2
PRINT 9012, *DR056, TAU2
READ 9012, *DR056, TAU3
PRINT 9012, *DR056, TAU3
G*HEPA=1.0
FRIAR=1.0
AXHEPA=1.0
FPEP=1.0
CSHEPA=1.0
FPPR=1.0
CNHEPA=1.0
READ 9065, *DR015, GWHT
IF (GWHT, EQ, YES) G*HEPA=0.01
PRINT 9066, *DR015, G*HEPA
READ 9067, *DR018, AXCH, AXHT
IF (AXCH, EQ, YES) FRIAR=0.1
IF (AXHT, EQ, YES) AXHEPA=0.01
PRINT 9068, *DR018, FRIAR, AXHEPA
READ 9022, *DR056, CONVCL
PRINT 9022, *DR056, CONVCL
READ 9022, *DR056, CFM
PRINT 9022, *DR056, CFM
READ 9071, *DR018, CSCH, CRHT, ENPD
IF (CSCH, EQ, YES) FPPR=0.1
IF (CRHT, EQ, YES) CSHEPA=0.01
ENPD, R*ENPD
PRINT 9072, EN
PRINT 9066, *DR018, FPEP, CSHEPA
READ 9069, *DR018, PNOV1, CNCH, CAHT

```

```

00001830
00001840
00001850
00001860
00001870
00001880
00001890
00001900
00001910
00001920
00001930
00001940
00001950
00001960
00001970
00001980
00001990
00002000
00002010
00002020
00002030
00002040
00002050
00002060
00002070
00002080
00002090
00002100
00002110
00002120
00002130
00002140
00002150
00002160
00002170
00002180
00002190
00002200
00002210
00002220
00002230
00002240
00002250
00002260
00002270
00002280
00002290
00002300
00002310
00002320
00002330
00002340
00002350
00002360
00002370
00002380
00002390
00002400
00002410
00002420
00002430
00002440
00002450
00002460
00002470
00002480

```

```

IF(CNCH,EG,YES)PFPR#0,1
IF(CNHT,EG,YES)CN=EP#0,01
IF (PNOV1,LT,1,0) GO TO 4448
PRINT 9070,WORD18,PNOV1,WORD18,PFPRN,CNHEPA
GO TO 4449
4448 PRINT 9073
4449 CONTINUE
TALK#1700,
PRINT 9064,TALK
READ 9020,WORD56,EVA
PRINT 9020,WORD56,EVA
READ 9020,WORD56,FEJ
PRINT 9020,WORD56,FEJ
KCRYD#0,0
IF(KCRYD,ER,0,0) GO TO 48
PRINT 9039
GO TO 49
48 PRINT 9040
49 CONTINUE
READ 9020,WORD56,PFLAUN
IF(PFLAUN,LE,0,0) PRINT 9048
PRINT 9026

C
C
C
CONVERSION OF UNITS
EDFLR#EDFLR*48,R
D*FLR#D*FLR*48,R
D*FL2#D*FL2*48,R
GO TO 240

C
C
C
READ DATA FOR B*E LIQUID CODE
50 READ 9022,WORD56,STMR
PRINT 9022,WORD56,STMR
READ 9022,WORD56,PCVOL
PRINT 9022,WORD56,PCVOL
FPEF#0,001
HEF#0,020
PRINT 9030,FPEF,HEF
READ 9022,WORD56,LETOX
PRINT 9022,WORD56,LETOX
READ 9022,WORD56,REGENT
PRINT 9022,WORD56,REGENT
READ 9022,WORD56,FFCOM
PRINT 9022,WORD56,FFCOM
READ 9022,WORD56,CILUT
PRINT 9022,WORD56,DILUT
PRINT 9045
READ 9013,WORD18,C*FLR,WORD8,C*F
READ 9014,DFICW,DFCSC*,DFC*
READ 9015,TC*,TSTORC,C*F0
PRINT 9016
PRINT 9017,WORD18,C*FLR,C*F,C*F0,TC*,TSTORC,DFIC*,DFCSC*,DFC*
READ 9013,WORD18,D*FLR,WORD8,D*F
READ 9014,DFIDW,DFCSD*,DFD*
READ 9015,TD*,TSTORD,D*F0
PRINT 9017,WORD18,D*FLR,D*F,D*F0,TD*,TSTORD,DFID*,DFCSD*,DFD*
READ 9013,WORD18,C*FER,WORD8,CHA
READ 9014,DFICW,DFCSCW,DFCW
READ 9015,TCW,TSTORW,C*F0
PRINT 9017,WORD18,C*FER,CHA,C*F0,TCW,TSTORW,DFICW,DFCSCW,DFCW

```

```

00002490
00002500
00002510
00002520
00002530
00002540
00002550
00002560
00002570
00002580
00002590
00002600
00002610
00002620
00002630
00002640
00002650
00002660
00002670
00002680
00002690
00002700
00002710
00002720
00002730
00002740
00002750
00002760
00002770
00002780
00002790
00002800
00002810
00002820
00002830
00002840
00002850
00002860
00002870
00002880
00002890
00002900
00002910
00002920
00002930
00002940
00002950
00002960
00002970
00002980
00002990
00003000
00003010
00003020
00003030
00003040
00003050
00003060
00003070
00003080
00003090

```

C  
C  
C

```
READ 9037, RGWFK 00003100
READ 9014, DFIRG, DFCSRG, DFRG 00003110
READ 9015, TRG, TSTORR, RGFD 00003120
PRINT 9038, RGWFK, XGFD, TRG, TSTORR, DFIRG, DFCSRG, DFRG 00003130
00003140
READ DATA FOR BWR GAS CODE 00003150
00003160
PRINT 9046 00003170
READ 9022, WORD56, GGS 00003180
PRINT 9022, WORD56, GGS 00003190
READ 9022, WORD56, -STE 00003200
PRINT 9022, WORD56, XSTE 00003210
READ 9011, WORD56, TIM3 00003220
PRINT 9011, WORD56, TIM3 00003230
READ 9011, WORD56, TIM4 00003240
PRINT 9011, WORD56, TIM4 00003250
HEPA1#1,0 00003260
FIL1#1,0 00003270
HEPA2#1,0 00003280
FIL2#1,0 00003290
HEPA5#1,0 00003300
FIL5#1,0 00003310
HEPA6#1,0 00003320
FIL6#1,0 00003330
CSR#1,0 00003340
READ 9060, WORD15, CHCH, CHHEPA 00003350
IF (CHCH, EQ, YES) FIL1#0,1 00003360
IF (CHHEPA, EQ, YES) HEPA1#0,01 00003370
PRINT 9061, WORD15, FIL1, HEPA1 00003380
READ 9062, WORD15, TRCH, TRHEPA, TRCS 00003390
IF (TRCH, EQ, YES) FIL2#0,1 00003400
IF (TRHEPA, EQ, YES) HEPA2#0,01 00003410
IF (TRCS, EQ, YES) CSR#0,2 00003420
PRINT 9063, WORD15, FIL2, HEPA2, CSR# 00003430
READ 9022, WORD56, FIL3 00003440
PRINT 9022, WORD56, FIL3 00003450
READ 9022, WORD56, FIL4 00003460
PRINT 9022, WORD56, FIL4 00003470
READ 9060, WORD15, AXCH, AXHEPA 00003480
IF (AXCH, EQ, YES) FIL5#0,1 00003490
IF (AXHEPA, EQ, YES) HEPA5#0,01 00003500
PRINT 9061, WORD15, FIL5, HEPA5 00003510
READ 9061, WORD15, R=CH, R=HEPA 00003520
IF (R=CH, EQ, YES) FIL6#0,1 00003530
IF (R=HEPA, EQ, YES) HEPA6#0,01 00003540
PRINT 9061, WORD15, FIL6, HEPA6 00003550
READ 9021, KCHAR 00003560
READ 9012, WORD56, KKR 00003570
READ 9011, WORD56, KXE 00003580
READ 9012, WORD56, KNO 00003590
READ 9022, WORD56, KMASS 00003600
IF (KCHAR, EQ, 0) GO TO 54 00003610
IF (KCHAR, EQ, 1) GO TO 55 00003620
PRINT 9023 00003630
GO TO 56 00003640
54 PRINT 9024 00003650
GO TO 56 00003660
55 F#10, *KNO 00003670
CHT11#(0,53*KKR*KMASS)/(F*24,*2.) 00003680
CHT12#(0,53*KXE*KMASS)/(F*24,*2.) 00003690
PRINT 9025, KKH, KXE, KNO, KMASS, CHT11, CHT12 00003700
```



```

56 CONTINUE
  READ 9020, *ORD56, PFLAUN
  IF (PFLAUN, LE, 0, 0) PRINT 9028
  PRINT 9026
57 DO 58 I=1, ITOT
  B(I)=0, 0
58 CONTINUE
C
  DFIED=1,
  DFCSFD=1,
  DFED=1,
  DFID2=1,
  DFCSD2=1,
  DFD2=1,
240 CONTINUE
C
  CALCULATE PRIMARY COOLANT CONCENTRATIONS FOR PWR
C
  IF (TYPE, EQ, 8) GO TO 251
  AFPTES=0, 0
  DO 242 I=1, ITOT
242 PCOINC(I)=P*COINC(I)
  POWA=POW*I
  PCVDA=PCVOL*1E3
  LETDA=LETD*LN*500, 53
  SHLDA=SHLDR*, 3476
  CRFLA=CHFLR*500, 53
C
  CHECK TO SEE IF PRIMARY PLANT PARAMETERS ARE WITHIN SPECIFIED
  RANGES
  IF (ABS(POWA-3400), GT, 400, 1) GO TO 243
  IF (ABS(PCVDA-5, 5E5), GT, 0, 5001E5) GO TO 243
  IF (ABS(LETD-3, 7E4), GT, 0, 5001E4) GO TO 243
  IF (ABS(SHLDA-625, ), GT, 375, 1) GO TO 243
  IF (ABS(CRFLA-3750, ), GT, 3750, 1) GO TO 243
  GO TO 247
C
  CALCULATE PWR PRIMARY COOLANT ADJUSTMENT FACTORS
243 AFPTES=1, 0
  RHAL2=(LETD-1*0, 9+0, 1*SHLDA)/PCVDA
  RCSRH2=(LETD*0, 5+0, 5*(SHLDA+CRFLA*0, 9))/PCVDA
  RCFP2=(LETD*0, 9+0, 1*(SHLDA+CRFLA*0, 9))/PCVDA
  RK2=161, 76*POWA/PCVDA
  DO 246 J=1, ITOT
  IF (PCOINC(J), EQ, 0, 0) GO TO 246
  NZ=NUCL(J)/10000
  DL=DIS(J)*3600,
  IF (NZ, EQ, 53, OR, NZ, EQ, 35) GO TO 244
  IF (NZ, EQ, 37, OR, NZ, EQ, 55) GO TO 245
  PCOINC(J)=PCOINC(J)*RK2*(0, 0612+DL)/(RCFP2+DL)
  GO TO 246
244 PCOINC(J)=PCOINC(J)*RK2*(0, 0606+DL)/(RHAL2+DL)
  GO TO 246
245 PCOINC(J)=PCOINC(J)*RK2*(0, 0371+DL)/(RCSRH2+DL)
246 CONTINUE
247 SHLDR=SHLDR*48, 8
  PCVOL=PCVOL*1000, *0, 7/62, 4
C
  CALCULATE PWR SECONDARY COOLANT CONCENTRATIONS
  SCVDA=SCVOL*1E3
  BLDA=BLD*LN*1E3
  STHFA=STHFR*1F6
  FPCDA=FFCDM
C
  CHECK TO SEE IF SECONDARY PLANT PARAMETERS ARE WITHIN SPECIFIED

```

```

00003710
00003720
00003730
00003740
00003750
00003760
00003770
00003780
00003790
00003800
00003810
00003820
00003830
00003840
00003850
00003860
00003870
00003880
00003890
00003900
00003910
00003920
00003930
00003940
00003950
00003960
00003970
00003980
00003990
00004000
00004010
00004020
00004030
00004040
00004050
00004060
00004070
00004080
00004090
00004100
00004110
00004120
00004130
00004140
00004150
00004160
00004170
00004180
00004190
00004200
00004210
00004220
00004230
00004240
00004250
00004260
00004270
00004280
00004290
00004300
00004310

```



```

C  RANGES
  IF(BLMDHN.EQ.0.0) GO TO 263
  IF(PWCOM.LE.0.01) GO TO 261
  PHTYPE=2.0 IS A PLANT WITH U-TUBE STEAM GENERATORS AND VOLATILE
  SECONDARY CHEMISTRY
  PHTYPE=2.0
  DO 240 I=1,ITOT
    SCON(I)=SCUTV(I)
  IF(APTES.EQ.1.0) GO TO 266
  IF(ABS(SCVDA-4.5E5).GT.0.5001E5)GO TO 266
  IF(ABS(STWA-1.5E7).GT.0.2001E7)GO TO 266
  IF(ABS(BLMDMA-7.5E4).GT.2.5001E4)GO TO 266
  IF(ABS(PFCA-0.05).GT.0.10001)GO TO 266
  IF(NRTSC.LT.0.8999)GO TO 278
  GO TO 276
C  PHTYPE=3.0 IS A PLANT WITH U-TUBE STEAM GENERATORS AND PHOSPHATE
  SECONDARY CHEMISTRY
  PHTYPE=3.0
  DO 262 I=1,ITOT
    SCON(I)=SCUTP(I)
  IF(APTES.EQ.1.0) GO TO 266
  IF(ABS(SCVDA-4.5E5).GT.0.5001E5)GO TO 266
  IF(ABS(STWA-1.5E7).GT.0.2001E7)GO TO 266
  IF(ABS(BLMDMA-9E3).GT.1.001E3)GO TO 266
  IF(ABS(PFCA-0.05).GT.0.05001)GO TO 266
  IF(NRTSC.LT.0.8999)GO TO 278
  GO TO 276
C  PHTYPE=1.0 IS A PLANT WITH ONCE-THROUGH STEAM GENERATORS
  SECONDARY CHEMISTRY
  PHTYPE=1.0
  DO 264 I=1,ITOT
    SCON(I)=SCOT(I)
  IF(APTES.EQ.1.0) GO TO 266
  IF(ABS(STWA-1.5E7).GT.0.2001E7)GO TO 266
  IF(ABS(PFCA-0.65).GT.0.10001)GO TO 266
  GO TO 276
C  CALCULATE PHR SECONDARY COOLANT ADJUSTMENT FACTORS
  RHAL=(BLMDMA*PNTSI+0.9*MEP*STWPA*PFCA)/SCVDA
  RCBRS=(BLMDMA*NRTSC+0.5*PEP*STWA*PFCA)/SCVDA
  RCPFR=(BLMDMA*PNTS+0.9*PEP*STWA*PFCA)/SCVDA
  IF(PHTYPE.EQ.1.0)GO TO 274
  RK3=4.5E5/SCVDA
  IF(PHTYPE.EQ.2.0)GO TO 270
  DO 269 I=1,ITOT
    IF(SCON(I).EQ.0.0)GO TO 269
    NZ=NUCL(I)/1000
    DL=DIS(I)*2600
    IF(NZ.EQ.53.OR.NZ.EQ.35) GO TO 267
    IF(NZ.EQ.31.OR.NZ.EQ.55) GO TO 266
    SCON(I)=SCON(I)*RK3*(1.02+DL)/(RCPFR+DL)*PWCNC(I)
    GO TO 269
  SCON(I)=SCON(I)*RK3*(1.02+DL)/(RHAL+DL)*PWCNC(I)
  GO TO 269
  SCON(I)=SCON(I)*RK3*(1.02+DL)/(RCBRS+DL)*PWCNC(I)
  CONTINUE
  GO TO 278
  CONTINUE
  DO 273 I=1,ITOT
    IF(SCON(I).EQ.0.0)GO TO 273
    NZ=NUCL(I)/1000
    DL=DIS(I)*3600
    IF(NZ.EQ.53.OR.NZ.EQ.35)GO TO 271

```



3-96

```

305 CONTINUE
C CALCULATE RADIOISOTOPE INVENTORIES ON PAR CONDENSATE RESINS
T(I)*REGENT
CALL SOLVE
DO 330 I=1,ITOT
330 RINV(I)*XTEPR(I)
CALL EFFTAB
GO TO 30

C
C
251 CONTINUE
C CALCULATE BWR PRIMARY COOLANT CONCENTRATIONS
DO 225 I=1,ITOT
225 PCOHC(I)=PCOHC(I)
PCO=PCO*I
PCVDA=PCVOL*1E6
LETD=LETD*N*1E6
STMFA=STMFR*1E6
FFCDA=FFCDM
C CHECK TO SEE IF PLANT PARAMETERS ARE WITHIN SPECIFIED RANGES
IF(ABS(PCO-3400),GT,400)GO TO 252
IF(ABS(PCVDA-3,RE5),GT,0.4001E5)GO TO 252
IF(ABS(LETD-1.3E5),GT,0.2001E5)GO TO 252
IF(ABS(STMFA-1.5E7),GT,0.2001E7)GO TO 252
IF(ABS(FFCDA-0.9),GT,0.1001)GO TO 252
GO TO 256
C CALCULATE BWR ADJUSTMENT FACTORS
252 RHAL2=((LETD-0.9+FFCDA*STMFA*0.01E)/PCVDA
RCSRH2=((LETD-0.5+FFCDA*STMFA*5E-4)/PCVDA
RCFP2=((LETD-0.9+FFCDA*STMFA*9E-4)/PCVDA
RK2=111.76*PCO/PCVDA
DO 255 J=1,ITOT
IF(PCOHC(J),EQ,0,0) GO TO 255
NZ=NUCL(J)/10000
DL=DIS(J)*3600
IF (NZ,EQ,53,OR,NZ,EQ,35)GO TO 253
IF (NZ,EQ,37,OR,NZ,EQ,55)GO TO 254
PCOHC(J)=PCOHC(J)*RK2*(0.3434+DL)/(RCFP2+DL)
GO TO 255
253 PCOHC(J)=PCOHC(J)*RK2*(0.1908+DL)/(RCSRH2+DL)
GO TO 255
254 PCOHC(J)=PCOHC(J)*RK2*(0.1908+DL)/(RCSRH2+DL)
255 CONTINUE
256 PCVOL=PCVOL*1000000./62.4
LETD=N*LETD*N*2000.
STMFR=STMFR*2R51.
DO 2255 J=1,ITOT
IF (PCOHC(J),GT,0,0)PCOHC(J)=PCOHC(J)/(DIS(J)*1.6283E13)
2255 CONTINUE
IF(REGENT,GT,0,0) GO TO 257
CALL EFFTAB
GO TO 30

C
C
COMPUTE REMOVAL CONSTANT FOR CONDENSATE DEMINERALIZER IN BWR
257 CCRDM=0.9*STMFR*FFEF/(PCVOL*7.48*60.)*FFCDM
CSRDM=0.5*STMFR*FFEF/(PCVOL*7.48*60.)*FFCDM
DO 258 I=1,ITOT
NZ=NUCL(I)/10000
PR(I)=CCRDM
IF(NZ,EQ,53,OR,NZ,EQ,35)PR(I)=CCRDM*HEF/FFEF
IF(NZ,EQ,37,OR,NZ,EQ,55)PR(I)=CSRDM

```

```

00005540
00005550
00005560
00005570
00005580
00005590
00005600
00005610
00005620
00005630
00005640
00005650
00005660
00005670
00005680
00005690
00005700
00005710
00005720
00005730
00005740
00005750
00005760
00005770
00005780
00005790
00005800
00005810
00005820
00005830
00005840
00005850
00005860
00005870
00005880
00005890
00005900
00005910
00005920
00005930
00005940
00005950
00005960
00005970
00005980
00005990
00006000
00006010
00006020
00006030
00006040
00006050
00006060
00006070
00006080
00006090
00006100
00006110
00006120
00006130
00006140

```

|      |  |  |
|------|--|--|
|      | XZMJ=PCONC(I)*PR(I)*PCVOL*0.02832  | 00006150   |
|      | R(I)=XZMJ  | 00006160   |
|      | XZH(I)=XZMJ*86400.   | 00006170   |
| 258  | CONTINUE   | 00006180   |
|      | XZERO(I)=0.  | 00006190   |
| C    | CALCULATE INVENTORIES ON BKR CONDENSATE RESINS   | 00006200   |
| 290  | T(I)=REGENT  | 00006210   |
|      | CALL SOLVE   | 00006220   |
|      | DO 295 I=1,ITOT  | 00006230   |
| 295  | RINV(I)=XTEMP(I)   | 00006240   |
|      | CALL EFRTAB  | 00006250   |
|      | GO TO 30   | 00006260   |
| C    |  | 00006270   |
| C    | FORMATS  | FORMATS  |
| C    |  | FORMATS  |
| 9000 | FORMAT(20A4)   | 00006300   |
| 9001 | FORMAT(10E8,2)   | 00006310   |
| 9002 | FORMAT(8E10,3)   | 00006320   |
| 9003 | FORMAT(5(16,F9,2),I5)  | 00006330   |
| 9004 | FORMAT(16I5)   | 00006340   |
| 9005 | FORMAT('10MMN OR MORE EXCEEDS DIMENSIONS')   | 00006350   |
| 9006 | FORMAT('10MMN SHOULD NOT EXCEED MMN BY MORE THAN 10%')   | 00006360   |
| 9007 | FORMAT(8(8,2,I2))  | 00006370   |
| 9008 | FORMAT(20I4)   | 00006380   |
| 9009 | FORMAT(10A4,F7,0,A3,F10,3)   | 00006390   |
| 9010 | FORMAT(32X,7A4,16X,A4)   | 00006400   |
| 9011 | FORMAT(16X,13A4,A3,F9,0)   | 00006410   |
| 9012 | FORMAT(16X,14A4,F8,4)  | 00006420   |
| 9013 | FORMAT(15X,4A4,A2,8X,FR,0,1X,A4,A2,F5,3)   | 00006430   |
| 9014 | FORMAT(20X,FB,0,2(5X,FB,0))  | 00006440   |
| 9015 | FORMAT(27X,FB,2,10X,FB,2,10X,FB,2)   | 00006450   |
| 9016 | FORMAT('10',30X,'FRACTION FRACTION COLLECTION DECAY',10X,'STREAM<br>1 FLOW RATE OF PCA DISCHARGED TIME TIME',10X,'DECONTAMINATION<br>2 MINUTION FACTORS',20X,'(GAL/DAY)',23X,'(DAYS) (DAYS)',7X,<br>3'I',RX,'CS',8X,'OTHERS')  | 00006460<br>00006470<br>00006480<br>00006490                         |
| 9017 | FORMAT(2X,4A4,A2,1PE9,2,1X,4(0PF8,3,2X),3(1PE9,2,1X))  | 00006500   |
| 9020 | FORMAT(16X,14A4,FR,4)  | 00006510   |
| 9021 | FORMAT(79X,I1)   | 00006520   |
| 9022 | FORMAT(16X,14A4,FR,4)  | 00006530   |
| 9023 | FORMAT(16X,'THERE IS A CRYOGENIC DISTILLATION COLUMN',20X,'IODINE<br>1 AND XENON DECONTAMINATION FACTOR',T71,'10000.',1/20X,'KRYPTON DECONTAMINATION<br>2 AMINATION FACTOR',T72,'10000.',1/20X,'KRYPTON AND XENON HOLDUP TIME (DAYS)',<br>3DAYS)',T74,'90.')   | 00006540<br>00006550<br>00006560<br>00006570                         |
| 9024 | FORMAT(16X,'THERE IS NO CHARCOAL DELAY SYSTEM')  | 00006580   |
| 9025 | FORMAT(16X,'THERE IS A CHARCOAL DELAY SYSTEM',20X,'KRYPTON DYNAMIC<br>1 ADSORPTION COEFFICIENT (CM <sup>3</sup> /GM)',T72,F9,4/20X,'XENON DYNAMIC ADSORPTION<br>2 RPTION COEFFICIENT (CM <sup>3</sup> /GY)',T72,F9,4/20X,'NUMBER OF MAIN CONDENSER<br>3R SHELLS',T72,F9,4/20X,'MASS OF CHARCOAL (SHORT TONS)',T72,F9,4/20X,<br>420X,'KRYPTON HOLDUP TIME (DAYS)',T72,F9,4/20X,'XENON HOLDUP TIME (DAYS)',<br>5DAYS)',T72,F9,4) | 00006590<br>00006600<br>00006610<br>00006620<br>00006630<br>00006640 |
| 9026 | FORMAT(1H1)  | 00006650   |
| 9027 | FORMAT(16X,'PLANT CAPACITY FACTOR',T75,'0.80')   | 00006660   |
| 9028 | FORMAT(16X,'PERCENT FUEL WITH CLADDING DEFECTS',T75,FB,4)  | 00006670   |
| 9029 | FORMAT(16X,'MASS OF WATER IN STEAM GENERATORS (THOUSAND LBS)',T73,<br>1FB,4)   | 00006680<br>00006690   |
| 9030 | FORMAT(16X,'FISSION PRODUCT CARRY-OVER FRACTION',T75,FB,4/16X,<br>1'HALOGEN CARRY-OVER FRACTION',T75,FB,4)   | 00006700<br>00006710   |
| 9032 | FORMAT(2X,7A4,F7,0,3A4,A1,F5,3,3A4,A3,I2,2A4)  | 00006720   |
| 9034 | FORMAT(2X,'BLOWDOWN',10X,1PE9,2,10X,0PF5,3,2X,2(FB,0,2X),<br>13(1PE9,2,1X))  | 00006730<br>00006740   |
| 9035 | FORMAT(2X,'UNTREATED BLOWDOWN',1PE9,2,11X,' 1,000 0.0  | 00006750   |

```

10.0      1.00E 00  1.00E 00  1.00E 00')
9036 FORMAT(16X,'THERE IS NOT A CONDENSATE DEMINERALIZER')
9037 FORMAT(72X,FR,2)
9038 FORMAT(2X,'REGENERANT SOILS',1PE9,2,14X,OPF5,3,2X,2(FR,3,2X),
13(1PE9,2,1X))
9039 FORMAT(16X,'THERE IS A CRYOGENIC OFFGAS SYSTEM')
9040 FORMAT(16X,'THERE IS NO CRYOGENIC OFFGAS SYSTEM')
9041 FORMAT(16X,'PRIMARY TO SECONDARY LEAK RATE (LBS/DAY)',T73,'100.')
```

9045 FORMAT (/, '0 LIQUID WASTE INPUTS')

9046 FORMAT (/, '0 GASEOUS WASTE INPUTS')

9048 FORMAT(10,'15X,'THERE IS NOT AN ON-SITE LAUNDRY')

9051 FORMAT(16X,'FLOWDOWN RATE (THOUSAND LBS/HR)',25X,F1,4)

9052 FORMAT(16X,'THERE IS CONTINUOUS STRIPPING OF FULL LETDOWN FLOW')

9053 FORMAT (16X,'THERE IS NOT CONTINUOUS STRIPPING OF FULL LETDOWN FLOW')

9054 FORMAT(16X,'FLOW RATE THROUGH GAS STRIPPER (GPM)',20X,F8,4)

9055 FORMAT(36X,FR,4,35X,T1)

9056 FORMAT(15X,444,A2,8X,FR,0)

9060 FORMAT (16X,444,10X,A3,6X,A3)

9061 FORMAT (16X,444,'IODINE RELEASE FRACTION',16X,F10,5/32X,'PARTICULATE  
1E RELEASE FRACTION',10X,F10,5)

9062 FORMAT(16X,444,10X,A3,6X,A3,15X,A3)

9063 FORMAT(16X,444,'IODINE RELEASE FRACTION',16X,F10,5/32X,'PARTICULATE  
1E RELEASE FRACTION',10X,F10,5/32X,'RELEASE FRACT.=SPECIAL DES. FE40  
2THRES',1X,F10,5)

9064 FORMAT(16X,'STEAM LEAK TO TURBINE BLDG (LBS/HR)',19X,F10,5)

9065 FORMAT(16X,444,6X,A3)

9066 FORMAT(16X,444,4X,'PARTICULATE RELEASE FRACTION',6X,F10,5)

9067 FORMAT(16X,544,10X,A3,6X,A3)

9068 FORMAT(16X,544,'IODINE RELEASE FRACTION',11X,F10,5/36X,'PARTICULATE  
1E RELEASE FRACTION',6X,F10,5)

9069 FORMAT(16X,544,9X,FR,2,9X,A3,6X,A3)

9070 FORMAT(16X,544,'RATE (C/M<sup>2</sup>)',27X,FR,2/16X,544,'IODINE RELEASE FRACTION  
10N',11X,F10,5/36X,'PARTICULATE RELEASE FRACTION',6X,F10,5)

9071 FORMAT(16X,544,10X,A3,6X,A3,19X,F3,0)

9072 FORMAT (16X,'FREQUENCY OF CNTMT BLDG HIGH VOL PURGE (TIMES/YR)',  
1T74,F8,0)

9073 FORMAT (16X,'THERE IS NOT A CNTMT BLDG LOW VOL PURGE')

9075 FORMAT(16X,'THERE IS CONTINUOUS LOW VOL PURGE OF VOL. CONTROL TK')

END

SUBROUTINE EFFTAR

INTEGER\*2 NAME(3)

DIMENSION NZMRDM(26),NZCRDM(26),REACTR(7)

DIMENSION TURBDR(800),DACHN(2(800)),EDCONC(800)

DIMENSION LAUNDRY(12),LAWND(12)

COMMON/ER/XZERO(800),XZ(800),XTMR(800),XFER(10,800),  
1 H(800),D(800)

COMMON/FLUXN/T(20),PDIFFR(10),TUCAR(800),FISS(100),DIS(800),ILITE,  
1 IACT,IFP,ITOT,IGN,INRT

COMMON/OUT/NUCL(800),TITLE(20),G(800),FG(800),CUTOFF(7),  
1 PDK,BURNUP,FLUXR,HSTAR,ALPHA(100),SPONE(100),ABUND(500),  
2 BASIS(10),TCONST,TUNIT

COMMON/COOL/REACTR,PDK\*,TYPE,PCVOL,LETDWN,NGAS,SCVOL,STMVOL,NDGEN  
1 ,NPURGE,NVDEPG,SHLDR,GASOLA,STLKR,BLWDRN,EJCTR,HLRAT,00007280

2 GASLKH,CUNGLR,DFMRDM,DFCDB, NZMRDM,NZCRDM,NE,PF, 00007290

3 STMR,PFER,HEF,FFCOF,DFMBS,CHFLR,DFI,DFCS,DF, 00007300

4 ENFLR,DFIED,DFCED,DFED,D=FLR,DFIDW,DFCSA,DFDA,DILUT 00007310

5 ,SHA,FOA,OWA,C=FLR,CHFR,C=,CHA,DFCM,DFICM,DFCSM, 00007320

6 DFC,DFIC,DFCSK,MHLD,MMHLD,MMHLD,MMHLD,MMHLD 00007330

7 ,BTER,DFID,DFCSD,DFHD,MMHLDK,REGEN, 00007340

8 SRF,DFMO,DFY,EDFD,DFMEO,DFYED,D=FD,DFMBA,DFYD-, 00007350

```

9      OFMOR0,DFYND,C&FD,DFMDCW,DFYCH,C&FD,DFMUCW,DFYCH 00007360
A      ,TS,TE,TD,TR,TC,TCH,TSTORC,TSTORR,TSTORR,TRSC,DWFL2,DW2,DWF2, 00007370
R      T2,TSTOR2,DFI02,DFCS02,DFM002,DFY02,DFD2,PFLAUF 00007380
COMMON/APCOOL/RG&FR,DFIRG,DFCSR0,DFRG,TRG,TSTORR,RGF0 00007390
COMMON/ROTES/RFNRT 00007400
COMMON/FLEX/FLOX(10),MMN,NOU1,INDEX,GXN,AXN,ERR,NOBLND,HZERO 00007410
COMMON/CUNC/PCUNC(R00),DWCUNC(R00),CWCUNC(R00),CWCUNC(R00), 00007420
1      SCUN(R00),RINV(R00) 00007430
COMMON/HPC/HPC&TAB,ANPC(R00),HPC(R00) 00007440
EQUIVALENCE (XZERO(1),TURHOR(1)),(XZH(1),D&CON2(1)) 00007450
DATA PWR/1 PWR1/2 PWR2/3 PWR3/4 00007460
DATA LAUNDRY/250540,270580,270600,400950,410950,441030,441060, 00007470
1      471101,531310,551340,551370,581440/ 00007480
DATA KLAUND/0,001,0,004,0,0087,0,0014,0,002,0,00014,0,0024, 00007490
1      0,00044,0,000062,0,013,0,024,0,0052/ 00007500
DO 10 I=1,ITOT 00007510
10  D(I)=DIS(1) 00007520
    IF(TYPE,EQ,H&R) GO TO 15 00007530
    H3PRP=0,4&P0&1 00007540
C    H3COPH IS THE HWR TRITIUM PRIMARY COOLANT CONCENTRATION IN 00007550
C    UCI/GM 00007560
    H3COP=1,0 00007570
    C1=SHLOR&CWA 00007580
    C2=ROFLW&CWA 00007590
    C1=C1/(C1+C2) 00007600
    C2=1,=C1 00007610
    GO TO 20 00007620
C    TRITCO IS THE HWR TRITIUM PRIMARY COOLANT CONCENTRATION IN 00007630
C    UCI/GM 00007640
15  TRITPH=.025&P0&1 00007650
    TRITCO=.01 00007660
20  DO 30 J=1,ITOT 00007670
    CWCUNC(J)=0,0 00007680
    EDCUNC(J)=0,0 00007690
    DWCUNC(J)=0,0 00007700
    DWCUN2(J)=0,0 00007710
    CMCUNC(J)=0,0 00007720
    NZ=NUCL(J)/10000 00007730
    IF(NZ,EQ,36,OR,=Z,EQ,54) GO TO 30 00007740
    CWCUNC(J)=PCUNC(J)*CWA 00007750
    EDCUNC(J)=PCUNC(J)*EDA 00007760
    DWCUNC(J)=PCUNC(J)*DWA 00007770
    DWCUN2(J)=PCUNC(J)*D&2 00007780
    IF(TYPE,EQ,H&R) CWCUNC(J)=PCUNC(J)*CWA 00007790
    IF(TYPE,EQ,H&R) GO TO 30 00007800
    CMCUNC(J)=SCUN(J) 00007810
    DFCVCS=10, 00007820
    IF(NZ,EQ,1)DFCVCS=1,0 00007830
    IF(NZ,EQ,37,OR,=Z,EQ,55) DFCVCS=2, 00007840
    CWCUNC(J)=CWCUNC(J)/DFCVCS 00007850
30  CONTINUE 00007860
C 00007870
C 00007880
C 00007890
    CALL COLLECT(TC*86400,,CWCUNC,ILITE,ITOT) 00007900
    CALL COLLECT(TE*86400,,EDCUNC,ILITE,ITOT) 00007910
    CALL COLLECT(TD*86400,,DWCUNC,ILITE,ITOT) 00007920
    CALL COLLECT(T2*86400,,DWCUN2,ILITE,ITOT) 00007930
    CALL COLLECT(TC*86400,,CMCUNC,ILITE,ITOT) 00007940
40  IF(REGENT,LE,0,0) GO TO 50 00007950
    CALL STORAG(TRG*86400,,RINV,ILITE,ITOT) 00007960

```



```

50  DO 100 I=1,ITOT                                00007970
    NZ=NUCL(I)/10000                               00007980
    TURBDR(I)=1991.*5.*SCON(I)                    00007990
    IF(NZ,EQ,1) GO TO 100                          00008000
    IF(NZ,EQ,55,OR,NZ,EQ,53) GO TO 60             00008010
    IF(NZ,EQ,37,OR,NZ,EQ,55) GO TO 70            00008020
C                                          00008030
C  CHEMICAL TREATMENT FOR OTHER CATIONS          00008040
C                                          00008050
    CHCONC(I)=CHCONC(I)/DFCH                     00008060
    EDCONC(I)=EDCONC(I)/DFED                     00008070
    DWCONC(I)=DWCONC(I)/DFDW                     00008080
    DCON2(I)=DCON2(I)/DFD2                      00008090
    CHCONC(I)=CHCONC(I)*(1.0-RDTR*(1.0-CHFD/DFCH)) 00008100
    TO TREAT P&W TURBINE BUILDING FLOOR DRAINS THROUGH DIRTY WASTE 00008110
    SYSTEM, DELETE C FOR COMMENT ON CARDS BELOW, UNTIL NEXT MESSAGE 00008120
C  RINV (I)=RINV (I)/DFRG                        00008130
    TURBDR(I)=1991.*5.*SCON(I)*PFEP             00008140
    TURBDR(I)=1991.*5.*SCON(I)*PFEP/DFDW        00008150
    GO TO 100                                      00008160
C                                          00008170
C  CHEMICAL TREATMENT FOR ANIONS                00008180
C                                          00008190
60  CHCONC(I)=CHCONC(I)/DFICH                     00008200
    EDCONC(I)=EDCONC(I)/DFIED                     00008210
    DWCONC(I)=DWCONC(I)/DFIDW                     00008220
    DCON2(I)=DCON2(I)/DFID2                      00008230
    CHCONC(I)=CHCONC(I)*(1.0-RDTR*(1.0-CHFD/DFICH)) 00008240
    RINV (I)=RINV (I)/DFIRG                       00008250
    TURBDR(I)=1991.*5.*SCON(I)*HEF              00008260
    TURBDR(I)=1991.*5.*SCON(I)*HEF/DFIDW        00008270
    GO TO 100                                      00008280
C                                          00008290
C  CHEMICAL TREATMENT FOR RH AND CS             00008300
C                                          00008310
70  CHCONC(I)=CHCONC(I)/DFCSCH                    00008320
    EDCONC(I)=EDCONC(I)/DFESED                    00008330
    DWCONC(I)=DWCONC(I)/DFCSDW                    00008340
    DCON2(I)=DCON2(I)/DFCSD2                     00008350
    CHCONC(I)=CHCONC(I)*(1.0-RDTR*(1.0-CHFD/DFCSCH)) 00008360
    RINV (I)=RINV (I)/DFCSPG                      00008370
    TURBDR(I)=1991.*5.*SCON(I)*PFEP             00008380
    TURBDR(I)=1991.*5.*SCON(I)*PFEP/DFCSDW      00008390
C  100 CONTINUE                                  00008400
C                                          00008410
C  COMPUTE RADIOACTIVE DECAY DURING PROCESSING AND SAMPLING 00008420
C                                          00008430
    CALL STORAG(TSTORC#86400.,,CHCONC,ILITE,ITOT) 00008440
    CALL STORAG(TS #86400.,,EDCONC,ILITE,ITOT)    00008450
    CALL STORAG(TSTORD#86400.,,DWCONC,ILITE,ITOT) 00008460
    CALL STORAG(TSTOR2#86400.,,DCON2,ILITE,ITOT) 00008470
    CALL STORAG(TSTORH#86400.,,CHCONC,ILITE,ITOT) 00008480
    CALL STORAG(TSTORR#86400.,,RINV,ILITE,ITOT)   00008490
    CALL STORAG(21600.,,TURBDR,ILITE,ITOT)        00008500
    DO 130 I=1,ITOT                                00008510
    NZ=NUCL(I)/10000                               00008520
    ARL#0.0                                         00008530
    IF(REGENT,LT,0.001) GO TO 110                 00008540
    ARL#RINV(I)*365.*S*RGFD/REGENT                00008550
    IF(TYPE,EQ,R#R) GO TO 120                     00008560
    ARL#ARL#RL#DWN*1991.*CHCONC(I)*(1.0-RFNRT) 00008570

```

```

GO TO 130
120 ABLOW=ABLOW+C*FR*1.382*C*CONC(I)
130 C*CONC(I)=ABLOW
IF (TYPE, EQ, BWR) GO TO 133
C*FR=ABLOW*(C*FR+0.02832)
EDFLR=EDFLR+EDFD*0.02832
D*FR=D*FLR*D*FD*0.02832
D*FR2=D*FL2*D*F2*0.02832
T*LRP=C*FR*C*A+EDFLR*ED*A+D*FR*D*A+D*FR2*D*2
H*3R*LP=T*LRP*H*3C*OP=
IF (H*3R*LP, GT, 0.5*H*3P*RP) H*3R*LP=0.5*H*3P*RP
RH*3R*LP=H*3R*LP/10.
INTRIM=RH*3R*LP
IH*3R*LP=INTRIM*10
GO TO 136
133 C*FR=C*FLR*1.382*C*FD
D*FR=D*FLR*D*FD*1.382
TLR=(C*FR+D*FR)+1.382*(C*FD+C*FR+R*GD*R*G*FR)
TRITRL=TRITCO*TLR
IF (TRITRL, GT, 0.5*TRITPR) TRITRL=0.5*TRITPR
RTRITR=TRITRL*0.5
ITRITH=RTRITR
136 TOTAL=0.0
DO 140 I=1, ITOT
NZ=NUCL(I)/10000
IF (NZ, EQ, 36, OR, NZ, EQ, 54) GO TO 140
DISI=DIS(I)*1.6283E13
C*CONC(I)=DISI*(C*CONC(I)+C*FR+ED*CONC(I)+ED*FLR)
D*CONC(I)=(D*CONC(I)+D*FR+D*CON2(I)+D*FR2)*DISI
C*CONC(I)=C*CONC(I)*DISI
TURBDR(I)=TURBDR(I)*DISI
IF (NUCL(I), EQ, 10030) GO TO 140
TOTAL =TOTAL +C*CONC(I)+D*CONC(I)+C*CONC(I)+TURBDR(I)
140 CONTINUE
ADI=0.15
ADR=(ADI+TOTAL)/TOTAL
150 SCNDR=0.0
SAPRI=0.0
SSEC=0.0
SCWAST=0.0
SD*AST=0.0
SARLOW=0.0
STH=0.0
STOTAL =0.0
SCANAL=0.0
SPER=0.0
PAPRI=0.0
PSEC=0.0
PCWAST=0.0
PD*AST=0.0
PARLOW=0.0
PTB=0.0
PTOTAL =0.0
PCANAL=0.0
PPER=0.0
PNDR=0.0
TLAUND=0.0
CTOTAL=0.0
PRINT 9001, REACTR
IF (TYPE, EQ, PWR) PRINT 9002
IF (TYPE, EQ, BWR) PRINT 9006

```

```

00008580
00008590
00008600
00008610
00008620
00008630
00008640
00008650
00008660
00008670
00008680
00008690
00008700
00008710
00008720
00008730
00008740
00008750
00008760
00008770
00008780
00008790
00008800
00008810
00008820
00008830
00008840
00008850
00008860
00008870
00008880
00008890
00008900
00008910
00008920
00008930
00008940
00008950
00008960
00008970
00008980
00008990
00009000
00009010
00009020
00009030
00009040
00009050
00009060
00009070
00009080
00009090
00009100
00009110
00009120
00009130
00009140
00009150
00009160
00009170
00009180

```



```

PRINT 9000
KOUNT#K
I=I+I*ACT+1
L#1
DO 180 I#1,I*DT
IF(I.EG.I) PRINT 9011
N#NUCL(I)/1000
IF(NZ.EG.36.OR.NZ.EG.56) GO TO 180
IF(NZ.EG.1) GO TO 180
DIS#DIS(I)*1.6263E+13
APRIM#CONC(I)*DISI
ASEC#0
IF(TYPE.EG.PHR) ASECS#CON(I)*DISI
CHASTE#CONC(I)
DWASTE#DWCONC(I)
ABL#CHCONC(I)
TBTURB#R(I)
TOTAL#CHASTE+DWASTE+ABLOW+TB
TOTAL#TOTAL#ACHR
NUCL#NUCL(I)
XLAUND#0
TOTAL#TOTAL#
TOTAL#TOTAL#
IF(NUCL#NE.LAUNDRY(I)) GO TO 155
XLAUND#XLAUND(I)*PFLAUN
TOTAL#TOTAL#XLAUND(I)*PFLAUN
L#L+1
155 CONTINUE
IF (TOTAL#LT.1E-5) GO TO 156
ISUB#2
IF (TOTAL#GT.1.) ISUB#1
DIV#10.*INT(ALOG10(TOTAL#))=ISUB)
TOTAL#GAIN(TOTAL#/DI+0.5)*DIV
156 CONTINUE
IF(NUCL(I).EG.10030) TOTAL#TOTAL
CANAL# TOTAL/DILUT*35.31E
PEREN#CANAL/#R#C(I)*100.
IF(NZ.EG.1) GO TO 160
SAPRIM#SAPRIM+APRIM
SSEC#SSEC+ASEC
SABLOW#SABLOW+ABLOW
SCHASTE#SCHASTE+CHASTE
SOWASTE#SOWASTE+OWASTE
STRETS#TB
STOTAL#STOTAL+TOTAL
SCANAL#SCANAL+CANAL
SPER#PER+PEREN
SCNDR#SCNDR+TOTAL#
TLAUND#TLAUND+XLAUND
CTOTAL#CTOTAL+TOTAL#
160 IF(CTOTAL#LT.1E-5) GO TO 160
IF(#DO#KOUNT#R,50).NE.0) GO TO 170
PRINT 9000, REACT#
IF(TYPE.EG.PHR) PRINT 9002
IF(TYPE.EG.BRR) PRINT 9006
CALL I#NO#(NUCL(I),NAME#)
THAL#S.022E#6/DIS(I)
IF(TYPE.EG.PHR) PRINT 9003, NAME#THAL#,APRIM#ASEC,CHASTE,DWASTE,00009750
1. ABLOW+TB,TOTAL,XLAUND,TOTAL#
1. ABLOW+TB,TOTAL,XLAUND,TOTAL#
1. ABLOW+TB,TOTAL,XLAUND,TOTAL#
KOUNT#KOUNT#R+1

```

```

IF(NZ,EG,1) GO TO 180
PAPRIM=PAPRIM+APRIM
PSEC=PSEC+ASEC
PCWAST=PCWAST+CWAST
PDWAST=PDWAST+DWASTE
PARLOW=PARLOW+AWLOW
PTR=PTR+TR
PTOTAL=PTOTAL+TOTAL
PCANAL=PCANAL+CANAL
PPER=PPER+PERCENT
PNORM=PNORM+TOTALN
180 CONTINUE
PAPRIM=SAPRIM-PAPRIM
PSEC=SSSEC-PSEC
PCWAST=SCWAST-PCWAST
PDWAST=SDWAST-PDWAST
PARLOW=SARLOW-PARLOW
PTR=STR-PTR
PTOTAL=STOTAL-PTOTAL
PCANAL=SCANAL-PCANAL
PPER=SPER-PPER
PNORM=SCNORM-PNORM
ISURC=2
IF (CTOTAL.GT.1.) ISURC=1
DIV=10,**(INT(ALOG10(CTOTAL))-ISURC)
CTOTAL=INT(CTOTAL/DIV+0.5)*DIV
IF (PNORM.LT.1E-5) GO TO 184
DIV=10,**(INT(ALOG10(PNORM))-2)
PNORMT=INT(PNORM/DIV+0.5)*DIV
GO TO 186
184 PNORMT=PNORM
186 CONTINUE
IF(TYPE,EG,BNKH) GO TO 190
PRINT 9004, PAPRIM, PSEC,PCWAST,PDWAST,PARLOW,PTR,PTOTAL,PNORM,
1 PNORMT
PRINT 9005, SAPRIM,SSSEC,SCWAST,SDWAST,SARLOW,STR,STOTAL,SCNORM,
1 TLAUND,CTOTAL
PRINT 9012, ITRITR
RETURN
190 PRINT 9008, PAPRIM,PCWAST,PDWAST,PARLOW,PTOTAL,PNORM,PNORMT
PRINT 9009, SAPRIM,SCWAST,SDWAST,SARLOW,STOTAL,SCNORM,TLAUND,
1 CTOTAL
195 PRINT 9012, ITRITR
RETURN
9000 FORMAT(1H1,20X,744,' LIQUID EFFLUENTS (CONTINUED)')
9001 FORMAT(1H1,20X,744,' LIQUID EFFLUENTS')
9002 FORMAT(1H0,55X,'ANNUAL RELEASES TO DISCHARGE CANAL',20X,'COOLANT CONCENTRATIONS',57(' '),
10CONCENTRATIONS',57(' '), ' ADJUSTED DETERGENT TOTAL ','NUCLIDE
2E HALF=LIFE PRIMARY SECONDARY BORON RS MISC. WASTES SECON
3DARY TURB HLDG TOTAL LKS TOTAL WASTES
4'(DAYS) '(2('MICRO CI/ML)'),1X,4('COURTES) '),('CONIES) ',
5' (CI/YR) (CI/YR) (CI/YR)')
9003 FORMAT(1X,A2,I3,A1,2X,1PE9,2,2(2X,E9,2,2X),5(1X,OPF9,5,1X),2(1X,OPF10,5,1X),
1 F9,5,1X),OPF10,5)
9004 FORMAT(1X,'ALL OTHERS',4X,1PE9,2,4X,E9,2,2X,5(1X,OPF9,5,1X),
1 1X,OPF9,5,4X,'0,0',5X,OPF10,5)
9005 FORMAT(' TOTAL',',',('EXCEPT TRITIUM) ',1PE9,2,4X,E9,2,2X,
1 5(1X,OPF9,5,1X),2(1X,OPF9,5,1X),OPF10,5)
9006 FORMAT(1H0,17X,'CONCENTRATIONS ANNUAL RELEASES TO DISCHARGE CANAL',17X,
1AL',19X,' IN PRIMARY ',43(' '), ' ADJUSTED DETERGENT TOTAL
2 ','NUCLIDE HALF=LIFE COOLANT HIGH PURITY LOW PURITY CHEMICALS')

```

```

00009800
00009810
00009820
00009830
00009840
00009850
00009860
00009870
00009880
00009890
00009900
00009910
00009920
00009930
00009940
00009950
00009960
00009970
00009980
00009990
00010000
00010010
00010020
00010030
00010040
00010050
00010060
00010070
00010080
00010090
00010100
00010110
00010120
00010130
00010140
00010150
00010160
00010170
00010180
00010190
00010200
00010210
00010220
00010230
00010240
00010250
00010260
00010270
00010280
00010290
00010300
00010310
00010320
00010330
00010340
00010350
00010360
00010370
00010380
00010390
00010400

```

```

3L TOTAL LWS      TOTAL      WASTES      1/210X,1(DAYS) (MICRO C00010410
4I/ML),3(I (CURIES) ), 1 (CURIES) (CI/YR) (CI/YR) (CI/Y00010420)
5P)')
00010430
9007 FORMAT(1X,A2,I3,A1,2X,1PE9.2, 2X,E9.2,2X ,4(1X,0PF9.5,1X),2(1X,0P00010440
1F9.5,1X),1X,0PF9.5) 00010450
9008 FORMAT(1X,'ALL OTHERS',9X,1PE9.2,2X,4(1X,0PF9.5,1X),1X,0PF9.5,4X, 00010460
1 10.0,6X,0PF9.5) 00010470
9009 FORMAT(' TOTAL 1/,' (EXCEPT TRITIUM) 1,1PE9.2,2X,4(1X,0PF9.5,1X),00010480
1 2(1X,0PF9.5,1X),1X,0PF9.5) 00010490
9010 FORMAT(' CORROSION AND ACTIVATION PRODUCTS') 00010500
9011 FORMAT(' FISSION PRODUCTS') 00010510
9012 FORMAT (1H0,1X,' TRITIUM RELEASE',12X,13,' CURIES PER YEAR') 00010520
END 00010530
BLOCK DATA 00010540
COMMON /CONR/RCONC(800) 00010550
COMMON /CONP/RCONC(800),SCUTV(800),SCUTP(800),SCUT(800) 00010560
DATA RCONC/3E+0,9E+3,13E+0,2E+4,53E+0,5E+3,4E+0,6E+5,0,0,5E+2,3E+0, 00010570
11E+3,3E+0,3E+5,0,0,2E+4,2E+0,4E+4,7E+0,1E+6,0,0,3E+4,2E+0,3E+2,4E+0, 00010580
22E+4,3E+0,2E+3,9E+0,3E+4,6E+0,7E+3,63E+0,3E+3,4E+0,5E+3,2E+0,3E+3, 00010590
319E+0,5E+3,1E+4,3E+0,6E+6,5E+0,4E+3,0,0,4E+5,3E+0,1E+2,6E+3,4E+0,4E+3, 00010600
411E+0,7E+6,0,0,7E+6,8E+0,5E+6,5E+0,4E+3,2E+0,2E+3,2E+2,8E+0,9E+2,7E+0, 00010610
52E+5,3E+0,8E+2,6E+0,2E+3,4E+0,3E+6,21E+0,1E+6,10E+0,4E+5,13E+0,1E+4, 00010620
60,0,5E+3,5E+0,1E+5,3E+2,4E+0,2E+2,5E+0,7E+2,2E+0,3E+5,2E+0,2E+2,8E+0, 00010630
72E+5,3E+0,7E+5,4E+0,1E+2,4E+0,1E+2,3E+0,4E+4,4E+0,1E+2,0,0,3E+5,3E+0, 00010640
8E+3,5E+3,7E+0,3E+5,4E+5,2E+0,3E+6,10E+0,3E+6,81E+0/ 00010650
DATA RCONC/104E+0,1,9E+3,4E+0,5,1E+4,5E+0,1,6E+3,3E+0,1E+3,0,0,0,01E, 00010660
12E+0,2E+3,185E+0,1,2E+3,63E+0,4,8E+3,4E+0,2,6E+3,2E+0,3E+4,6E+0,8,5E+5, 00010670
28E+0,2,2,4E+0,3,5E+4,3E+0,1E+5,0,0,1,2E+6,3E+0,6,5E+4,3,6E+4,6,4E+5,9E+00010680
3,3,4E+5,11E+0,6E+5,0,0,5E+5,15E+0,0,0,4,0,0,4,16E+0,4,5E+5,4,5E+5,14E+0, 00010690
41E+5,0,0,1E+5,103E+0,2,4E+5,8E+0,2,8E+4,8,5E+4,10E+0,1,4E+3,1,6E+3, 00010700
58E+0,2,1E+3,3E+0,2,5E+3,1,1E+3,27,5E+0,0,0,27,1,4E+0,3,8,5E+0,0,0,7,2E+0, 00010710
6,025,2E+0,1,9,8E+0,0,0,13,3E+0,0,0,1E,0,0,12E+0,2,2E+4,1,5E+4,5E+0,7E+5, 00010720
712E+0,4E+5,5E+5,2E+0,3,3E+5,3,3E+5,91E+0/ 00010730
DATA SCUTV/104E+0,9E+8,4E+0,2E+8,5E+0,8E+8,3E+0,6E+8,0,0,8E+7,2E+0, 00010740
19E+8,185E+0,6E+8,63E+0,6,9E+8,4E+0,1,5E+8,2E+0,2E+10,6E+0,4,4E+9,8, 00010750
27,4E+7,4E+0,2E+8,3E+0,4E+10,0,0,8E+11,3E+0,2E+8,1E+8,3E+9,9E+0,1E+9, 00010760
311E+0,4E+9,0,0,4E+9,15E+0,4E+6,3E+6,16E+0,2E+9,2E+9,14E+0,4E+10,0,0, 00010770
44E+10,103E+0,1E+09,8E+0,1E+8,3E+8,10E+0,6E+8,6E+8,8E+0,4,6E+8,3E+0, 00010780
51E+7,2E+8,6,8E+6,5E+0,1E+6,1,9E+6,4E+0,8,9E+6,5E+0,3,8E+7,2E+0,1,3E+6, 00010790
62E+0,3,8E+6,8E+0,6,7E+7,3E+0,9,4E+7,9E+7,12E+0,1E+8,7E+9,5E+0,4E+9, 00010800
712E+0,1E+09,2E+9,2E+0,2E+9,2E+9,91E+0/ 00010810
DATA SCUTP/104E+0,8E+7,4E+0,2E+7,5E+0,7E+7,3E+0,5E+7,0,0,7E+6,2E+0, 00010820
19E+7,185E+0,3E+7,63E+0,1,5E+7,4E+0,2E+8,2E+0,2E+10,6E+0,4E+8,8E+0,8E+7, 00010830
24E+0,2E+7,3E+0,5E+9,0,0,2E+9,3E+0,6E+8,3E+8,3E+8,9E+0,4E+9,11E+0,3E+8, 00010840
30,0,3E+8,15E+0,3,0E+5,3,0E+5,16E+0,2E+8,2E+8,14E+0,5E+9,0,0,5E+9, 00010850
4103E+0,9E+9,8E+0,9E+8,2E+7,10E+0,6E+7,6E+7,8E+0,2,5E+7,3E+0,5E+7,5E+7, 00010860
51,1E+4,5E+0,8E+6,1,1E+5,4E+0,6,5E+5,5E+0,5,7E+7,2E+0,1,2E+5,2E+0, 00010870
61,4E+5,8E+0,5E+6,3E+0,8E+6,8E+6,12E+0,9E+8,8E+8,5E+0,3E+8,12E+0,9E+9, 00010880
72E+8,2E+0,2E+8,2E+8,91E+0/ 00010890
DATA SCUT/104E+0,9E+10,4E+0,2E+10,5E+0,8E+10,3E+0,5E+10,0,0,8E+9,2E+0, 00010900
19E+10,185E+0,6E+10,63E+0,2,3E+9,4E+0,1,2E+9,2E+0,1,4E+10,6E+0,7E+11,8E+0 00010910
2,2,8E+7,4E+0,2E+10,3E+0,5E+12,0,0,6E+13,3E+0,3E+10,2E+10,3E+11,9E+0, 00010920
32E+11,11E+0,3E+11,0,0,2E+11,15E+0,4E+7,2E+7,16E+0,2E+11,2E+11,14E+0, 00010930
45E+12,0,0,5E+12,103E+0,1E+11,8E+0,1E+10,4E+10,10E+0,7E+10,8E+10,8E+0, 00010940
51E+9,3E+0,5E+10,5E+10,1,3E+7,5E+0,1E+8,4,7E+8,4E+0,1,8E+7,5E+0,2,2E+8, 00010950
62E+0,2,0E+8,2E+0,9,0E+8,8E+0,1,0E+8,3E+0,1,5E+8,8E+9,12E+0,1E+10,7E+11, 00010960
75E+0,3E+11,12E+0,2E+11,2E+11,2E+11,2E+11,2E+11,91E+0/ 00010970
END 00010980
SUBROUTINE SOLVE 00010990
COMMON/EQ/XZERO(800), XZH(800),XTEMP(800),XNE*(10,800), 00011000
1 H(800),D(800) 00011010

```

```

COMMON/FLEX/FLEX(10),NEN,HDUT,INDEX,GXN,AXN,ERR,NORLND,"ZERO
COMMON/PROCS9/ *PROS,PRATE(R),NUPROS(R),"ZPROS(8,20),PR(RDC)
COMMON/FLUXN/VT(20),POWER(10),TCCAP(800),FISS(100),DIS(800),ILITE,
1 IACT,IFP,ITOT,NON,INPT
COMMON/OUT/NUCL(800),TITLE(20),R(R00),FG(800),CUTOFF(7),
1 POW,ROUNDO,FLUXR,STAR,ALPHA(100),SPOKE(100),AROUND(500),
2 BASIS(10),TCONST,ATUNIT
DO 10 I=1,ITOT
D(I)=DIS(I)
10 XTEP(I)=0.0
DELTA(I)=TCONST
CALL DECAY(I,DELTA,ITOT)
CALL TEMP(DELTA,I,ILITE,ITOT)
CALL EQUIL(I,ITOT)
DO 30 I=1,ITOT
XTEP(I)=XME*(I,I)
RETURN
END
SUBROUTINE TEMP(I,M,ILITE,ITOT)
C
C TERM ADDS ONE TERM TO EACH ELEMENT OF THE SOLUTION VECTOR
C CSUM(J) IS THE CURRENT APPROXIMATION TO XME(M,J)
C CIMO(J) IS THE VECTOR CONTAINING THE LAST TERM ADDED TO EACH
C ELEMENT OF CSUM(J)
C CIMNJ(J) IS THE VECTOR CONTAINING 1/TOTN TIMES THE NEW TERM TO BE
C ADDED TO CSUM(J)
C CIMNJ(J) IS GENERATED FROM CIMO(J) BY A RECURSION RELATION:
C CIMN(J)=SUM OVER L OF (CAP(J,L)*CIMO(L))
C AP(I,J) IS THE REDUCED TRANSITION MATRIX FOR THE LONG-LIVED
C NUCLEIDES
C
LOGICAL*1 LONG
INTEGER*2 LOC,NOMX,KD
INTEGER*2 LDCP(2500)
INTEGER*2 NONP(R00)
INTEGER*2 NO,NGU,NGUEUE
REAL*8 RATE,BATM
REAL*8 CIM(R00),CSUM(R00),CIMSI
DIMENSION AP(2500),CIMR(R00),CIMO(R00)
DIMENSION GUR(50)
COMMON/SERIES/ XPR(R00),XPAR(R00),LONG(R00)
COMMON/FLEX/FLEX(10),NEN,HDUT,INDEX,GXN,AXN,ERR,NORLND,"ZERO
COMMON/EQ/ZERO(R00),XZ(R00),XTEP(R00),XNEW(10,R00),
H(R00),D(R00)
1 COMMON/MATRIX/A(2500),LDC(2500),NONO(R00),KD(R00)
COMMON/DERIVS/GAP
COMMON/TERM/DU(100),DAP(100),QUEUE(50),NGU(50),NGUEUE(50),NG(R00)
NULEO
NNEO
FIRST CONSTRUCT REDUCED TRANSITION MATRIX FOR LONG-LIVED ISOTOPES
DO 20 L=1,ITOT
IF(.NOT.LONG(L)) GO TO 210
NUNNONO(L)
IF(M.GT.MXN,OR,N.EQ.NZERO) NUNNONO(L)
CIMR(L)=R(L)
IF(NUN.LE.NUL) GO TO 210
NUNNUN+1
NENUL
NLENUN=NUL
DO 200 N1=1,NL
NEN+1

```

```

00011430
00011440
00011450
00011460
00011470
00011480
00011490
00011500
00011510
00011520
00011530
00011540
00011550
00011560
00011570
00011580
00011590
00011600
00011610
00011620
00011630
00011640
00011650
00011660
00011670
00011680
00011690
00011700
00011710
00011720
00011730
00011740
00011750
00011760
00011770
00011780
00011790
00011800
00011810
00011820
00011830
00011840
00011850
00011860
00011870
00011880
00011890
00011900
00011910
00011920
00011930
00011940
00011950
00011960
00011970
00011980
00011990
00020000
00020010
00020020
00020030
00020040
00020050
00020060
00020070
00020080
00020090
00020100
00020110
00020120
00020130
00020140
00020150
00020160
00020170
00020180
00020190
00020200
00020210
00020220
00020230

```

C JLOC(N)  
C DJE=0(J)  
C THIS IS A TEST TO SEE IF ONE OF THE ASYMPTOTIC SOLUTIONS APPLIES  
C IF(.NOT.,LONG(J)) GO TO 10  
C N=NON+1  
C AP(N)=A(N)  
C LCP(N)=LJ  
C GO TO 200  
C GOING BACK UP THE CHAIN TO FIND A PARENT WHICH IS NOT IN  
C EQUILIBRIUM  
C 10 NSAVE=0  
C GUESS(N)=DJ  
C D=1  
C C1=N(L)\*C1\*(L)+D\*E\*(J)  
C N(L)=30  
C NG(J)=L  
C NUX=NON+(J)  
C IF(.NOT.,GT.,MNN.,UR.,\*FO.,ZERO) NUX=K0(J)  
C 20 NUF=0  
C IF(JACT,1) NUF=NON+(J=1)  
C NUX=NON+(J)  
C IF(BX,LT.,1) GO TO 190  
C K=50  
C DO 190 K=1,UX  
C K=K+1  
C J1=LLOC(K)  
C DJE=D(J1)  
C KPEJ  
C 30 IF(J1,EG.,N0(KP)) GO TO 190  
C KPE=K(P)  
C IF(KP,NE.,0) GO TO 30  
C AKD=KPE\*(K1+DJ)  
C IF(.NOT.,LONG(J1)) GO TO 190  
C TR=1.-KXP(J1)  
C IF(TR,LT.,1.-DE=0) GO TO 120  
C N0(J1)=J  
C I=1  
C KPEJ1  
C 40 DO(I)=0(KP)  
C DXP(I)=KXP(KP)  
C KPE=0(KP)  
C IF(KP,EG.,0) GO TO 50  
C I=I+1  
C IF(I,LE.,100) GO TO 40  
C IF QUEUE OF SHORT-LIVED NUCLESIDES EXCEEDS 100 ISOTOPES, TERMINATE  
C CHAIN AND WRITE MESSAGE  
C PRINT 9000, 'L',J1,J,AKDJ6  
C 9000 FORMAT(10F10.4) LONG A QUEUE HAS BEEN FORMED IN TERMS OF IS, E(2,5)  
C GO TO 190  
C 50 RAY=0.0  
C I=I-1  
C DO 110 I=2,14  
C DLE=0(I)  
C XPL=DXP(I)  
C RAY=0.0  
C I=I-1  
C D H VONDY FORM OF RATE-AK EQUATIONS == F(1-L-T)=561

```

DO 100 KR=1,I1
XPJ=DYP(KR)
IF(XPL*XPJ,LT,ENR) GO TO 100
DK=DD*(KR)
PROD=(DL/DK*1,0)
DKR=PROD
IF(ABS(PROD),GT,1.E=4) GO TO 80
USE THIS FORM FOR TWO NEARLY EQUAL HALF-LIVES
PROD=T*DK*XPJ*(1,0=0,5*(DL=DJ)*1)
GO TO 70
60 PROD=(XPJ=XPL)/PROD
PRD=XPJ/DKR
70 PI=1,0
SI=2,/(DK*T)
DO 90 JK=1,I1
IF(JK,EG,KR) GO TO 90
S=1,0=DK/DD(JK)
IF(ABS(S),GT,1.E=4) GO TO 80
IF(ABS(DKR),GT,1.0E=4) PROD=PRD
R=S1
80 PI=PI*S
IF(ABS(PI),GT,1.E25) GO TO 100
90 CONTINUE
RATE=RATE+PROD/PI
100 CONTINUE
C IF SUMMATION IS NEGATIVE, SET EQUAL TO ZERO AND PRINT MESSAGE
IF(RATE,LT,0,DD) PRINT 9001, L,IM,RATE,BATH
9001 FORMAT('RATE IS NEGATIVE IN TERM, THERE ARE MORE THAN TWO SHORT-
LIVED NUCLIDES IN A CHAIN WITH NEARLY EQUAL DIAGONAL ELEMENTS')
21 L,IM,RATE,BATH = 1,215,1PZE12,5)
IF(RATE,LT,0,DD) RATE=0,00
BATH=BATH+RATE
110 CONTINUE
DRA=AKDJQ*DJ*(TRM=RATM)/TRM
GO TO 130
120 DRA=AKDJQ*AMAX1(DRR,0,0)*DJ
130 IF(NS,GT,NN) GO TO 150
DO 140 LJ=NS,NN
IF(LOCP(LJ),NE,J1) GO TO 140
AP(LJ)=AP(LJ)+DRA
GO TO 180
140 CONTINUE
150 NV=NN+1
AP(NV)=DRA
LOCP(NV)=J1
GO TO 180
160 IF(AKDJQ,LE,1.0E=06) GO TO 180
IF(NSAVE,GE,50) GO TO 180
170 NSAVE=NSAVE+1
NQUEUE(NSAVE)=J1
QUEUE(NSAVE)=AKDJQ
NQU(NSAVE)=J
QUB(NSAVE)=DRR=1,/(DJ*T)
180 CONTINUE
190 IF(NSAVE,LE,0) GO TO 200
J=NQUEUE(NSAVE)
QUE=QUEUE(NSAVE)
NQ(J)=NQU(NSAVE)
DRR=QUB(NSAVE)
CIMR(L)=CIMR(L)+QUE*H(J)*AMAX1(DRR,0,0)
NSAVE=NSAVE+1

```

```

00012240
00012250
00012260
00012270
00012280
00012290
00012300
00012310
00012320
00012330
00012340
00012350
00012360
00012370
00012380
00012390
00012400
00012410
00012420
00012430
00012440
00012450
00012460
00012470
00012480
00012490
00012500
00012510
00012520
00012530
00012540
00012550
00012560
00012570
00012580
00012590
00012600
00012610
00012620
00012630
00012640
00012650
00012660
00012670
00012680
00012690
00012700
00012710
00012720
00012730
00012740
00012750
00012760
00012770
00012780
00012790
00012800
00012810
00012820
00012830
00012840

```

3-47



```

00012850
00012860
00012870
00012880
00012890
00012900
00012910
00012920
00012930
00012940
00012950
00012960
00012970
00012980
00012990
00013000
00013010
00013020
00013030
00013040
00013050
00013060
00013070
00013080
00013090
00013100
00013110
00013120
00013130
00013140
00013150
00013160
00013170
00013180
00013190
00013200
00013210
00013220
00013230
00013240
00013250
00013260
00013270
00013280
00013290
00013300
00013310
00013320
00013330
00013340
00013350
00013360
00013370
00013380
00013390
00013400
00013410
00013420
00013430
00013440
00013450

GO TO 20
CONTINUE
NUL=NUMO(L)
NONP(L)=ANN
CONTINUE
C FIND NORM OF MATRIX AND ESTIMATE ERROR AS DESCRIBED IN LAPLIDUS
C AND LOSS, OPTIMAL CONTROL OF ENGINEERING PROCESSES HLAISCELL 1967
C FIND THE MINIMUM OF THE MAXIMUM ROW SUM AND THE MAXIMUM COLUMN SUM
ASUM=0.0
ASUMJ=0.0
NUL=1
DO 250 I=1,ITOT
IF(.NOT.LONG(I)) GO TO 250
DIM=0(I)*T
AJ=DI
NUM=NONP(I)
IF(NUL.GT.ASUM) GO TO 240
DO 230 ANUL,NUM
AJ=AJ+AP(N)
AJ=DI+DI
IF(AI.GI.ASUM) ASUM=AI
IF(AJ.GI.ASUM) ASUM=AJ
NUL=NONP(I)+1
IF(ASUM.JLT.ASUM) ASUM=ASUMJ
USE ASUM TO DECIDE HOW MANY TERMS ARE REQUIRED AND ESTIMATE ERROR
NLARGE=3.5*ASUM+.5
XLARGE=NLARGE
ERR1=EXP(ASUM)*(ASUM*.271828/NLARGE)**NLARGE/SORT(A.2832*XLARGE)
IF(ERR1.GI.1.E-3) PRINT 9002, ERR1,ASUM,NLARGE
9002 FORMAT('MAXIMUM ERROR GT 0.001, #F10.0.', TRACE=#'F10.0,
1 NLARGE=#'F6)
C NEXT GENERATE MATRIX EXPONENTIAL SOLUTION
DO 260 I=1,ITOT
CSUM(I)=XTMP(I)
CIPX(I)=XTMP(I)
CONTINUE
ERR=0.001*ERR
DO 310 N=1,NLARGE
DO 270 I=1,ITOT
CIP(I)=CIPX(I)
CONTINUE
TOM=AT
NUL=1
DO 300 I=1,ITOT
IF(.NOT.LONG(I)) GO TO 300
NUM=NONP(I)
CIP=0.0
IF(.NOT.EQ.1) CIP=I*CIPX(I)
IF(NUL.GT.NUM) GO TO 290
DO 280 ANUL,NUM
J=LOC(P(N))
CIP=I*CIP+AP(N)*CIPX(J)
280 CIP=I*CIP+0(I)*CIPX(I)
290 CIP=I*CIPX(N)
IF(OARS(CIP,N),LT,ERR3) CIP=I*0.00
CIP(I)=CIP
CSUM(I)=CSUM(I)+CIP
NUL=NONP(I)+1
CONTINUE
DO 320 I=1,ITOT
IF(CSUM(I).LT,ERR) CSUM(I)=0.0
00013450

```

```

320 IF(LONG(I)) XN=(N,I)XSUM(I)
CONTINUE
RETURN
END
SUBROUTINE DECAY(M,T,ITOT)
DECAY TREATS SHORT-LIVED ISOTOPES AT BEGINNING OF CHAINS USING
BATEMAN EQUATIONS
LOGICAL*1 LONG
REAL*8 BATE
INTEGER*2 LDC,NUM0,KD
INTEGER*2 NG,NQU,NQUEUE
COMMON/DEHGG/AP(2500)
COMMON/SERIES/ XPI(800),XPAR(800),LONG(800)
COMMON/FLEX/FLEX(10),MMS,MOU,INDEX,DXN,XN,ERR,NOBLEN0,MZERO
COMMON/EGZER0(Z0),XZ(800),XTEPR(800),XNEW(10,800),
1 H(800),D(800)
COMMON/PATRX/AT(2500),LDC(2500),NM0(800),KD(800)
COMMON/TERND/DO(100),DXP(100),QUEUE(50),NGU(50),NQUEUE(50),KD(800)
DO 10 I=1,ITOT
XPAR(I)=0
LONG(I)=.FALSE.
XPI=0
DTRD(I)*
IF(DT.LT=.50) GO TO 10
IF(ABS(DT).LE.XN) LONG(I)=.TRUE.
XPI=EXP(DT)
10 XPI=XPI
NULL=1
DO 100 L=1,ITOT
XTE=0
DL=0(L)
NUM=NUM0(L)
IF(M*GT.MMA,OR,M*EQ.MZERO) NUM=KO(L)
IF(NUM.LT.NULL) GO TO 150
DO 140 N=NUM,NUMH
J=LDC(N)
CJ=0(J)
IF(LONG(J)) GO TO 140
USE THIS FORM FOR TWO NEARLY EQUAL HALF-LIVES
IF(ABS(DL/DJ)=1.0),LE,1,GE=5) XTE=XTE+XTEMP(J)*XN*(N)*XPI(J)*T
IF(ABS(DL/DJ)=1.0),GT,1,GE=5)
1 XTE=XTE+XTE*PI(J)*XN*(N)*(XPI(J)-XPI(L))/(DL-DJ)
QUE=(N)/DJ
NG(L)=NG
NG(J)=NL
NSAVE=0
NUM=NUM0(J)
IF(M*GT.MMA,OR,M*EQ.MZERO) NUM=KO(J)
NUM=1
IF(J*GT,1) NUM=NUM0(J)+1
IF(NUF*GT,NUX) GO TO 150
DO 120 K=NUF,NUX
J=LDC(K)
IF(LONG(J)) GO TO 120
K=J
IF(J,EG,NG(KP)) GO TO 120
K=NG(KP)
IF(KP,NE,0) GO TO 30
DJ=0(J)
AKDJ=AK(K)/DJ*QUE
IF(AKDJ,LE,1,OF=06) GO TO 120

```



```

00014070
00014080
00014090
00014100
00014110
00014120
00014130
00014140
00014150
00014160
00014170
00014180
00014190
00014200
00014210
00014220
00014230
00014240
00014250
00014260
00014270
00014280
00014290
00014300
00014310
00014320
00014330
00014340
00014350
00014360
00014370
00014380
00014390
00014400
00014410
00014420
00014430
00014440
00014450
00014460
00014470
00014480
00014490
00014500
00014510
00014520
00014530
00014540
00014550
00014560
00014570
00014580
00014590
00014600
00014610
00014620
00014630
00014640
00014650
00014660
00014670

```

```

00014070
00014080
00014090
00014100
00014110
00014120
00014130
00014140
00014150
00014160
00014170
00014180
00014190
00014200
00014210
00014220
00014230
00014240
00014250
00014260
00014270
00014280
00014290
00014300
00014310
00014320
00014330
00014340
00014350
00014360
00014370
00014380
00014390
00014400
00014410
00014420
00014430
00014440
00014450
00014460
00014470
00014480
00014490
00014500
00014510
00014520
00014530
00014540
00014550
00014560
00014570
00014580
00014590
00014600
00014610
00014620
00014630
00014640
00014650
00014660
00014670

```

```

160 CONTINUE
DO 170 I=1,ITOT
IF(LONG(I)) XTEMP(I)=XTEMP(I)+XPAR(I)
IF(.NOT.,LONG(I)) XTEMP(I)=0.0
170 CONTINUE
RETURN
END
SUBROUTINE EQUIL(M,ITOT)
C
C EQUIL PUTS SHORT-LIVED DAUGHTERS IN EQUILIBRIUM WITH PARENTS
C EQUIL USES GAUSS-SEIDEL ITERATION TO GENERATE STEADY STATE
C CONCENTRATIONS
C
LOGICAL*1 LONG
INTEGER*2 LOC,NONO,K0
COMMON/SEQ/XZERO(800),XZ(800),XTEMP(800),XNE*(10,800),
1 R(800),O(800)
COMMON/MATRIX/A(2500),LOC(2500),NONO(800),KP(800)
COMMON/FLEX/FLOX(10),MNN,ROOT,INDEX,DXN,AXN,ERR,NORLND,MZERO
COMMON/SERIES/ XP(800),XPAR(800),LOG(800)
DO 10 I=1,ITOT
XPAR(I)=0.0
IF(.NOT.,LONG(I)) GO TO 10
XTEMP(I)=XTEMP(I)*XP(I)
XPAR(I)=MAX1(XNE*(I,I)-XTEMP(I),0.0)
10 CONTINUE
ITER=1
N=0
BIG=0.0
DO 60 I=1,ITOT
NUM=NONO(I)*N
DI=D(I)
IF(LONG(I)) GO TO 50
XN=X(I)
IF(M.GT.,MNN,OR,M.EQ.,MZERO) NUM=K0(I)*N
IF(NUM.EQ.,0) GO TO 31
DO 30 K=1,NUM
N=N+1
J=LOC(N)
DJ=D(J)
XJ=XPAR(J)
IF(LONG(J)) XJ=XJ+XTEMP(J)/(1.0=DJ/DI)
XN=XN+A(N)*XJ
30 CONTINUE
31 XN=XN/DI
IF(XN.LT.,1.0F=50) GO TO 40
ARG=ABS((XN-XPAR(I))/XN)
IF(ARG.GT.,BIG) BIG=ARG
40 XPAR(I)=XN
50 N=NONO(I)
60 CONTINUE
IF(BIG.LT.,DXN ) GOTO 70
ITER=ITER+1
IF(ITER.LT.,100) GO TO 20
PRINT 9000
STOP
70 DO 80 I=1,ITOT
IF(.NOT.,LONG(I)) XNE*(M,I)=XNE*(M,I)+XPAR(I)
80 CONTINUE
RETURN
9000 FORMAT(' GAUSS SEIDEL ITERATION DID NOT CONVERGE IN EQUIL')

```

```

00014680
00014690
00014700
00014710
00014720
00014730
00014740
00014750
00014760
00014770
00014780
00014790
00014800
00014810
00014820
00014830
00014840
00014850
00014860
00014870
00014880
00014890
00014900
00014910
00014920
00014930
00014940
00014950
00014960
00014970
00014980
00014990
00015000
00015010
00015020
00015030
00015040
00015050
00015060
00015070
00015080
00015090
00015100
00015110
00015120
00015130
00015140
00015150
00015160
00015170
00015180
00015190
00015200
00015210
00015220
00015230
00015240
00015250
00015260
00015270
00015280

```

```

END 00015290
SUBROUTINE NUDATA(NLIBE) 00015300
NUDATA VERSION TO HANDLE THREE TYPES OF NUCLEAR DATA LIBRARIES 00015310
HAS POINTER, NLIBE, = 1 FOR HTGR 00015320
      = 2 FOR LIGHT WATER REACTOR 00015330
      = 3 FOR LMFBR 00015340
      = 4 FOR MSRS 00015350
INTEGER*2 LOC,NONO,KO 00015360
INTEGER*2 FLE(99),STA(2) 00015370
INTEGER*2 KAP(800),HMAX(800) 00015380
INTEGER*2 NAME(3) 00015390
DIMENSION COEFF(7,800),NPROD(7,800),CAPT(6), 00015400
1 NUCAL(6),NSORS(5), YIELD(5,500),TYLD(5) 00015410
DIMENSION Y(5) 00015420
DIMENSION SKIP(20) 00015430
DIMENSION MSRS(20) 00015440
COMMON/LABEL/LEF,STA 00015450
COMMON/FLEX/FLUX(10),HMN,MOUT,INDEX,GXN,AXN,ERR,NOBLND,MZERO 00015460
COMMON/ZER/XZERO(800),XZH(800),XTEMP(800),XNE(10,800), 00015470
1 B(800),D(800) 00015480
COMMON/PC/NPCTAB,ANPC(800),NPRC(800) 00015490
COMMON/FLUX/NT(20),PDAEN(10),TOCAP(800),FISS(100),DIR(800),LITE, 00015500
1 IACT,IFP,ITOT,NOH,INPT 00015510
COMMON/ZOUT/NUCL(800),TITLE(20),Q(800),PG(800),CUTOFF(7), 00015520
1 POK,BURNUP,FLUXH,HSTAR,ALPHAN(100),SPDNF(100),AHUND(500), 00015530
2 BASTS(10),TCONST,TUNIT 00015540
COMMON/MATRIX/A(2500),LOC(2500),NONO(800),KO(800) 00015550
EQUIVALENCE (XZERO(1),KAP(1)),(XZERO(401),HMAX(1)), 00015560
1 (XZH(1),COEFF(1,1)),(XNE(1,401),NPROD(1,1)) 00015570
EQUIVALENCE (A1,DLAH) 00015580
DATA NUCAL/20030,10000,10,11,10,9/ 00015590
DATA MSRS/922330,922350,902320,922380,942390,922330,922350,942410, 00015600
1 922380,942390,942410,922350,942400,922380,942390,922330, 00015610
2 922350,902320,922380,942390/ 00015620
PROGRAM TO COMPUTE A MATRIX (TRANSITION MATRIX) FROM NUCLEAR DATA 00015630
READ 9011, (TITLE(I),I=1,10),NLIBE 00015640
IF(NLIBE.LT.0) PROGRAM WILL READ TAPE IN CASDAR FORMAT 00015650
IG=C#0 00015660
IF(NLIBE.GT.0) GO TO 10 00015670
IG=C#1 00015680
NLIBE=NLIBE 00015690
PRINT 9000 00015700
9000 FORMAT(1H0,'WILL READ TAPE GENERATED BY CASDAR') 00015710
10 N1=NLIBE 00015720
20 READ 9001, THERM,RES,FAST,ERR,HMO,NDAY,NYR,NPCTAB,INPT,IR 00015730
PRINT 9005, HMO,NDAY,NYR 00015740
PRINT 9006 00015750
PRINT 9007 00015760
PRINT 9008 00015770
PRINT 9009 00015780
PRINT 9010 00015790
PRINT 9013 00015800
PRINT 9014 00015810
THERM = RATIO OF THERMAL FLUX TO TOTAL FLUX 00015820
RES = RATIO OF RESONANCE FLUX TO TOTAL FLUX 00015830
FAST = RATIO OF FAST FLUX TO TOTAL FLUX 00015840
ERR = TRUNCATION ERROR LIMIT 00015850

```

|     |   |          |
|-----|---|----------|
| C   | READ DATA FOR LIGHT ELEMENTS                                      | 00015900 |
| C   |   | 00015910 |
|     | K=5*(NLINE+1)   | 00015920 |
|     | DO 30 K=1,5   | 00015930 |
|     | K2=K*K1   | 00015940 |
| 30  | NSURS(K1)=MSRS(K2)  | 00015950 |
|     | PRINT 9016, THERM,RES,FAST,(NSURS(K),K=1,5),NLINE                 | 00015960 |
|     | I=0   | 00015970 |
|     | NJTAPE=0  | 00015980 |
| 40  | I=I+1   | 00015990 |
| 50  | READ(R,9034,END=260)NUCL(I),DLAM,IU,FR1,FP,FP1,FT,FA,FSF,         | 00016000 |
|     | IG(I),FG(I),ABUND(I),AMPC(I),AMPC(I)                              | 00016010 |
|     | IF(IG(I),GT,0) GO TO 70   | 00016020 |
|     | DO 60 N=1,NLINE   | 00016030 |
| 60  | READ(R,9035) SIGTH,FNG1,FNA,FNP,WITH,FINA,FINP,SIGMEV,FN2N1,FFNA, | 00016040 |
|     | FFNP,IT   | 00016050 |
|     | GO TO 90  | 00016060 |
| 70  | DO 80 N=1,NLINE   | 00016070 |
| 80  | READ(R,9040) SIGTH,FAG1,FNA,FNP,WITH,FINA,FINP,SIGMEV,FN2N1,FFNA, | 00016080 |
|     | FFNP,IT   | 00016090 |
| 90  | IF(N1,EQ,0) GO TO 110   | 00016100 |
|     | DO 100 N=1,N1   | 00016110 |
| 100 | READ(R,9036) SKIP   | 00016120 |
| 110 | IF(IT,EQ,0) GO TO 50  | 00016130 |
| 120 | M=0   | 00016140 |
|     | CALL HALF(A1,IH)  | 00016150 |
|     | NUCLI=NUCL(I)   | 00016160 |
|     | IF(NUCLI,EQ,0) GO TO 260  | 00016170 |
|     | CALL NUAM(NUCLI,NAME)   | 00016180 |
|     | IF(MOD(I-1,50) .EQ. 0) PRINT 9012, (TITLE (N),N=1,18)             | 00016190 |
|     | IF(MOD(I-1,50) .EQ. 0) PRINT 9016                                 | 00016200 |
|     | SIGTH=THERM*SIGTH   | 00016210 |
|     | RITH=RES*RITH   | 00016220 |
|     | SIGMEV=FAST*SIGMEV  | 00016230 |
|     | SIGNA=SIGTH*FNA+RITH*FINA+SIGMEV*FFNA                             | 00016240 |
|     | SIGNP=SIGTH*FNP+RITH*FINP+SIGMEV*FFNP                             | 00016250 |
|     | FNG=1,0-FNA-FNP   | 00016260 |
|     | IF(FNG,LT,1,0E-4)FNG=0,   | 00016270 |
|     | FING=1,0-FINA-FINP  | 00016280 |
|     | IF(FING,LT,1,0E-4)FING=0,   | 00016290 |
|     | FN2=1,0-FFNA-FFNP   | 00016300 |
|     | IF(FN2,LT,1,0E-4)FN2=0,   | 00016310 |
|     | SIGNG=SIGTH*FNG+RITH*FING   | 00016320 |
|     | SIGN2N=SIGMEV*FN2N  | 00016330 |
| 130 | PRINT 9033, NAME, DLAM,FR1,FP,FP1,FT,FA,SIGNG,                    | 00016340 |
|     | FNG1,SIGN2N,FN2N1,SIGNA,SIGNP,G(I),FG(I),ABUND(I)                 | 00016350 |
| C   | TEST RADIOACTIVITY  | 00016360 |
| C   |   | 00016370 |
| 140 | IF(A1,LE,ERR) GO TO 180   | 00016380 |
|     | AHETA=1,0   | 00016390 |
| C   |   | 00016400 |
| C   | TEST POSITRON EMISSION  | 00016410 |
| C   |   | 00016420 |
|     | IF(FP,LT,ERR) GO TO 150   | 00016430 |
|     | M=+1  | 00016440 |
|     | COEFF(M,I)=FP*A1  | 00016450 |
|     | NPROD(M,I)=NUCL I=10000   | 00016460 |
|     | AHETA=AHETA+FP  | 00016470 |
| C   |   | 00016480 |
| C   | TEST POSITRON EMISSION TO EXCITED STATE OF PRODUCT NUCLIDE        | 00016490 |
| C   |   | 00016500 |

|     |  |          |
|-----|--|----------|
|     | IF(FP1,LT,ERR) GO TO 150                                   | 00016510 |
|     | M=M+1  | 00016520 |
|     | COEFF(M,I)=FP1*COEFF(M-1,I)                                | 00016530 |
|     | NPROD(M,I)=NPROD(M-1,I)+1                                  | 00016540 |
|     | COEFF(M-1,I)=COEFF(M-1,I)-COEFF(M,I)                       | 00016550 |
| C   |  | 00016560 |
| C   | TEST ISOMERIC TRANSITION                                   | 00016570 |
| C   |  | 00016580 |
| 150 | IF(FT,LT,ERR) GO TO 160                                    | 00016590 |
|     | M=M+1  | 00016600 |
|     | COEFF(M,I)=FT*A1   | 00016610 |
|     | NPROD(M,I)=NUCLT   | 00016620 |
|     | ARETA=ABETA*FT   | 00016630 |
| C   |  | 00016640 |
| C   | TEST ALPHA EMISSION  | 00016650 |
| C   |  | 00016660 |
| 160 | IF(FA,LT,ERR) GO TO 170                                    | 00016670 |
|     | M=M+1  | 00016680 |
|     | COEFF(M,I)=FA*A1   | 00016690 |
|     | NPROD(M,I)=NUCLT-20040                                     | 00016700 |
|     | M=M+1  | 00016710 |
|     | COEFF(M,I)=COEFF(M-1,I)                                    | 00016720 |
|     | NPROD(M,I)=20040   | 00016730 |
|     | ARETA=ABETA*FA   | 00016740 |
| C   |  | 00016750 |
| C   | TEST NEGATRON EMISSION                                     | 00016760 |
| C   |  | 00016770 |
| 170 | IF(ABETA,LT,1,E=4) GO TO 180                               | 00016780 |
|     | M=M+1  | 00016790 |
|     | COEFF(M,I)=ABETA*A1  | 00016800 |
|     | NPROD(M,I)=NUCLT+10000                                     | 00016810 |
| C   |  | 00016820 |
| C   | TEST NEGATRON EMISSION TO EXCITED STATE OF PRODUCT NUCLIDE | 00016830 |
| C   |  | 00016840 |
|     | IF(FR1,LT,ERR) GO TO 180                                   | 00016850 |
|     | M=M+1  | 00016860 |
|     | COEFF(M,I)=FR1*COEFF(M-1,I)                                | 00016870 |
|     | NPROD(M,I)=NPROD(M-1,I)+1                                  | 00016880 |
|     | COEFF(M-1,I)=COEFF(M-1,I)-COEFF(M,I)                       | 00016890 |
| C   |  | 00016900 |
| C   | COMPUTE NEUTRON CAPTURE CROSS SECTIONS IN THREE REGIONS    | 00016910 |
| C   |  | 00016920 |
| 180 | KAP(I)=#   | 00016930 |
|     | DO 190 K=1,6   | 00016940 |
| 190 | CAPT(K)=0.0  | 00016950 |
|     | CAPT(1)=SIG#4  | 00016960 |
|     | CAPT(2)=SIG#P  | 00016970 |
|     | CAPT(4)=SIG#G*#NG1   | 00016980 |
|     | CAPT(3)=SIG#G-CAPT(4)                                      | 00016990 |
|     | CAPT(5)=SIG#2N*#N2N1                                       | 00017000 |
|     | CAPT(6)=SIG#2N-CAPT(5)                                     | 00017010 |
| 200 | TOCAP(I)=0.0   | 00017020 |
| C   | TOTAL NEUTRON CROSS SECTION FOR NUCLIDE(I)                 | 00017030 |
|     | DO 220 K=1,6   | 00017040 |
|     | CAPK=CAPT(K)   | 00017050 |
|     | IF(CAPK1,LT,ERR) GO TO 220                                 | 00017060 |
|     | M=M+1  | 00017070 |
|     | NPROD(M,I)=NUCLT+NUCAL(K)                                  | 00017080 |
|     | COEFF(M,I)=CAPK1   | 00017090 |
|     | TOCAP(I)=TOCAP(I)+CAPK1                                    | 00017100 |
|     | IF(K,NE,1) GO TO 210                                       | 00017110 |

3-55

```

      M=M+1
      COEFF(M,I)=COEFF(M-1,I)
      NPROD(M,I)=20040
210  IF(K,=E,2) GO TO 220
      M=M+1
      COEFF(M,I)=COEFF(M-1,I)
      NPROD(M,I)=10010
220  CONTINUE
230  IF(MOD(NHCL1, 10),=0,0) GO TO 250
      DO 240 K=1,M
240  NPROD(K,I)=NPROD(K,I)+1
250  MMAX(I)=M
      IF(M,GT,7) PRINT 9039, M
      DIS(I)=A1
      GO TO 40
260  ILITE = I-1
      IACT=0
C
C   READ DATA FOR ACTINIDES
C
270  READ(R,9054,FND=450)NUCL(I),DLAM,IU,FRI,FP,FP1,FT,FA,FSF,
      IG(I),FG(I),DUMMY,=MPC(I),AMPC(I)
      DO 280 N=1,NLITE
      READ(R,9057) SIGNG,RING,FNG1,SIGF,RIF,SIGFF,SIGN2N,FN2N1,SIGN3N,IT
280  CONTINUE
      IF(MI,=0,0) GO TO 300
      DO 290 N=1,M1
290  READ(R,9036) SKIP
300  IF(IT,=0,0) GO TO 270
310  M=0
      NUCL1=NUCL(I)
      IF(NUCL1,=0,0) GO TO 450
      DO 320 K=1,5
      IF(NUCL1,=R,NSURS(K)) NSURS(K)=I
320  CONTINUE
      CALL HALF(A1,IU)
      CALL NOAH(NUCL1,NAME)
      SIGNG=THRN*SIGNG+RES*RING
      SIGF =THRN*SIGF +RES*RIF +FAST*SIGFF
      SIGN2N=SIGN2N+FAST
      SIGN3N=SIGN3N+FAST
      IF(MOD(IACT,50),=0,0) PRINT 9012, (TITLE(N),N=1,18)
330  IF(MOD(IACT,50),=0,0) PRINT 9024
      PRINT 9026, NAME, DLAM,FRI,FP,FP1,FT,FA,FSF,SIGNG,
      FNG1,SIGF,SIGN2N,SIGF3N,Q(I),FG(I)
340  IACT=IACT+1
C
C   TEST RADIOACTIVITY
C
      IF(A1,LT,ERR) GO TO 380
      ABETA=1.0
C
C   TEST POSITRON EMISSION
      IF(FP,LT,ERR) GO TO 350
      ABETA=ABETA+FP
      M=M+1
      COEFF(M,I)=FP*A1
      NPROD(M,I)=NUCL1+10000
C
C   POSITRON EMISSION TO EXCITED STATE
      IF(FP1,LT,ERR)GO TO 350
      M=M+1
      COEFF(M,I)=FP1*COEFF(M-1,I)

```

```

00017120
00017130
00017140
00017150
00017160
00017170
00017180
00017190
00017200
00017210
00017220
00017230
00017240
00017250
00017260
00017270
00017280
00017290
00017300
00017310
00017320
00017330
00017340
00017350
00017360
00017370
00017380
00017390
00017400
00017410
00017420
00017430
00017440
00017450
00017460
00017470
00017480
00017490
00017500
00017510
00017520
00017530
00017540
00017550
00017560
00017570
00017580
00017590
00017600
00017610
00017620
00017630
00017640
00017650
00017660
00017670
00017680
00017690
00017700
00017710
00017720

```

```

      NPROD(M,I)=NPROD(M-1,I)+1
      COEFF(M-1,I)=COEFF(M-1,I)-COEFF(M,I)
C     ISOMERIC TRANSITION
350   IF(FT .LT. ERR) GO TO 360
      M=M+1
      COEFF(M,I)=FT+*1
      NPROD(M,I)=NUCLI
      ABETA=ABETA+FT
C     ALPHA EMISSION
360   IF(FA .LT. ERW) GO TO 370
      M=M+1
      COEFF(M,I)=FA+*1
      NPROD(M,I)=NUCLI-20040
      M=M+1
      COEFF(M,I)=COEFF(M-1,I)
      NPROD(M,I)=20040
      ABETA=ABETA+FA
C     BETA DECAY
370   IF(ABETA.LT.1.E+4) GO TO 380
      M=M+1
      COEFF(M,I)=ABETA+*1
      NPROD(M,I)=NUCLI+10000
      IF(FR1 .LT. ERK) GO TO 380
      M=M+1
      COEFF(M,I)=COEFF(M-1,I)+FR1
      COEFF(M-1,I)=COEFF(M-1,I)-COEFF(M,I)
      NPROD(M,I)=NPROD(M-1,I)+1
C
C     NEUTRON CAPTURE CROSS SECTIONS
C
380   KAP(I)=M
      DO 390 K=1,6
390   CAPT(K)=0.0
      CAPT(2)=SIGN0+FN01
      CAPT(1)=SIGN0-CAPT(2)
      CAPT(4)=SIGN2+FN241
      CAPT(3)=SIGN2-CAPT(4)
400   FISS(I)=SIGF
      TDCAP(I)=0.0
      DO 410 K=1,4
      CAPKI=CAPT(K)
      IF(CAPKI.LT.ERR) GO TO 410
      M=M+1
      TDCAP(I)=TDCAP(I)+CAPKI
      COEFF(M,I)=CAPKI
      NPROD(M,I)=NUCLI+NUCAL(K+2)
410   CONTINUE
      TDCAP(I)=TDCAP(I)+FISS(I)
C     N-3N CROSS SECTION
      A17=SIGN3N
      IF(A17.LT.ERR) GO TO 420
      M=M+1
      COEFF(M,I)=A17
      NPROD(M,I)=NUCLI-20
      TDCAP(I)=TDCAP(I)+A17
420   IF(MOD(NUCLI,10).EQ.0) GO TO 440
      DO 430 K=1,M
430   NPROD(K,I)=NPROD(K,I)+1
440   MMAX(I)=M
      IF(M.GT.7) PRINT 9039, M
      SPUNF(I)=FSF+*1+*,023E23

```

```

00017730
00017740
00017750
00017760
00017770
00017780
00017790
00017800
00017810
00017820
00017830
00017840
00017850
00017860
00017870
00017880
00017890
00017900
00017910
00017920
00017930
00017940
00017950
00017960
00017970
00017980
00017990
00018000
00018010
00018020
00018030
00018040
00018050
00018060
00018070
00018080
00018090
00018100
00018110
00018120
00018130
00018140
00018150
00018160
00018170
00018180
00018190
00018200
00018210
00018220
00018230
00018240
00018250
00018260
00018270
00018280
00018290
00018300
00018310
00018320
00018330

```



```

ALPHACACT38FAA146,025E13=Q(I)**3.65
DIS(I)=A1
I=I+1
GO TO 270
450 IL=0
DO 460 K=1,5
460 YLD(K)=0
C
C READ DATA FOR FISSION PRODUCTS
C
470 HEAD(A,9054,END=690)NUCL(I),DLAY,IU,FBI,FP,FPI,FT,PA,FSF,
IQ(I),FG(I),DUMY,MP(CI),AMPC(I)
DO 480 N=1,NLIRE
480 HEAD(A,9058) SIGNG,PIG,FNGI,Y,IT
IF(NL,EG,0) GO TO 500
DO 490 N=1,N1
490 HEAD(R,9056) SKIP
500 IF(IT .EQ. 0) GO TO 470
510 M=0
CALL HALF(AI,IT)
NUCL=NUCL(I)
IF(NUCL,EG,0) GO TO 690
CALL NOAH(NUCL,NAME)
IF(MOD(IL,50),EQ,0) PRINT 9012, (TITLE(N),N=1,18)
SIGNG=THEM*SIGNG+RES*PIG
IF(NLIRE,EG,3) GO TO 540
IF(MOD(IL,50),EQ,0) PRINT 9019
PRINT 9021, NAME, DLAY,FBI,FP,FPI,FT,SIGNG,
FNGI,Y,QLI),FG(I)
GO TO 550
540 IF(MOD(IL,50),EQ,0) PRINT 9020 DLAY,FBI,FP,FPI,FT,SIGNG,FNGI,
PRINT 9022, NAME, Y(2),Y(4),Y(5),QLI),FG(I)
C
C TEST RADIOACTIVITY
C
550 IF(AI,LT,ERR) GO TO 600
APETA=1.0
POSITION EMISSION
A=FP
IF(A3,LY,ERR) GO TO 570
AETA=AMETA+A3
A1=A3*EPI
IF(AP,LT,ERR) GO TO 560
M=M+1
COEFF(M,1)=A*AI
NPROD(M,1)=NUCL-10000
IF(API,LT,ERR) GO TO 570
M=M+1
COEFF(M,1)=A*AI
NPROD(M,1)=NUCL-9999
ISOMERIC TRANSITION
IF(FT ,LY, ERR) GO TO 580
M=M+1
COEFF(M,1)=FT*AI
NPROD(M,1)=NUCL
AETA=AMETA-FT
NEGATRON EMISSION
IF(CAPETA,LT,1.0E-4) GO TO 600
A2=PHI

```

```

00018340
00018350
00018360
00018370
00018380
00018390
00018400
00018410
00018420
00018430
00018440
00018450
00018460
00018470
00018480
00018490
00018500
00018510
00018520
00018530
00018540
00018550
00018560
00018570
00018580
00018590
00018600
00018610
00018620
00018630
00018640
00018650
00018660
00018670
00018680
00018690
00018700
00018710
00018720
00018730
00018740
00018750
00018760
00018770
00018780
00018790
00018800
00018810
00018820
00018830
00018840
00018850
00018860
00018870
00018880
00018890
00018900
00018910
00018920
00018930
00018940

```



```

590 AMIBARETA*2
    AMIBETA*PI
    IF(AR.LT.1.F*4) GO TO 590
    MEM*1
    COEFF(M,I)4R*41
    NPROD(M,I)NUCLI*1000
    IF(AR.LT.1.E*6) GO TO 600
    MEM*1
    COEFF(M,I)4R1*41
    NPROD(M,I)NUCLI*10001
C
C NEUTRON CAPTURE CROSS SECTIONS FOR FISSION PRODUCTS USING THREE
C REGION APPROXIMATION
C
600 KAP(I)M
    DO 610 KBI,6
    CAPT(K)M,0
    CAPT(2)SIGN*F*61
    CAPT(1)SIGN*CAPT(2)
    TOCAP(I)M,0
    DO 620 KBI,2
    CAPT(CAPT(K))
    IF(CAPT(LY,ERH) GO TO 620
    MEM*1
    TOCAP(I)TOCAP(I)+CAPT(K)
    COEFF(M,I)CAPT
    NPROD(M,I)NUCLI*NUCAL(K*2)
620 CONTINUE
630 IF(NUC(NUCL,1),EQ,0) GO TO 650
    DO 640 KBI,M
    NPROD(K,I)NPROD(K,I)+1
    ILBI=1
    DO 660 JBI,5
    YBY(J)M,0*10
    YLD(J)BYLD(J)*YJ
660 YIELD(J,I)BYJ
    IF(NUC(LI,5),OR,NUC(LI,6),OR,NUC(LI,7)) GO TO 660
670 IF(NUC(LI,8),OR,NUC(LI,9)) YIELD(I,I)BYJ
    YIELD(3,I)BYJ
680 MMAX(I)M
    IF(NUC(LI,7) PRINT 9030, M
    DIS(I)M
    IBI=1
    GO TO 470
690 IPRBI
C
C ALL DATA ON NUCLES HAS BEEN READ, BEGIN TO COMPUTE MATRIX CUEFF
C
C ITOTBI=1
C
C FINE PRODUCT NUCLES FOR REACTIONS OF LIGHT ELEMENTS
C
700 NDK=0
    DO 700 KBI,ITOT
    NONG(K)M
    IF(ILITE.LT.1) GO TO 760
    DO 750 IBI,ILITE
    NUCLI=NUCL(I)
    DO 720 JBI,ILITE
    KWAKKAP(IJ)
    IF(KKAX.LT.1) GO TO 720

```

```

DO 710 M=1,KMAX
IF(NUCLI,NE,NPROD(M,J)) GO TO 710
NONO(I)=NONO(I)+1
NON=NON+1
IF(NON,GT,2500) PRINT 9041, NON,NUCL(I)
A(NON)=COEFF(M,J)
JT=J
LOC(NON)=JT
710 CONTINUE
720 CONTINUE
KD(I)=NONO(I)
DO 740 J=1,ILITE
K1=KAP(J)+1
KMAX=KMAX(J)
IF(KMAX,LT,K1) GO TO 740
DO 730 M=1,KMAX
IF(NUCLI,NE,NPROD(M,J)) GO TO 730
NONO(I)=NONO(I)+1
NON=NON+1
IF(NON,GT,2500) PRINT 9041, NON,NUCL(I)
A(NON)=COEFF(M,J)
JT=J
LOC(NON)=JT
730 CONTINUE
740 CONTINUE
750 CONTINUE
C
C
C
NONM ZERO MATRIX ELEMENTS FOR THE ACTINIDES
760 IF(IACT,LT,1) GO TO 820
ID=ILITE+1
I1=ILITE+IACT
DO 810 I=ID,I1
NUCLI=NUCL(I)
DO 780 J=ID,I1
M1=KAP(J)
IF(M1,LT,1) GO TO 780
DO 770 M=1,M1
IF(NUCLI,NE,NPROD(M,J)) GO TO 770
NONO(I)=NONO(I)+1
NON=NON+1
IF(NON,GT,2500) PRINT 9041, NON,NUCL(I)
A(NON)=COEFF(M,J)
JT=J
LOC(NON)=JT
770 CONTINUE
780 CONTINUE
KD(I)=NONO(I)
DO 800 J=ID,I1
M1=KAP(J)+1
M2=KMAX(J)
IF(M2,LT,M1) GO TO 800
DO 790 M=1,M2
IF(NUCLI,NE,NPROD(M,J)) GO TO 790
NONO(I)=NONO(I)+1
NON=NON+1
IF(NON,GT,2500) PRINT 9041, NON,NUCL(I)
A(NON)=COEFF(M,J)
JT=J
LOC(NON)=JT
790 CONTINUE

```

```

00019560
00019570
00019580
00019590
00019600
00019610
00019620
00019630
00019640
00019650
00019660
00019670
00019680
00019690
00019700
00019710
00019720
00019730
00019740
00019750
00019760
00019770
00019780
00019790
00019800
00019810
00019820
00019830
00019840
00019850
00019860
00019870
00019880
00019890
00019900
00019910
00019920
00019930
00019940
00019950
00019960
00019970
00019980
00019990
00020000
00020010
00020020
00020030
00020040
00020050
00020060
00020070
00020080
00020090
00020100
00020110
00020120
00020130
00020140
00020150
00020160

```

```

800 CONTINUE
810 CONTINUE
C
C
C MATRIX ELEMENTS FOR FISSION PRODUCTS
820 IF(IFPL7,1) GO TO 900
IF(MLI+I+IAC
IEM+1
IF(IOT,LT,10) GO TO 900
DO 880 I=0,ITOT
NUCL=NUCL(I)
IEMAX(I)=I+10
IEMIN(I)=I+10
DO 840 J=12,13
KXEMAX(J)
IF(KMAX,LT,1) GO TO 840
DO 830 K=1,KMAX
IF(NUCL,NE,NPROD(M,J)) GO TO 830
NONR(I)=NONR(I)+
NONR(N)
IF(NON,GT,2500) PRINT 9041, NON,NUCL(I)
A(NON)=COEFF(M,J)
JTB
LOC(NON)=JT
830 CONTINUE
840 CONTINUE
KD(I)=NON(I)
DO 860 J=12,13
KEMAX(J)+1
IF(KMAX,LT,4) GO TO 860
DO 850 K=1,KMAX
IF(NUCL,NE,NPROD(M,J)) GO TO 850
NONR(I)=NONR(I)+
NONR(N)
IF(NON,GT,2500) PRINT 9041, NON,NUCL(I)
A(NON)=COEFF(M,J)
JTB
LOC(NON)=JT
850 CONTINUE
860 CONTINUE
IF(IAC,LT,1) GO TO 880
DO 870 K=1,5
ILMI=I
IF(YIELD(K,IL),LT,ERR) GO TO 870
NONR(N)+
IF(NON,GT,2500) PRINT 9041, NON,NUCL(I)
NONR(I)=NONR(I)+1
KMSOR(K)
LOC(NON)=K
KEMAX(ILITE)
A(NON)=YIELD(K,IL)*FISS(KF)
870 CONTINUE
880 CONTINUE
IF(ILP,LE,0) GO TO 900
IF(PLINE,NE,3) GO TO 890
PRINT 9027, TYLD(2),TYLD(4),TYLD(5)
GO TO 900
PRINT 9030, (TYLD(I),I=1,5)
890
C
C ALL MATRIX ELEMENTS ARE NOW COMPUTED

```

```

C      BEGIN TRANSIENT SOLUTION                                00020780
C      C                                                        00020790
C      C                                                        00020800
C      TEMPORARILY WRITE OUT MATRIX ELEMENTS                  00020810
C      C                                                        00020820
900  IF(CIR, EQ, 0) RETURN                                     00020830
      PRINT 9029                                              00020840
      N=0                                                     00020850
      DO 910 I=1, ITOT                                        00020860
      NUM=KOND(I)                                           00020870
      IF(NUM, LE, 0) GO TO 910                                00020880
      N1=N*NUM                                               00020890
      N=N+1                                                  00020900
      PRINT 9028, I, DIS (I), TOCAP(I), (A(K), LOC(K), K=N, N1) 00020910
      N=N+1                                                  00020920
910  CONTINUE                                               00020930
      RETURN                                                 00020940
920  STOP                                                    00020950
C      C                                                        00020960
C      FORMATS          FORMATS          FORMATS          FORMATS 00020970
C      C                                                        00020980
9001  FORMAT(4F10.5, 6I2)                                    00020990
9002  FORMAT(16, F5.3, I1, 5F3.3, E5.2, F3.3,                13X, E5.2, F3.3, 2E5.2, 00021000
      , F4.3, F3.3, F6.4)                                    00021010
9003  FORMAT(16, F5.3, I1, 3X, 4F3.3, 2E5.2, F3.3, 4E5.2, F4.3, F3.3) 00021020
9004  FORMAT(16, F5.3, I1, 5F3.3, 2F5.2, F3.3, 4E5.2, F3.3, F4.3, F3.3, 2E5.2) 00021030
9005  FORMAT(1H1, 43X, 'NUCLEAR TRANSMUTATION DATA  REVISED ', I2, '/', I2, '00021040
      1/', I2, '/', 'NUCL = NUCLIDE = 10000 * ATOMIC NO + 10 * MASS NO + 180H00021050
      2ERIC STATE (0 OR 1)', 10X, 'DLAM = DECAY CONSTANT (1/SEC)', '/', 'FR, 00021060
      3FR, FA, FT = FRACTIONAL DECAY BY BETA, POSITRON (OR ELECTRON CAPTURE)00021070
      4RE), ALPHA, INTERNAL TRANSITION, FR = 1 - FR - FA - FT', '/', 'FRI, 00021080
      5 FPI, FNG1, FN2N1 = FRACTION OF BETA, POSITRON, N= GAMMA, N=2N TRAN00021090
      6ITIONS TO EXCITED STATE OF PRODUCT NUCLIDE', '/', 'SIGTH, SIGNG, SIG00021100
      7F, SIGNA, SIGNP = THERMAL CROSS SECTIONS (BARN) FOR ABSORPTION, 00021110
      8= GAMMA, FISSION, N=ALPHA, N=PROTON, ') 00021120
9006  FORMAT('  SIGNG = SIGTH * (1 - FNA - FNP), SIGNA = SIGTH * FNA, 00021130
      1SIGNP = SIGTH * FNP, FNA, FNP = FRACTION THERMAL N=ALPHA, N=PROT00021140
      2N, '/', '/', 'RITH, RING, RIF, RINA, RINP = RESONANCE INTEGRAL FOR ABSOR00021150
      3PTION, N= GAMMA, FISSION, N=ALPHA, N=PROTON, '/', '/', 'RING = RITH * (00021160
      41 = FINA = FINP), RINA = RITH * FINA, RINP = RITH * FINP, FINA, F00021170
      5INP = FRACTION RESONANCE N=ALPHA, N=PROTON, '/', '/', 'SIGMEV, SIGFF, S100021180
      6GN2N, SIGNAF, SIGNPF = FAST CROSS SECTIONS (BARN) FOR ABSORPTION, 00021190
      7FISSION, N=2N, N=ALPHA, N=PROTON, '/', '/', 'SIGN2N = SIGMEV * (1 - F00021200
      8NA = FNP), SIGNAF = SIGMEV * FNA, SIGNPF = SIGMEV * FNP, FF00021210
      9A, FFNP = FRACTION FAST N=ALPHA, N=P, ') 00021220
9007  FORMAT(' Y23, Y25, Y26, Y28, Y49 = FISSION YIELD (PERCENT) FROM 2500021230
      13=U, 235=U, 232=TH, 238=U, 239=PU, '/', '/', 'Q = HEAT PER DISINTEGRATI00021240
      2ON, FG = FRACTION OF HEAT IN GAMMAS OF ENERGY GREATER THAN 0.2 ME00021250
      3V, '/', '/', 'E EFFECTIVE CROSS SECTIONS FOR A VOLUME AVERAGED THERMAL (L00021260
      4T 0.876 EV) FLUX ARE AS FOLLOWS, '/', '/', ' N= GAMMA = SIGNG * THERM00021270
      5 + RING * RES, '/', '/', ' FISSION = SIGF * THERM + RIF * RES + SIGF00021280
      6F * FAST, '/', '/', 'THERM = 1/V CORRECTION FOR THERMAL SPECTRUM AND T00021290
      7MPERATURE, '/', '/', ' N=2N = SIGN2N * FAST, '/', 36X, 'RES = RATIO 00021300
      8OF RESONANCE FLUX PER LETHARGY UNIT TO THERMAL FLUX, ') 00021310
9008  FORMAT(' N=ALPHA = SIGNA * THERM + RINA * RES + SIGNAF * FAST00021320
      1, '/', 7X, 'FAST = 1.45 * RATIO OF FAST (GT 1.0 MEV) TO THERMAL FLUX 100021330
      2/ N=PROTON = SIGNP * THERM + RINP * RES + SIGNPF * FAST, ') 00021340
9009  FORMAT(1H0, 50X, 'REFERENCES', '/', '/', ' HALF LIVES, DECAY SCHEMES, AND 00021350
      1THERMAL POWER, '/', ' C M LEDERER, J M HOLLANDER, AND I PERLMAN 11TAR00021360
      2LE OF ISOTOPES = SIXTH EDITION 11 JOHN WILEY AND SONS, INC (1967) 11, 00021370
      3/ B S DZHELEPUV AND L K PEKER 11 DECAY SCHEMES OF RADIOACTIVE NUC00021380

```

4LEI11 PERGAMON PRESS (1961)1,7,1 D T GOLDMAN AND JAMES R ROSSER 100021390  
 51CHART OF THE NUCLIDES11 NINTH EDITION GENERAL ELECTRIC CO (JULY 00021400  
 A1966)1,7,1 E O ARNOLD 11PROGRAM SPECTRA11 APPENDIX A OF ORNL-1576 00021410  
 7(APRIL 1964)11 00021420  
 9010 FORMAT(11 CROSS SECTIONS AND FLUX SPECTRA1,7,1 R E PRINCE 11NEUT00021430  
 1RON REACTION RATES IN THE MSRE SPECTRON11 ORNL-4119, PP 79-83 (JUL00021440  
 2Y 1967)1,7,1 R E PRINCE 11NEUTRON ENERGY SPECTRA IN MSRE AND MSRR100021450  
 31 ORNL-4191, PP 50-58 (DEC 1967)1,7,1 M O GOLDBERG ET AL 11NEUTRON00021460  
 4 CROSS SECTIONS11 BNL-325, SECOND ED, SUPP NO 2 (MAY 1964 - AUG 1966)21470  
 566) ALSO EARLIER EDITIONS1,7,1 H T KERR, UNPUBLISHED FRC COMPILATIO0021480  
 6ON (FEB 1966)1,7,1 M K BRAKE 11A COMPILATION OF RESONANCE INTEGRAL00021490  
 7811 NUCLEONICS, VOL 24, NO 8, PP 108-111 (AUG 1966)1,7,1 BNAL STAF00021500  
 8E 11INVESTIGATION OF N-2N CROSS SECTIONS11 BN-C-98, PP 64-98 (JUN00021510  
 9 1965)11 00021520  
 9011 FORMAT(18A4,I3) 00021530  
 9012 FORMAT(1H1,20X,18A4) 00021540  
 9013 FORMAT(11 H ALTER AND C E WEBER 11PRODUCTION OF H AND HE IN METALS 00021550  
 1DURING REACTOR IRRADIATION11 J NUCL MATLS, VOL 16, PP 68-73 (1965)00021560  
 21,7,1 L L BENNETT 11RECOMMENDED FISSION PRODUCT CHAINS FOR USE IN 00021570  
 3REACTOR EVALUATION STUDIES11 ORNL-TM-165R (SEPT 1966)11 00021580  
 9014 FORMAT(11 FISSION PRODUCT YIELDS1,7,1 M E MEEK AND S F RIDER, 1100021590  
 1SUMMARY OF FISSION PRODUCT YIELDS FOR U-235, U-238, PU-239, AND P-00021600  
 2-241 AT THERMAL, FISSION SPECTRUM AND 14 MEV NEUTRON ENERGIES00021610  
 3ES11 APED-539A(AEVE.), (OCT. 1968)11 S KATCOFF 11 FISSION PRODUCT0021620  
 4YIELDS FROM NEUTRON INDUCED FISSION11 NUCLEONICS, VOL 18, NO 11, 00021630  
 5(NOV 1960)11 N O DUDLEY 11 REVIEW OF LOW-MASS ATOM PRODUCTION IN F00021640  
 6AST REACTORS11 ANL-7430, (APRIL 1968) 11 00021650  
 9015 FORMAT(1H0,20X,1 LIGHT ELEMENTS, MATERIALS OF CONSTRUCTION, AND ACT00021660  
 1IVATION PRODUCTS 1,7,10 NUCL DLAM FB1 FP FP1 FT F00021670  
 2A SIGH ENG1 FNA FNP RITH FINA F1NP SIGMEV FA2N100021680  
 3 FFA FFP G FG1) 00021690  
 9016 FORMAT(1H0,20X,1 LIGHT ELEMENTS, MATERIALS OF CONSTRUCTION, AND ACT00021700  
 1IVATION PRODUCTS 1,7,10 NUCL DLAM FB1 FP FP1 FT F00021710  
 2A SIGNG ENG1 SIGN2N FN2M1 SIGNA SIGNP G FG AH100021720  
 3NDANCE11 00021730  
 9017 FORMAT(1H ,A2,I3,A1,1PE9,2,0PSF6,3,1PE9,2,0P3F6,3,1PE9,2,0P2F6,3, 00021740  
 11PE9,2,0P4F6,3,0PF5,2) 00021750  
 9018 FORMAT(1H0,10X,1 THERM= 'F10,5,5X,1 RES= 'F10,5,5X,1 FAST= 'F10,5, 00021760  
 177,1X,1 NEUTRON SOURCE= 'S(110,5X),5X,1 NLIRE= '13) 00021770  
 9019 FORMAT(1H0,36X,1 FISSION PRODUCTS1,7,10 NUCL DLAM FB1 FP 00021780  
 1 FP1 FT SIGNG 1, 1 ENG1 Y23 Y25 Y02 Y00021790  
 228 Y49 G FG1) 00021800  
 9020 FORMAT(1H0,36X,1 FISSION PRODUCTS1,7,10 NUCL DLAM FB1 FP 00021810  
 1 FP1 FT SIGNG ENG1 Y25 Y28 Y49 G FG1) 00021820  
 9021 FORMAT(1H ,A2,I3,A1,1PE9,2,0P4F6,3, 1PE9,2,0PF6,3,1PSE9,2, 00021830  
 10P2F6,3) 00021840  
 9022 FORMAT(1H ,A2,I3,A1,1PE9,2,0P4F6,3,1PE9,2,0PF6,3,1PSE9,2,0P2F6,3) 00021850  
 9023 FORMAT(1H0,32X,1 ACTINIDES AND THEIR DAUGHTERS1,7,7 00021860  
 11 NUCL DLAM FB1 FP FP1 FT FA FAF E+6 SIGNG 00021870  
 2ING ENG1 SIGF RIF SIGFF SIGN2N SIGN3N G FG1)00021880  
 9024 FORMAT(1H0,32X,1 ACTINIDES AND THEIR DAUGHTERS1,7,7 00021890  
 11 NUCL DLAM FB1 FP FP1 FT FA FAF E+6 SIGNG F00021900  
 2NG21 SIGF SIGN2N SIGN3N G FG1) 00021910  
 9025 FORMAT(1H ,A2,I3,A1,1PE9,2,0PSF6,3,0PF6,1,1P2F9,2,0PF6,3,1PSE9,2, 00021920  
 1 0PF6,3,FS,2) 00021930  
 9026 FORMAT(1H ,A2,I3,A1,1PE9,2,0PSF6,3,0PF9,1,1PE9,2,0PF6,3,1PSE9,2, 00021940  
 1 0PF7,3,FS,2) 00021950  
 9027 FORMAT(10SUM OF YIELDS OF ALL FISSION PRODUCTS =1,15X,1P3E9,2) 00021960  
 9028 FORMAT(15,2X,1PE10,3,3X,F10,3,5(2X,E10,3,3X,I5)/(50X,5(2X,E10,3, 00021970  
 1 3X,I5))) 00021980  
 9029 FORMAT(1INDN=ZENO MATRIX ELEMENTS AND THEIR LOCATIONS1/ 00021990

```

17 I DIS(I) CAP(I) A(I,J) J A(I,J) 00022000
2J A(I,J) J A(I,J) J A(I,J) J 00022010
9030 FORMAT(64HOSUM OF YIELDS OF ALL FISSION PRODUCTS 00022020
1 ,1PSE9,2) 00022030
9031 FORMAT(SI10) 00022040
9032 FORMAT(I6,F5,3,I1,5F3,3,E5,2,3F3,3,E5,2,2F3,3,E5,2,3F3,3,F4,3,F3,3 00022050
1,F6,4) 00022060
9033 FORMAT(IH ,2,I3,A1,1PE9,2,0P5F6,3,1PE9,2,0PF6,3,1PE9,2,0PF6,3, 00022070
1 1P2E9,2,0P2F6,3,F7,3) 00022080
9034 FORMAT(I7,F9,3,I1,5F5,3,1PE9,2,0P2F5,3,F7,3,2E6,0) 00022090
9035 FORMAT(7X,F9,2,3F5,3,F9,2,2F5,3,F9,2,3F5,3, 5X,I1) 00022100
9036 FORMAT(20A4) 00022110
9037 FORMAT(7X,2F9,2,F5,3,4F9,2,F4,3,F9,2,I1) 00022120
9038 FORMAT(7X,2F9,2,F5,3,5F9,2, 4X,I1) 00022130
9039 FORMAT(10 *WARNING, MUST OF RANGE IN NUDATA, =1 I5) 00022140
9040 FORMAT( 7X,F9,2,3F6,6,F4,2,2F3,1,F9,2,3F5,3,5X,I1) 00022150
9041 FORMAT(10 *NUM HAS EXCEEDED 2500, EQUAL TO I2I6) 00022160
END 00022170
SUBROUTINE COLLECT(TMB,CHASTE,ILITE,ITOT) 00022180
COMMON/EG/XZERD(800), XZH(800),XTEMP(800),XNEW(10,800), 00022190
1 B(800),D(800) 00022200
DIMENSION CHASTE(800) 00022210
IF(TMB,LT,1) RETURN 00022220
DO 10 I=1,ITOT 00022230
B(I)=CHASTE(I) 00022240
XTEMP(I)=0.0 00022250
10 CALL DECAY(1,TMB,ITOT) 00022260
CALL TERM(TMB,1,0,ITOT) 00022270
CALL EQUIL(1,ITOT) 00022280
DO 20 I=1,ITOT 00022290
20 CHASTE(I)=XNEW(1,I)/TMB 00022300
RETURN 00022310
END 00022320
SUBROUTINE STORAG(TMB,CHASTE,ILITE,ITOT) 00022330
COMMON/EG/XZERD(800), XZH(800),XTEMP(800),XNEW(10,800), 00022340
1 B(800),D(800) 00022350
DIMENSION CHASTE(ITOT) 00022360
IF(TMB,LT,1) RETURN 00022370
DELT=TMB 00022380
DO 10 I=1,ITOT 00022390
B(I)=0.0 00022400
10 XTEMP(I)=CHASTE(I) 00022410
CALL DECAY(1,DELT,ITOT) 00022420
CALL TERM(TMB,1,ILITE,ITOT) 00022430
CALL EQUIL(1,ITOT) 00022440
DO 20 I=1,ITOT 00022450
20 CHASTE(I)=XNEW(1,I) 00022460
RETURN 00022470
END 00022480
C PROGRAM BLOCK DATA 00022490
BLOCK DATA 00022500
INTEGER*2 ELE(99),STA(2) 00022510
COMMON/LABEL/ ELE,STA 00022520
DATA ELE/'H','HE','LI','BE','B','C','N','O','F','NE','NA',' 00022530
1G','AL','SI','P','S','CL','AR','K','CA','SC','TI','V','CR','Mn'00022540
2','FE','CO','Ni','CU','Zn','Ga','Ge','As','Se','Br','Kr','Rb','Sr'00022550
3','Y','Zr','Nb','Mo','Tc','Ru','Rh','Pd','Ag','Cd','In','Sn','Sb'00022560
4','Te','I','Xe','Cs','Ba','La','Ce','Pr','Nd','Pm','Sm','Eu','Gd'00022570
5','Tb','Dy','Ho','Er','Tm','Yb','Lu','Hf','Ta','W','Re','Os','Ir'00022580
6','Pt','Au','Hg','Tl','Pb','Bi','Po','At','Rn','Fr','Ra','Ac','Th'00022590
7','U','Np','Pu','Am','Cm','Bk','Cf','Es'/' 00022600

```

3-63

```

DATA STA/1 1,1,1,1
END
SUBROUTINE HALF(C,I)
SUBROUTINE HALF CONVERTS HALF-LIFE TO DECAY CONSTANT (1/SEC)
DIMENSION C(9)
DATA C/9.9315E+01,1.1552E+02,1.9254E+04,1.0226E+06,2.1965E+08,0.0,
1 2.1965E+11,2.1965E+14,2.1965E+17
IF(C.GT.0.0) GO TO 10
IF(I.EQ.6) GO TO 20
A9.00
RETURN
A9(C)/A
RETURN
A9.0
RETURN
END
SUBROUTINE NOAH(NUCL,NAME)
SUBROUTINE NOAH CONVERTS SIX DIGIT IDENTIFIER TO ALPHABETIC SYMBOL
INTEGER*2 NAME(3)
INTEGER*2 FLE(99),STA(2)
COMMON/LABEL/ ELE,STA
NZ =NUCL/10000
NAME(1)=ELE(NZ)
NAME(2)=M
NAME(3)=STA(19)
RETURN
END

```



CHAPTER 4. DATA NEEDED FOR RADIOACTIVE SOURCE TERM  
CALCULATIONS FOR BOILING WATER REACTORS (BWRs)

This chapter lists the information needed to generate source terms for BWRs. The information is provided by the applicant and should be consistent with the contents of the Safety Analysis Report (SAR) and the Environmental Report (ER) of the proposed boiling water reactor. This information is the basic data required to calculate the releases of radioactive material in liquid and gaseous effluents (the source terms). All data is on a per-reactor basis.

4.1 GENERAL

1. The maximum core thermal power (MWt) evaluated for safety considerations in the SAR. (Note: All of the following responses should be adjusted to this power level.)
2. The quantity of tritium released in liquid and gaseous effluents (Ci/yr per reactor).

4.2 NUCLEAR STEAM SUPPLY SYSTEM

1. Total steam flow rate (in lb/hr).
2. Mass of reactor coolant (in lb) in the reactor vessel at full power.

4.3 REACTOR COOLANT CLEANUP SYSTEM

1. Average flow rate (in lb/hr).
2. Demineralizer type (deep bed or powdered resin) and size (in ft<sup>3</sup>).
3. Regeneration or replacement frequency.
4. Regenerant volume (in gal/event) and activity (if applicable).

4.4 CONDENSATE DEMINERALIZERS

1. Average flow rate (in lb/hr).
2. Demineralizer type (deep bed or powdered resin).
3. Number and size (in ft<sup>3</sup>) of demineralizers.
4. Regeneration or replacement frequency.
5. Indicate whether ultrasonic resin cleaning is used and waste liquid volume associated with its use.
6. Regenerant volume (in gal/event) and activity.

4.5 LIQUID WASTE PROCESSING SYSTEMS

1. For each liquid waste processing system, provide in tabular form the following information:
  - a. Sources, flow rates (in gal/day), and expected activities (fraction of primary coolant activity, i.e., PCA) for all inputs to each system.
  - b. Holdup times associated with collection, processing, and discharge of all liquid streams.
  - c. Capacities of all tanks (in gal) and processing equipment (in gal/day) considered in calculating holdup times.
  - d. Decontamination factors for each processing step.

- e. Fraction of each processing stream expected to be discharged over the life of the plant.
  - f. For waste demineralizer regeneration, the time between regenerations, regenerant volumes and activities, treatment of regenerants, and fractions of regenerant discharged. Include parameters used in making these determinations.
  - g. Liquid source term by radionuclide (in Ci/yr) for normal operation, including anticipated operational occurrences.
2. Provide piping and instrumentation diagrams and process flow diagrams for the liquid radwaste systems, along with all other systems influencing the source term calculations.

#### 4.6 MAIN CONDENSER AND TURBINE GLAND SEAL AIR REMOVAL SYSTEMS

1. The holdup time (in hr) for offgases from the main condenser air ejector prior to processing by the offgas treatment system.
2. A description and the expected performance of the gaseous waste treatment systems for the offgases from the condenser air ejector and mechanical vacuum pump. The expected air inleakage per condenser shell, the number of condenser shells, and the iodine source term from the condenser.
3. The mass of charcoal (in tons) in the charcoal delay system used to treat the offgases from the main condenser air ejector, the operating and dew point temperatures of the delay system, and the dynamic adsorption coefficients for Xe and Kr.
4. A description of the cryogenic distillation system, the fraction of gases partitioned during distillation, the holdup in the system, storage following distillation, and the expected system leakage rate.
5. The steam flow (in lb/hr) to the turbine gland seal and the source of the steam (primary or auxiliary).
6. The design holdup time (in hr) for gas vented from the gland seal condenser, the iodine partition factor for the condenser, and the fraction of radioiodine released through the system vent. A description of the treatment system used to reduce radioiodine and particulate releases from the gland seal system.
7. Piping and instrumentation diagrams and process flow diagrams for the gaseous waste treatment system, along with all other systems influencing the source term calculations.

#### 4.7 VENTILATION AND EXHAUST SYSTEMS

For each plant building housing the main condenser evacuation system, the turbine gland seal system exhaust, or any system that contains radioactive materials, provide the following:

1. Provisions incorporated to reduce radioactivity releases through the ventilation or exhaust systems.
2. Decontamination factors assumed and the bases (include charcoal adsorbers, HEPA filters, and mechanical devices).
3. Release rates for radioiodines, noble gases, and radioactive particulates (in Ci/yr); radioactive particulate size distribution; and the bases.
4. Release point description including height above grade, height above and location relative to adjacent structures, expected average temperature difference between gaseous effluents and ambient air, flow rate, exit velocity, and size and shape of flow orifice.
5. For the containment building, indicate the expected purge and venting frequencies and duration and the continuous purge rate (if used).

## REFERENCES

1. ANS 18.1 Working Group, American National Standards Source Term Specification N237, "Radioactive Materials in Principal Fluid Steams of Light-Water-Cooled Nuclear Power Plants," Draft, July 7, 1975.
2. U.S. Atomic Energy Commission, Docket RM-50-2, "Effluents from Light-Water-Cooled Nuclear Power Reactors; AEC Staff Exhibit No. 22; Results of Independent Measurements of Radioactivity in Process Systems and Effluents at Boiling Water Reactors," C. A. Pelletier, May 1973.
3. General Electric Co., Licensing Topical Report NEDO-10871, "Technical Derivation of BWR 1971 Design Bases Radioactive Material Source Terms," J. M. Skarpelos and R. S. Gilbert, San Jose, Calif., March 1973.
4. General Electric Co., NEDM-12426, "Carryover Measurements at Oyster Creek Nuclear Power Station, March 27-28, 1973," R. S. Gilbert and H. R. Helmholtz, Table 1, p. 5, advance copy pending final General Electric Co. and customer clearance, May 1973.
5. Commonwealth Edison Co., Report No. 21, "Measurements of Radioactivity in Process Systems of the Dresden Nuclear Power Station and in the Environment, Jan. - Feb. 1971," J. Golden and R. Pavlick, Table 7, p. 34, April 1973.
6. Report from Nuclear Environmental Services to Yankee Atomic Electric Company concerning "Iodine-131 Releases from the Vermont Yankee Nuclear Power Station," Oct. 15, 1974.
7. General Electric Co., NEDE-11215, "Noble Gas and Iodine Activity in the Oyster Creek Ventilation and Offgas Systems During Power Operation," H. R. Helmholtz, R. S. Gilbert, and M. E. Meek, March 1973.
8. General Electric Co., "Millstone Nuclear Power Station, Ventilation Sampling Program, July 13 - August 5, 1972," H. R. Helmholtz, Draft, April 1973.
9. Letter from F. E. Kruesi, Director, Regulatory Operations, to B. B. Stephenson, Superintendent, Quad Cities Station, Commonwealth Edison Company, "Results of Measurements at Quad Cities Station," May 22, 1973.
10. Letter from R. S. Gilbert, General Electric Co., to V. Benaroya and J. Collins, USAEC, Re: "Information Disclosure of Progress on Ventilation Studies (Nine Mile Point Ventilation Measurements)," May 23, 1974.
11. Nuclear Environmental Services for Electric Power Research Institute, "Radionuclide Releases from Vermont Yankee Nuclear Power Station," Jan. 1975.
12. Pilgrim Unit 1, "Augmented Systems for Reduction of Radioactive Material in Effluents," Amendment 31 to Final Safety Analysis Report (FSAR), November 1971.
13. Hope Creek Preliminary Safety Analysis Report (PSAR), Amendment 4, p. 9.4-3, March 1971.
14. Nuclear Containment Systems, Inc., NCS-1101, "Dynamic Adsorption Coefficient and Its Application for Krypton - Xenon Delay Bed Design," J. L. Kovach, Draft, November 1971.
15. L. R. Michaels and N. R. Horton, "Improved BWR Offgas Systems," 12th Air Cleaning Conference, San Jose, Calif., August 1972.
16. Oak Ridge National Lab., ORNL Central Files Number 59-6-47, "Removal of Fission Product Gases from Reactor Offgas Streams by Adsorption," W. E. Browning, R. E. Adams, and R. D. Ackley, June 11, 1959.
17. H. J. Schroeder, H. Queiser, and W. Reim, "Offgas Facility at the Gundremmigen Nuclear Power Plant," J. Nucl. Eng. Sci., No. 5, pp. 205-213, May 1971.
18. Letter from Kernkraftwerk Lengen GmbH to Peter Lang, North American Carbon, "Gas Delay System at KWL," Dec. 30, 1970.

19. General Electric Co., NEDO-10751, "Experimental and Operational Confirmation of Offgas System Design Parameters," C. W. Miller, proprietary report, October 1972.
20. Letter from J. L. Kovach, Nuclear Containment Systems, Inc., to V. Benaroya, USAEC, "Gas Delay System," Dec. 1, 1971.
21. D. P. Siegwarth, C. K. Neulander, R. T. Pao, and M. Siegler, "Measurement of Dynamic Adsorption Coefficients for Noble Gases on Activated Carbon," 12th Air Cleaning Conference, August 1972.
22. Letter from R. W. Scherer, Georgia Power Company, to R. S. Boyd, USAEC, "Edwin Hatch Source Term Data," Feb. 24, 1972.
23. R. J. Rivers, M. Pasha, and W. H. Buckler, "Correlation of Radioiodine Efficiencies Resulting from Standardized Test Program for Activated Carbons," 12th AEC Air Cleaning Conference, CONF-720823, Vol. 1, August 1972.
24. Hope Creek Preliminary Safety Analysis Report (PSAR), Amendment 11, p. 9.4-6a, November 1973.
25. Air Products and Chemicals, Inc., "Supplemental Information for the Offgas Treatment System, Newbold Island Nuclear Generating Station," proprietary report, Nov. 1971.
26. Battelle Columbus Laboratories, "Evaluation of Data Regarding the Efficiency of Activated Charcoal Adsorbers at Low Gas Phase Iodine Concentration," R. M. Ritzman and G. M. Genco, pp. 25-26, May 1961.
27. J. G. Wilhelm, H. G. Dillman, and K. Gerlach, "Testing of Iodine Filter Systems Under Normal and Post Accident Conditions," 12th AEC Air Cleaning Conference, CONF-720823, Vol. 1, August 1972.
28. ANSI Standard N510, "Testing of Nuclear Air Cleaning Systems," 1975.
29. ANS 52.3 Working Group, American National Standards draft standard, "Boiling Water Reactor Liquid Radioactive Waste Processing System," Aug. 30, 1974.
30. Letter from J. S. Abel, Commonwealth Edison Company, to D. F. Ziemann, AEC, Re: "Condensate Demineralizer Regeneration Data," May 9, 1974.
31. J. H. Hollway and P. J. Hollifield, "Ultrasonic Cleaning of Deep Bed Resins for Condensate Demineralizer Systems," Proceedings of the American Power Conference, Vol. 33, 1971.
32. Letter from R. C. Haynes, Boston Edison Company, to Director, Directorate of Licensing, USAEC, Re: "Ultrasonic Resin Cleaner Performance Report," April 10, 1973.
33. Westinghouse Corp., WCAP-8253, "Source Term Data for Westinghouse Pressurized Water Reactors," May 1974.
34. Oak Ridge National Lab., ORNL-4792, "Application of Ion-Exchange Technology in Nuclear Industry," K. H. Lin, April 1972.
35. Oak Ridge National Lab., ORNL-4790, "Use of Evaporation for the Treatment of Liquids in the Nuclear Industry," H. B. Godbee, September 1973.
36. Letter from R. Hurley, Rochester Gas & Electric, to W. Hewitt, USAEC, "Ginna Station Reverse Osmosis Data," Feb. 7, 1973.
37. Letter from Rochester Gas & Electric to J. Markland, Westinghouse Power Systems, "Isotopic Analysis of Laundry Reverse Osmosis Water," June 18, 1973.
38. Westinghouse Trip Report to Ginna Station by P. Manard, Sept. 1974.
39. Memo from L. Becker, Westinghouse, to S. Works, R. Trailer, and M. Gross, Wisconsin Electric Power Co., Re: "Results of Reverse Osmosis Unit Tested at Point Beach, Wisconsin," Aug. 2, 1971.
40. Westinghouse Research Laboratories, "Evaluation of a Westinghouse Reverse Osmosis Radioactive Laundry Water Concentrator," R. R. Stanna and J. W. Foenst, May 1973.

41. W. R. Greenway, W. J. Klein, J. Marking, and R. R. Stanna, "Treatment of Radioactive Steam Generator Blowdown," 33rd Annual Meeting of International Water Conference of the Engineers Society of Western Penn., Oct. 24-26, 1972.
42. C. Kunz et al., "C-14 Gaseous Effluents from Boiling Water Reactors," Transactions of the American Nuclear Society, 1975 Annual Meeting, June 8-13, 1975, New Orleans, La., pp. 91-92.