



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

TERA

JANUARY 10 1980

Docket Nos. 50-277
and 50-278

Mr. Edward G. Bauer, Jr., Esquire
Vice President & General Counsel
Philadelphia Electric Company
2301 Market Street
Philadelphia, Pennsylvania 19101

Dear Mr. Bauer:


In response to our letter of August 29, 1978, you provided information on your 1977 experience of control rods failing to fully insert. We evaluated your response along with those provided by other BWR owners. We concluded that such events are general and that the frequencies of occurrence vary among the BWRs, apparently because of different maintenance programs.

Our August 29, 1978 letter recommended that you maintain an ongoing tabulation of any additional such events. To determine whether or not the frequency of these events has changed for a given plant, we now request that you report your more recent experience. This report should include the experience from the time of the last reported occurrence through 1979. In addition please provide a summary of other control rod drive malfunctions, such as unlatchings, for the same time period.

The information should be provided within 90 days. For each event, identify the number of rods not fully inserted, the position of the rods, the cause for failure to fully insert, and any related maintenance activities.

This request for additional generic information is in accordance with the GAO blanket clearance number B-180225 (R0536) which expires June 30, 1981.

Sincerely,


Thomas A. Ippolito, Chief
Operating Reactors Branch #3
Division of Operating Reactors

8002150 307

Mr. Edward G. Bauer, Jr.
Philadelphia Electric Company

- 2 -

cc:

Eugene J. Bradley
Philadelphia Electric Company
Assistant General Counsel
2301 Market Street
Philadelphia, Pennsylvania 19101

Troy B. Conner, Jr.
1747 Pennsylvania Avenue, N. W.
Washington, D. C. 20006

Raymond L. Hovis, Esquire
35 South Duke Street
York, Pennsylvania 17401

Warren K. Rich, Esquire
Assistant Attorney General
Department of Natural Resources
Annapolis, Maryland 21401

Government Publications Section
State Library of Pennsylvania
Education Building
Commonwealth and Walnut Streets
Harrisburg, Pennsylvania 17126

M. J. Cooney, Superintendent
Generation Division - Nuclear
Philadelphia Electric Company
2301 Market Street
Philadelphia, Pennsylvania 19101

Edward Greenman
U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Peach Bottom Atomic Power Station
P. O. Box 399
Delta, Pennsylvania 17314

Philadelphia Electric Company
ATTN: Mr. W. T. Ullrich
Peach Bottom Atomic
Power Station
Delta, Pennsylvania 17314