



bcc to DAC:ADM:  
CENTRAL FILES  
PDR:HQ  
LPDR  
~~TIC~~  
NSIC

ARKANSAS POWER & LIGHT COMPANY  
POST OFFICE BOX 551 LITTLE ROCK, ARKANSAS 72203 (501) 371-4000

STATE

December 12, 1979

1-129-5  
2-129-4

Mr. K. V. Seyfrit, Director  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Region IV  
611 Ryan Plaza Drive, Suite 1000  
Arlington, Texas 76011

Subject: Arkansas Nuclear One - Units 1 & 2  
Docket Nos. 50-313 and 50-368  
License Nos. DPR-51 and NPF-6  
Response to IE Bulletin No. 79-25

(File: 1510.1 and 2-1510.1)

Gentlemen:

In response to the subject bulletin, there are no Westinghouse BFD/NBFD relays used or planned for use in safety related systems at either Arkansas Nuclear One, Unit 1 or Arkansas Nuclear One, Unit 2.

Very truly yours,

*David C. Trimble*

David C. Trimble  
Manager, Licensing

DCT:MAS:skm

cc: Mr. Victor Stello, Jr., Director  
Office of Inspection and Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Mr. W. D. Johnson  
U. S. Nuclear Regulatory Commission  
P. O. Box 2090  
Russellville, AR 72801

8002150

355