

POOR ORIGINAL



**UNITED STATES
NUCLEAR REGULATORY COMMISSION**

In the matter of:

~~SCHEDULE 1~~
TERA (1)

MEETING OF THE ADVISORY COMMITTEE ON
REACTOR SAFEGUARDS,
SUBCOMMITTEE ON THREE-MILE ISLAND, UNIT 1
NUCLEAR POWER PLANT

Place: Middletown, Pennsylvania

Date: January 31, 1980

Pages: 1 - 282

INTERNATIONAL VERBATIM REPORTERS, INC.
499 YOUTH CAPITOL STREET, S. W. SUITE 107
WASHINGTON, D. C. 20002
202 484-3550

8002190

808

1
2 UNITED STATES
3 NUCLEAR REGULATORY COMMISSION
4
5
6
7
8
9
10

American Legion Hall
137 East High Street
Middletown, Pennsylvania

Thursday, January 31, 1980

11 The Committee on Reactor Safeguards, Subcommittee
12 on Three-Mile Island, Unit 1, Nuclear Power Plant,
13 convened at 8:30 a.m., in Middletown, Pennsylvania,
14 Harold Etherington (Chairman of the Subcommittee),
15 presiding.

16 PRESENT:

17
18 Dr. Stephen Lawroski

19 Mr. Jesse Ebersole

20 Mr. William Mathis
21
22
23
24
25

P R O C E E D I N G S

MR. ETHERINGTON: The meeting will now come to order.

This is a meeting of the Advisory Committee on
Reactor Safeguards Subcommittee on Three Mile Island-1.

I am Harold Etherington.

The other ACRS Members present today are;

Dr. Stephen Lawroski, Mr. Jesse Ebersole, Mr. William Mathis;
and the ACRS Consultants are : Dr. Lipinski, Dr. Catton,
Dr. Foster, and Dr. Dillon.

The purpose of this meeting is to discuss the NRC
Staff Status Report on the Evaluation of Metropolitan Edison
Company Compliance with the NRC Order dated August 9, 1979,
and other matters connected with the restart of Three Mile
Island Nuclear Station Unit 1.

The meeting is being conducted in accordance with
the provisions of the Federal Advisory Committee Act and the
Government in the Sunshine Act. Mr. Ragnwald Muller is
the Designated Federal Employee for the meeting. Also
present from the ACRS Staff is Mr. Peter Tam.

The rules for participation in today's meeting have
been announced as part of the notice of this meeting pre-
viously published in the Federal Register.

A transcript of the meeting is being kept, and it
is requested that each speaker first identify himself and
speak with sufficient clarity and volume that he can be

1 readily heard.

2 We have received no requests for oral statements
3 from members of the public. We have received no written
4 statements from members of the public.

5 The Subcommittee will now have a brief open session
6 following which we will begin the Staff presentation as
7 scheduled on the agenda. The Open Executive Session will be
8 recorded.

9 A number of our Members and Consultants had an
10 opportunity to visit the Three Mile Island site yesterday
11 and I would like at this time to poll the Committee to see
12 if there are any things they would like to have added to the
13 agenda as a result of what they saw.

14 I think we might just defer that until we've looked
15 at the agenda and I'll raise the question again later.

16 I'll state very briefly the purpose of the meeting
17 in more detail than was covered by the notice.

18 Following the Unit 2 accident, Unit 1 was kept in
19 the shutdown condition and on July the 2nd, the Commission
20 issued a formal order that the Unit remain shutdown until
21 further orders. On August 9, the Commission issued a follow-
22 up order giving reasons for its July the 2nd order and
23 specifying requirements to be met as a condition for con-
24 sideration of approval of continued operation.

25 The second order requires a hearing by an Atomic

1 Safety and Licensing Board and this implies a review by the
2 ACRS, this being a Subcommittee preliminary to that meeting.

3 The technical and administrative requirements im-
4 posed by the order of August 9, include the post Three Mile
5 Island 2 accident short term and long term items applicable
6 to all nuclear power reactors. Those applicable only to
7 B&W reactors and those unique to Three Mile Island 1 because
8 of the proximity of Three Mile Island 2 during cleanup.

9 The Subcommittee has the Met Ed report on the
10 status of the restart requirements with amendments through
11 ten. It also has the Regulatory Staff Safety Evaluation
12 Report dated January 11, covering amendments through eight,
13 as well as many earlier documents that we've been receiving
14 over the past year, including B&W analyses.

15 I understand the NRC Staff and Met Ed wish to make
16 a presentation to the ACRS in its February meeting next week.
17 The Subcommittee will have to decide whether to recommend
18 that course to the Full Committee. The Regulatory Staff's
19 SER, Safety Evaluation Report, shows that many of the ordered
20 items had not been implemented to the satisfaction of the
21 Staff at the time the report was written. And, that other
22 items are still under review by the Staff.

23 Unless most of these items have subsequently been
24 cleaned up, it appears that a review by the Full Committee
25 could be premature. I think the Subcommittee would like to

1 have a schedule and a prognosis for the full assurance
2 of conformance with all of the requirements of the order.

3 The Met Ed and ACRS reports and the agenda for this
4 meeting address the specific items of the order for continued
5 shutdown. It's possible, however, that the ACRS will want to
6 discuss and make recommendations on matters outside the
7 scope of the NRC order particularly concerning generic matters.
8 These are not addressed in the SER, appropriately; there's
9 no reason for them to be addressed, but I think the Sub-
10 committee probably should decide what other items it wishes
11 to hear at this meeting or to prepare the licensee for the
12 future meeting with the Full Committee.

13 Now, we have the agenda prepared by Mr. Muller.
14 I think we've all seen it. We might take a moment to look
15 it over and decide whether we wish to have other things added
16 to the items listed. I might say that tomorrow's meeting
17 will stop promptly at 12 o'clock because of travel plans,
18 so any additional items we will add to today's agenda.

19 I might ask, Steve, do you have anything that you
20 feel can be added?

21 DR. LAWROSKI: Perhaps it's been covered -- I
22 wondered if we could get a short presentation on what has been
23 done with respect to better sampling capabilities in the
24 event of problems.

25 MR. ETHERINGTON: Now, can that be covered in any

1 of these items or is that a separate item, Steve?

2 DR. LAWROSKI: Well, it could be covered under some
3 of these; I'm not sure that they will be.

4 MR. ETHERINGTON: Well, to the extent that it can
5 be, let's just alert Met Ed to the fact that we would like
6 to hear on those items.

7 Is there any other -- Jesse?

8 MR. EBERSOLE: No, I have none.

9 MR. ETHERINGTON: The Consultants, Ivan, is there
10 anything that is not covered or that we'd like to alert the
11 licensee to?

12 DR. CATTON: There are some things that I can't
13 really find; that doesn't mean that they are not being
14 covered, maybe I should just mention them.

15 MR. ETHERINGTON: Yes, just mention them.

16 DR. CATTON: The first is pressurizer and I think
17 Walt probably described that better than I. The hydrogen
18 recombiners -- I'd like to hear something about the incon-
19 tainment recirculation and how they're going to avoid buildup
20 above the air conditioner intakes.

21 MR. ETHERINGTON: Yes, I would imagine questions
22 like that can be answered without preparation when we come
23 to it.

24 DR. CATTON: I would think so. The system is
25 designed and they already know where they're going to hook it

1 in. I'd like to hear a little bit about how they are going
2 to meet Re guide 197. Also, a description of the control
3 room data retrieval system; we heard a little bit about that
4 yesterday during our tour and one thing that came out of
5 reading some of the reports; I'd like to know what the minimum
6 steam generator level at which circulation can occur.

7 DR. LIPINSKI: Most of the items of interest that
8 we tried to examine on the tour were not yet installed, for
9 example, the Controlatron Corporation flow meters; they're
10 not in place yet, but there is a description of the material
11 in the TMI 1 report by Met Ed.

12 We did look at the question of steamline break and
13 its influence on the electrically driven aux feed pumps. I
14 don't know that anymore needs to be discussed in that area.

15 The subcooling meter for determining the condition
16 of the core was discussed. This meter's being provided by
17 another vender other than B&W and the question came up
18 whether it should indicate superheat as well. This has been
19 discussed at other meetings of the ACRS Subcommittee meetings
20 by one of the Members of that Committee.

21 We did find out that fluffing valves are not in
22 place at Unit 1 as they are in 2 because of the difference
23 in handling the water clean up system, but we did find out
24 that the instruments there in service are interconnected
25 and there is some question to the desirability of maintaining

such interconnection. Perhaps the Applicant would like to discuss the benefits of maintaining this cross-connection.

We did see the Highpoint vents and the Candycanes; those are physically present, but motor operators are yet to be installed and that's indicated as an item still open requiring completion.

MR. ETHERINGTON: I think some of these questions -

DR. LIPINSKI: They can be covered in the course of the --

MR. ETHERINGTON: -- can be covered within questions -

DR. LIPINSKI: Right. We did examine the heater wiring because the current recommendation to place a minimum amount of heaters on emergency power such that the system pressure can be maintained. The susceptibility of the wiring to conditions within containment is of question. On Unit 2, these heaters were not necessarily available with reliability and it appears that the incontainment conditions were responsible with respect to the heaters being able to function. Provisions are being made to provide the electrical power to heaters from the diesels, but the question remains as to the suitability of the wiring within containment as to even though if they had emergency power available whether those heaters will operate under accident conditions and I think some discussion along that line is warranted.

I think that covers the points that I have.

1 MR. ETHERINGTON: Thank you, Walt.

2 Mr. Mathis?

3 MR. MATHIS: There is just one thing that I think
4 we need a little bit more elaboration on: we discussed, some-
5 what, yesterday on our tour the change that was being made
6 in procedures and we just covered it very superficially.
7 I think we would like to know more about the overall status
8 of the procedural write-up changes.

9 That's all I have to say.

10 DR. FOSTER: My questions are going to be focused
11 mainly on the emergency preparedness. Since there's heavy
12 State involvement there, I'm wondering whether there will be
13 anyone here from the State of Pennsylvania.

14 MR. DORNSIFE: I'm from DER.

15 DR. FOSTER: Thank you.

16 MR. DORNSIFE: I'm Bill Dornsife.

17 DR. FOSTER: Very good, thank you.

18 There are a couple of other things relative to those
19 plans; one of them is a little discussion on the capability
20 of rapidly estimating releases to the environment which might
21 trigger action plans. Another aspect which I've seen little
22 of so far is emergency plans which relate to downstream
23 water users.

24 That's all I have.

25 DR. DILLON: I share a little of Dr. Lawroski's

1 concern about the post accident sampling capability. I
2 would like to hear something about that, particularly the
3 objectives. And, I noticed in reference to an augmented
4 materials technology capability in the new organization; I
5 would like to know whether that includes any significant
6 way to prove analytical capability, anything to do with
7 augmented water chemistry monitoring.

8 That's all I have.

9 MR. ETHERINGTON: Yes?

10 MR. ARNOLD: Robert Arnold, with Metropolitan
11 Edison Company and GPU Service Corporation.

12 I wonder if we could have some clarification to
13 be sure that we're covering all of these items, Mr. Chairman.
14 We do have the reactor coolant sampling listed under agenda
15 item number 9 and we would expect to cover at that point
16 those items that relate to sampling of the primary coolant
17 system.

18 Is there other sampling that is desired that we
19 be prepared to discuss outside of that?

20 DR. LAWROSKI: Yes, sampling of, for example, the
21 containment from the standpoint of you having a better
22 value of a source term should a problem arise than might
23 otherwise be the case if there were no good provisions for
24 a good representative sample or samples of that.

25 MR. ARNOLD: Then I believe there was a very brief

1 reference to the pressurizer and it wasn't clear to me if
2 there's additional information anticipated there or not.
3 I wasn't sure what the issue was that was being identified.

4 DR. CATTON: I think it was concerned about its
5 being able to survive or rather what environment.

6 MR. ARNOLD: The pressurizer heaters.

7 DR. CATTON: Heaters.

8 MR. ARNOLD: Now, prior to the discussion on the
9 heaters, there was a very -- kind of a passing reference
10 almost to a pressurizer and then I think the comment that,
11 perhaps, that that was going to be covered already. I don't
12 want to raise an issue if there's not one there.

13 DR. CATTON: I commented on the pressurizers and
14 turned it over to Walt Lipinski.

15 DR. LIPINSKI: For the details.

16 DR. CATTON: For the details.

17 MR. ETHERINGTON: I think if there should be any
18 question that you're not quite prepared with, we'll give an
19 opportunity tomorrow to clean it up.

20 MR. ARNOLD: I think that if we can be sure of
21 the people that we have lined up for tomorrow, though, we can
22 expedite the proceedings, sir.

23 MR. ETHERINGTON: Yes.

24 DR. LIPINSKI: Mr. Chairman, I have two other
25 points I would like to add.

1 We did examine the hydrogen recombiner that was
2 already in place waiting to be connected. But, the report
3 references a second hydrogen recombiner that's to be obtained
4 and stored in a seismic location and pulled into place and
5 connected if needed.

6 The question is: is this a dedicated hydrogen
7 recombiner to Unit 1 and if it is, why isn't it pulled into
8 place to begin with and connected? Why the intermediate
9 requirement for storage?

10 MR. ARNOLD: We'll be prepared to answer that
11 question.

12 DR. LIPINSKI: Okay. The other one is that the
13 security system, in getting through the various doors in the
14 plant, when your computer goes down, key cards do not allow
15 anyone to pass through those doors. Your guards are required
16 to appear with a key --

17 MR. MULLER: I think that's a security question and
18 that it should be handled in a closed meeting.

19 DR. LIPINSKI: Okay, but this is with respect to
20 the emergency plan; let me point at what the thing is that's
21 bothering me and then you can decide whether it should be
22 closed or not. But, under emergency conditions, the
23 operators have to gain access through the various parts of
24 the plant and your security computer is down, they then
25 have to wait for the guard to appear with a key and the

question is: should there be a quicker method for the operators to be able to move through that plant in the event that the card computer is not working.

MR. ARNOLD: I would suggest that that is a topic for a closed session and I think we could address that in a closed session at this meeting.

DR. LIPINSKI: Okay.

MR. ETHERINGTON: I think probably we'd better proceed with the agenda now and if difficult questions come up for today, we can take care of them tomorrow.

MR. ARNOLD: Excuse me, Mr. Chairman, I did have two other items that I'd like clarification on, if I may.

One is: Is there additional information desired on the flow meter or is the information that was in the report sufficient at this point?

DR. CATTON: I believe that we heard about the flow meter at a meeting a week or so ago. I personally would like some of the details and so forth, but I don't think that this meeting is the place for it. If you could direct me to a report that describes it.

DR. LIPINSKI: It's right here.

DR. CATTON: Oh, it's already here; I just missed it. Thank you.

MR. ARNOLD: Mr. Dornis is here from the State Department of Environmental Resources and they are the ones

1 that we interface directly with in the event of emergency
2 but the Pennsylvania Emergency Management Agency has overall
3 responsibility for emergency planning within the State and
4 if the Subcommittee wanted someone from that agency here
5 tomorrow, I would think we'd want to make arrangements for
6 it today.

7 MR. ETHERINGTON: Is there any further pre-meeting --

8 DR. FOSTER: Perhaps I could respond to that. If
9 Mr. Dornsife could, perhaps, respond to some of the questions
10 relative to evacuation plans and capabilities, why that,
11 perhaps, would take care of my special questions.

12 MR. ARNOLD: The last item I have, Mr. Chairman,
13 is the -- we'd like to change the sequence, if you could
14 indulge us, to move agenda item 9 up to follow agenda item 2,
15 on the discussion of plant changes for this afternoon.

16 MR. ETHERINGTON: Agenda item 9 to item 2; all
17 right. That's this afternoon; is that right?

18 MR. ARNOLD: Yes, sir.

19 MR. ETHERINGTON: That's Arabic 2, not Roman 2.

20 MR. ARNOLD: Excuse me, sir. We would like to move
21 it up to the following, Arabic 2, yes. We would like to
22 treat -- to deal with that immediately after the separation
23 of Unit 1 and Unit 2 since some of the same people will be
24 involved.

25 MR. ETHERINGTON: Yes?

1 MR. DORNSIFE: Mr. Chairman, Bill Dornsife from
2 Pennsylvania DOE.

3 May I please ask a question about the emergency
4 planning aspects? If you would like to ask about emergency
5 plans; evacuation plan in particular, our agency would not
6 be the one who would be the experts in that area. We inter-
7 face only with the emergency, the radiological aspects of the
8 implementation of the plan. We are not familiar with the
9 evacuation set-ups, so if your questions are concerning
10 evacuation primarily, it would be appropriate to have someone
11 from the Pennsylvania Emergency Management --

12 MR. ETHERINGTON: I think, perhaps, we might wait
13 to see what the questions are and whether they can be
14 adequately answered by Met Ed and their own Staff.

15 Are there any further comments on the agenda?

16 DR. LAWROSKI: With respect to the samplings, I
17 also had in mind that there would be provisions made for
18 sampling either liquid or gaseous materials in all the places
19 that one might postulate the stuff might get to, not just
20 where it normally should be.

21 MR. ARNOLD: Yes, sir, I think we understand the
22 question.

23 MR. ETHERINGTON: Well, the first item on the
24 agenda is an introduction by Mr. Vollmer for the NRC Staff.

25 MR. VOLLMER: Thank you, Mr. Chairman.

We appreciate the opportunity to discuss with the Subcommittee our evaluations, to date, on the TMI 1 restart.

First of all, I would like to introduce the Staff Members that we have here who have participated in this review. Going down the line: John Vogelwede, Jerry Mazetis, Harley Silver, who is the project manager for this effort; continuing on down this table: Jerry Wermeil, John Nehemias, Doug Collins, Lee Bettenhausen, Don Haverkamp; then on the back row here: Jay Lee, Scott Newberry, and Bruce Boger.

We brought, generally, most of the people who have been involved in this review because we realize that the restart SER was not as complete as we would have liked. We have been fighting a battle of trying to be expeditious in the plan to the Commission order, but on the other hand, being as technical and complete as possible. And, again, we have a number, as you indicated, a number of open items in the report which are yet to be addressed.

Harley Silver will try to give you a full status report on where those items stand and when we expect to have complete information and complete review by the Staff on them. I might indicate that the large number of open items is partly a reflection to the fact that we are doing a more detailed review of many of these issues than we normally do, particularly to the extent that we are looking at detailed procedures and test plans and implementation whereas normally, in many

1 cases, the Staff does not review that type of topic.

2 Finally, we will be prepared to give you a full
3 status report on how the generic items are being handled
4 as well as all of the licensing backlog issues are also being
5 handled. I include in those all of the issues that have been
6 requested of operating reactors since TMI 1 has been shut down
7 through the IE Bulletins, through requests from DOR as well
8 as all the pending license amendments and changes that occur,
9 that were since it was backlogged at the time of shutdown.

10 MR. ETHERINGTON: When will this supplementary
11 material be available, Mr. Vollmer?

12 MR. VOLLMER: Okay, well, today we will address
13 precisely what we are doing, or tomorrow, what we are doing
14 with the backlog issues and the generic issues and we have
15 not included those in the restart report, but we would intend
16 to get them in either through supplements or testimony.
17 As you indicated, at this point in time, we essentially
18 address only the issues covered by the Commission order.

19 DR. LAWROSKI: Could you give us an estimate of
20 about where you think you are? Half-way, two thirds?

21 MR. VOLLMER: Maybe Mr. Silver could cover that.

22 MR. SILVER: Well, I can cover it -- Harley Silver.
23 I can cover it briefly. I gave your Staff people a single
24 copy as of now of the status report of these additional
25 items. The front page of which summarized the number of

1 these items which would probably be completed by the time
2 of restart. I don't have a copy with me; I think Rags has
3 it over there.

4 I'm not knowledgeable in detail on this material.
5 The person who is had planned to be here tomorrow to present
6 this to you.

7 DR. LAWROSKI: You wouldn't happen to guess whether
8 it's a half --

9 MR. SILVER: It's significantly more than half, if
10 I recall. Mr. Etherington is apparently looking at it right
11 now.

12 DR. LAWROSKI: Oh, just percentages?

13 MR. VOLLMER: Let me say that the philosophy that's
14 been approached on this recognizing that many of the generic
15 issues -- we don't have the specific generic resolution in
16 criteria to many of the DOR backlog issues that you will --
17 and those issues that are being dealt across the board on
18 operating reactors do not have specific criteria. But, as
19 a policy, if you will, or an objective, we have -- it's been
20 indicated by -- in our management that we would, prior to
21 restart, try to settle all of those that we had established
22 criteria on. And, therefore, to clean up all the backlog and
23 everything except the generic issues that we don't really
24 have a resolution on.

25 So, it's our intent to clean that up and it is an

1 ongoing thing and there was a fair amount of backlog to be
2 addressed.

3 MR. ETHERINGTON: This document is going to be
4 discussed then this morning, is it?

5 MR. VOLLMER: Tomorrow.

6 MR. ETHERINGTON: Tomorrow, all right, yes.

7 MR. VOLLMER: Okay, well, I'd like to turn the
8 meeting over to Harley Silver then who will bring you a
9 status report on the Staff review.
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

1 MR. SILVER: As Mr. Etherington noted, the safety
2 evaluation that we have prepared covered the restart
3 report through Amendment A. It was also noted there
4 are many items that are, indeed, opened. I attempted
5 in the evaluation to list and categorize these in Section
6 B of the report, but since the time the safety evaluation
7 was prepared, Amendment 9 and 10 have been received.

8 We have also received a schedule, a verbal
9 schedule, from the licensee as to when most of the missing
10 information will be submitted.

11 In addition, I have picked up some errors in
12 that summary table of open items. What I have done, was
13 to mark up by hand a copy of this summary table to kind
14 of give a pictorial feeling for the status of these things,
15 and the expectant status.

16 I have copies of this here and I have some supplies
17 which may or may not be useful but we will try.

18 I would like to point out one statement that
19 applies to almost all of the items. We have not attempted
20 yet to verify the installation of any of the hardware, as
21 of yet. We are still essentially operating on a design
22 basis. We will, of course, do this and report it in
23 the supplement.

24 The legend that I used on this markup is quite
25

1 simple, the heavier the picture, the closer to resolution
2 the items are. Where I have shown a solid block around the
3 item, that is resolved as of today, a dash line is the
4 item expected to be resolved by the time of the Full Com-
5 mittee meeting next week. The dotted enclosure indicates
6 that we would expect it to be resolved by the first supple-
7 ment to the evaluation, which is scheduled for Mid March.

8 Where a date appears it indicates that the
9 information is scheduled to be received by that date,
10 if no date we either have the material in hand, in which
11 case, it would immediately be some indication of this sort,
12 or we do not have a schedule for it, which is the case in
13 some items.

14 I think these things are really self explanatory
15 and I -- unless the Committee wishes, I would not propose
16 to go through with each item, but would simply let the
17 picture speak for itself.

18 There are some changes even in the couple of days
19 since this was prepared, and I can point those out rather
20 than change them. For example, as of yesterday we did
21 review some procedures on which we have had previous dis-
22 cussions with the licensee, and indicated what changes we
23 felt needed to be made. In some cases, these have already
24 been made and we have examined the procedure and are pre-
25 pared to state that the procedures are acceptable.

1 We also would like to point out, in that con-
2 nection, however, that we have not witnessed any actual
3 performance of the operations covered by the procedures
4 and, of course, in some cases, existing procedures already
5 accepted, may be affected by changes in other procedures
6 which have not yet been accomplished. So, an acceptance
7 or a write off at this point, may not necessarily be
8 forever.

9 So, that this item and this item, as of this
10 time, are accepted with the caveat I just mentioned
11 in addition to what is on here. In other words, it should
12 be a solid box, if you will.

13 Of course, where there are no other items across,
14 for example, on this item the acceptance of these proced-
15 ures essentially means that the licensee is in compliance
16 with that particular item.

17 So, in some cases, where that has been known,
18 at the time I prepared the chart, that does appear in
19 writing. In other words, where the changes made yester-
20 day does not yet. So, there should be a box, and this
21 should say compliance, and, I guess, as well on this
22 item.

23 DR. LAWROSKI: Where it says the design, am I
24 to take it that means the "as built" design drawing --
25 detail design?

1 MR. SILVER: No, again, in many cases, the in-
2 stallation is not complete and there may well be changes
3 in the detail design, when the modification is completed.

4 We have not -- that has not been done, I would
5 say, in most cases. We have essentially a proposed design
6 from which the installation will be made and presumably any
7 necessary "as built" changes will be made in the future.

8 DR. LAWROSKI: Has there been much emphasis on
9 trying to get as much of so called "as built" drawings
10 rather than is often the case where such drawings are
11 really not available?

12 MR. SILVER: During the lessons learned after the
13 subject of available "as built" drawings, of course, was
14 considered and one of the items does cover certain classes
15 of "as built" drawings, and I must admit that I don't know
16 at this moment the status of the whole collection of "as
17 built" drawings that is available.

18 DR. LAWROSKI: Well, I was thinking about the
19 problem that ensues and you have difficulties when you
20 have not -- you do not have "as built" drawings, then,
21 somebody has to guess, really, is it like the drawing
22 says it is, or isn't it?

23 MR. SILVER: I agree. That is a problem.

24 MR. ETHERINGTON: I think I understood that
25 Met Ed had a contract with an architect engineer to keep

1 their drawings up to date. Perhaps Mr. Arnold will address
2 this later.

3 MR. ARNOLD: Yes, sir. We will discuss drawing
4 staffs.

5 MR. SILVER: Is the Committee clear on what the
6 categorization of the open items is? The SER does identify
7 that.

8 Is there some problem?

9 MR. ETHERINGTON: I would comment that the num-
10 ber of items which are not completed now, will be
11 completed at the Committee meetings. I guess you are
12 going to have a busy weekend.

13 MR. SILVER: I have had one or two busy weekends
14 in the last few weeks.

15 On the second page, the one change is this pro-
16 cedure item here which has now been completed. I wish
17 you would bring this item into compliance.

18 In addition, there are the changes indicated
19 where there was essentially an item which should have been
20 on the list, but it wasn't.

21 I added an emergency preparedness. As far as
22 the order is concerned, this is not an open item, I don't
23 believe, but we did indicate in the SER that we would re-
24 quire that the emergency plans be brought into conformance
25 with the proposed rule and we do not specify any time frame

1 but that is still our intent. There has been no active
2 effort on our part to get this started yet. I am not sure
3 whether the licensee has done anything in this frame or
4 not. Plus, the rule has only been on the street in
5 proposed form for a short time.

6 There are no additional changes on this page.
7 Again, there was an omission of an item that should have
8 been on the table.

9 We did receive the QA program several days ago,
10 I believe it was on the 25th of January and that has been
11 in review between our own QA group and licensees. At
12 present, our clients are to visit with the licensee sev-
13 eral days before the ACRS meeting, I believe it is Tues-
14 day and Wednesday of next week, and we do indeed expect
15 that we will be in agreement on the QA program by the
16 actual ACRS meeting. That will not yet be documented but we
17 can presumably or hopefully be prepared to state that is
18 the case.

19 On this page, there are also no additional
20 changes. This procedure review, I might mention, is, of
21 course, an ongoing thing. There are many, many procedures
22 and we are reviewing these continuously and are in close
23 contact with the licensee's people who are doing this, so
24 that, in fact, we do expect the changes or the completion
25 of these items by next week.

1 There are some items, if you notice, where there
2 are no dates or indication of completion and, again, gener-
3 ally, that reflects the lack of information from the li-
4 censee. There are some cases where the licensee has sub-
5 mitted information, which I presume he believed would
6 satisfy our requirements of what recently, which in fact
7 did not, and, for example, we have sample lined this as
8 one of these, and we have not yet, in fact, communicated
9 back with the licensee and indicate that is the case. We
10 will, of course, do that. So, I don't have a schedule,
11 for example, for completion of that particular item.

12 The next page contains some items which perhaps
13 were miscategorized and these two things ought to be covered
14 by the procedures and should have appeared in the group
15 D column. In fact, both of those have been reviewed and
16 are acceptable as of this time. That is this item and
17 this item. They should appear over here with a solid
18 box around them so that both of these items, shift super-
19 visor responsibilities and shift turnover, are, in fact,
20 in compliance.

21 Now, there were some additional items which
22 perhaps probably should have been included in the table
23 which were not. These are additional items in Order Item
24 1A, which are in the text of the safety evaluation, they
25 are not, strictly speaking, part of the order, but they

1 are requirements that really have been imposed on other
2 plants, in this connection. They should, in fact, be
3 represented in some way. The status of them is as shown
4 in the table.

5 These conditions in the letter to SMUD, a branch
6 of SECO, I believe have been incorporated into the questions
7 submitted to the licensee but the provisions remain the same.

8 That essentially completes what I think is a
9 reasonable picture of the status of the open items,
10 obviously, this is an abbreviation. I have not listed
11 numbers and percentages of completion and so forth, but I
12 believe this presents a picture of the present status and
13 of the status that we may expect in the near future.

14 Again, we are planning to have a supplement is-
15 sued in Mid March.

16 MR. ETHERINGTON: Thank you, Mr. Silver.

17 Are there any questions that would not be better
18 deferred to later?

19 I would like to ask, in proposing a hearing before
20 the Full Committee next week, were you expecting that there
21 would be a follow up meeting later, or hoping that there
22 would not be one, or maybe both?

23 MR. SILVER: Obviously, when the meetings were
24 scheduled, we had hoped the safety evaluation would be more
25 complete than it was.

1 I think I would have to throw this question,
2 I think, on the mercy of the Committee.

3 It is certainly not as complete as a regular
4 case SER would be at the time of its presentation to the
5 Committee.

6 We took into account the Commission's directive
7 to attempt to expedite the proceedings and, again, I think
8 their decision is yours rather than ours.

9 MR. ETHERINGTON: Well, of course, an alternative
10 would be to defer the Full Committee meeting until later.

11 MR. SILVER: I believe there is a great deal
12 which can be discussed. I would like to point out that
13 even if the item is open, there are certainly a single
14 line, let us say in the chart is in fact open, this may be
15 because of one single sub-item within that general subject.
16 There may well be dozens of other requirements in that item
17 that have, in fact, been met.

18 We have not written off on a single item, until
19 each facet or every facet of it is covered -- is written
20 off, so, any one item might be 90, or 95, or 99% complete,
21 or 50%, in some cases, I guess. But, because it is not
22 fully completed, we have not indicated compliance. So,
23 in every one of these there is a great deal, I believe,
24 which can be discussed and examined by the Committee.

25 MR. ETHERINGTON: Okay, thank you.

1 I think it is Mr. Arnold next.

2 Are we suppose to have a break, are we? Let's
3 move on.

4 Mr. Arnold.

5 MR. ARNOLD: Thank you, Mr. Chairman.

6 My name is Robert C. Arnold. I am a Senior
7 Vice President of Metropolitan Edison Company and a
8 Vice President of GPU Service Corporation.

9 I head up a organizational entity within the
10 GPU system that is titled the "Three Mile Island Gener-
11 ation Group" and which is composed of technical and
12 management personnel, who are on either the Metropolitan
13 Edison Company payroll or are employees of GPU Service
14 Corporation.

15 The details of the organizational structure we
16 will address in the first agenda item scheduled for to-
17 morrow morning. In the course of this presentation today,
18 there will be status and questions answered by people
19 from both companies, but we are an integrated organization
20 within the GPU System.

21 I would like to first of all introduce some
22 of the people that we have with us. I will defer to the
23 time of their presentation, the introduction of some of
24 the other people who will be involved in later agenda
25 items.

1 Immediately to my right is Mr. Philip Clark, and
2 Mr. Clark is a Vice President of GPU Service Corporation
3 and will have a leadership role in the "Three Mile Island
4 Generation Group Organization" and its successor's steps
5 which I will be describing tomorrow.

6 To his right, is Mr. John Herbein, Vice President
7 of Metropolitan Edison Company, and is the Director of
8 "Three Mile Island Unit Number 1".

9 To his right, is Mr. David Slear. Mr. Slear
10 is the Engineering Project Manager for the "Three Mile
11 Island Generation Group" and is the manager of the technical
12 efforts involved with the restart of Unit 1, in particular,
13 the plant modifications that are being undertaken.

14 Across from him, is Mr. Charlie Hartman, who is
15 the lead Electrical Engineer at "Three Mile Island Unit 1".

16 Mr. Cortney Smythe, Licensing Engineer from the
17 licensing section of GPU Service Corporation.

18 To Mr. Smythe's left, is Mr. John Thorpe, who
19 is our Director of Environmental Health and Safety and
20 includes within that group the licensing section which
21 is headed up by Mr. Edward Wallace to Mr. Thorpe's left.
22 Excuse me, to Mr. Thorpe's right. I couldn't handle the
23 mirror image there.

24 The way that we would like to approach our pre-
25 sentation today, is to have Mr. Slear spend a few minutes

1 discussing the items which -- for which modifications are
2 being made to the plant and are not specific agenda items later
3 on. So, that we attempt in the course of the Subcommittee's
4 meeting to provide a complete coverage of all the modifications
5 but we will do that in a relatively abbreviated form for those
6 which detailed questions have not been indicated by the Sub-
7 committee.

8 I would also like to comment at this time on the
9 question that was asked of Mr. Silver, if I may, with regard
10 to the feasibility of a Full Committee meeting next week.

11 It is my understanding that many of these items
12 that are open at this time, are open because of the ap-
13 proach that was described by Mr. Vollmer at the beginning
14 of his remarks. That is, that in the course of the Staff's
15 review for the startup of Unit 1, they have been going
16 into much greater detail, they have been looking at com-
17 pleted work and there has been an effort that goes beyond
18 what is their normal licensing approach, which is to make
19 the evaluations based upon the commitments on the part
20 of the applicant as to the criteria which will be fulfilled
21 and that the licensing process proceeds, which obviously
22 includes the verification that those criteria are in fact
23 satisfied. The judgment as to the acceptability of the
24 effort is preliminarily made, and I believe, reviewed with
25 the ACRS Full Committee, based upon that level of effort

1 by the Staff.

2 So, I think in terms of the understanding of
3 what the licensee, in this case, is going to do to satisfy
4 those items, that there are very few open issues. I
5 think that most of the open issues relate to the degree
6 of the implementation of that, the degree of completeness
7 of the description on paper, the details of the design,
8 the specific procedure having been prepared, and those
9 things. I would suggest that it would be very productive
10 to have a Full Committee meeting next week, that the
11 majority of the issues could be reviewed, we could identify
12 to the Committee how we intend to address all the items
13 that have been raised in the course of restart, and we
14 can give the status on our implementation of our actions
15 on those items.

16 I would request that the Committee consider that
17 in deciding whether or not to have next week's meeting.

18 With that, I could ask Mr. Slear to proceed
19 with his presentation.
20
21
22
23
24
25

1 MR. SLEAR: As Bob indicated, I am David Slear
2 and I am the Project Engineering Manager with responsibi-
3 lity for implementing modifications that are being com-
4 pleted at Three Mile Island Unit 1.

5 The handout that you have covers three separate
6 presentations. The first two pages of that handout are
7 what I intended to talk about during this parti-
8 cular presentation of the modifications.

9 I would suggest as I proceed through each topic,
10 if you will, each modification, that as you have questions,
11 you raise them at that time.

12 I have additional information with me which will
13 allow me, perhaps, to address some questions that you
14 may have and for others, I may not know the answer, but
15 we can certainly get the answer.

16 I basically made the presentation and put it
17 in the order of the presentation that is in the order itself,
18 if you will.

19 The first requirement has to do with auxiliary
20 repeat water, as I indicated, we have a separate half hour
21 presentation on the modifications of the repeat water
22 system. I would suggest we defer the discussion and the
23 questions in that area until I -- until this afternoon
24 sometime.

25 The second topic is the anticipatory reactor

1 trip.

2 We have installed an anticipatory reactor trip
3 or are proceeding to install an anticipatory reactor
4 trip. The signals that would be sensed to trip the
5 reactor is loss of both MFP or turbine. We sense that
6 through the control oil pressure to the inlet valves of
7 that particular equipment.

8 The trip itself is, in fact, safety grade.
9 There is an automatic bypass at preselected power levels.
10 My recollection is, it is 20% for the turbine trip and
11 10% for MFP trip, but I am not absolutely sure, I might
12 have that in reverse.

13 The intent, obviously, is that poor feedwater
14 transients that will, in fact, result in loss of heat
15 steam instead of allowing the reactor to trip on high
16 pressure, we would anticipate that transient and trip the
17 reactor on the signals that indicate throughout the second-
18 ary system, that, in fact, we are proceeding into a loss
19 of heat steam effect.

20 That was the extent of what I wanted to say about
21 it. Are there any specific questions that I might be able
22 to address?

23 If not, let's go to the second item. It is
24 entitled small break response. We had in house some
25 modification that was proceeding to reduce the operator

1 action, if you will, that was required in order to respond
2 to small breaks.

3 Specifically, what we have done is we have
4 inside containment cross connected to high pressure in-
5 jection lines, such that A and C loop lines are cross
6 connected and the B and the D loop lines are cross con-
7 nected. Meaning that if one high pressure injection pump
8 does not, in fact, start, the remaining high pressure
9 injection pump will feed all four reactor coolant loops.

10 The need is to get the appropriate flow split
11 so that you are sure that you get adequate for coolant.
12 I believe you only get 70% of the high pressure injection
13 flow to the core but you are allowed 30% to go out of the
14 leak itself.

15 In addition, we have added cavitating venturis
16 inside containments in the high pressure injection lines.
17 These cavitating venturis are sized such that they limit
18 the flow out of the break to insure that you get the
19 appropriate flow split.

20 In addition, if one pump is operating in the
21 past, it may have been at runout without operator action
22 to problemsome valves and this cavitating venturis also
23 limit the flow when one makeup pump is running, such that
24 the pump is not a runout.

25 So, basically, in the past we had the operator

1 had to assess the situation, perhaps make some decisions
2 on where he thought the leak was, and perhaps, throttle
3 some flow back which might have tended to go against his
4 intuition, if you will, because obviously, he wanted to
5 provide flow to the reactor.

6 In this case, we think we made the system rela-
7 tively insensitive to operator action, and in fact, he
8 just has to stand back and let it work.

9 Are there any questions with regard to those
10 cross connects cavitating venturis? I have a picture
11 that would show the system itself, if that would be help-
12 ful.

13 MR. EBERSOLE: You do have a picture?

14 MR. SLEAR: Yes, I do have the picture.

15 MR. EBERSOLE: I wish you would throw it up
16 there.

17 MR. SLEAR: I would be glad to.

18 MR. EBERSOLE: Basically, I am just trying to
19 get at whether the cross connects implied a new point of
20 vulnerability and necessitated the cavitating venturis
21 or whether it was never around?

22 MR. SLEAR: I guess -- I am not sure. Let me
23 explain the picture, to begin with, and I don't know what
24 came first or if they both came together. Basically,
25 the three makeup pumps cross connect downstream to

1 lock post valves. Two separate paths going toward
2 the reactor coolant system, four separate reactor coolant
3 loops and therefore, once inside containment four separate
4 paths for injecting water. The addition is what I've indi-
5 cated in red.

6 So we have cross connected the A and the C
7 loop with a two and a half inch cross connect. The
8 B and the D loop with a two and half inch cross connect.

9 Basically meaning, that this pump doesn't start,
10 this pump provides flow with closings to these two loops
11 and by cross connector also getting together.

12 My recollection of the cavitating venturis is
13 minimum. Basically, it precludes the need for the operator
14 to assess the flow of the individual line to make decisions
15 on which of these valves, perhaps, need to be shut.

16 So the system before and with the cross connects
17 require an assessment such that if the break was here,
18 for example, I think we would have to isolate that line
19 within something like 20 minutes, to assure adequate
20 core cooling.

21 Now, with the cavitating venturis installed
22 right here, that limits the break -- some of the break
23 is downstream and we saw how the reactor coolant loop
24 such that the system as designed, without operator action,
25 to flaw the flow, will, in fact, provide sufficient cooling

1 to the core, i. e., 7030 close board I described, and
2 secondly, if only one pump starts, and is providing flow
3 to all four of these loops, the pump will not be running.

4 MR. ARNOLD: Dave, it might be worth clarifying
5 also, I believe there is check valves that are downstream
6 of where are shown the entry points into each of the loops.

7 MR. SLEAR: You may be right.

8 MR. ARNOLD: I think there are some downstream
9 to the right of the drawing, as it were.

10 MR. EBERSOLE: Could you comment on the break
11 between the cavitating venturis and the check valves of
12 the system performance?

13 MR. SLEAR: Are you talking about a break --

14 MR. ARNOLD: Say in the cross connector.

15 MR. EBERSOLE: In the region in between the
16 check valve and the cavitating venturis.

17 MR. SLEAR: I know I have heard discussions
18 about a break there, unfortunately, I don't have the
19 details of how the system performs with the break there.

20 MR. ARNOLD: We will pick that up later, please.

21 MR. SLEAR: A break there has been considered,
22 I guess the bottom line is that you get adequate flow to
23 the core and I believe we did the analysis of B & W
24 reviews or visa versa.

25 MR. EBERSOLE: Mainly, I am only getting to the

1 point, that an additional new cross connect complies a
2 new point of runout, as well as a new point of supply.
3 I want us to look at both sides.

4 MR. ARNOLD: I am sure the analysis has looked
5 at both sides and will address it later.

6 DR. CATTON: Before you go on, you can take that off.
7 How quickly will you trip the reactor cooling pumps forestal-
8 ling a small break and possible accident?

9 MR. SLEAR: I might have to defer to Jack Herbein
10 or someone from operation.

11 I know we certainly have in place operating proce-
12 dures where a certain set of conditions require their pumps
13 to be tripped but I don't know what --

14 MR. HERBEIN: An initiation of high pressure
15 injectors.

16 DR. CATTON: Have you fully assessed the impact
17 if it is an overcooling accident rather than a small
18 break?

19 MR. HERBEIN: I believe we have, and the action
20 is the same in either case. It prevents voiding in the
21 core and enables the maintenance of a 50° slow cooling
22 margin. Jack Herbein, Vice President Met Ed.

23 MR. ARNOLD: If we would like a more structured
24 discussion on it, why don't we give us a chance to perhaps
25 put it together for later.

1 MR. EBERSOLE: Before we leave this topic
2 of small break, will there be a discussion which pretty
3 much is against the model of TMI 2, the accident, in
4 aspect to your knowledge of inventory in the primary loop?
5 Whether it referred to vessel level or saturation meters
6 or whatever device you know you have to ascertain that
7 you have adequate inventory.

8 MR. SLEAR: We have a discussion on adequate
9 core coolings.

10 MR. EBERSOLE: Is it contained in that?

11 MR. SLEAR: Yes.

12 MR. EBERSOLE: Thank you.

13 MR. SLEAR: The next item is the diverse con-
14 tainment isolation modifications. The essence of the
15 modification is as follows.

16 There are selected valves which will be isolated
17 on either reactor trip or four pounds in containment.
18 There are selected valves that will be isolated on only
19 four pounds in containment. There is another group of
20 selected valves that would be isolated on thirty pounds.

21 The reactor trip isolation and the pressure
22 isolation are safety grade installations. In addition,
23 to those specific isolation signals that are safety grade,
24 we are installing control grade containment isolation
25 in selected process lines. By that I mean we have

1 radiation detectors, attached to lines that could contain
2 radioactive fluid leaving containment. In some cases,
3 those lines are automatically shut based on a high reading
4 on the radiation detectors. In other cases, those lines
5 are merely alarmed.

6 I guess that the fundamental criteria or
7 at least one of the fundamental criteria for this contain-
8 ment isolation, is that we want to maintain in service those
9 supplies to the reactor fluent pumps which would leave them
10 operational, and those supplies to containment cooling
11 such that we have a high probability to the pumps assuming
12 that we continue to have power to the pumps, etcetera,
13 will, in fact, be available. In addition, we are providing
14 cooling to the coolers inside containment.

15 I believe there was a question on the sump
16 drain line with regard to does it isolate on high level
17 in the sump?

18 The answer is no. The sump drain line is the
19 gravity drain, it drains to the auxiliary building sump,
20 that valve is normally shut. That valve is controlled in
21 the control room and opened to gravity drain to sump
22 and then reshut. The isolation signal for that valve
23 is it goes shut on any reactor trip and it goes shut
24 four PSIG.

25 In addition, we have a radiation detector on that

1 line which will shut that valve if there is high radiation
2 effect.

3 Are there any other questions on containment
4 isolation that I can answer?

5 DR. LIPINSKI: I have a question.

6 In connection with the Four PSI containment
7 pressure, if your perch valves are open, it will take
8 a terrific amount of flow to develop Four PSI.

9 Under what conditions and what fraction of the
10 time do you run with the perch valves open?

11 MR. SLEAR: It is my understanding that we are
12 limited to running with the perch valves 90 open hours a
13 year. I would point out that those perch valves are also
14 shut on reactor trips.

15 DR. LIPINSKI: I understand that, but when you
16 say they will shut with Four PSI, where the words currently
17 appear in the report, this takes a terrific amount of flow
18 when you are open to say that they are going to close in
19 Four PSI.

20 MR. SLEAR: Your talking valve reliability as
21 opposed to --

22 DR. LIPINSKI: No, I am talking about developing
23 a pressure in the containment when I have got two 48-inch
24 holes open, and I must flow through those holes to get
25 a differential pressure.

1 MR. SLEAR: You heard me say that there is
2 diversity in the isolation signal for those valves and
3 that it closes on both reactor trip and Four PSI, and
4 in addition, we have a high radiation deductors.

5 DR. LIPINSKI: But, if I don't have a reactor
6 trip, my next indication is Four PSI signal, and with
7 the valves open the Four PSI signal will not close those
8 valves.

9 MR. SLEAR: Because you won't reach four pounds,
10 correct?

11 DR. LIPINSKI: That is correct. The velocities
12 of air steamed through those 48-inch openings are going to
13 have to be terrific to get all the Four PSI within
14 containment.'

15 So that where you see these words, saying you
16 are going to close the valves on Four PSI, I question
17 how much flow is involved, in order to develop the Four
18 PSI.

19 MR. SLEAR: I guess I don't -- does anyone know
20 if we have done analysis with the valves open in contain-
21 ment for pressure? I don't know the answer.

22 He is questioning the fact that we have a diverse
23 isolation, one of those signals was four pounds and if the
24 valves are open and they needed to go shut, would you
25 develop four pounds in the building?

1 MR. ARNOLD: Perhaps a pertinent data point,
2 at least, on that issue, is that with the PORV failure,
3 we didn't begin to get close to four pounds but we did
4 get low pressure reactor trip point reached quickly.

5 DR. LIPINSKI: That is not the point. The issue
6 is to state that the valves will close with Four PSI if
7 they are open. I am saying that is a condition that does
8 not allow you to develop Four PSI to close the valves.

9 The fact that you have other redundant signals
10 is fine.

11 MR. ARNOLD: Are you suggesting that we remove
12 that signal from the closure valve logic?

13 DR. LIPINSKI: No, but you qualify it, okay?
14 Unless you have got an analysis to state under what
15 conditions you are going to develop Four PSI as to what
16 the flow rates are through two 48-inch holes that will
17 develop Four PSI and then allow those valves to close.

18 But, to arbitrarily say, those valves will close
19 on Four PSI when they are open is not a comparable state-
20 ment.

21 MR. EBERSOLE: Here is another part of that
22 question, even if you are able to develop the Four PSI,
23 some PSI differential, probably those valves won't close
24 anyway no matter how many signals you put into it. I
25 wonder if you could tell us at what pressure they cease to

1 close? Is it because they overloaded into the dynamic
2 context?

3 MR. ARNOLD: I am not sure that we have the
4 analysis on that. We did do the analysis on Unit 2, but
5 those valves are a different size, so we would like to
6 defer on that for now.

7 MR. EBERSOLE: Do you happen to know what basis
8 four pounds is selected?

9 MR. SLEAR: I think perhaps we should probably
10 come back to this question. It is certainly a valid
11 question and needs to be answered.

12 MR. HARRIS: I would like to indicate that this
13 is one of the few generic issues that are being covered
14 and our requirements for all operating reactors are first
15 involved in the demonstrated capability of closing those
16 valves into whatever condition they may be opened under
17 of those mechanical capabilities in addition to the require-
18 ment that we maintain a maximum of capability for 90 hours
19 a year.

20 I am not sure we will be able to address tomor-
21 row, the specific information that they have provided us
22 in this regard, I just want to lay out what our require-
23 ments for the operating reactor are.

24 MR. ETHERINGTON: Did the Four PSI originate
25 with NRC or with Met Ed?

1 MR. VOLLMER: No, what I said was, we required
2 that the valves have demonstrated capability, mechanical
3 capability in closing under whatever the actuation signals
4 are.

5 They arranged scenarios under which it would have
6 to close and we would have to see if they could have mechani-
7 cal capability in closing under those conditions. If they
8 don't, the valves that have to be closed during operation or
9 block 2A position, whereby they still would be able to be
10 mechanically still.

11 I think you are probably aware that some of our
12 operating plants do have these valves blocked, partially
13 closed so that they would have capability of closing
14 in the actuation signal three's. These criteria will
15 be required in detail to be closed.

16 MR. SLEAR: I guess that I would like to
17 point out that this Four PSI and these valves did not
18 change with the way it was in the past, and perhaps
19 why we are having a little with -- to some extent, asking
20 for past history. Why was four pounds chosen six years ago?

21 I am not sure we assess four pounds other than
22 it already has four pounds -- we were looking for diversity
23 and headed toward reactor trip as a selection of the
24 diverse signal and we are going to have to recreate past
25 history to some extent to answer your question.

1 MR. ARNOLD: Well, if I could summarize what
2 the recollection is of the people that are here, the
3 history on that is that it was a level that was selected
4 somewhat on a judgment basis in terms of the reliability
5 of instrumentation, as far as how low you could set that
6 signal without getting spurious isolations, and that
7 there was discussions between the Staff and the Babcock
8 and Wilcox people as to the appropriate level to select
9 for isolation, and that that is a set point that is common
10 with the B and W design.

11 MR. EBERSOLE: I think that it is probably fair
12 to say that signal was probably set by somebody who didn't
13 know these 48-inch valves were in there open.

14 MR. ARNOLD: I can't address that, sir.

15 MR. SLEAR: Are there any other specific
16 questions?

17 DR. LAWROSKI: Yes. You mentioned that there
18 were certain selected process lines which are provided
19 with sensors to isolate containment on high radiation.

20 MR. SLEAR: Yes, sir.

21 DR. LAWROSKI: Could you identify it for us?

22 MR. SLEAR: Well, with Charlie Hartman's help,
23 I probably can.

24 What I have is a slide that shows which valves
25 are containment isolation valves, and also identifies which

ones have a high radiation signal. Unfortunately,
I may not know enough of the nomenclature of the plant to
understand for sure what these valves -- what system these
valves refer to.

What is CAB?

MR. HARTMAN: Steam generator sample valves.

MR. SLEAR: Steam generator sample valves or
reactor fluent system sample valve?

MR. HARTMAN: Steam generator sample valve.

MR. SLEAR: These are CAB valves once again.
Steam generator sampling valves.

I think these are -- is that the drain from
the south and the reactor fluent drain tank perhaps, WDLZ,
303, and 534?

MR. HARTMAN: Some of the valves.

MR. SLEAR: What about WDLZ-303?

MR. ARNOLD: Let me suggest, that maybe we
will give you a copy of this slide with some noun descrip-
tion of the valves.

MR. SLEAR: From an overview point of view you
will see on this slide, the alarming dictation means that
it doesn't automatically shut, rather than get an alarm
in the control room, and on the second slide the same
thing once again.

These valves are awful extreme, but in any case,

1 on the second slide it indicates which one you are alarming
2 on.

3 We can get copies of these made, get them so
4 that you understand what systems were affected, if
5 that is acceptable?

6 DR. LAWROSKI: Please, that would be fine.

7 MR. EBERSOLE: If I may refer to that list,
8 in reference to our discussion just now on the containment
9 vent valves, are any of those valves susceptible to the
10 pressure increase and any effect on their closure? By and
11 large, I realize a modest increase in pressure. Most of
12 these valves won't affect their closure at all.

13 But, there may be some which are normally low
14 pressure systems by drain valves or what not that may see
15 some transient flows which are not normally expected until
16 you develop containment pressure. Are any of those
17 susceptible to the same phenomena that the containment
18 vent valves are susceptible to?

19 Is my question clear?

20 MR. ARNOLD: I think we understand your question,
21 and let us answer that along with the anotated copy of the
22 slide.

23 MR. SLEAR: The next topic I think is really
24 cut and dried. We have been directed and we have changed
25 the PORV setpoint and raised to 2450 PSIG automatically.

1 We have reduced the reactor at high pressure trip set-
2 point to 2300 PSIG.

3 The last item automatic reactor coolant pump
4 trip, we are proceeding with the design which would auto-
5 matically trip the reactor coolant pumps on a coincidence
6 logic.

7 The low reactor coolant system pressure and
8 low reactor coolant pump power coincident of logic.

9 We are working with the B and W Owner's Group
10 and B and W, to determine what analyses that has not yet
11 been done, perhaps needs to proceed in order to select
12 a setpoints, I mentioned HPI and perhaps that is the
13 appropriate pressure. I think that probably is. I guess
14 the real question revolves around reactor fluent pump power.
15 What is the appropriate setpoint on which the trip reactor
16 fluent pumps and I guess I don't really have much more
17 to say other than this is intended to replace the current
18 procedure which would have the operators manually tripping
19 these reactor fluent pipes for which HBI initiates.

20 The fact that it is coincident logic, low reactor
21 coolant pump power is an indication that the reactor
22 coolant pumps are no longer pumping fluid but are pumping
23 some fluid and void fraction.

24 I think on 1/20 of the 1/5 model scale test,
25 has proved that there is a trend of -- as you pump voids

1 lower reactor fuel pump power, the question is, what is
2 the setpoint?

3 This would mean not only had you had high pres-
4 sure injection but for some reason the accident was pro-
5 ceeding in an adverse manner and you were starting a
6 void in the system which was not normally expected to
7 happen.

8 Do you have any questions?

9 MR. EBERSOLE: That is a sort of an anti-cavita-
10 tion trip, isn't it?

11 I mean you are cavitating, that is what changes
12 the power.

13 Does it leave any bias on pressure or tempera-
14 ture, or is that all you need?

15 MR. SLEAR: I have not heard discussions on the
16 need for bias on pressure or temperature.

17 Is there any one here from B & W who knows
18 more than I do about what is proceeding?

19 MR. TAYLOR: Jim Taylor from B & W. I doubt
20 if I know more than Mr. Slear about this, but let me
21 make a comment, Mr. Ebersole.

22 I don't think it really would be accurate to say
23 this is an anti-cavitation trip, really. Because, as soon
24 as you have saturated conditions or a little before, you are
25 going to be cavitating on the propeller but this is a

1 very long term effect.

2 I think the point is to try and get the trip
3 as soon as you have something less dense than the normal
4 primary coolant system. So, it is really not an anti-
5 cavitation trip, per se.

6 There is something in the sense that you
7 have got less than the normal density included.

8 MR. ETHERINGTON. I think that it is time
9 that we might take a break when you find you have
10 come to a convenient stopping point.

11 MR. SLEAR: This is as convenient as any.
12 The first line is finished.

13 MR. ETHERINGTON: Then, we will follow the
14 agenda with a 15 minute break.

15 (Whereupon a 15 minute recess was taken.)
16
17
18
19
20
21
22
23
24
25

1 MR. SLEAR: Before I proceed to the next topic,
2 it has been pointed out to me that this drawing is not in
3 fact correct and we're going to have to correct it before
4 we give it to you, but, there are check valves there
5 that we have discussed.

6 It is left out of this particular drawing, and
7 we will correct this and make it right and then perhaps
8 that would satisfy your concern.

9 DR. LAWROSKI: But as built. those check valves are
10 there?

11 MR. SLEAR: Yes, that is something we added in
12 addition to that.

13 The next topic is pressurizer heaters emergency
14 power supply. We are providing the capability to
15 manually transfer two groups of pressurizer heaters to
16 the diesel generator. That means a total of 252 kilo-
17 watts, the pressurizer heaters can be placed on the
18 diesels. We have calculated and we need about 107
19 kilowatts to maintain pressure. The fundamental
20 driving force for this particular modification
21 is to consider loss of offsite power and the benefit
22 of being able to maintain pressure for natural
23 circulation with the pressurizer heaters has an
24 optimum capability to have. The transfer, as I indicated -
25 is manual and I don't think that I want to dwell too long on

1 this drawing but basically there are -- the normal power
2 supply is from control center 1B. Using these t's, you're
3 able to remove this element which has a Tab A on it. That
4 element only fits over here and allows you to remove the
5 P3 and therefore, get you the ability manually to close this
6 breaker and provide power from the Red diesel to this group
7 of pressurized heaters.

8 This breaker is tripped open on either undervoltage
9 on this box, or any ES actuation would physically trip open
10 this breaker and you would have to walk down and reclose
11 the breaker once, in fact, you've convinced yourself that
12 there was adequate room on this bus to handle the load.

13 DR. LIPINSKI: I have a question on the element
14 that you're talking about that has to be manually transfered.

15 MR. SLEAR: Yes, sir.

16 DR. LIPINSKI: How big is this and what happens if
17 it gets dropped in the process of being moved from one lo-
18 cation to the next?

19 MR. SLEAR: I don't know how big it is. Charlie,
20 do you have any idea what these elements are like?

21 MR. HARTMAN: No, I don't.

22 MR. SLEAR: I guess I don't know.

23 MR. ETHERINGTON: I would suggest that whenever
24 there's a question that can't be answered today that you
25 have an answer ready for the -- if you can have it for

tomorrow, that's good; otherwise, for the Full Committee.

MR. SLEAR: Yes, sir, we'll do that.

MR. EBERSOLE: Before you leave that idea -- present in that idea of connecting the heaters to the diesel is the thesis that you're going to use these for small break accidents, were you?

Unfortunately, the pressurizer heaters, in general, have never been qualified for the hostile environment that it would be in the containment. And, I expect a creation of shorts and other electrical difficulties.

Are we going to let that be a long --

MR. SLEAR: Let me describe that we're proceeding with; the containment boundary is essentially here on this drawing. As you can see, there are small circuit breakers inside the containment much like your house circuit breakers. These are being removed so that they are outside of any adverse environments.

That's why we are filing Phase 2 of this evolution.

MR. EBERSOLE: And the timing for that?

MR. SLEAR: The timing is -- I guess I don't have the update on that yet. It's not necessarily a commitment to do prior to restart. We are looking for equipment and trying to get the appropriate cabling and what have you. I don't know the in date of that particular modification, but we're treating basically Phase 1 which is a prior restart

1 effort as the emergency power supply. Phase 2 is removing
2 the breakers so that they're out of the adverse environment
3 and Phase 3 is to replace the cables inside containment to
4 these two groups of pressurizer heaters with cables that
5 are today's quality as opposed to late 1960 quality. Not to
6 say that what's in there is a quality that won't necessarily
7 survive because we think that we can provide better cables
8 although in starting to try to step up and spec out those
9 cables and purchase them, I guess we are having trouble
10 identifying cables that we --

11 MR. EBERSOLE: Well, isn't it the terminal point
12 at which you attach the cables to the heaters that you have
13 a vulnerable place?

14 MR. SLEAR: I guess that does not come up as a
15 vulnerable place and perhaps it has been overlooked.

16 MR. EBERSOLE: Well in the interim, then, are we
17 going to argue that we can get along without pressurizers
18 if we get in trouble?

19 MR. SLEAR: As I indicated, this is -- having the
20 heaters available to maintain natural circulation is optimum
21 because you certainly have the capability to take the
22 thrust of the system solid, I presume, as a means of pressure
23 control.

24 MR. EBERSOLE: Thank you.

25 DR. CATTON: I would just like to comment on what

1 we observed as the existing state of the cables.

2 Apparently they're used as a ladder and --

3 DR. LIPINSKI: Walked on.

4 DR. CATTON: Walked on and the surface seems all
5 chewed up and the first layers of this plastic type material
6 is worn through already.

7 So, I think your comment about -- as far as you
8 know that the quality is okay now and you should take a look
9 at that, it was our feeling that they were not. And that
10 you would have to do something to improve them to survive the
11 hostile environment.

12 MR. SLEAR: My comment was based on, basically,
13 an engineer assessing what was what and its qualifications
14 not on a physical inspection of the cables.

15 MR. ARNOLD: We will review that issue and we
16 appreciate you pointing it out to us.

17 DR. CATTON: And another aspect is the box that's
18 down on the side of the shield wall where the, I guess, the
19 power's brought in from outside and then hooked to the
20 cables that go up to the heaters. They're fairly low down
21 and they don't look very waterproof to me.

22 MR. SLEAR: These -- once these breakers are
23 moved, that will be a butt splice -- instead of a terminal --
24 if it is now a terminal block, it will not be a terminal
25 block in the future, I don't believe. It will be a butt splice

1 with each shrink tubing. So, I'm not sure that the box needs
2 to be watertight when you've made that kind of joint on
3 an electrical connection.

4 DR. CATTON: I'm not an electrical engineer, so I
5 don't know.

6 MR. EBERSOLE: Concerning the electrical penetration
7 by the way, are they in two classes, one of which is 1E, an
8 aspect in maintaining continuity of service inside and the
9 other not 1E, or are they all 1E in this aspect? Are they
10 all alike?

11 MR. SLEAR: Refer to the experts; I don't know.

12 MR. EBERSOLE: I'm really only pointing to the
13 penetration, now.

14 MR. HARTMAN: From the standpoint of containment
15 pressure, they are all assigned alike. From the standpoint
16 of separation, there are Class 1E and there are Non 1E.
17 1E has separation criteria that Non 1E does not.

18 MR. EBERSOLE: Right, well, does this mean that
19 the terminals on the containment side are susceptible to
20 short circuits in the presence of moisture on the Non 1E's
21 and they are not on the 1E's.

22 MR. HARTMAN: On the Class 1E equipment, we have
23 removed the wires from the terminal blocks and installed
24 heat treated tubing. On the Non 1E's, we have not done that.

25 MR. EBERSOLE: Well, then, this would be another

1 point where one might have to improve the design to maintain
2 it against the hostile environment at penetration, as well
3 as the cables.

4 MR. HARTMAN: It's my understanding that when the
5 breakers are removed to outside the building, the cable runs
6 will come directly from the connections on the pressurizers
7 to the penetrations and the connections there would, I believe,
8 be heat treated to that.

9 MR. EBERSOLE: Yes, thank you.

10 DR. LIPINSKI: That's not the total issue because
11 it's also a physical separation and when the cables appear
12 at the pressurizer, they're in an intimate configuration.
13 The physical location where the pressurizer heaters enter
14 the pressurizer are such that you have an intimate mix
15 of the cabling itself. Class 1E requires that these be
16 physically separated for the fire protection criteria. So,
17 in this particular case, you have a special problem.

18 MR. HARTMAN: That's correct. I think that on
19 connections on these heater bundles we do not get physical
20 separation; I don't know if the design includes any pro-
21 visions for another type of ar.

22 DR. DILLON: Do you have any idea what your
23 design exposure on the insulation on that cable ought to be?
24 What are you shooting to?

25 MR. HARTMAN: I've not been involved in specifica-

1 tions for the cable; I'm not familiar with that.

2 MR. SLEAR: I don't know the number, but I know
3 we have a criteria for the cable or a specification, if you
4 want to call it that. It would be easy to get that. I just
5 don't have the number on the tip of my tongue.

6 The next item is the position indication for
7 the power operator relief valve and the two safety valves on
8 top of the pressurizer.

9 We are proceeding with diverse indication of the
10 position of those valves that I can describe as follows:
11 I guess our first line of defense, so to speak, is the
12 elbow tap differential pressure cells that we are putting on
13 downstream of each individual valve. The question has been
14 asked, physically where: I don't know the answer to that.
15 Those lines from those valves called the tail pipes, pro-
16 ceed for many feet as separate independent lines until they
17 finally combine before they go into the drain tank.

18 So, my guess would be that 20 to 40 feet away --
19 we're going to have to ask someone to get us a specific
20 answer to the physical location of the DP cells.

21 But, I think the key I wanted to point out was
22 they are three independent lines for a fair distance until
23 they combine into one large line.

24 There was a question concerning the indication
25 being provided to the operators where it was going to be.

1 It's basically called flow indications. It's going to be
2 hard to see this and I think that if I just walk over here --
3 it's on the panel directly adjacent to the existing indication
4 that the Celluloid in fact, does or doesn't have power.
5 This is what we're now calling a demand indication as opposed
6 to an actual indication. In fact, we've added a nameplate
7 here to remind the operator that that position indication for
8 the PORV is demand indication action. It merely indicates that
9 the Celluloid has been energized and that the valve is
10 mechanically sounded to the shut.

11 Right above that, will be flow meters indicating
12 inches of water from the different pressure cells and the elbow
13 taps downstream of these valves. The name plates indicating
14 RCRV 1A discharge flow, et cetera. In addition, as pre-
15 selected set points, there will be an enunciation that there
16 is flow downstream of the PORV's to provide the operator
17 not only a meter indicating that he has flow, but an alarm
18 enunciating that he has flow down to the PORV's.

19 The criterias that we can detect at least down to
20 10 percent flow through those valves and we are currently
21 finishing the calculations to confirm that, you know, we can
22 in fact detect a flow that low. I think it can even detect
23 flows of even less than 10 percent. The fundamental criteria
24 was DP cells must be able to detect down to 10 percent flow.
25 To some extent, it's a go-no go; we're not intending that this

1 provides the operator the ability to deduce that the valve is
2 52 percent open. We merely want to alert the operator to the
3 fact that the valve is not closed when it needs to be closed
4 because of the presense of flow.

5 MR. EBERSOLE: In view of the presence of the block
6 valve, can't you manipulate the block valve and detect
7 differences and ascertain that the valve is shut or not shut?

8 MR. SLEAR: Detect differences in what, the flow --

9 MR. EBERSOLE: In flow or temperature or whatever.

10 MR. SLEAR: I guess -- there's only a block valve
11 downstream --

12 MR. EBERSOLE: Is the block valve downstream?

13 MR. SLEAR: Downstream of the PORV, I believe --
14 it's upstream of the PORV, I'm sorry.

15 MR. EBERSOLE: Because you can use it for main-
16 tenance, I believe. But, certainly the presence of the block
17 valve implies an ability to close and you can have any
18 number of block valves to guarantee closure and the
19 of any closure is simply to challenge the safeties, correct?

20 MR. SLEAR: Well, you increase the probability of --

21 MR. EBERSOLE: Of a safety variety. So, it would
22 seem that as an opportunity here to use the block valves,
23 an aspect to check into the function of a PORV itself, which
24 has not been exercised.

25 MR. SLEAR: I guess the action that I perceived was

1 that the operator be given the intelligence that the PORV
2 is malfunctioning, i.e. is stuck open, and would then shut
3 the block valve as his corrective action, if you will.

4 MR. ARNOLD: I'm not sure that we're understanding
5 your point, Mr. Ebersole.

6 MR. EBERSOLE: I'm merely saying that the closure
7 of the block valve implies a rising challenge to open the
8 safeties and that's the only price you pay. But, it would
9 appear to me to be a convenient way to ascertain that the
10 PORV's are open or closed, especially if the block valves
11 are downstream, because then you would have a means of check-
12 ing the rise in pressure.

13 MR. ARNOLD: But, I think the lack of being ble
14 to close the PORV and getting a unambiguous identification
15 of whether or not you've got leakage or flow through one
16 of the three streams in a very short timeframe is the reason
17 that these individual flow meters provide us with a lot more
18 intelligence as to the conditions.

19 I don't think that it's to necessarily identify
20 this as a basis for closing the block valve as much as to
21 gain that intelligence and obviously, if you know you have
22 flow through the PORV, closing the block valves is the
23 appropriate thing to do.

24 MR. EBERSOLE: I see, yes, thank you.

25 MR. SLEAR: What parameters were you looking at to

1 assess the block valve, I guess that -- were you thinking of
2 the temperature detectors downstream and their response
3 to this --

4 MR. EBERSOLE: Yes.

5 MR. SLEAR: Okay, I guess -- and that's what I
6 thought you might be thinking of. We have the temperature
7 detectors listed as a diverse means to give the operator
8 intelligence that, in fact, the PORV is open and hasn't
9 shut.

10 But, I think it's -- we are putting together
11 calculations and plots that basically show the response of
12 that detector versus time for various initiating transients
13 in this case, it's normal operating pressure and temperature
14 PORV opens and then closes at this time and how that tem-
15 perature responds.

16 I think you can see that it responds within a matter
17 of 20 seconds to a peak of, you know, 425 degrees. But, this
18 is going to be on some decay ramp and as the valve goes shut.
19 And if, in fact, the valve is not shut, you know, it perhaps
20 could be on a different decay ramp or maintaining a hot
21 temperature.

22 But, it takes time to assess it; it takes seconds to
23 assess what's going on.

24 MR. EBERSOLE: I would think that a relatively minor
25 leak would create a horizontal line out there.

1 MR. SLEAR: It may. I guess that I don't have
2 all those calculations finished yet, so I don't know the
3 answer.

4 But, it still takes a period of at least maybe a
5 minute to assess what's really happening as opposed to just
6 walking over, perhaps, in a matter of a few seconds and
7 deducing that he has --

8 MR. ETHERINGTON: Is the tail pipe insulated in
9 the region of the pickup?

10 MR. SLEAR: The pickup is on the wall of the tail
11 pipe and I don't know if the tail pipe is insulated.

12 MR. ARNOLD: The tail pipe is not insulated on the
13 PORV from the isolation valve to that point.

14 DR. CATTON: In the questions and answers to the
15 NRC, there were questions about this flow meter. And it was
16 indicated that the answers could be found in Appendix A and
17 I cannot find Appendix A.

18 Could you tell me when and how and where it will
19 be available?

20 MR. SMYTHE: Cortney Smythe from GPU.

21 I believe that you're referring to the question
22 that where the NRC asked for flow calculations and test data?

23 DR. CATTON: That's correct.

24 MR. SMYTHE: Okay, the question refers you to
25 Appendix 2A which currently does not exist. There's a fly

1 page there that says, to be supplied and the information
2 should be available by mid-February.

3 DR. CATTON: Thank you.

4 MR. ETHERINGTON: Along with your curve for
5 temperature decay, have you drawn curve for, well, have you
6 calculated the temperature for an acceptable leak rate
7 through the PORV's?

8 MR. SLEAR: I don't believe that that was one of
9 the curves that we had planned to --

10 MR. ARNOLD: Mr. Chairman, the -- currently, the
11 acceptable leak rate is in terms of the technical specifica-
12 tions for identified and unidentified leakage. PORV leak-
13 age would be identifiable. We have not looked at whether
14 at this point, and Bob, you can verify this for me, we have
15 not looked at this point as to whether 10 GPM identifiable
16 leakage or which is our limit from the PORV alone
17 is unacceptable leakage through the PORV for other reasons.

18 MR. ETHERINGTON: My question was -- let's assume
19 that your 10 GPM is acceptable. I would expect that to raise
20 the temperature of your tail pipe probably as high as a
21 fully opened valve -- no, probably not as high, but --

22 MR. ARNOLD: We are currently doing some analyses -
23 on leakage or let me restate it, on tail pipe temperature as
24 a function of leakage but we have not completed those.

25 MR. ETHERINGTON: That was my question, okay.

1 MR. EBERSOLE: Well, this is why I was asking about
2 that check, you know, in using the isolation potential of
3 the block valves to force the deviation of the temperature
4 and determine whether you had a similar condition or
5 significantly different or whatever.

6 MR. ARNOLD: We recognize that if we suspect leak-
7 age as opposed to a failed valve, that isolation of the block
8 valve or by isolation by use of the block valve, should
9 isolate the leakage and be reflected in the tail pipe
10 temperature.

11 MR. EBERSOLE: I wonder if you could comment on
12 the price you pay for closing the block valve. Now, as I
13 see it, it is the incipient opening of the safety valve
14 which you would rather avoid, at which you have time before
15 that occurs and there's a minimum time, I guess, arguing
16 whether or not you have secondary cooling, but there must
17 be some workable time in there before you lift the safeties;
18 during which the operator has some manipulation opportunities.

19 Is that time in just the order of a few minutes or
20 is it more comfortable than that? I don't see what price
21 you pay other than the challenge to the safeties.

22 MR. ARNOLD: I think the major factor is the
23 challenging of the safeties, but, it also, I think, needs
24 to be recognized that if that block valve is shut, you do
25 introduce, also, some possibility that it will not be able to

1 be reopened and your exposure to challenging the safeties
2 may be greater than --

3 MR. EBERSOLE: It's permanent then.

4 MR. ARNOLD: Yes.

5 MR. EBERSOLE: Do the safeties dump directly to the
6 containment atmosphere or do they go to a quench tank?

7 MR. ARNOLD: They go to the same quench tank
8 through, eventually, common piping with the PORV discharge

9 MR. EBERSOLE: Thank you.

10 MR. SLEAR: Okay, the next topic I've lumped under
11 this particular section of NUREG 0578 is called inadequate
12 core cooling and fundamentally, that has to do with
13 instrumentation changes to improve our capability to assess
14 that we do have inadequate poor cooling.

15 And we have, in fact, taken the all incore thermo-
16 couples terminated them inside containment and they are
17 available in the computer. We have added, or are adding I
18 should say, a reactor coolant system saturation margin
19 monitor which will look at reactor coolant system pressure
20 and hot leg temperature and give an indication of the margin
21 for saturation in either degrees Fahrenheit or PSIG, de-
22 pending on the position of the selector switch, which is spring
23 returned for temperature margin. And, will also alarm when
24 the margin, temperature margin to saturation goes below a
25 pre-selected value.

Are there any questions?

MR. EBERSOLE: Yes. Could you comment on that ancient topic of whether we're going to have level indication for the primary vessel and what you're doing about that sort of thing.

MR. SLEAR: I guess we currently have no plans for level indication in the reactor --

MR. EBERSOLE: I believe that's implied in the long range action plan that you have such.

MR. KEATEN: I'm Bob Keaten from GPU.

We have been in the process of evaluating the need for level instrumentation and we've also been working with the vender on this subject. I believe that the long term lessons learned simply requires that that be considered and if does not take a definite position on it.

And, our current position, I believe, is that we feel that the instrumentation which is shown on the slide there is a more direct measure of what we're concerned with: namely, whether the core is being cooled or not, then would level measurement.

MR. EBERSOLE: However, doesn't this information require that you operate blind in aspect to the pressurizer level under certain circumstances which you might otherwise not need to operate?

In other words, you're going to have to drive

1 through the den to the point where you go to water solid
2 conditions where you would really rather not.

3 MR. ARNOLD: Could I comment on that?

4 As I understand what you're suggesting, is that
5 if we had water level indication for the reactor vessel
6 and did not have pressurizer level, we would be willing to
7 operate the system blind as far as water level in the total
8 reactor coolant system goes, relying upon reactor vessel
9 level.

10 I guess it's not clear to me that that would be
11 an acceptable approach.

12 MR. EBERSOLE: I believe B&W has indicated
13 that they have a capability of feed-and-bleed, even if you
14 lose all secondary side. I think it's implicit in the
15 feed-and-bleed mode that you have a primary vessel level of
16 indication. Otherwise, you're going to be forced into a
17 holding mode, with a water-steam interface and you
18 won't know where you are.

19 MR. HALLMAN: Don Hallman from B&W.

20 Are you questioning that this is the impression
21 where you would be able to determine the presence or absence
22 of

23 MR. EBERSOLE: I'm saying if you invoke the thesis,
24 you can invoke feed-and-bleed without secondary cooling?

25 MR. HALLMAN: That's correct.

1 MR. EBERSOLE: Is it implicit in that claim that
2 you can do that and need to know the primary coolant level?

3 MR. HALLMAN: No, it's the need to know --

4 MR. ETHERINGTON: Would you come up to the micro-
5 phone, please?

6 MR. HALLMAN: It's the need to know the degree of
7 subcooling that you have in the system. If you have sub-
8 cooling, then the water is existing in a solid state.

9 If you do not have subcooling, the in-core thermo-
10 couples give you a direct readout of the temperature con-
11 ditions at the top of the core; which is going more toward
12 the problem that we're trying to solve which is protection
13 of overheating in the core.

14 So our belief is that the use of the in-core
15 thermocouples is a very direct reading of the exact
16 conditions you have.

17 MR. EBERSOLE: Yes, well, those thermocouples
18 are within the core itself and they indicate that the
19 core is marginally covered without any margin whatsoever,
20 or not covered.

21 It gives you no marginal information as to
22 how much margin that you have.

23 MR. HALLMAN: No.

24 MR. EBERSOLE: This tells you that you are or
25 you are not.

1 MR. HALLMAN: Well, it triggers certain actions
2 depending on whether the thermocouples are in a
3 saturated condition or not.

4 MR. EBERSOLE: Well, thank you. I can only stop
5 the question at this point.

6 MR. HALLMAN: Okay.

7 MR. EBERSOLE: Thank you.

8 MR. SLEAR: The last thing to mention is
9 that we have expanded the range of the hot leg temper-
10 ature detector from 120 to 920 degrees, current. The
11 new range will be 120 to 920 degrees Fahrenheit. And
12 that is the input temperature to the reactor coolant
13 system saturation margin line.

14 Next is the topic of hydrogen control, post
15 accident.

16 DR. CATTON: Before you leave inadequate core
17 cooling, are you responsive to Reg guide 197?

18 MR. SLEAR: I think --

19 MR. ARNOLD: I think what we'd like to do --

20 MR. SLEAR: Which revision --

21 DR. CATTON: The current revision 2 that's up
22 for comment.

23 MR. ARNOLD: We would like to take advantage of
24 the suggestion of the Chairman and defer our response
25 to that to the Full Committee meeting. We would like

1 to do some additional work.

2 DR. CATTON: That's fine. The only reason I
3 mentioned it is because it's the next step beyond
4 Mr. Ebersole's question -- line of questioning in
5 that he was asking about water in the core.

6 MR. ARNOLD: Yes, sir.

7 MR. EBERSOLE: I might comment that, the main
8 thrust of my question to you, is that your instruments will
9 tell whether or not you have saturation cooling or not.
10 But, they have no margin of information as to how
11 much coolant is in there. Before you get into this
12 state, it's kind of an idiot gauge -- it tells you that
13 you're already in trouble, not that you're about to get
14 there.

15 MR. ARNOLD: Well, I think our understanding of the
16 way in which we would approach that problem at this time
17 is that if we did not have pressurizer level indication,
18 we would not hesitate to take the plant solid, regardless
19 of the mode of cooling that we want to then enter into.

20 MR. EBERSOLE: Right, thank you.

21 MR. SLEAR: The next topic is hydrogen control.
22 We are proceeding to install a hydrogen recombiner at
23 Three Mile Island Unit 1 with the capability to install a
24 backup. The backup recombiner will be available on site;
25 it is essentially TMI 2's recombiner, which is either being

1 decontaminated or has been decontaminated and will be
2 available for installation.

3 It's my understanding that the timeframe for
4 installation under, at least, the current guidelines, would
5 allow approximately seven days to have a recombiner
6 operation. And, with one installed and the ability to test
7 it and deduce that it is not, in fact, operational for
8 whatever reasoning and either fix it or get the backup one
9 available, we feel that's an adequate approach to hydrogen
10 recombination under the criteria that exists today.

11 In addition, there were some discussions about the
12 ability to sweep containment, if you will. My understanding
13 of the design is that it is in using the existing ventilation
14 ducting that terminates high in the containment building so
15 that the dome or that high area would, in fact, be swept and
16 then discharges at a separate location lower in the building
17 for hydrogen removal.

18 But, it's our plan to have this installed prior to
19 restart.

20 DR. CATTON: In going through the plant, I noticed
21 that at the top of the cylindrical section of the containment
22 there's a ring that has the intakes. And, this is significant-
23 ly below the top of the dome.

24 Has any assessment been made of the circulation
25 patterns one would expect inside the containment to assure

1 themselves that you're going to sweep up hydrogen?

2 It seems to me that normal flow rates are not too
3 high; you're going to have a separator built into your con-
4 tainment and if your recombiner is taken out of your normal
5 circulation system, you're not going to pick that up.

6 I have a few more comments. There are quite a few
7 rooms when you walk around in the containment where you have
8 the air conditioning intake ducting, or whatever, in doorways.
9 So that there's lots of places that you can collect hydrogen
10 within the system.

11 I couldn't tell because of the equipment whether
12 these all had holes in the roof or not.

13 There's another part to this and maybe you can
14 answer it all at once. There's the capacity of your units;
15 the person who was taking us through on the tour didn't know,
16 I'm wondering if, in deciding that you would have two com-
17 biners instead of one, if this is a rate kind of thing. Have
18 you assured yourself that, indeed, if you could collect all
19 the hydrogen you could handle it with your recombiners at
20 a rate maybe picked TMI 2.

21 MR. SLEAR: I think first of all with regard to
22 the rate, the hydrogen recombiner flow rate-----

23 MR. ETHERINGTON: Let's hear first of all from
24 Met Ed, shall we?

25 MR. SLEAR: Pardon?

MR. SILVER: I would just like to state for the record, Harley Silver, NRC, that the order does not require the installation of recombiners, and we have so noted in the safety evaluation.

However, your question, of course, is still -- again the order does not require it to be installed prior to re-start.

MR. ARNOLD: It was a decision on the part of the company that we would install a hydrogen recombiner prior to start up. That was an internal decision. The one recombiner has sufficient capacity to handle the design basis accident and specific flow rate they can identify.

It is -- our conclusion based upon work that was done for us subsequent to the TMI 2 accident, I think, individuals who would be recognized as experts in the behavior of hydrogen that there is not a tendency for the hydrogen to pocket or to separate within the containment building; that it does diffuse so that the issue of taking suction in the area of the containment building below the dome does not lead, in our opinion, to a susceptibility of hydrogen collecting in the top of the dome in a way that gives you a non-uniformed distribution.

I think there is a need to have the ventilation system running to be completely confident that we would not get pocketing in an individual closed area within the building

1 if the hydrogen was being released in that area. But, in
2 the post TMI 2 review, as we looked at that building
3 structure that was not a concern to us then. I do not know
4 that we have looked at specifically for other release points
5 for the hydrogen with regard to Unit 1 at this time.

6 DR. CATTON: Well, it's standard practice with
7 facilities that have a lot of hydrogen around that your pick
8 up point to the highest point within any given room or build-
9 ing or whatever. My observation of inside the containment is
10 that this is not the case. And, I recommend that you get
11 a hold of the NASA handbook on hydrogen hazards .

12 MR. ARNOLD: It was a NASA hydrogen expert that we
13 worked with subsequent to the accident; we would be glad
14 to review the --

15 DR. CATTON: Well, it's our feeling that there must
16 be, I don't know the height of the top of the dome above
17 the ring of intake; I thought it was at least 20 or 30 feet.

18 MR. ARNOLD: I'm sure it's on that order.

19 DR. CATTON: And, I think that you have to couple
20 it with the circulation patterns you might find inside the
21 containment to make the decision.

22 See, this is not really -- it should be pursued
23 somewhere else.

24 MR. ETHERINGTON: I'd like to ask the Staff whether
25 they've made any studies of hydrogen concentration by gravity,

1 either in still space or in containment.

2 MR. SILVER: I'm not aware of any, sir. I will
3 check to see if there's any generic studies on going.

4 MR. ETHERINGTON: Thank you.

5 DR. CATTON: One last part, you're venting the
6 top of the Candycane; it wasn't clear what you were going to
7 do with what you took out of the vent.

8 Are you going to stick it right into the air vessel
9 or have a line running right to the hydrogen recombiner or
10 what are you going to do with it?

11 MR. SLEAR: I think the answer is that we haven't
12 decided yet exactly what we're going to do with it. We're
13 still working on the criteria for where that discharge should
14 go and what analysis needs to be done in order to deduce how
15 to use that vent.

16 DR. CATTON: If you'd point it straight up, you'd
17 have a jet and if it was hydrogen, the jet would be pointed
18 well above that ring, I believe, of intakes.

19 DR. LAWORSKI: Isn't it true that, in the record,
20 that this hydrogen recombiner is not meant to deal with the
21 kind of releases that occurred of hydrogen in the accident.

22 MR. SLEAR: That's correct. It meets today's
23 criteria, which I think is hydrogen --

24 DR. LAWORSKI: Right, and it's important to make
25 that distinction. That's an entirely different kind of

1 volume rate -- rate of volume of hydrogen removal that's
2 to be dealt with.

3 DR. CATTON: We've handled just one part of the
4 question; one had to do with the collection and where the
5 intakes were. And the other was with respect to the
6 capacity.

7 MR. SLEAR: The next topic is high range effluent
8 monitors. We really have two phases to our ability to
9 monitor the effluent for radiation.

10 The interim phase involves strap on Geiger-Mueller
11 probes for the reactor building purge, condenser off-gas,
12 and main steam. In addition, we are extending the range
13 of the existing auxiliary building and field handling building
14 radiation monitors and we are moving the stack monitor
15 up one level to get it away from, I believe, it's the KE
16 pipes that pass close to it now and would, in fact, result
17 given the source terms of the Unit 2 type accident in high
18 background radiation.

19 Our solution to that is to move the monitor itself
20 to an area of lower background radiation.

21 Are there any questions on the effluent monitors?

22 Yes, sir.

23 DR. FOSTER: Are you making any study on the
24 design of that that would indicate that it is, in fact,
25 providing a reasonable sample of the total volume of gas

1 material which has gone up the stack? Or is it just an
2 open pipe sticking into the side of the stack?

3 MR. SLEAR: I guess I'd better to defer to --
4 I don't have the answer to that.

5 MR. ARNOLD: We'll address that question after
6 we check on it.

7 MR. SLEAR: And, the last item has to do with
8 the failure modes and effect analysis that was completed
9 with the integrated control system. That analysis identified
10 the potential weak point in the reliability, if you will,
11 of the integrated control system in that it's power supply
12 is fed from two different sources through a common of
13 automatic buzz transfer switch and we are proceeding with
14 a modification that if, in fact, that buzz transfer switch
15 malfunctions and does not provide a backup source of power
16 to the integrated control system, the operator in the control
17 room will have the ability to manually transfer via a second
18 transfer switch that he has control of the power to the
19 ICS, to a back-up protected power supply.

20 MR. EBERSOLE: You imply that in doing this there
21 is a substantial increase in the reliability to the ICS.

22 MR. SLEAR: Well, I don't know the numbers .

23 MR. EBERSOLE: Okay.

24 MR. SLEAR: I'm sure that numbers could be prepared.
25 Basically the failure modes and effects analysis was done

1 by Babcock and Wilcox and I'm not sure if
2 it identified the reliability in improvement quantitatively.

3 MR. EBERSOLE: Well, I suspect that the lack
4 of reliability is intrinsic to the ICS system rather than
5 just a source of power supply; am I correct?

6 MR. SLEAR: I guess I don't -- I certainly wouldn't
7 want to --

8 MR. EBERSOLE: So, its power supply is a sub-
9 stantial part of this unreliability; is that right?

10 MR. SLEAR: Well, I guess I'm not even sure that
11 you'd -- I wouldn't want to say the ICS is unreliable.

12 MR. EBERSOLE: Well, it's just a bad word.

13 MR. TAYLOR: Mr. Ebersole, ICS failure modes
14 and effects analysis identified the power supplies as the
15 principal source of unreliability and that the power supplies
16 are not a part of the ICS, per se.

17 MR. EBERSOLE: Yes.

18 MR. TAYLOR: They are -- and as a result of that,
19 they are plant specific to a very large extent. But, it
20 did identify that as the principle source.

21 MR. EBERSOLE: So, this then is a substantial
22 contributor to increasing reliability.

23 MR. TAYLOR: Yes.

24 MR. EBERSOLE: Thank you.

25 MR. SLEAR: That concludes the presentation that

I had on modifications that we are proceeding with on a prior to restart type basis in addressing the order.

There are other things, as you may or may not be aware, that the company is doing on its own and is permitted to, but this closes, if you will, my discussion of the order items with the exception of the longer term items, the category B NUREG items which I'll discuss at a later time and in addition, the auxiliary feed water modifications which is a separate topic.

MR. ARNOLD: Before we proceed with that, Mr. Chairman, Mr. Keaten would be prepared to discuss data gathering and display in the control room in response to a question that, in addition to the agenda item, and this would be a convenient time to do that.

MR. ETHERINGTON: Go ahead.

MR. KEATEN: Was there a specific question that I can address with respect to the computer?

MR. ARNOLD: Mr. Keaten wasn't here at the time that the question was initially asked.

MR. EBERSOLE: Describe it.

MR. KEATEN: We have two computer systems for Unit 1. The one system is the one that was originally supplied with the plant and it is analogous to the system which we had in Unit 2.

The second system is a very much expanded computer

1 system which -- work had started on this system, in fact,
2 prior to the TMI accident. It uses a Mod Comp 4 machine
3 which is a larger computer than the original one and has
4 approximately, I think, something over 2,000 inputs to
5 the computer. The hardware, we have basically, I believe,
6 in what would be its final form. The software programs
7 are not, at the present, in their final form.

8 The computer system as it presently exists to
9 date has the capability of monitoring the input signals
10 and providing output signals at any of the output devices.
11 It does not have the capability of constructing some of
12 the types of sophisticated displays that we would eventually
13 expect to do in the system.

14 The computer has a capability that we refer to
15 as the transient monitor to storing information from about
16 112 analog and 112 digital signals which can be recorded
17 at rates in excess of one cycle per second. And, storing
18 this information up to 24 hours on the discs that are a
19 part of the computer system and then the information is
20 subsequently transferred to magnetic tape for permanent
21 storage.

22 So, this provides us with the capability of mon-
23 itoring these critical signals in retrospect if the plant
24 undergoes a transient, we can call this data back and analyze
25 what happened.

1 On a longer term basis, we eventually expect
2 to have the capability to do a similar type of data storage
3 and retrieval for all of the signals going into the com-
4 puter, although they would not all be monitored at that
5 very high scan rate.

6 DR. CATTON: That's a part of the interest.

7 The second part is what are you going to do in
8 the control room? Right now, as far as I can tell, you
9 have the same system that you had in Unit 2, except with
10 maybe an extra typewriter: namely, very slow output, 12
11 seconds per line on the typewriter and 3 seconds per line
12 on the CRT.

13 And, it's my recollection that this was the big
14 problem in TMI 2; what are your plans for doing something
15 about that, and what are your dates or what is your schedule
16 for getting it done?

17 MR. KEATEN: Yes, sir. I can answer your questions.

18 Let me first answer it by saying that our evaluation
19 has not shown that the computer system was a big problem
20 as far as the TMI 2 accident causes were concerned.

21 The operator had the information available to
22 him that he would be normally expected to use. The operators
23 have not made a habit of using the existing computer system
24 to help them during transient conditions. It has been
25 relied on primarily during steady state operations for

1 certain types of monitoring.

2 DR. CATTON: Let's see; I wasn't prepared for
3 that type of an answer. What I had heard earlier was quite
4 different. I'm going to have to review what I heard earlier
5 before I want to agree with what you're saying.

6 MR. KEATEN: Yes, sir. Let me also add something --

7 DR. CATTON: Part of the testimony of the operators.

8 MR. KEATEN: Yes, sir. Let me also address the
9 second part of your question.

10 We have installed faster printers in the existing
11 computer system -- the original computer system, because
12 it is true that the original printers did create a situation
13 where there could be a backlog of --

14 DR. CATTON: They're not installed yet. At least
15 they weren't yesterday.

16 MR. KEATEN: That's true. When I say installed,
17 I mean that we have committed to have them installed prior
18 to the time of the plant restart.

19 DR. CATTON: Could you give me the specs? Not
20 details, just signals and the rate that you can receive
21 them.

22 MR. HARRIS: Wayne Harris, GPU.

23 We have presently the old selectric typewriters
24 that were on there and are capable of about 12½ characters
25 per second, proof that they're very unreliable mechanically.

1 The printers that we're replacing them with is
2 part of restart modification seven, RM7, are Texas Instru-
3 ment's 820 type printers which are capable of 280 lines
4 per minute. They'll be run at, I think it's 12 hundred
5 characters or 120 characters per second. The computer
6 itself is not capable of generating the alarms that fast.
7 The cycle time between alarms, between discrete alarm
8 messages on Unit 1 computers is 3 seconds; it can't generate
9 an alarm and print it out in less than 3 seconds.

10 DR. CATTON: Where is the problem then? Is
11 it the CRT system, the computer, or what?

12 MR. HARRIS: It's the computer itself. The com-
13 puter that we have in Unit 1 is an older model of the one
14 in Unit 2. It is a Bailey 55G and the cycle time on it
15 is about 2 microseconds, between 2 and 2½ microseconds.
16 It's a sinc-jam type computer in that there are five function-
17 al computers and each one gets a certain timeslice of the
18 12½ millisecond period.

19 The operator communications system, which is
20 functional computer C, I'm not sure what the exact percent-
21 age of that 12½ millisecond timeslice that it gets, but
22 it must share with the other computers, with the data
23 acquisition computer and the NSS computer, the balance
24 of plant computer; it must share its time with those.

25 There is a method which is used in Unit 2 for

1 controlling through software what those percentages of
2 that timeslice are. It's not used in Unit 1. That's on
3 a hardware basis; it's a hardware option to change the
4 percentage rates of each of those functions that the com-
5 puter gets to fill the time slots.

6 DR. CATTON: Do you plan to upgrade the computer
7 in Unit 1, and if so, when?

8 MR. KEATEN: Yes, sir. As I said, we have to
9 date in a room adjacent to the control room, a new computer
10 which is very much faster and we have the specifications
11 on it if you would like to have them.

12 But, we have not taken the position that this
13 was an activity that had to be completed prior to restart.
14 It was, as I said, something that we had started, in fact,
15 before the TMI accident and we are in the position today
16 to make some use of that computer system. But, we expect
17 some of the software developments to continue on past the
18 timeframe of the restart.

19 DR. CATTON: Let me see if I understand.

20 What you're telling me is that in TMI 2, the
21 data retrieval rate in no way directed the course of actions,
22 the course of action that took place. Therefore, you con-
23 clude that really no changes are needed, but you're going
24 to make some anyway.

25 Is that a correct interpretation of what you're

1 saying?

2 MR. ARNOLD: I don't think it is and I'll let
3 Bob speak for himself. But, as far as, you know, what
4 he said earlier.

5 Let me point out that the computer modification,
6 the installation of Mod Comp 4 which Mr. Keaten described,
7 was initiated as an engineering and procurement action in 1975.
8 The computer was installed in '76 and we had that computer
9 capability upgrade as a three phase activity, the first
10 phase was the installation of the first computer with the
11 type of software capability that Bob indicated that we
12 have there now Phase two was the development of software
13 and installation of additional hardware which increased
14 the man-machine interface capability and made the computer
15 more reliable as a monitoring and a data display tool for
16 the operators. The software development on that has been
17 underway since, I guess, the middle of 1976, at least,
18 and it has been a very extensive effort, it has been a
19 very difficult one to develop the necessary software. And
20 that effort, though, is still being pursued. It is seen
21 as, obviously, a significant improvement in the information
22 available to the operator and his ability to assess what's
23 going on.

24 Now, I'll let Bob clarify or comment on his
25 interpretation or his understanding of the contribution

1 of the lack of that capability in the Unit 2 accident.

2 DR. CATTON: I'm surprised that it has taken
3 four years to develop the software. It must be a fairly
4 low-level effort.

5 MR. ARNOLD: Not at all, sir. We've also been
6 very surprised, but it has been a very high priority effort
7 within the GPU throughout that time period. It is, I think,
8 one of the misunderstanding or misconception within the
9 industry that this kind of software is commonly in place.

10 It is not, to your knowledge and we --

11 DR. CATTON: Well, I would agree with that and
12 I understand that you have to develop the software and
13 you first have to decide what you want before you can
14 develop it.

15 But, four years seems an awful long time from
16 the point that you decided that you were going to start
17 the change.

18 MR. ARNOLD: I agree with you and I think it's
19 indicative of the state of the art on the software develop-
20 ment for this type of process monitoring.

21 We have --

22 DR. CATTON: Within the nuclear industry, I would
23 agree with you. As far as other industries are concerned,
24 that's not the case.

25 DR. LIPINSKI: I'd like to go back to TMI 2.

1 The operators had testified that they were not
2 pressing the enunciator button for fear of clearing some
3 of the alarms because they wanted to have knowledge on
4 which alarms had come up. Consequently, the enunciator
5 horn was blowing in their ears for some unspecified amount
6 of time.

7 The status of the quench tank pressure and temper-
8 ature were not recorded; they were only indicated. The
9 alarms on that tank went into the plant computer, but in the
10 first interval, there was something like 1½ hours' backlog
11 of data on point status in the computer that did not get
12 recorded for the operators to observe. And they reset
13 that memory and then built up another backlog of about
14 another hour of data in the plant computer, because it
15 was not printing out fast enough.

16 I consequently can't agree with you that the
17 plant computer did not play an important part in helping
18 the operators with TMI 2.

19 Now, in observing Unit 1, there are some variables
20 that are recorded and they are the key variables. But,
21 a majority of the variables are only indicated and their
22 alarm status is going to appear through your plant computer
23 and the time of occurrence and value are going to appear
24 in the plant computer, because you will not get them off
25 the control panels if they are not recorded.

1 MR. KEATEN: I did not mean to imply from my
2 earlier statement that I could stand here and say that
3 the computer, or that the computer capability had zero
4 impact. But, I personally have spent a great deal of time
5 talking to the operators who were in the control room
6 during the critical period of the accident; and without
7 exception, to the best of my knowledge, they have told
8 me that they did not feel that the computer contributed
9 and that they were not normally using the computer during
10 this kind of a timeframe where they were in a transient
11 situation. They just relied on their normal panel instru-
12 mentation.

13 I agree with Mr. Lipinski that there are things
14 that could have been different such as a good record of
15 the parameters in the reactor coolant drain tank that could
16 have been useful to the operators. But, in fact, when
17 the operators wanted the information on the reactor coolant
18 drain tank parameters, what they did was to go to the normal
19 indicators which were located on the back panel of the
20 control room.

21 And, as you've pointed out, they were simply indi-
22 cators that were not recorded.

23 DR. LIPINSKI: The disc had ruptured and reset
24 to zero.

25 MR. KEATEN: Exactly.

1 We have recognized for some time, as Mr. Arnold
2 said, that it would be a desirable thing to have an up-
3 graded computer system in both Unit 1 and Unit 2 as a matter
4 of fact, and we have been working in that direction and are
5 continuing to work in that direction at a very high priority
6 fashion. And, as I indicated earlier, the new computer sys-
7 tem as it exists today and even more so as the condition
8 that it will be in at the time that we restart the Unit will
9 be able to provide the operators information in a better
10 fashion and a more complete fashion than they had available
11 previously.

12 So, I do not mean to imply that we place no im-
13 portance on that, but in addressing specifically the issues
14 that arose from the TMI accident, it was not our conclusion
15 that it was necessary for the operators to have to rely
16 on a plant computer in order to be able to correctly res-
17 pond to those kinds of transients.

18 DR. LIPINSKI: That quench tank was one of the
19 most important parameters in determining what was going
20 on in terms of the closure of that PORV. That information
21 was lost in that plant computer.

22 MR. ARNOLD: But, I think that what we would
23 conclude from that experience is that we should have had
24 a recording device on the direct indicator because that's
25 where the operator normally would go to as opposed to only--

1 DR. LIPINSKI: Correct, given that as a postulate,
2 but not having had that information, the information that
3 was available was lost in the plant computer because the
4 alarm was generated, if I recall, and the disc ruptured
5 in about 15 minutes and the fact that the alarms had been
6 reached were lost in the computer backlogs.

7 MR. KEATEN: That's a true statement.

8 I think that part of our response, though, is
9 simply that the real issue was the fact that the operator
10 did not have any direct method of knowing the the PORV
11 was open and therefore, was forced to rely on indirect
12 indications such as the reactor coolant drain tank parameters.

13 And, our response to that is simply to give him
14 a direct indication of whether there's flow in that line
15 so that he doesn't have to rely on any indirect indications.

16 DR. LIPINSKI: Again, we're only using this as
17 a prime example where we've got something concrete to show.
18 But, if you look again at your control room in Unit 1
19 and the variables that are recorded, and then ask yourself,
20 how many variables have I only indicated that will be im-
21 portant to me under a different set of circumstances and
22 when they do alarm, what the values are when they alarm
23 will only be coming through your plant computer.

24 So, take a close look at your control room, see
25 what you are not recording, and then you will conclude

1 what information will pass through the plant computer that
2 is important, under a different scenario.

3 MR. ETHERINGTON: I think there's a gentlemen
4 who wishes to say something.

5 MR. HARRIS: In reference to what you're talking
6 about, the quench tank, had we been able to output the
7 alarms at the frequency that they were coming in, the
8 points that were actually being sampled, had we had fast
9 enough output devices to do that, I think the operator,
10 I think you would find that the operator would be so
11 inundated with information that it would be very difficult
12 for him to pick that specific alarm out of the printout
13 that was coming out.

14 DR. CATTON: But, he ought to have the option
15 to say, hey, I would like to check that. And, he didn't.

16 MR. HARRIS: Okay, toward that end, on the
17 new system that we're presently developing there has been
18 specified a priority organization of the alarms where you
19 can specify work -- the points that are marked by the plant,
20 what the priority of the alarm, should that point exceed
21 its operatin limits.

22 DR. CATTON: The setting of priorities will be
23 a difficult task. You're going to have to postulate all
24 possible scenarios in order that you can do it.

25 And, I think that we're a little concerned that

1 you won't be able to.

2 MR. KEATEN: And, we agree with you very much
3 as far as the difficulty of that task is concerned. And,
4 our approach is going to be, on the new computer system
5 now, will have high speed line printers, which will, in
6 fact, print out all of the alarms.

7 And, then through some other output device, we
8 hope to be able to develop eventually some sort of a scheme
9 for prioritizing the alarms. But, we do not underestimate
10 the difficulty of doing that.

11 In any event, we would always maintain the
12 capability for the operator to go and look at a complete
13 list.

14 DR. CATTON: I think that 280 lines a minute
15 is a significant improvement over what we had before.

16 But, I still, a personal feeling, that when you
17 start piling up that paper on the floor and you get a hunch
18 of people scrambling around looking for a signal that was
19 600 lines back, I would rather, personally, have a CRT.

20 MR. KEATEN: Yes, sir. And we do, in fact, in
21 the new computer system have CRT's.

22 MR. ARNOLD: I think that, well maybe it's not
23 directly germane to the computer capability, it seems to
24 me the philosophy of operations here is germane and I think
25 that if the company learned anything out of the accident,

1 it was that the major contributor, in our opinion, to having
2 had the accident was the lack of preparation of the operators
3 for the conditions that he was faced with.

4 And, that that's still where we should be focusing
5 our first line of defense is on the training of the
6 operators in the procedures that are provided for him to
7 deal with in plant situations; the pre-thinking and pre-
8 planning that goes into that as opposed to a heavy reliance
9 upon him being able to assimilate a lot of information
10 and digest it in a way that lets him diagnose what's develop-
11 ing.

12 DR. CATTON: That presupposes that you know what's
13 going to happen and I would agree that when you do know
14 what's going to happen the operator should be trained
15 and proper procedures should be put together for him to
16 handle this.

17 I think, though, that what we're trying to put
18 across is that there are going to be things that happen
19 that you don't anticipate and he's going to have to have
20 information to act properly. If he doesn't have the proper
21 information, then the amount of training doesn't matter.

22 MR. ARNOLD: And, I think our approach to that
23 issue which, you know, we don't disagree with, is that
24 there are certain basic plant parameters and basic indicators
25 of plant conditions upon which he should focus and insure

1 that he retains those within acceptable envelopes and not
2 orient him towards very subtle analyses that he may be
3 encouraged to do on the spot, so to speak, that the pro-
4 tection of the core is where his focus has to be and I
5 don't think that it requires a large number of data points
6 for him to have available to him to insure that he is
7 protecting the core.

8 MR. ETHERINGTON: In that sort of context, I
9 think it's clear to all of us, and I can't help but think
10 of the CE system 80, where great difficulty was found in
11 introducing computers into the safety complex; this is
12 the automated aspect.

13 Here, I think, TMI dramatically illustrated that
14 the operator plays a very vital in the safety feature and
15 therefore, you feed him information which is going to
16 necessitate the computer processing which then implies
17 a kind of 1E reliability on the computer output to him;
18 which goes beyond just increasing its speed or its amount
19 of recording capability. It may, in fact, go the other
20 way that you should trim-down how much information a computer
21 group ought to have and call it a safety class computer
22 which will provide that critical but not superfluous informa-
23 tion for him to say, please shut the plant down.

24 I'm a little bit concerned about the intermixing
25 of the safety/nonsafety aspects of computer systems here.

1 And I'm wishing, perhaps, that we could trim and lean down
2 those aspects of the computer systems that are fairly crit-
3 ically safety oriented and avoid flooding his mind with
4 superfluous information, even though it's coming from a
5 computer, and even from a CRT.

6 In short, I think we're entering an era where we
7 have safety grade 1E type computers, which we don't have yet.
8 But, we are going to have to admit that they have to be con-
9 sidered as such.

10 DR. LAWROSKI: I believe that it's in the long
11 term lessons learned where the so-called definition of plant
12 safety factor is yet to be defined and the NRC has this as
13 one of their tasks to be undertaken.

14 Implicit in that will be the reliability of the
15 information if this is going to be grouped as key information
16 to be presented to the operator, the reliability in the
17 information will be part of that assessment.

18 MR. ARNOLD: I might just point out that since we
19 have wandered somewhat astray; there is a recognition within
20 GPU of the points you make and we are looking at the possi-
21 bility of undertaking, in conjunction with others, what
22 amounts to a research development effort for identifying the
23 kind of equipment that would be appropriate for something
24 like Three Mile Island Unit 1 to give the segregation of
25 information that is really critical to understanding plant

1 safety.

2 MR. EBERSOLE: Thank you.

3 MR. ETHERINGTON: I think that's probably as much
4 as we want to say on the subject now.

5 MR. ARNOLD: All right, sir, if we could pick up
6 the agenda again and ask Mr. Slear to proceed with section
7 4, Roman numeral 4, item 1.

8 MR. SLEAR: This is the time to discuss emergency
9 feed water and the modifications that we're making as a
10 separate issue.

11 First, I wanted to briefly describe the fundamentals
12 of our emergency feed water system so that we're all at least
13 playing the same ball game, so to speak. We have three
14 emergency feed water pumps, two motor driven pumps, one steam
15 driven pump; those pumps can all take the common suction on
16 either condensate storage tank, the hot well, or in cases
17 where there's no water there, from the river itself. They
18 discharge into a cross-connective header and provide emergency
19 feed water to both steam generators.

20 You will hear me discussing failure mode modifications
21 to the throttle valves or the block valve, I guess you would
22 call them, EFE30A and EFE30B have received some modifications
23 and you will hear me discuss the addition of some flow
24 instruments; those flow instruments are two safety grade flow
25 instruments downstream of this cross-connect line, two for

1 steam generator A and two for steam generator B.

2 So now we're at least talking the system and
3 I can throw that up again if there are any questions about,
4 as I go through the specifics of the modifications that
5 we've made.

6 DR. LAWORSKI: Excuse me. You said that you were
7 under Roman number 4? I've got a 4 but it's in a different
8 place.

9 MR. ARNOLD: It is still under Roman numeral 3,
10 it is item number 1 that was scheduled to start at 1 o'clock
11 this afternoon on emergency feed water changes.

12 MR. SLEAR: Are we all together? Good.

13 Emergency feed water changes: Change number 1, we
14 have a automatic pump start. Signals that we sense auto-
15 matically start the emergency feed water pumps are currently,
16 we have a control grade installed which senses loss of
17 core reactor coolant pumps or loss of too many feed pumps.
18 The engineering is scheduled to be complete the end of this
19 month for a safety grade emergency feed water automatic
20 pump start initiating signals for the safety grade pump start
21 or once again, loss of core reactor coolant pumps, loss
22 of automatic feed pumps, or the feed steam delta feed, which
23 is a feature we have taken from Unit 2.

24 The second modification: emergency feed water pump
25 power. We are, in addition to automatically starting the

1 motor driven pumps, we are loading them on the diesel based
2 on block five loading with the red pump obviously on the red
3 diesel and the green pump automatically loaded on the green
4 diesel.

5 With regard to flow indication, we have added sonic
6 flow detectors between the cross over and the individual
7 steam generators two sonic flow detectors in each line going
8 to each steam generator for a total of four flow indicators.
9 These devices indicate in the control room up to 15 hundred
10 gallons per minute. We are enunciating in the control room
11 for all of these auto start conditions to provide the operator
12 with an alert that we have called for emergency feed water
13 so that he can, in fact, confirm emergency feed water flow
14 to the steam generator if the system is functioning as it's
15 supposed to and providing heat samples to the reactor coolant
16 system.

17 I mention the 30 valves, the emergency feed water
18 control valve; we have modified the valve itself, it is
19 an air operated valve, we have modified it such that on loss
20 of instrument air, or really loss of air supply to it, it
21 will, in fact, fail open. In order to reduce the potential
22 for loss of air, IE improve the reliability of continuing
23 to maintain remote control of that valve from the control
24 room we've added two additional backup air compressors and
25 they provide backup instrument air to not only these valves

1 but selected other valves in the plant. We have an air
2 resevoir dedicated to each of these valves which will in
3 fact require air pressure to operate them and as long as
4 all else fails, there is still a resevoir of pressurized air
5 to allow you some more time before you have to take manual
6 control of the valves.

7 And in addition the current control for those valves
8 from the standpoint of remote control in the control room
9 is either through the ICS or through a manual loading station
10 as we call it, which has a power supply coupled with the
11 ICS. And in order to, once again improve the reliability of
12 that manual loading station, we have added a redundant manual
13 loading station, what I refer to here as a new manual
14 control station; its power supply is controlled separate
15 from the ICS. All of this to improve the reliability of
16 these two control valves and to insure the ability to provide
17 cooling water to the steam generators.

18 The last thing we have done is, as I indicated,
19 these emergency feed water pumps will take a suction on
20 both condensate storage tanks and it takes hours if not
21 days to finally drain those tanks; but because it is a long
22 time and into some sort of a transient when you might be
23 taking a suction on those tanks, perceive the need to provide
24 a low level alarm to alert the operator that he had run out
25 of that water supply and it was time to find another one.

Any questions that I might be able to answer?

MR. EBERSOLE: Is all this to say that instrument air is now regarded as exercising a safety function and you're making the appropriate modifications to qualify it that way?

MR. SLEAR: I guess I don't have a good answer to that; I don't think so. It certainly made modifications to improve its reliability.

MR. EBERSOLE: Yes, it's kind of in a hazy state somewhere in between and I --

MR. ARNOLD: I don't think that we have taken the position that instrument air should be designed to safety grade equipment, but we recognize the contribution to the reliability of operation that that system has by operating its functions.

MR. EBERSOLE: Let me mention --

MR. SLEAR: To give you a feel for where we're headed, please recognize that what I have shown you is what we are proceeding to do prior to restart; that we have also taken a look at, I guess you could call it, making the emergency feed water system single failure proof. And, in the longer term of what modifications are required, my recollection is that includes backup valves to these valves which are motor operated.

MR. EBERSOLE: Well, we are rapidly approaching

1 the aspect of making these things safety grade.

2 You know, that includes seismic and part supplies
3 and the whole bit. And it includes, then, considerations
4 which are not currently being taken up. I just mention
5 two in -- what are really concerns of a colleague of mine,
6 Mr. Michaels, and I guess you know that he's mentioned to
7 me from time to time that to make these standing leaks in
8 an instrument air system which are easily overridden by
9 the decompressor, you simply don't know that they are there
10 because the capacity blinds you to the fact the they're
11 there. Such leaks would be large enough to prevent the
12 operation successfully of smaller compressors if you fell
13 back to those small compressors. So, suggest a periodic
14 inventory of the leak rate which is occurring as well as
15 a consumption rate of the instruments.

16 Another aspect is the desiccants in the systems
17 have, to my knowledge, never been proven capable of sustaining
18 advisal followed by physical upset, like in seismic shelf
19 shock or something like that without the potential of en-
20 training the desiccants into the systems and commonly then
21 affecting instrument devices that use air.

22 I'm merely saying that if you're going to go the
23 whole way, that some more needs to be done in modifying
24 these safety grade systems. I see you're going part way,
25 but I guess I don't know where we're headed.

1 DR. LIPINSKI: I think questions have been raised
2 with respect to emergency feed water system to tanks, connect-
3 ing pipes, all the way to the steam generators, but, now
4 you've raised the question of the qualification of the air
5 supplies that go to operate these valves. The fact that
6 the rest of the system is seismically qualified doesn't
7 help you to balance the system. does it?

8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

1 It was pointed out that you have an inter-
2 connection between your instrument air and your plant service
3 air. In the case of Unit 2, this connection existed
4 and the explanation was given at that time, that one of
5 the systems was under supply and that connection was
6 put in as a method of fixing, I forget which one. It
7 was where the instrument air was short and the service
8 air was short. Now, I found out this condition exists
9 on Unit 1. Is there a good reason as to why it exists
10 on Unit 1?

11 MR. ARNOLD: We are going to try and address
12 that a little later with a different person than Mr.
13 Slear.

14 Could I go back, I think to your comment earlier
15 because I wasn't sure -- they said yes to some questions
16 but these valves can be operated manually, locally.
17 They can also be operated in the control room in a manual
18 mode.

19 We are not taking the approach, at this point,
20 and don't believe that it is necessary in terms of the
21 overall plant design and criteria that apply that these
22 systems have to fulfill safety rate system design criteria.

23 We are doing those things that make sense to im-
24 prove the reliability operation of these, because obviously
25 they are very useful and important in plant upsets and

1 mitigating the deterioration of the situation.

2 DR. LIPINSKI: I have one further question.
3 I think it was March 27 of last year that an LER was
4 written on the closure of the steam belt and the steam
5 driven emergency feedwater pump. The handbelt had been
6 wound down and the condition was such that a LER had
7 to be written. The maintenance had been done and the
8 belt was left in the block condition.

9 What is it that you are doing now that prevents
10 the reoccurrence of a similar event because the position
11 of that handwheel is not indicated although the valve
12 position supposedly is indicated in the control room?

13 MR. ARNOLD: The event was a result of a break-
14 down in the administrative controls for valve lineups,
15 prior to startup.

16 The plant was coming back from refueling outage
17 in Mid March and as part of the prestart up preparation,
18 a valve lineup was initiated.

19 There was a delay in the schedule for return of
20 the plant to service and that delay was taken advantage
21 of by the maintenance people to do some maintenance on
22 the feed pump which involved closure of that valve.

23 On completion of the maintenance work, in re-
24 moving the tags the shift foreman did not direct the
25 valve lineup to return to normal relying instead upon

1 utilizing the valve lineup check that would be done for
2 the preparation for startup for returning all the valves
3 to their normal position for operation.

4 When they continued or the valve lineup is a
5 very extensive one, it would normally take a couple of
6 days to complete, that is required prior to startup, and
7 the one that was initiated earlier was picked up at the
8 point that it had been left off with. It had already
9 gone pass those particular valves.

10 We would not permit if we had changed our ad-
11 ministrative controls, as to not permit that type of
12 picking up of the valve lineup that is required prior
13 to startup, so that we are primarily addressing that issue
14 with the administration of the valve lineup check off
15 prior to startup and also the routine shift-to-shift
16 valve lineups. I am not aware whether Dave can clarify
17 that we have added any indication of the position of the
18 manual override for the valve to the control room.

19 MR. SLEAR: There is no modification like that
20 that I am aware of.

21 DR. LIPINSKI: I believe it is Reg guide 147
22 that is to be made effective February 1980, that is to
23 cover the status of systems and based on the configuration
24 this handwheel override, I am not sure whether the Reg
25 guide covers that point. I am going to have to read

1 the fine print carefully.

2 The purpose of the Reg guide is to be able
3 to determine the status of all the valves that are
4 important to safety from the control room. These handwheel
5 overrides are not indicated in the control room.

6 MR. ARNOLD: That is correct, and we have
7 modified our routine valve lineup checks that are carried
8 on on a shift-to-shift basis to substantially increase
9 the frequency of local visual verification of those posi-
10 tions.

11 MR. SLEAR: That was the extent of the presentation
12 I had on emergency feedwater.

13 MR. ARNOLD: If I could add one other point to that?

14 Those types of operators are also included under
15 our lock valve controls.

16 MR. EBERSOLE: I believe your logic on your
17 instrument air you open valves to insure water flow, is that
18 right?

19 MR. SLEAR: That is correct.

20 MR. EBERSOLE: Now, this means that there is some
21 potential for all three responding full open to fill the boilers.

22 MR. SLEAR: That is correct.

23 That also then brings up the question of what
24 happens if you put too much in?
25

1 MR. SLEAR: We have looked at the amount of
2 time, and I had somewhere between 10 and 15 minutes --
3 MR. EBERSOLE: He has time to respond to that.
4 MR. SLEAR: -- get to the valve and close the
5 valve. He also has got the ability from the control
6 room to just stop the pump.
7 MR. EBERSOLE: He can stop the pump.
8 Is the level indication by any chance dependent
9 on the air supply? It is not, is it?
10 MR. SLEAR: Not that I am aware of.
11 MR. EBERSOLE: It is an electrical system?
12 MR. SLEAR: Yes.
13 MR. EBERSOLE: Thank you.
14 MR. SLEAR: You are welcome.
15 MR. ETHERINGTON: We will break for lunch now.
16 (Whereupon the meeting broke for lunch at 12:00.)
17
18
19
20
21
22
23
24
25

1 (Whereupon, the proceeding
2 continued at 1:25)

3 MR. SILVER: Just a clarifying remark. Earlier,
4 I indicated I had no comment on the Emergency Feed Water Items
5 and that's quite true, but I would like to explain that.

6 The SCR, of course, does make comment on the
7 various items that we discussed and the status report does
8 indicate our--the status of our review. I did not mean to
9 reply when I said, "no comment" that there is any change
10 in those items. We have stated our position in the status
11 report and the safety evaluation and these things are still
12 in effect. But, the meaning of my statement, was that
13 we have nothing additional to offer at this state based
14 on the presentation as given.

15 MR. ETHERINGTON: I think that was understood.

16 Let us see, is it Mr. Elam, next?

17 MR. ARNOLD: Yes. Mr. Chairman, I would like to
18 introduce Branch Elam. He is currently the manager of
19 plant engineering assigned to Unit 2, but has been taking
20 the lead in the design work for the separation of Unit 1
21 and Unit 2.

22 MR. ELAM: Our objective in the area of separation
23 between the two units, as related to the Unit 1 restart, is
24 to implement separation of systems to facilities to the
25 extent that the

1 plant operations on the Unit 2 recovery will not affect safety
2 operations at Unit 1.

3 The Unit 2 recovery operations in progress or
4 plan include continued orderly KE removal from the reactor
5 this is on Unit 2 side, reactor coolant pressure and
6 chemistry control, clean up of contaminated waste water from
7 the auxiliary building and reactor building, clean up
8 courage of the reactor building atmosphere, decontamination
9 of the auxiliary building and reactor building and ultimate-
10 ly reactor core disposition.

11 In consideration of this objective and the plant
12 operations at Unit 2, we've identified the following systems
13 and facilities where specific design modifications or
14 procedural actions are required.

15 Liquid RAD waste treatment system, the nuclear
16 sampling system, and a fuel handling building, and associated
17 ventilation systems.

18 First, addressing the liquid RAD waster system.
19 At the time of the accident, there were five piping inter-
20 connections between Unit 1 and Unit 2 which permitted the
21 movement of contaminated water, or potential contaminated
22 water between units. These interconnections were installed
23 to transfer reactor coolant, miscellaneous waste, concen-
24 trated waste, evaporative compensate, and spent resin from
25 unit to unit.

3
1 As a result of our separation objective, each of
2 these interconnections will be positively isolated, in a
3 manner that will provide at least two closed valves isolating
4 processed components in the two units. The details of how we
5 are going to do this will be covered in a later presentation
6 on the waste treatment system.

7 Second system are requiring action, nuclear samp-
8 ling system. The original station design at TMI for nuclear
9 sampling for Unit 2 basically utilized the sample sink in-
10 stalled in Unit 1 with piping from Unit 2 into Unit 1 and use
11 of the TMI high chemistry lab for sample preparation of
12 counting. Return lines were also installed for establishing
13 research paths--path back to Unit 2 for purging lines. The
14 sample lines from Unit 2 are not shielded in the TMI 1 portion
15 of fuel handling building to the extent that after the
16 accident, we experienced high radiation fields around the
17 piping.

18 In access to the fuel handling and auxiliary buildings
19 to be limited because of the need to take periodic let down
20 samples at radiation levels, piping might still cause certain
21 kind of difficulty in taking the samples.

22 To resolve this area we designed and currently
23 installing a new sampling sink in Unit No. 2; we call it the
24 temporary sampling system. All Unit 2 samples will be routed
25 to this facility, with the exception of the samples that have been

1 taken from other facilities that are not piped into the
2 systems, such as hard processes from depth core two and
3 future systems that will be installed. The pipe samples that
4 now go to Unit 1 will go to a temporary sink in Unit 2.

5 This system consists of the tubing valves and
6 the necessary equipment to perform the sampling. The
7 sources of water that go to the system are the reactor
8 coolant bleed tanks, the reactor coolant system, miscellaneous
9 waste holdup tanks, the new mini decay heat system that
10 we are currently installing, the pressurized re-stage space
11 and water space, and the fuel cooler waste--waste storage.

12 The entire new sink will be shielded and enclosed
13 with its own independent ventilation system and will exhaust
14 into the Unit 2 aux building ventilation system. The sink
15 is located in the Unit 2 auxiliary building adjacent to the
16 model room.

17 The third system that I mentioned requiring the
18 significant action is the fuel handling building. Basically,
19 presently the Units 1 and 2 share a common fuel handling
20 building. There is no physical barrier existing to divide
21 the air space between the two units.

22 Conceivably, the release of radioactive gases,
23 in particular, from either unit, could possibly migrate
24 to the other unit.

25 In consideration with this, we intend to modify

the building layout and to install physical barriers to the extent that we positively isolate the building volumes below the operating deck level, 348 foot elevation; above the operating deck level there will remain a common air space.

Additionally we would modify the Unit 1 fuel handling building vent system to prevent potential leak paths to the auxiliary building by adding appropriate dampers, they close on the radiation signal in the exhaust from the auxiliary building on the Unit 1 side.

Additionally we address the other changes to the fuel handling building to accommodate a potential fuel drop accident.

MR. ARNOLD: Go ahead and clarify that.

MR. ELAM: Okay.

To address the impact of a potential fuel drop on the Unit 1 side, we are attempting to install an independent issue and safety function grade ventilation system in Unit 1 fuel handling building. The actual implementation of this would involve some dampers and it would involve an up filter system on the discharge in the fuel handling building

The corresponding sytem--ventilation system on Unit 2 fuel handling building will remain unchanged. Of these three systems are the ones that most interest that have the most significant actions associated with them. In addition, we reviewed all other systems and facilities and

activities that can be considered to have the interface between the two units, and I'll go through those.

The solid waste disposal system. Prior to the accident, basically the solid waste process system was a shared system located in Unit 1. Again, as a result of our separation objective, we intend to separate it, this function from Unit 2. But, considering the various types of solid wastes, firstly, the compact waste and LSA box, lower level types of solid waste, Unit 1 and Unit 2 now employ their own separate compacting machine. Interstorage on sight is separate, once the waste is either in a 50 gallon drum or in a LSA box. The shipments are separate, however, the Unit 2 organization manages all the shipments.

But, considering other solid waste, the nature of solidification systems, Unit 1 will eventually have its own separate permit system. Unit 2 also had separate facilities for solid waste, Mr. Horne. The nature of what these will be is somewhat in the planning stage, but the one clearly identified system is the--is the one that will support submerge ventilizer system, but will be installed in Unit 2, sir.

Regarding the upper core two, the processing system is presently in operation in Unit 2. We are investigating what is the best way to handle the solid--resin solidification in that system.

1 There is a small portable solidification system
2 in place in Unit 2 now, which is processing decontamination
3 solutions. There is no exchange of use between the units
4 of these facilities.

5 The last item on solid waste, as I mentioned is
6 the epicore one system, which is physically located in Unit 1.
7 The resin line from that system are being stored on the
8 Unit 2 side, in Unit 2 storage. However, they are clearly
9 identified and they are, in fact, treated and shipped as
10 Unit 2 waste.

11 Liquid effluent monitoring, there is a common
12 discharge piping on liquid effluent monitoring from the
13 two units, however there are separate monitors monitoring
14 the waste from the two units. The waste does join in a
15 common piping system before it goes overboard.

16 Auxiliary steam presently on the Unit 2 side
17 together with auxiliary steam from oil fired boilers located
18 on the Unit 1 side by an intercom. We also have a backup
19 from an oil fired package boiler located physically on the
20 Unit 2 side.

21 Our present needs for Unit 2 steam are for
22 turbine sealing maintaining connective vacuum to allow
23 the natural circulation of the reactor core, as our present
24 mode of cooling.

25 Future needs for steam on the Unit 2 side would be

1 most likely for a waste evaporator system and for general
2 decontamination units. The demineralized water storage
3 tank an in balance storage tank, is a common facility be-
4 tween the two units, upon both units. Domestic water supply
5 is a common unit--common facility; likewise, hydrogen and
6 CO₂ supply.

7 The fire protection system including the fire
8 water supply, pumps and piping, and the site organization is
9 by necessity a common facility system.

10 Industrial waste treatment, presently processes
11 a non-radioactive waste from both units. Typical sources
12 on the Unit 2 side are the degenerative building sump,
13 turbine building sump, the tendenaccess (?) gallery sump,
14 Unit 1 auxiliary boiler blow down, Unit 1 and Unit 2
15 pretreatment system and Unit 1 condensate back wash.

16 Again, we don't believe specific action when
17 separation was required due to the normally non-radioactive
18 wastes treated by the system, as well as procedural re-
19 quirements for sampling the waste, that is just before it
20 is routed to the system in every case.

21 MR. ETHERINGTON: This is going into a little
22 more detail than we had scheduled time for. Do you have
23 much more?

24 MR. ELAM: No, I am near the end.

25 Sanitary drains are common; the fuel handling

1 building, the crane is a common machine; make-up work treat-
2 ment, basically we rely on the Unit 1 system to supply
3 Unit 2. Condensate system has an inter-tie which basically
4 returns the condensate to the auxiliary boiler back to
5 Unit 1. River water chlorination is common, lubrication of
6 storage is common. There is a common machine shop that this
7 will be separated as part of the restart.

8 MR. ETHERINGTON: Questions?

9 DR. FOSTER: Is the Rad waste to the river
10 separated now?

11 ME. ELAM: There is a common place but there is
12 separate monitoring.

13 DR. FOSTER: How do you do that?

14 MR. ELAM: We have a monitoring branch from
15 Unit 2 and a monitoring branch from Unit 1.

16 MR. ARNOLD: The confusion on the--perhaps, on
17 the answer is where the discharge actually goes into the
18 river, it's common at that point. But a matter of feet
19 upstream from that, the Unit 1 and Unit 2 discharges go in
20 separately, but they don't go into the river at different
21 points on the riverbank.

22 DR. FOSTER: Thank you.

23 DR. DILLON: You described your hot sample
24 locations in the two reactors, do you have a staff that
25 divides its time between both units, or how do you do the

1 analytical work that is associated with the samples?

2 MR. ELAM: Separate staff.

3 MR. ETHERINGTON: What use will be made of the
4 Unit 2 pool, the spent fuel pool?

5 MR. ELAM: One use would be the installation
6 of the SDS's submerged demineralization system that will be
7 located in the feed spent fuel pool.

8 MR. ARNOLD: Do you want to explain the purpose
9 of it?

10 MR. ELAM: The purpose--the mission of the
11 submerged mineralizer system is treatment of high activity
12 waste. First from the reactor building sump and then,
13 second, from the reactor building system.

14 MR. ETHERINGTON: It is no intention ever to
15 unload the fuel from Unit 2 into the pool, is there?

16 MR. ELAM: I think there could be. That's an
17 open area as part as our recovery studies.

18 MR. ARNOLD: There is two sections to the fuel
19 pool and there is two pools.

20 MR. ETHERINGTON: Yes, sir, I understand that.

21 MR. ARNOLD: Okay. And one of them we currently
22 have 110 thousand gallons of capacity for storage of
23 contaminated water, the other will be used for the submerged
24 demineralizer system installation. It is one possibility
25 or one scenario we're looking that would involve removing

1 the tanks that were temporarily installed and which would
2 not be needed at the at the point that we are ready to bring
3 fuel out of the reactor containment building and use that
4 fuel pool in conjunction with the off loading of fuel from
5 the reactor vessel; but, those plans are not yet firm.

6 MR. ETHERINGTON: I'm sure that will be a question
7 for future review, then, wouldn't it?

8 MR. ARNOLD: I would anticipate it so, sir.

9 DR. LAWROSKI: I understand it from the standpoint
10 of reducing exposure to the sampling points having been
11 provided with adequate shielding, or there will be. And
12 so that aspect of the problem has been reviewed by your-
13 selves and NRC. What about the quality of the samples
14 themselves. Has somebody reviewed those to ensure themselves
15 that they indeed will be representative of what you hope
16 this--

17 MR. ELAM: From the Unit 2 side?

18 DR. LAWROSKI: Well, Unit 1.

19 MR. ELAM: I think there will be a presentation
20 on Unit 1, sir, later.

21 DR. LAWROSKI: Oh, okay. I'll defer that.

22 MR. ETHERINGTON: Thank you, Mr. Elam.

23 Does the staff have any comments on this item?

24 MR. SILVER: Yes, one item. On Page C47 of the
25 SER, we noted the implementations situation as it existed

as of Amendment 8 and stated that the proposed installations modifications will be completed prior to restart which was our understanding of Met Ed's Amendment at that time. In Amendment 9, and this does not change the open item status as recently mentioned earlier, in Amendment 9 the licensee informed us that we--ESF a filter system for fuel handling floor area will not be installed until the first reload after the restart. We have examined this and have concluded this would be acceptable since the fuel would not be handled in the Unit 1 fuel handling building until that reload in any event. On that basis we will accept that implementation date and words obviously in the safety evaluation will be changed ourselves.

MR. ETHERINGTON: Who will review any possible use of Unit 2 pool activities that might affect Unit 1?

MR. SILVER: Insofar as any handling of Unit 2--

MR. ETHERINGTON: Yes.

MR. SILVER: --core, the staff will also do that I'm sure at that time; when there is some understanding of what it is that has to be done.

MR. ARNOLD: Mr. Chairman, right now our technical specifications for Unit 2 require that procedures for performing that type of evolution be specifically approved by the NRC on an individual procedure basis.

MR. ETHERINGTON: Yes, okay, thank you.

1 Let's see, I think Unit--Section--Item 9 comes
2 next; isn't it, Mr. Arnold?

3 MR. ARNOLD: Yes. I would like to introduce
4 Mr. Ed Fuhrer. Mr. Fuhrer is the supervisor of Radioactive
5 Waste Operations for Unit 1.

6 MR. FUHRER: Good afternoon. I would first like
7 to give you a short presentation on the compenents that
8 comprise Unit 1 liquid Rad waste system by way of going
9 over the plot diagram.

10 The system is divided into three general catagories
11 or parts. The first part deals with reactor cooling clean
12 up, the second part deals with miscellaneous waste processing,
13 and the third part deals with the treating of solid wastes,
14 such as resins or wet solid wastes.

15 The reactor coolant core to the system starts
16 with three reactor coolant bleed tanks in which reactor
17 coolant water or borated water of varying concentrations
18 is maintained for the feed and bleed activity. Reactor
19 coolant is collected in one of the bleed tanks and it maybe
20 processed in a number of different ways. It can either be
21 cleaned up by going through three coat filters which would
22 take out solids, suspended solids, or it could go through
23 what we term the demineralizers. Actually, we have
24 filled them with mixed resins. Or we can run the reactor
25 coolant through both of those processees in series and

1 resert that material back to either the same bleed tank or
2 another bleed tank.

3 Another alternative to that would be to process
4 reactor coolant to concentrate it to retain the boric acid
5 for use in another fuel site. And, in that process we either
6 use the same--we use the same clean up capability or if based
7 on sampling, the reactor coolant was of a sufficiently high
8 quality that you would want to save that boric acid you would
9 process the material through the reactor coolant evaporator
10 and retain the boric acid in solution in the retained boric
11 acid tank.

12 This ends up with concentrated boric acid in these
13 tanks and it also ends up with distilled condensate coming
14 off the evaporator and being stored in the condensate storage
15 tanks for ultimate release to the enviroment.

16 In this area there are three inter-ties with
17 Unit 2 to provide addtional flexibility and the processing
18 of station wide waste prior to the accident. The reactor
19 coolant could either be transported via pipe from Unit 2
20 to the reactor coolant evaporator or it could be transported
21 from the bleed tank over to Unit 2 to their reactor coolant
22 evaporator in order to take--make the best possible use of
23 safety equipment. Condensate could either be sent to the Unit 1
24 condensate storage tanks or the Unit 2 condensate test tanks
25 where it would be tested prior to release to the enviroment.

1 Reclaimed boric acid, likewise, can either be
2 transferred to Unit 2 or from Unit 2 to make the best possible
3 use of storage space.

4 The second portion of the system is the miscellane-
5 ous waste portion of the system and that collects non-reactor
6 coolant grade water from a variety of sources. The auxiliary
7 building sump collects four grades and other sump waters,
8 specifically that from the reactor building or from the
9 fuel handling building.

10 Other sumps neutralize waste which would be say,
11 reboric--regenerate solutions from the deborating deminerali-
12 zers or water that had Ph greater than, say nine or less than
13 five would be safe--would be collected in neutralizers waste
14 tanks, would be neutralized through, essentially, a neutral
15 Ph and would then be transferred to miscellaneous waste
16 storage tank along with auxiliary building sump water.

17 Miscellaneous waste storage tank is the central,
18 sort of focal point for the miscellaneous system. Virtually,
19 all the water that has to be processed through this system
20 must be collected in that tank and from there the water will
21 be either processed directly through the miscellaneous
22 waste evaporator or could be transferred through a precoat
23 filter, it would be this line, to the miscellaneous waste
24 evaporator in order to a preliminary clean-up step prior to
25 evaporation.

1 There are two evaporators in Unit 1, the miscellaneous
2 waste evaporator and the RC evaporator and they are located
3 and their piping is such that either evaporator could be used
4 for miscellaneous waste or reactor coolant, depending upon
5 the availability of those pieces of equipment.

6 The bottoms from the miscellaneous waste evaporator
7 will be collected in the condensate waste storage tank for
8 ultimate solidification.

9 Boric acid is found to be off spec, it cannot be
10 reused but also be solidified. The distillate or condensate
11 from both RC evaporator and the miscellaneous waste evapor-
12 ator is processed through a final clean-up step through a de-
13 mineralizer and then stored in condensate storage tanks where
14 they are recirculated, tested, and then released to the
15 environment through radiation and low monitor.

16 DR. FOSTER: Question.

17 MR. FUHRER: Yes, sir.

18 DR. FOSTER: I presume your condensate storage
19 is sampled before you dump it into the river?

20 MR. FUHRER: Yes, sir.

21 DR. FOSTER: What if it's off spec, then what do
22 you do with it?

23 MR. FUHRER: If it is off spec, the piping exists,
24 and I haven't shown it to make the drawing a little bit
25 simpler. To either send it back to miscellaneous waste

1 evaporator for another clean up or to be dumped into the
2 four drains and then go back to the auxiliary building sump
3 and miscellaneous waste storage tanks.

4 As with the RC portion of the system, there are
5 inter-ties that connect to miscellaneous waste systems in
6 the two units. Raw miscellaneous waste can either be sent to
7 Unit 2 for storage or it can be returned to Unit 2 for
8 processing. Unit 2 does not have or did not have a capability
9 of processing its own miscellaneous liquid waste, as before
10 the condensate can be sent to either Unit 1 or Unit 2 for
11 storage and then dumped into the environment.

12 Concentrated waste resulting from the evaporator
13 bottom can be stored in either unit. Solidification is only
14 available, or was only available to Unit 1 and solidification
15 capability would be retained from Unit 1 although it would
16 be replaced by No.2.

17 DR. LAWROSKI: Does that include being able to
18 handle the discarded resin?

19 MR. FUHRER: Yes, sir.

20 The third portion of that liquid waste system is
21 the resin, and use three precoat parts of the system. The
22 precoat filter is a filter that removes particular matter and
23 originally was designed to use diatomaceous earth or some
24 other inter-earth filter aide. We currently use powder
25 resin on the precoat filter--filter, itself and that material

1 is transferred to the precoat storage tank, resins from the
2 various demineralizers are transferred into this kind of
3 resin tank. The liquid that is used as the transfer medium
4 is decanted through a series of pipe that come off the side
5 of the tank and that decant would then be transferred to
6 the miscellaneous waste storage tank for future evaporation.

7 The solid resins and precoats are transferred to
8 solidification on --

9 MR. ETHERINGTON: When you use a precoat resin, do
10 you change the resin when it is chemically exhausted or
11 when it is physically fouled out?

12 MR. FUHRE : Well, that would depend on the prior
13 sampling and what we intended to do with that particular
14 process. There are times when you are looking for removal
15 of ionic material and then based on sampling you take it out
16 of service at the end of then it has reach its break. There
17 are other times when you are only looking for particular re-
18 moval and then you do it based on Delta pressure across the precoat filter.

19 MR. EBERSOLE: Question.

20 MR. FUHRER: Yes, sir.

21 MR. EBERSOLE: When you do such things as this, do
22 you any longer use the air system to process the deminerali-
23 zer resins at the risk of having the incident that started
24 the TMI sequence?

25 MR. ARNOLD: We are talking about two different kinds

1 of systems here and I'll have to rely on Ed. I don't believe
2 that there is any fluffing arrangement with any of the
3 radioactive waste processing.

4 MR. EBERSOLE: Well, have you denied a fluffing
5 arrangement that started TMI series of events? Do you do
6 that any more? Remember that was a case where there was a
7 resin bypass or water backed up into the air.

8 MR. ARNOLD: The condensate polishing system on
9 Unit 1 does not involve a fluffing arrangement. We have not
10 yet addressed the issue of what we will do with the Unit 2
11 condensate clean-up system when it gets to that point.

12 MR. EBERSOLE: So you don't have that kind of
13 operation in Unit 1?

14 MR. ARNOLD: That's correct.

15 MR. FUHRER: That is correct; and in the area of
16 a primary plant with mineralizers that are noted here, only
17 that deep water demineralizer is regenerated, the other three
18 are throw away resins and use them once and you are done.
19 The deep water demineralizer doesn't use an air fluff step.

20 DR. LAWROSKI: Well, if it doesn't--one uses the
21 fluffing step and you use the tube?

22 MR. FUHRER: Pardon.

23 MR. ARNOLD: Unit No. 1 has a precoat filter type
24 of arrangement and not deep bed demineralizers.

25 MR. FUHRER: This is in the condensate polishing

1 out in the secondary point.

2 DR. LAWROSKI: This was a choice of the AE that
3 resulted in the difference, or what?

4 MR. ARNOLD: There was a combination of decision
5 between the architect and the engineer and GPU. I might --
6 pursuing that just a little bit, because I think it is pro-
7 bably of interest to the subcommittee. In the time
8 frame of the design of TMI 1 and TMI 2, there was considera-
9 ble discussion within the industry as to whether the deep
10 bed demineralizers or the polishers were the best approach.
11 Since we had both at Three Mile Island, we did take part in
12 a kind of a research or testing program with the industry
13 to attempt to make some quantitative judgments as to the
14 preferred system, when you had the same set of operators
15 who were caring for both of them. I think the subject
16 may have been commented by some others here that memories
17 may be better on it, but I think the decision was generally
18 the Unit 1 type of installation was preferable.

19 MR. FUHRER: As with the other two portions of
20 the system, the spent resin from Unit 2 would normally be
21 transferred to Unit 1 for the solidification module for
22 ultimate disposal. That capability exists to go back the
23 other way, but good old value served, they didn't have
24 solidification system here.

25 Branch indicated that I would discuss isolation

1 of the various RAD waste systems. The isolation of the
2 two liquid waste disposals systems was required by the NRC
3 Order and essentially as Branch had said, we are relying on
4 double valve isolation rather than a physical cutting of
5 pipe. And, I'm not sure that you wanted me to go through
6 each individual valve. I think that's just a matter of
7 showing the origin of the valve installation.

8 Any questions?

9 MR. ARNOLD: Are you prepared to discuss the
10 samples for upset conditions? Why don't you just get--

11 MR. ETHERINGTON: I guess there are not questions.

12 MR. ARNOLD: Let me suggest that we ask Richard
13 Dubiel, he's the supervisor of radiation engineering at the
14 plant and has been involved with chemistry and radiological
15 controls of the plant for many years, address the sampling
16 both the normal sampling and off normal sampling, I think.

17 We also have the supervising chemist here and
18 hopefully between the three of those fellows, we can cover
19 the items that are of interest here.

20 MR. DUBIEL: I would like to give you just a brief
21 of our plans on the post accident sampling to the reactor
22 cooling system. Our new REG 578 and lessons learned from
23 TMI 2 incident, requires the capability to sample the RCS
24 system reactor coolant system following an accident, must be
25 analyzed for radioactivity of isotopic analysis, chlorides

1 and borons. To comply with the requirements the following
2 factors are being incorporated into the RCS sampling program
3 for post accident sampling.

4 First, the existing sampling system installed in
5 Unit 1 will be used. Second, the procedures for sampling
6 are being revised to incorporate, first of all, the radio-
7 logical concerns of the post accident sampling. The pro-
8 cedures are going to be based on first of all, the initial
9 sampling technique that was used following the Unit 2
10 accident; secondly, the sampling procedures that were
11 developed within the weeks following the accident, were
12 sampling of the Unit 2 reactor coolant system. And, in-
13 corporated to those two procedures or combinations of those
14 two procedures, some of the lessons that we have learned.
15 Specifically, in the area adding long handled--the use of
16 long handled tools, gloves with shielding in the gloves for
17 handling of the samples, specific shielding in the sampling
18 room and particular sampling of the sample coolers, which
19 is the single largest source of reactor coolant within the
20 room, and of course, the use of a portable lead-glass shield.

21 The analytical procedures are not going to vary
22 in technique from the standard methods that are normally
23 employed. Specific radiological concerns for each of the
24 sampling, the analytical techniques however are going to be
25 incorporated into the procedures.

1 Long term basis we expect to incorporate the
2 use of an on-line boronometer, for RCS boron analysis, and
3 to review the existing sampling system to determine if
4 additional modifications can be made to further improve our
5 capabilities.

6 That's all the prepared remarks that I have;
7 are there any questions in this area?

8 DR. DILLON: Yes, I've got a couple things that I
9 wanted to discuss briefly. In the first place, the precise
10 objectives of the post accident sampling are mildly obscure
11 at this point. You people better than anybody else in the
12 world, I guess, have a pretty good idea of what you really
13 got a value to see from. I would like to have some comments
14 about where you got most of the information from these
15 post accident sampling processes and then anything that that
16 might relate to in terms of your sampling capability or
17 modifications you recommend on that.

18 MR. DUBIEL: I am not sure that I understand
19 what--

20 DR. DILLON: Well, tell me first what you got out
21 of the sampling program that is of greatest value to you in
22 estimating the condition of the plant.

23 MR. DUBIEL: In other words, the value came from
24 reactor--

25 MR. DILLON: Yes.

1 MR. DUBIEL: Of course, from the immediate response
2 I think, the most important factor was the boron. To
3 determine the status of the--what the reactor of the core
4 was or could become critical, in other words, shutdown
5 margin.

6 I think from the activity standpoint, the
7 important factor there is not the activity that is in
8 the coolant system, but rather that activity which is
9 escaping, so I think I would probably put the reactor coolant
10 system activity as a lower priority to the monitoring of
11 that activity which escaping or leaving the center.

12 MR. DILLON: Volatile, primarily, is what you are
13 talking about?

14 MR DUBIEL: Correct. And, as far as the--any
15 additional factors--well, in reference to our specific
16 sampling capability after the Unit 2 accident, we did not
17 work for chlorides. I think, we--I would personally
18 question the value of the chloride analyses to the
19 immediate period after an accident, specifically what one
20 would do with the information if one were to obtain it for
21 values and obviously would be valuable from a long range
22 standpoint.

23 MR. ARNOLD: Let me ask for Mr. Keaton to comment
24 on that also.

25 MR. KEATON: One other thing that we were very

1 concerned with in the early days, was the results of the
2 uranium analysis of the sampling, because we were trying to
3 get information of whether the fuel likely had remained
4 within the reactor vessel or whether there was a possibility
5 was uranium distributed to the primary system.

6 DR. DILLON: One other thing. I probably should
7 know this, but since I don't, what kind of specific activities
8 were you dealing with early in the--

9 MR. DUBIEL: The early samples range from
10 approximately 100 microcuries per millimeter. That is the
11 total activity in a cooled sample, depressurized sample.
12 To approximately 1,000 microteries per mil in the three
13 to four hour period and then in the following day, I think,
14 we are up a couple orders of magnitude.

15 MR. KEATON: I think we had at least one that was
16 up in the order.

17 MR. DILLON: And you really think you got enough
18 protection to do the job with long-handled tools and shield-
19 ing. Do you need, essentially, a cage to deal with this?

20 MR. DUBIEL: Looking back at the techniques that
21 were employed following the accident, we did end up with
22 one whole body over exposure and several extremities over
23 exposures. In each case, the over exposures were not by
24 orders of magnitude, but rather by a small factor.

25 I personally feel looking at the radiation levels

1 that with the techniques that can be incorporated with,
2 first of all, long-handled tools and shielded gloves, and for
3 the whole body case, shielding the sample core, because we
4 do believe that was a major external whole body source, that
5 we could stay within the limitations; the extremity and the
6 whole body limits.

7 DR. LAWROSKI: What has been your experiences as to
8 the introducability content of two consecutive samples, which
9 are not in the RCS; what set-up do you have?

10 MR. DUBIEL: During normal operations?

11 DR. LAWROSKI: No, after the accident.

12 MR. DUBIEL: Well, of course, the reproducibility,
13 I think, is not easy to define because we could not, during
14 immediate period take two samples in a period of time that
15 one would expect us to find some of these results. From a
16 normal operations standpoint, I would say that the produca-
17 bility is very good. We have fairly good confidence in our
18 system to accurately portray the system.

19 DR. DILLON: Is there any value --

20 DR. LAWROSKI: Has this been recorded anywhere?

21 DR. DILLON: Excuse me. Is this information
22 available in any of your reports that would indicate the
23 reproducibility --

24 MR. ARNOLD: All analysis' results are available.
25 I think they are probably a part of the public record at this
point.

21 1 But, certainly any of them, in fact, I am sure we have sub-
2 mitted all of them to the NRC.

3 DR. DILLON: Is the information you have
4 representative of the entire liquid inventory that you are
5 really interested in, or are you sampling only one portion
6 of the primary system in such a way as to not give you a
7 knowledge of what is a sump and all that sort of thing.?

8 MR. DUBIEL: Of course, the sampling I am addressing
9 is strictly reactor coolant system. And that includes
10 the RCS system proper and the pressurized. It does not
11 address the reactor building sump.

12 DR. DILLON: Now, did you need that? Would that
13 information be worth the problem of advising sampling
14 systems that would accommodate them.

15 MR. ARNOLD: The reactor coolant sample--

16 DR. DILLON: In the sumps, anything that escaped
17 the various parts of the containment system. I want to know
18 if we have--is one sample sufficient to deal with the
19 inventory of activity that you may need to have information
20 about.

21 MR. ARNOLD: As I understand your question, it
22 relates to the typicalness of the containment building sump
23 sample, if what we are doing is obtain a sump--a sample
24 from a sump area and the building in general was flooded to
25 some depth. I don't think there is any argument that the

26

1 exact sample has less reliability to it in terms of repre-
2 senting average conditions. We have in the way of a data
3 point on that that a sample taken at three different
4 elevations at one particular location--

5 MR. MULLER: Can we stop it for just a second, so
6 that she may change the tape?
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

1 MR. ARNOLD: The one data point we have on uniformity
2 is at a particular location in the building, but at different
3 elevations at that cross-section of the building through
4 about 6 feet of flooding. And, there's very little difference
5 in analysis results at those three different elevations.

6 There is some question among us as to whether we're
7 looking for consistency of the analyses of the sump water
8 to the reactor coolant system, a correlation there, or if
9 we're just looking for the desirability of knowing what the
10 average analytical result is throughout the building's flood
11 area.

12 Maybe you can clarify that for us, please.

13 DR. DILLON: I'm not sure that I can either. This
14 is partly fishing rather than anything else.

15 I wanted to ask a little bit about the sampling
16 system itself. Do you have some sort of a pump or something
17 that was available to take samples from the containment
18 system?

19 MR. ARNOLD: No, we had to modify a spare penetration
20 so that we could go in and obtain the sample that I referred
21 to. We are, as one of the long term items, modifying the
22 sump piping system so that we can take a sample from the
23 reactor building sump. But, it would be a specific location
24 within the building and I guess I'm not prepared at this time
25 to address how much less desirable it is to have that one

1 point than to have maybe four points or five points around
2 the building.

3 DR. DILLON: I appreciate that.

4 One other comment or question: what about solids
5 in this material? Was there any evidence of solid material
6 like fragments of paint, something of this sort, that might
7 have complicated the sampling process under different con-
8 ditions?

9 MR. ARNOLD: The samples that we took were centri-
10 fugal for solid material and let me check our record -- common
11 recollection on how much there was.

12 We'll get that data for you for tomorrow.

13 DR. DILLON: All right, sir.

14 May I ask another question while we're at it:
15 will this discussion treat gaseous samples or will we treat
16 that specifically somewhere else?

17 MR. ARNOLD: Can you address that?

18 MR. DUBIEL: I can address that -- referring to
19 containment atmospheres. Let me address that separately --
20 I did not prepare specifically for that area, but the plans
21 in that particular area -- our sampling system in Unit 2
22 proved to be quite valuable. We were able to take what we
23 believe to be very representative samples and get accurate
24 hydrogen concentrations.

25 The system in Unit 1 is extremely similar; they

1 were built by the same manufacturer. The sample panels for
2 each of the containment monitors were both designed by
3 Met Ed and they're patterned after one another.

4 We feel right now that the sampling capability
5 exists to obtain containment air samples and to perform the
6 hydrogen analysis. The only major concern is the radiological
7 concerns in drawing the sample. We don't believe that the
8 concern would be to be able to get the sample without
9 overexposing anyone since we are able to do it in Unit 2
10 in just that manner. But, rather just to reduce the exposure
11 to as low as possible.

12 DR. DILLON: Is this design something that is
13 fairly common in the industry or is it something unique?

14 MR. DUBIEL: I believe it's very common in the
15 industry to sample-tap off the normal building ventilation
16 system.

17 DR. FOSTER: Along that line, could you give us
18 a feeling for the length of the sampling line and how long
19 the sample takes to get from the point of pickup to the point
20 of analysis and the material that that line is made of?

21 MR. DUBIEL: You're referring to the containment --

22 DR. FOSTER: In this case, yes.

23 In other words, the basis of the question is how
24 much are you losing by play out in the sampling line from
25 the time between where you took the sample and when you ended

1 up analyzing it?

2 MR. DUBIEL: I believe the sample lines are stain-
3 less steel, but I can't be positive on that. The length
4 of line, let me approximate it, is relatively short. The
5 sample tap is right at the outer wall of the containment
6 building and I would estimate that a sample runs from the
7 containment to the monitor of approximately 40 feet, and
8 I think I'm being on the conservative side taking into
9 account the bends and elbows.

10 DR. DILLON: Now, is this under normal circumstances
11 from the circulating line that you tap off of?

12 MR. DUBIEL: Yes, it is.

13 DR. DILLON: And what about during the accident
14 situation?

15 MR. DUBIEL: During the accident, of course, the
16 monitoring system is isolated. We would have to bypass
17 the isolation valves to continue -- the normal building cool-
18 ing system, of course, would have to be in operation and
19 the sample line is into the return duct to the normal
20 building coolers.

21 DR. DILLON: Let me apply the same question to the
22 liquid sample; is it also a recirculating line under --

23 MR. DUBIEL: Yes, it is.

24 DR. DILLON: And was it circulating during the
25 accident condition, too?

1 MR. ARNOLD: This is the sample from which post
2 accident?

3 DR. DILLON: The core.

4 MR. DUBIEL: Specific to the Unit 2 incident, the
5 sample line normally is not under resurp. The resurp is
6 established prior to drawing the sample. We have a specified
7 resurp time before obtaining the sample.

8 Following the reactor trip, we have a test spec
9 that requires us to take an ACRS sample within four hours
10 and it was our resurp at the time of the increased activity.

11 If there are no other questions, then thank you.

12 MR. ETHERINGTON: Does the Staff have any comments?

13 MR. SILVER: Only that we hear some of this for
14 the first time ourselves. There has been no formal sub-
15 mittal from the licensee in this area as of yet that the
16 SER reflects. And I believe that some date in February
17 has been promised, mid-February. We as yet have not re-
18 ceived any submittal.

19 MR. ETHERINGTON: Mr. Arnold?

20 MR. ARNOLD: Yes, sir. I think we are now on
21 agenda item 3 for operating procedures and I'm sorry, I
22 just dispatched him to the telephone. But, Mr. Herbein
23 will be back very shortly and will pick up --

24 MR. ETHERINGTON: Would you like to pick up a later
25 item?

1 MR. ARNOLD: Yes, I would be happy for us to pick
2 up item number 6 at this point, if we could, Mr. Etherington.
3 Mr. Lawrence Lawyer who is the manager trainee at Three
4 Mile Island will make this presentation.

5 MR. LAWYER: Good afternoon. I'm Sandy Lawyer.
6 The subject is training.

7 I'll briefly describe for you seven of the train-
8 ing programs which we're developing and conducting. Some
9 of these represent extensive changes to the previous programs
10 while others are totally new programs planned in response
11 to the TMI 2 accident.

12 First of the programs is the license operator
13 training program. To further enhance the TMI 1 reactor
14 operator and senior reactor operator performance, TMI
15 committed in Section 6 of the restart reports to conduct an
16 accelerated operator retraining program. This I'll refer to
17 as the OARP, Operator Accelerated Retraining Program.

18 The major objectives of the OARP include an
19 improvement of operator performance during small break
20 LOCA's; assurance that the operator can recognize and respond
21 to conditions of inadequate core cooling; assurance that the
22 TMI 1 operators have an indepth understanding of the TMI 2
23 accident and the associated lessons learned; assurance that
24 the operators are provided with an indepth understanding of
25 the methods required to establish and maintain natural cir-

1 culation --

2 DR. CATTON: Excuse me. Are you going to give us
3 a little bit of a discussion of how you're going to assure
4 these things, such as the indepth understanding of the
5 accident?

6 MR. LAWYER: Yes, I can. In answer to that question
7 in particular, these are the objectives of the training
8 programs. These objectives are then incorporated into
9 individual training lessons and then we make measures to
10 assure that we have met the objectives.

11 Does that answer your question?

12 DR. CATTON: No. One of the things that I was
13 interested in knowing is how you have changed your past
14 program to this assurance?

15 For example; are you giving more attention to the
16 actual physical processes that go on or are you just giving
17 more training?

18 I am trying to contrast training with education.

19 MR. LAWYER: Yes, okay.

20 For the transmission of the knowledge of the operator
21 into the plant, several things have been done; and I don't
22 have these well-thought out, so I will stumble a little.

23 One piece of it which we had not previously done
24 or had not overtly previously done was to take the student
25 group into the control room so that after some of the present-

1 Mr. Chairman?

2 MR. ETHERINGTON: Yes, continue.

3 MR. LAWYER: Thank you.

4 As I was beginning to say, there are two external
5 committees which we utilize: One is a group of professorial
6 people from Penn State headed by Dr. Warren Witsig (?) and
7 those are all Penn State people on the staff at Penn State.

8 The second group is more of a mixed group, and
9 in their academic expertise or their areas of expertise, and
10 in their geographical location. I don't know quite why I
11 mentioned that to you, but I do. That second group has on
12 it, on that, and we have them as a committee, a human
13 factors engineer, a psychologist, a dean of a school of
14 engineering, a person who is now the vice-president of
15 research for a utility who was previously the dean of a
16 school of engineering, and a person somewhat like myself
17 in the manager capacity in training at a utility.

18 Those two groups in their feedback to us on
19 whether we have met the objectives for the course and for
20 the individual lessons will give me the confidence that we
21 have achieved the objectives.

22 I have no idea whether I have satisfied your
23 question now.

24 DR. CATTON: Well, that is a distinct improvement.

25 MR. LAWYER: Certainly, I would hope so.

1 ations, the group went into the control room, talked about
2 the physical locations of the various instruments and
3 controls. That was a translation into the plan.

4 What immediately occurs to me primary or major
5 enhancement to the program or at least in my comfort with
6 the program, is that whereas previously the experienced
7 reactor operators and people with experience in training
8 had been presenting the courses. We beefed this up with,
9 in each case -- in case of each lesson, we had both a
10 primary instructor and a backup instructor, so that we made
11 liberal use of vendors who were from B&W, for example. Also
12 the other kind was people from the training -- community
13 training centers.

14 In addition to that, and probably my greatest
15 assurance, comes from two committees that we utilize.
16 These were, in each case, people external to the GPU system
17 which were formulated. One of these consists of a purely --
18 let me start, restate that -- consists of people who are --

19 MR. ARNOLD: Mr. Lawyer: I would like to ask for
20 a short recess for a minute to discuss something with you,
21 Mr. Etherington?

22 MR. ETHERINGTON: For the record, the little pri-
23 vate conversation that we have had, Mr. Arnold has had a
24 personal misfortune and is excusing himself from the meeting.

25 MR. LAWYER: Is it appropriate that I continue,

1 DR. CATTON: I would like to know, however, if you
2 could contrast for me the amount of time that would be
3 spent on basic subjects such as fuel mechanics, aerodynamics,
4 ample feed flow through your system, and so forth, before
5 and now: energy transferred. Is it twice, three times, or
6 what?

7 MR. LAWYER: What immediately occurs to me is a
8 ratio of now to just prior, and I cannot give you the entire
9 history, but that ratio just from now to just prior cannot
10 be obtained; that is an indefinite number because the just
11 prior was very nearly zero.

12 It is -- one-sixth of this program concerns itself
13 with things like thermodynamics and heat transfers and fluid
14 flow. That is the first module of the program which --

15 DR. CATTON: So the ratio is a large number?

16 MR. LAWYER: Yes.

17 DR. CATTON: Thank you.

18 MR. LAWYER: A very distinctive improvement in
19 that area.

20 DR. CATTON: That is what I was driving at. Thank
21 you.

22 MR. EBERSOLE: Before you go on, I guess I was
23 impressed by the absence of, say, a B&W system's engi-
24 neer and architect engineer -- a system's engineer in making
25 these assessments of adequate audit operator training.

1 Do you not have any representatives from these
2 people?

3 MR. LAWYER: We had participation from those --
4 not the architect, the engineer. We had participation in the
5 individual program, but not on the two committees that I
6 spoke of.

7 MR. EBERSOLE: Not to do the check work, but you
8 had involvement by the AE and the vendor system's engineers
9 in the formation of the program; is that right?

10 MR. LAWYER. I cannot answer your question about
11 the AE; I can about the vendors.

12 MR. EBERSOLE: You understand that I am trying to
13 get some sense of integral systems analysis into this
14 training program.

15 MR. LAWYER: A couple of the engineers were involved
16 in the AE capacity. I think that is safe to say.

17 MR. HERBEIN: Just to make a point, with regard
18 to the architect engineers, you know now that we have merged
19 Met Ed and the service company capabilities. The service
20 company engineers, in many cases, do the function that
21 typically in the past Met Ed relied on the architect engineer
22 to do. And I think that is typical in the training areas.
23 There have been interactions with our engineering home office
24 force and the training department. And I think they have
25 played a rather strong role in putting together portions of
the training program.

1 MR. EBERSOLE: Then the check group really were
2 checking against some pre-established instructions.

3 In other words, you are checking function against
4 training. They had considerable literature and documentation
5 against which to perform their checking function.

6 MR. LAWYER: Yes.

7 MR. EBERSOLE: Thank you.

8 MR. LAWYER: At the point that I am here is part-
9 way through the objectives that we laid out for the course
10 and those objectives have guided the instructor and the back
11 up instructor in the preparation of their materials.

12 DR. LAWROSKI: Does this added training and
13 education, if I may put it that way, apply also to the main-
14 tenance people or just to the operating personnel?

15 DR. LAWYER: Yes, it did also apply to maintenance
16 people or just to the operating personnel?

17 MR. LAWYER: Yes, it did also apply to maintenance
18 people.

19 DR. LAWROSKI: They too are given enough
20 educational material to better appreciate the importance
21 of some of the things that they are doing in the reliability
22 of that plant?

23 MR. LAWYER: Yes, the importance of the system
24 and the importance of returning that system to operation,
25 the importance of isolation and that sort of thing.

1 MR. HERBEIN: Mr. Laworski, we are also upgrading
2 our maintenance training programs significantly from what
3 we had prior to the accident.

4 I would, however, point out the content of the
5 maintenance traning programs is not the same as the six
6 module program that Mr. Lawyer described for the operator
7 retraining.

8 DR. LAWROSKI: Yes, I appreciate that.

9 I was curious as to how much upgrading in the
10 maintenance people who have a great deal to do.

11 MR. LAWYER: The maintenance people we have --
12 we have an organized program which was started, well, within
13 its entirety will be a two-year program, the second six
14 months of that program is devoted to systems training, the
15 sections we were discussing. That began, I think, the first
16 of November of last year.

17 DR. LAWROSKI: But, it was frequently the case, but
18 maybe not in your utility but in others, that people who were
19 going to be on the -- were expected to be coming out as
20 operators, started off in some aspect of maintenance, or
21 well, operations -- portions of the plant that had -- did not
22 relate to the reactor itself.

23 Is this still the case?

24 MR. LAWYER: I do not refute that. My experience is
25 not broad enough to support it. Basically, my experience --

1 DR. LAWROSKI: You know what I'm driving at. I
2 have read where people say that --

3 MR. HERBEIN: Mr. Lawroski, I think I can address
4 that.

5 DR. LAWROSKI: The first place that somebody is
6 assigned as the beginning point for his future as a reactor
7 operator was to deal with the rest of the demineralizer
8 operations.

9 MR. HERBEIN: Sir, our operations personnel come
10 into an entry level auxiliary operator position, train there
11 for a year, take an examination, progress to the next level
12 and then the next over a two-year period. And, then they
13 become eligible for control room operator consideration.

14 So they all have at least two and a half years of
15 operations experience out in the plant before they progress
16 to the control room operator position.

17 MR. LAWYER: I had not referred to those as main-
18 tenance; I misunderstood.

19 DR. LAWROSKI: Well, I guess it wouldn't have been
20 correct. It is more than maintenance, because it is the
21 auxiliary operators, too, that form another group of people.

22 MR. LAWYER: That is one of the seven programs.

23 DR. CATTON: In your response to NRC, supplement
24 1, part 2, there is some fairly elementary kinds of questions.
25 One has to do with to estimate conservative steam generator

1 fill times for TMI 1 due to the uncontrolled condition of
2 auxiliary feed water to one steam generator.

3 When you complete your training program, your
4 modified training program, are your operators going to be
5 able to address questions like that?

6 Another one might be, I think it is question 4;
7 the formula development examining calculated heat rates from
8 primary to secondary for a given cool down rate. Are your
9 operators going to be able to do those? These just require
10
11 simple algebra and an understanding of heat balances.

12 MR. HERBEIN: I'm not sure that our operators would
13 be able to do that.

14 We will have, on each shift, a shift technical ad-
15 visor, advising each shift supervisor and he certainly, when
16 we have completed all our training for him, would be able to
17 perform those kinds of calculations.

18 DR. CATTON: My interpretation of your answer is
19 that your operators are then going to be further trained,
20 that you are going to supplement your operator with somebody
21 who has a little more education; is that a correct interpre-
22 tation?

23 MR. HERBEIN: That is correct. We do have six
24 shift technical advisors who, in fact, are all degreed
25 engineers assigned to each of our six shifts.

1 They do not report directly to the shift supervisor
2 as far as operations; they report to our engineering manager.
3 However, they are available as an advisory group to the shift
4 supervisor on each shift, with the primary emphasis on oper-
5 ating experience assessment and accident assessment functions.

6 DR. CATTON: Thank you.

7 MR. LAWYER: I am not quite sure if I am done or
8 if I have just begun.

9 I am sorry; some of this is going to be redundant,
10 now, and I will not be able to control it very well. I am
11 into the objectives of the OARP, the Operator Accelerated
12 Retraining Program.

13 The next one is assurance that the operators are
14 provided with the review of major administrative normal,
15 abnormal, and emergency procedures. And lastly, assurance
16 that the TMI 1 operators receive training on the B&W sim-
17 ulator covering the TMI 2 accident.

18 The OARP included material that was beyond the scope
19 of the various parts of the order dealing with operator
20 training. This material includes training in heat transfer
21 fluid dynamics, plant transient response, and plant safety
22 analysis, and therefore, provided operators --

23 DR. CATTON: Yes, but I do not understand. You just
24 said that your operators were going to be trained in heat
25 transfer and so forth?

1 MR. LAWYER: Yes, sir.

2 DR. CATTON: Maybe we are missing the point here.
3 The questions that were addressed that I just referred to
4 in my mind are extremely simplistic heat transfers.

5 And, if you have given them any heat transfer, I
6 would think your operators could address those questions; or
7 are we again missing the boat and I am misinterpreting
8 what you are saying.

9 MR. LAWYER: It is not what I have said that you
10 have misinterpreted. We do not --

11 DR. CATTON: Then what Mr. Herbein said.

12 MR. LAWYER: Yes. We have not prepared an answer on
13 it. That is a matter of judgment as to whether in the long
14 term those calculations can be performed by the operator.
15 That is my view. Mr. Herbein is saying that is that what
16 is certainly true & they have been trained in that, but
17 Mr. Herbein said that irrespective of whether they have the
18 retaintivity and can perform this at some time you specify
19 in the future prior to their retraining, we have a person
20 on the shift certainly who can and in more detail probably
21 than what you are asking here.

22 MR. HERBEIN: Sir, we do expect our operators to be
23 able to make primary heat balance calculations, secondary heat
24 transfer calculations, the UA delta T kinds of things and that
25 was addressed in the module that Sandy discussed on heat trans-

1 fer and fluid flow thermodynamics.

2 MR. LAWYER: Continuing, this training also exceeds
3 the firm NRC recall training requirements.

4 DR. CATTON: One more question: is it possible
5 for us to see those modules?

6 MR. HERBEIN: Certainly, sir, that is possible.

7 MR. LAWYER: By module, you mean --

8 DR. CATTON: I am not sure what I mean. I am
9 assuming that that would be an outline that would tell me the
10 number of hours and so on and so forth.

11 MR. HERBEIN: A good bit of that information is
12 available in the restart report in the chapter that relates
13 to training.

14 If you would like to see the lesson plans and the
15 detailed information that went into each module, that is
16 certainly available. It is rather voluminous, though.

17 MR. LAWYER: Listed in that restart report is
18 basically the title of each of about one hour --

19 DR. CATTON: Let me take a look at the restart
20 report and I will let you know tomorrow morning whether I
21 want the volumes.

22 MR. HERBEIN: All right, sir, fine.

23 MR. LAWYER: Section six.

24 DR. CATTON: Section six then it is.

25 MR. LAWYER: The OARP was scheduled in six modules

1 conducted at the site and one module conducted at the B&W
2 simulator in Lynchburg, Virginia.

3 The program incorporated a system of evaluation
4 to insure that the objectives were met and provided for a
5 company administered audit exam conducted by an independent
6 group; that is, independent of the GPU system, an outside
7 group.

8 The OARP scheduled for the seven modules has been
9 completed. The audit examination is scheduled in April and
10 May of this year. The time period between completion of the
11 OARP and the NRC exams has been scheduled to repeat those
12 lectures which were judged to have not fully met their
13 objectives, and to provide additional safety analysis train-
14 ing and to review the modified systems and procedures prior
15 to restart of Unit 1.

16 The program for licensed operators will have met
17 the letter and intent of the order by June 1, 1980.

18 The second program which I would like to address
19 is the auxiliary operator training, or what we discussed as
20 maintenance people before. The order does not specifically
21 mention the non-licensed auxiliary operator training.
22 However, as much as these operators have a responsibility
23 for operations in the plant, a retraining program with the
24 following objectives will be conducted.

25 One, to indoctrinate the auxiliary operator in

1 newly modified systems and procedures; and secondly, to
2 provide refresher training for the auxiliary operator prior
3 to Unit 1 restart.

4 The third area is senior reactor operators. And
5 this is -- senior reactor operators also participate in the
6 OARP. Senior reactor operators -- to emphasize and reinforce
7 the responsibility for safe operations in the management
8 function of assuring safe operations, a senior reactor
9 operator's precision analysis course was formulated with
10 objectives in two areas: the areas are decision analysis
11 and shift supervisors command role.

12 The objectives in the decision analysis were to
13 improve the performance in dealing with situations that have
14 not previously been encountered and for which written
15 procedures do not exist. Secondly, to assure a good under-
16 standing of how to use basic decision analysis techniques
17 including the handling of uncertainties.

18 The second area in the senior reactor operator
19 decision course, as I mentioned, was the shift supervisor's
20 command role. The objectives of that portion are to assure
21 that the shift supervisor maintains a broad overview of his
22 command at all times and makes decisions and gives directions
23 as required to assure safe and reliable operations. So,
24 the second one is to assure that the shift supervisor has
25 a thorough knowledge of physical and personnel resources

1 available to him from within and without the company; ones
2 that could be utilized and in addition, to assure that he
3 has the knowledge of when and how to obtain these resources.

4 The third objective of that portion is to assure
5 that proficiency of the shift supervisors at oral and written
6 communications for issuing clear and concise directions and
7 for giving effective status reports to their management.

8 The fourth and last: to assure the shift super-
9 visor has sufficient command and company perspective to
10 effectively carry out the emergency directors' responsibilities
11 until properly relieved of those responsibilities.

12 This program is scheduled to be conducted during the
13 weeks of February 25, March 3, and 17th. The initial program
14 will be conducted by an outside contractor. The program
15 will be evaluated on a short term and long term basis to
16 determine if the objectives were met.

17 In order to provide for replacement SRO's and to
18 maintain the ability of existing SRO's, a permanent program
19 is being developed and initiated.

20 The fourth major area: shift technical advisor,
21 to which we referred a few minutes ago. The shift technical
22 advisor positions have been established in the operating
23 organization and the billets have been filled with personnel
24 having bachelors' degrees in a scientific or engineering
25 discipline.

1 To qualify the personnel for the position, a
2 generic training program was established; that is, generic
3 to all of those six people. The six engineers assigned
4 were then interviewed and a program specific to each one
5 was established.

6 These personnel are currently pursuing that program.

7 The fifth area is emergency plan training. The
8 view on emergency plan has been revised to reflect recommenda-
9 tions from various regulatory documents and reports. A train-
10 ing program to support the implementation of the plan has
11 been established. It consists of three phases: phase one
12 is basic indoctrination into planning. Phase two is
13 instructions in the implementing procedures; and phase three
14 is the emergency plan drills. The training program is current-
15 ly being conducted. All personnel who support the plan have
16 received or are scheduled to complete the basic indoctrination
17 in February.

18 After plant operation review committee approval of
19 the implementing procedures, a schedule for phase two and
20 phase three will be promulgated. We expect phase three,
21 the emergency drill, to be conducted in March.

22 The general employee training program is also being
23 revised to reflect this new plan.

24 The sixth area is management training. A require-
25 ment for a training program for management personnel has

1 been identified. The program is currently under development
2 and the course content will include, but not be limited, to
3 test specs, the Kemeny Commission report, the operational
4 quality assurance plan, the TMI emergency plan, health
5 physics, decay heat removal and heat transfer mechanisms
6 including core decay heat generation, and lastly, safety
7 analysis.

8 Management personnel are currently involved in some
9 of the training that I have just discussed and a formalized
10 program is in the process of being developed.

11 The last area of the seven is health physics. Health
12 physics technician training program has been revised to make
13 the training more comprehensive. The areas of concern for
14 accurately measuring the iodine concentration throughout
15 the plant under accident conditions will be addressed in
16 that program. The technicians will receive training on their
17 equipment and procedures. Those were the two areas of concern
18 expressed.

19 Now, questions?

20 MR. ETHERINGTON: Does the Staff have any comment?

21 MR. LAWYER: I apologize for the redundant sections.

22 DR. CATTON: Just that -- would it be possible if
23 we finish at 12 o'clock tomorrow maybe to go out and take a
24 look at some of these and not have to carry all the volumes?

25 MR. LAWYER: The materials?

1 DR. CATTON: Yes. Where are the located?

2 MR. HERBEIN: They are at the plant, sir. We had
3 planned to bring some of the volumes here to let you look at
4 tomorrow morning and if after we are finished with our
5 session tomorrow you would like to see more than the two or
6 three --

7 DR. CATTON: I would just as soon look at them here.

8 MR. HERBEIN: We will bring them out here for you
9 tomorrow morning.

10 DR. CATTON: Okay, thank you very much.

11 MR. ETHERINGTON: Mr. Herbein, we missed your item
12 3 on operating procedures, I think.

13 MR. HERBEIN: I understand, sir, and I am ready
14 to proceed with that.

15

16

17

18

19

20

21

22

23

24

25

1 MR. HERBEIN: I had some general remarks that
2 I would like to make to update the Committee on our
3 procedural effort to date. Following that I think we
4 could go down the agenda items, if that would be acceptable?

5 The Group 1 emergency operating and surveillance,
6 as well as, administrative procedures which we committed
7 to revise, prior to TMI startup, are listed in chapter 3
8 of the restart report.

9 These revised procedures will incorporate the
10 lessons learned, the requirements of the I and E bulletins,
11 7905 A, B, and C, and the TMI 1 shut down order notice of
12 hearing requirements.

13 All of the Group 1 procedures have been through
14 the review, revision, and approval process at least once.

15 With regard to emergency procedures, they had
16 been revised to incorporate an objective statement that
17 will focus operator attention on the key requirement to
18 keep the core properly cooled.

19 For example, the objective statement in the
20 small break LOCA procedure, outlines the procedure
21 objective to trip the reactor, determine whether a LOCA
22 or over cooling event has occurred, establish natural
23 circulation, conserve RCS inventory, keep the core covered
24 and cooled by maintaining 50° subcooling.

25 Remove heat through the steam generator, and achieve

1 a cold shutdown condition while minimizing radioactive
2 release to the environment. Emergency procedure follow-
3 up actions require the reverification of key manual
4 actions steps using available redundant instrument
5 indications.

6 These reverification steps cover automatic start
7 of HPI pumps, verification of automatic feed pump start,
8 with feed pressure greater than a thousand pounds, feed-
9 water emergency valves 30 A and B open, increasing emer-
10 gency feed flow and steam generator level increasing to
11 50% or 30 inches with reactor coolant pumps off or on,
12 respectively.

13 Follow up action steps in the emergency procedures
14 must be initialed by the operator to verify completion.
15 For example, initials are required after each of the listed
16 23 reactor building isolation valves which automatically
17 close on reactor trip.

18 All emergency procedure notes and cautions will
19 be blocked to insure that they are fully marked and stand
20 out to the operator using the procedure.

21 In the process of our procedure review and
22 revision, we divided our original loss of coolant procedure
23 into three procedures.

24 These procedures basically address small, inter-
25 mediate, and large reactor coolant system breaks.

We have incorporated B&W's revision of guidelines that came out November 5, 1979 for small breaks into our loss of coolant procedures.

Additionally, we have prepared a new procedure entitled, Inadequate Core Cooling. This procedure also incorporates B&W's guidance which came out in November of 1979.

Surveillance and maintenance procedures are being reviewed and revised as necessary to insure the redundant safety system train is operable prior to removal of any safety related systems from service for maintenance.

Additionally, that no more than one safety system is defeated at a time and finally, that safety systems are checked for operability prior to return to service following maintenance or surveillance testing.

Surveillance procedures are being prepared to insure the added safety feature modification, such as emergency feed pump, auto start, manual control of feed valves, reactor building isolation on reactor trip and high radiation, as well as emergency power to pressurizer heaters maintain a continued state of reliability by periodic surveillance testing

Operating procedures are being revised to

incorporate the bulletins, NUREG, and shutdown order requirements, as well as the safety feature system modifications currently in progress.

Additionally, a procedure titled, Reactor Coolant System Natural Circulation Cooling, has been prepared.

Administrative procedures are being revised to require operator completion of an independent check list encompassing valve and breaker lineups within maintenance work boundaries in order to return either an ESFAS or an EFW system to operational status following maintenance.

This checklist will receive two independent review and signature verifications for correctness before it is actually used in the field to align the system following maintenance.

Additionally, independent second operator, valve alignment verification for ESFAS and EFW systems will be accomplished according to check lists following maintenance, surveillance testing, and operations governed by special operating procedures.

In the area of watch relief and turnover procedures, these have been developed and incorporate both ESFAS and EFW system valve and switch position, alignment check lists, which are signed by both the oncoming and

1 offgoing control room operators.

2 Additionally, inplant log sheets indicating
3 both the required and as found EFW and ESFAS valve posi-
4 tions are completed by auxiliary operators.

5 These log sheets insure that these valve positions
6 and major system flow pass that do not have control room
7 position indications will be verified and recorded on
8 log sheets at least once per day.

9 To insure that the specific requirements of the
10 bulletins, shutdown order, and NUREG are incorporated into
11 all of our procedures, we have assembled a matrix which
12 documents the various requirements and the procedures
13 in which these requirements must be stated.

14 This will insure that items such as the need
15 for verifying 50° subcooling prior to overriding high
16 pressure injection, the new power operated relief valve
17 and high pressure trip set points and the immediate
18 manual trip of reactor coolant pumps on automatic ini-
19 tiation of high pressure injection, are appropriately
20 incorporated into the operating emergency surveillance
21 and administrative procedures.

22 In addition to incorporating the guidance
23 specified in the documents mentioned, we are going to
24 insure that our operators are thoroughly trained in all
25 new procedures and procedure revisions. During future

1 annual operator simulator training, the actual plant
2 emergency procedures will be utilized by our operations
3 personnel. When applicable, changes will be made to
4 emergency procedures based on this experience.

5 Additionally, we expect to incorporate B and W's
6 recommended abnormal transient operating guidelines into
7 our emergency procedures.

8 These guidelines are currently under preparation
9 and are expected to be available in draft form in the
10 near future.

11 Now, that concludes the general remarks. I
12 would be glad to answer any questions at this point.

13 MR. MATHIS: Mr. Herbein, I gather from what you
14 just said, that you use a simulator then as a test on
15 how well or how thorough your procedures are.

16 MR. HERBEIN: We did use our procedures at
17 simulator, I guess, about a month and a half after the
18 accident. That was done to test our procedures at that
19 time.

20 We intend to take the procedures that we have
21 developed and use them on the simulator in the future,
22 as a part of the ongoing review of the procedures which
23 I think we recognize now, post accident, are in the
24 dynamic state and will continue to be for some time.

25 So there is the need to exercise our operators

1 on the simulator in the use of those procedures and in-
2 corporate any lessons that they have learned as a result
3 of that experience into the procedures on an ongoing basis.

4 MR. MATHIS: Thank you.

5 DR. CATTON: Will the people at the simulator
6 be specifically looking for improvements in your procedures
7 and trying to figure out what kind of things the operators
8 can do wrong?

9 I think it is different if the operator comes
10 home and says, hey, let's change the procedure because,
11 then if, the people who are observing him, also. I
12 think it would add to it if they also were looking for
13 improvement.

14 MR. HERBEIN: I feel that that is a part of
15 the simulator objectives that we rely on B&W to per-
16 form for us in the way of crew evaluation.

17 This is something that Babcock and Wilcox started
18 post TMI 2, where the performance of an integral crew
19 in their approach and handling of a casualty is evaluated.
20 Naturally, if the operators are using our procedures,
21 their performance will be a direct product of how firm
22 the guidelines are in our procedures that they are using
23 at the time they exercise on a particular casualty.

24 DR. CATTON: I think you have to make a deli-
25 berate attempt to sort -- to determine where the problem

1 is if there is a problem.

2 If your operators perform poorly, it is a
3 package that is performing poorly. Which piece of the
4 package is in trouble, is it the way the procedures
5 were written or is it just because you happen to have
6 poor operators at that time, or is it the operator's
7 training?

8 I think that you have to have a deliberate
9 intent to sort those things out.

10 MR. HERBEIN: I think that attempt is made at
11 the simulator both by our shift crew leader and the
12 training instructors on the simulator.

13 DR. CATTON: If that is the case, that is good.
14 It was not in the past.

15 MR. HERBEIN: Yes, sir.

16 MR. EBERSOLE: May I ask a general question?

17 In my view of reading procedures, there
18 were statements to the effect of intertransient to verify
19 this or confirm that or ascertain that such and such has
20 occurred, well, this is the end product of the industry
21 having ridden on the single failure criterion for a long
22 time. That is really a ritual you go through and behind
23 it is an assumption that when you ascertain it, it in fact,
24 that system will work, that it is there.

25 Everytime I come to those words, it says verify

1 that, I look for a parenthetical note that follows that.
2 When you verified it, you found that it was not there.
3 Now, what do I do? Then, beyond that, how long do I
4 have to do it before I go to the next step?

5 Do you follow me?

6 MR. HERBEIN: Yes, sir. I do.

7 I would state that we have made an effort in
8 all of our follow up actions to provide guidance to the
9 operator to look and reverify certain key manual and
10 automatic actions by, whenever possible, redundant instru-
11 ments. To verify that what he thought he saw, as he
12 executed the immediate manual actions, was, in fact, the
13 case, and has been verified by an additional indication.

14 MR. EBERSOLE: You are talking about verifying
15 the quality of the information at that step, I am talking
16 about verifying the function having occurred there,
17 and found out that it has not. Now he has to have a
18 bypass to go fix it and make the function occur.

19 Do you follow me?

20 Every where there is a word, verify or ascertain
21 or confirm, it is implicit in that action that you may
22 find, in fact, that it hasn't occurred.

23 Now, what do you do?

24 MR. HARTMAN: Charles Hartman. Mr. Ebersole,
25 I would like to address that question.

1 We have gone through a process in the past
2 six to eight months of going through the procedures at
3 certain times, that is one of the things that we have
4 looked for.

5 Our first step, in that regard, was to put
6 in the body of the procedure. For example, if it
7 says verify emergency feedwater is available, we put
8 an instruction in the body of the procedure in regard
9 to what we do if it is not available.

10 We found that part of the review process this would
11 make the procedure difficult to follow. So, what we have
12 done in that regard, in many cases, is make an attachment
13 and simply refer to the attachment.

14 That is part of our program.

15 MR. EBERSOLE: So, you now have another volume,
16 so to speak, to where you go for the verification process
17 in case that --

18 MR. HERBEIN: An example of that, sir, would
19 be in the case of the small break procedure we have
20 as an attachment to that the inadequate core cooling
21 guidelines, so that if you don't somehow execute the
22 sequential steps required to recover from a small break,
23 and it is not happening, now you go to the inadequate
24 core cooling guideline procedure which is an attachment.

25 DR. LIPINSKI: Let's take the reactor trip

1 procedure as a good example.

2 The operator verifies that rod bottom lights are
3 up and they are not up, so he hits the red scram button
4 as his immediate action and the rod bottom lights don't
5 come up.

6 How do you handle that in your procedures?

7 MR. HARTMAN: We have stepped in the procedure
8 where it verifies reactor power steam does not meet the
9 criteria in the procedure we commenced, emergency cor-
10 relation.

11 DR. LIPINSKI: Is this now part of the immediate
12 action step or does he got somewhere later in the procedure
13 and he is not aware of the fact that time is of essence?

14 MR. HARTMAN: That was to be performed within
15 one minute.

16 MR. LIPINSKI: Okay. So, that is part of his
17 immediate actions and this is something he has to have
18 committed to memory?

19 MR. HARTMAN: Yes, sir.

20 MR. LIPINSKI: Okay.

21 DR. LAWROSKI: Could I ask to what extent has
22 EPRI or one of the subgroups has been formed under
23 EPRI, assisted in this matter of getting ready for TMI 2 --
24 TMI 1?

25 You must have instances where you and your

1 Staff don't agree, do you always cave in or do you check
2 back with other people -- other owners give their view-
3 point so that you can bring not just the talent existent
4 in your own organization plus that which NRC has brought
5 to bear on it, but also that which may exist more industry
6 wide, and, of course, B&W? I know you have brought them
7 in.

8 MR. HERBEIN: Yes, sir. I would certainly like
9 to say that we do and I can positively state that.

10 We are a member of two B&W groups, operations
11 group represented by B&W plant superintendents and
12 then a technical group represented by our engineering
13 staff members and engineering staff members of the B&W
14 utilities. The engineering group deals pretty much with
15 generic items and an effort is made to solidify a position
16 among the B&W utilities and that is not always in
17 agreement with a position proposed by the Staff.

18 In addition to that, as you know, the Institute
19 of Nuclear Power Operations has been established with the
20 purpose of providing benchmarks excellence in the training
21 area.

22 We have taken an active role and Gary Miller,
23 the acting manager of TMI Unit 1, very recently attended
24 a conference that was held in Atlanta. I think Bill Lee,
25 President of Duke Power, kicked that off and I expect we

1 are going to see some very strong interaction with that
2 group and I expect some help out of that group.

3 MR. ETHERINGTON: Any further questions?

4 Does the Staff have any comments?

5 MR. SILVER: No, sir, we have no additional comments.

6 MR. HERBEIN: Move to the next area now, Mr.
7 Chairman?

8 MR. ETHERINGTON: Yes.

9 MR. HERBEIN: With regard to emergency --

10 DR. CATTON: When will the procedures be
11 available for review?

12 MR. HERBEIN: The procedures are in a continual
13 review process, certainly, before we restart, all the
14 procedures will have been through the final review
15 and revision process.

16 I am told by my Staff members that in the
17 next two to three weeks we should have all of the Group 1
18 procedure comments resolved and based on that I would
19 expect within four weeks the procedures would be in final
20 form. Those are the Group 1 procedures which we committed
21 to put together prior to Unit 1 restart.

22 DR. CATTON: I look forward to seeing them,
23 thank you.

24 MR. ETHERINGTON: Perhaps, before you proceed,
25 this might be a good time for a break. We will have

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

a 15 minute recess.

(Whereupon a 15 minute recess was taken.)

(Whereupon the proceeding
continued at 3:30.)

MR. ETHERINGTON: I think we are ready to
proceed Mr. Herbein.

MR. HERBEIN: Yes, sir, Mr. Chairman.

The next agenda item has to do with the control
of emergency feed water independent of the integrated
control system.

Our current procedure guidance on the use of
the manual loading station in the control room and local
hand wheel control of the emergency feed water valves
using sound power telephone communication has been
incorporated into the emergency feed water and loss of
feed water procedures.

The new manual loader station will provide
control of the emergency feed water valves, that is
EFE 30 A and B from the control room in a mode which is
independent of the ICS.

The guidance on the use of these alternate means
of control is also within the next few weeks going to be
incorporated following additional procedures: Blackout,
blackout with loss of diesels, and the loss of coolant
procedures which I mentioned were contained in three
separate procedures for small intermediate and large

1 breaks.

2 And finally, a modification allowing control
3 room transfer of ICS power is going to be addressed in
4 the appropriate procedures.

5 We also, as I stated previously, expect some
6 guidance from B&W on completion of their ICS failure modes
7 and effects analysis, and when that becomes available
8 why, we will certainly consider its applicability to our
9 procedures.

10 MR. ETHERINGTON: Is the independent controller
11 of B&W design?

12 MR. HERBEIN: Is the independent control of
13 the EFV of 30 A and B valves of B&W designed --

14 MR. SLEAR: Is that for manual loading station?

15 MR. HERBEIN: Yes.

16 MR. SLEAR: It is identical to the existing
17 manual loading station except that it has a different
18 power supply.

19 MR. HERBEIN: Who designed it, David?

20 MR. SLEAR: I don't have the foggiest idea
21 who designed it. I really don't know.

22 MR. SMYTHE: Was it Bailey?

23 MR. ETHERINGTON: Do you have any questions on
24 this?

25 MR. EBERSOLE: No, not on this part.

1 MR. SILVER: I will simply refer you to the
2 additional change I have made verbally this morning on
3 the status of this item. Otherwise, no comment.

4 MR. ETHERINGTON: All right, thank you.

5 Let's see, we are on Item 4 now, are we?

6 MR. HERBEIN: Yes, sir. The procedure for our
7 stuck open safety valve. The current procedure enables
8 the operator to detect a stuck open code safety valve
9 with the following control room indications: decreasing
10 pressure, increase in pressurizer level. The new alarm
11 annunciator from the elbow tap DP cells indicating flow
12 downstream if the pressurizer power operated relief and
13 code safety valves.

14 The elbow tap flow indications on the power
15 operated relief valve and code safeties which will read
16 out in the control room. High temperature and high
17 pressure in the reactor coolant drained tank and the
18 fact that the reactor coolant drained tank pump would
19 start and the cooler valves would open in the event of
20 discharge into the tank from the valves.

21 In the response to a detected stuck open
22 pressurizer code safety valve, the operator would
23 carry out the actions described in our EP 1202-6 loss
24 of reactor coolant pressure.

25 The objective of that procedure is to keep

1 the reactor coolant system sub-cooled using high-pressure
2 injection and steam generators on natural circulation
3 in order to cool down and de-pressurize the reactor
4 coolant system.

5 Depending on the reactor coolant system pressure,
6 the piggy-back mode of high-pressure injection, or low
7 pressure injection, until decay heat removal mode of
8 cooling is available would be established.

9 Within 24 hours, one of the long-term cooling
10 modes described in procedure in 1104-4 would be established
11 to prevent boron precipitation.

12 For a condition with a pressurized relief
13 valves may be leaking, the control room indications would
14 be the same but would occur over a longer time frame.

15 In this case, the operator would refer to
16 EP 1202-29, pressurizer system failure, for the guidance
17 on appropriate corrective action.

18 MR. EBERSOLE: Could you refresh my memory
19 on where you said direct coolant drain tank pump, you
20 made reference to that that it would start. Where does
21 that discharge?

22 MR. HERBEIN: It actually discharges two
23 places, sir. Re-circulation back into the drain tank
24 itself after passing through a cooler, and that enables
25 cooling the contents of the tank, and when the tank

1 reaches a high-level, the operator has the option to pump
2 the contents of the tank to our reactor coolant bleed tanks in
3 the auxiliary building.

4 MR. EBERSOLE: But that is blocked if that
5 affliction valves pump were to be blocked? Right?

6 MR. HERBEIN: That is correct, sir.

7 MR. EBERSOLE: All right, that is part of the
8 affliction complex is to stop, that last pumping function
9 you mentioned?

10 MR. HERBEIN: That is right.

11 MR. EBERSOLE: Thank you.

12 DR. CATTON: Did you say there would be flow
13 indication in the tail pipe?

14 MR. HERBEIN: Yes, sir, I did.

15 DR. CATTON: And what kind of flow meters?

16 MR. HERBEIN: I will ask Dave Slear to answer
17 the type of flow meters associated with the elbow tap
18 DP cells.

19 MR. SLEAR: These are the elbow tap differential
20 pressure cells that I mentioned in my presentation with
21 the indication on the console center of inches of water.

22 DR. CATTON: What is it, a veto tube or something?

23 MR. SLEAR: They are differential pressure
24 cells that tap on either side of the elbow. Inside the
25 radius bend and outside.

1 MR. EBERSOLE: And you can correlate this from
2 mass flux?

3 MR. HERBEIN: Mass flow.

4 MR. EBERSOLE: Flow.

5 MR. HERBEIN: Yes, sir.

6 MR. SLEAR: We are doing calculations which in-
7 dicate for mass flow of ten percent of rate of flow
8 through the valve, you would expect to see so many
9 inches of water, but we are not providing a meter that
10 says you have ten percent flow, we are providing a meter
11 that says inches of water.

12 This is intended to be go, no go indication
13 that there either is significant leakage or not significant
14 leakage through the PORB or safety valves.

15 It is not intended to be an accurate formula.

16 DR. CATTON: Well, that is good because measuring two
17 type flow is a very difficult thing to do. I am curious
18 as to how you accomplished it.

19 MR. SLEAR: We are trying to measure it accurately,
20 and we are merely trying to convince ourselves that there
21 will be a significant indication of inches of water on
22 the meter under two place flow conditions and are doing
23 calculations along those lines.

24 DR. CATTON: In your testing of this device,
25 are you going to attempt to use realistic conditions, the

1 kinds that you would expect during an actual PR reactuation.
2 Rapid temperature changes can cause funny things to happen
3 to pressure transducers.

4 MR. SLEAR: I guess I will have to defer the
5 answer, it has been tested in the lab by Dr. Wilcox, I
6 think under nominal types of conditions as opposed to
7 upset conditions.

8 DR. CATTON: That is Appendix 2-A I believe
9 which will be coming out in mid-February?

10 MR. TAYLOR: Dr. Catton that is not a transducer,
11 it is a differential pressure cell with two taps into
12 the elbow on the tail pipe and those tests were done
13 in our last research center we did the tests on both
14 the elbow flow meter and the acoustic flow detector
15 and as Mr. Slear said they were not intended to be
16 accuracy type tests, just to see what kind of flow it
17 took to get a good solid reading on the meter.

18 DR. CATTON: Did you do this with two-phase
19 flow?

20 MR. TAYLOR: I believe these tests were all
21 with steam.

22 DR. CATTON: Well, delta p meter with single
23 phase flow either vapor or liquid is one thing, two
24 phase flow is another.

25 MR. ETHERINGTON: It's -- I would call it wet

1 steam rather than really two phase. I think it is more
2 like ten percent steam.

3 MR. TAYLOR: Yes, they were the conditions that --

4 MR. ETHERINGTON: They are two phase of course but
5 it is wet steam.

6 MR. EBERSOLE: May I ask this, in view of all the
7 difficulty of obtaining flow, direct coolant drain tank
8 is a nice integrator. Why don't you just follow the
9 variation and level in it.

10 MR. TAYLOR: Well, I think that is right.
11 It is a good integrator. I am sure that would be a
12 case and --

13 MR. EBERSOLE: It sounds like an easy way to
14 do a hard thing.

15 MR. TAYLOR: Well, the high level of water
16 is certainly going to tell you whether the valves are
17 leaking or not.

18 MR. HERBEIN: On unit one, sir, we have
19 experienced leakage in the past from both our power
20 operator relief valve and code safeties and we were able
21 to measure the rising level versus time and calculate
22 the gallons a minute leakage --

23 MR. EBERSOLE: That is a lot more precise
24 than any full gage --

25 MR. HERBEIN: And we are able to do that and

1 and we have done it, sir.

2 MR. EBERSOLE: Well isn't that function useful
3 here to go back to the matter of whether the PR is
4 leaking or not without involving trying to go through
5 the exotic process of measuring flow.

6 MR. HERBEIN: I think it is a very meaningful
7 indication and certainly something that we would do, and
8 as I indicated our procedures do provide guidance to
9 the operator with regard to a number of indications telling
10 him that he has got either a leaking PORB or code
11 safety.

12 MR. EBERSOLE: As an aside question, what
13 is the capacity of that re-circulating cooler for that
14 tank? Is it just based on a similar condition or just
15 taking a charge, it's fairly small cooling capacity on
16 the reactor coolant drain tank heat exchanger, right?

17 You mentioned the fact that you pump through
18 a heat exchanger?

19 MR. HERBEIN: Yes, sir, that is true.

20 MR. EBERSOLE: What is it in BTU per hour --

21 MR. HERBEIN: I can't state that --

22 MR. EBERSOLE: Well, what is its functional
23 duties? Is it just to take a short-time discharge out?

24 MR. HERBEIN: Yes, sir. That is correct.
25 I can state from experience when the leakage from the

1 safety valves into the drain tank runs up around eight
2 or nine gallons a minute, we begin to have problems
3 with tank overheating.

4 MR. EBERSOLE: So then, you risk rupturing
5 the disc, all right.

6 MR. HERBEIN: Yes, sir.

7 MR. TAYLOR: Mr. Ebersole, I think the original
8 size and criteria of that cooler back, 12 or 14 years ago
9 was based on having the discharge of one cycle when you had
10 a turbine trip and PORB listed, it would return the
11 contents of the quenched tank back down to its normal
12 temperature in something like an hour or an hour and a
13 half.

14 MR. EBERSOLE: Thank you.

15 MR. ETHERINGTON: Are there any further questions
16 from the Committee or attendants? Does the staff have
17 any comments?

18 MR. SLEAR: No, sir, we do not.

19 MR. ETHERINGTON: All right. We will proceed
20 with the next one.

21 MR. HERBEIN: Four B, the procedure for handling
22 small break LOCA including ruptured steam generator two.
23 I would like to first of all address our LOCA procedures.

24 As I mentioned, we have three procedures for
25 small, intermediate and large-size breaks.

1 Into these procedures we have incorporated the
2 small-break operating guidelines from Babcock and Wilcox,
3 dated November '79.

4 Procedure 1202-6A contains instructions for
5 verifying feed water availability, monitoring margin
6 from saturation and verifying reactor containment isolation.

7 If the reactor coolant system pressure reaches
8 16 hundred pounds in our small-break procedure 1202-6A,
9 the operator is then referred to 1202-6B, the intermediate
10 break procedure.

11 1202-6B covering intermediate breaks contains
12 guidance in the following areas: Reactor coolant pump
13 trip and re-start criteria, verification of emergency
14 feed water flow, increase in steam generator level to
15 95 percent, verification of reactor building isolation,
16 the criteria for throttling high-pressure injection,
17 the guidance for detecting saturated conditions, actions
18 to respond to inadequate core cooling symptoms, instructions
19 to monitor for hydrogen build-up, and place the hydrogen
20 re-combiner in service; and finally, instructions for
21 transfer to the reactor building sump with low pressure
22 injections supplying suction to the high-pressure injection
23 pumps.

24 The next procedure in the series for large
25 breaks, which would result in low-pressure injection cooling

contains guidance for reactor building isolation and cooling, verification of core flood tank flow, verification of low-pressure injection flow. Response to the failure of one low-pressure injection loop; and transfer of low-pressure injection suction to the reactor building sump.

Our procedures are, over the next few weeks, again being reviewed to insure that the latest B&W revision for guidelines on small breaks have in fact been correctly addressed in this series of procedures.

In addition, the procedures are being reviewed to assure they are usable for the operator and that the symptoms for each condition are clearly stated and readily recognizable.

Additionally, we do plan to incorporate the anticipated transient operating guidelines that are applicable to TMI into the LOCA procedures when they become available, and as I stated previously, they are expected in the NEAR future. I think they should be in final form prior to the beginning of April.

That covers small-break LOCAs. I have some additional remarks on ruptured steam generator tubes, but I think we perhaps ask if there are any questions on this.

MR. EBERSOLE: Item 4A read procedure for stuck-

1 open safety valve, I guess I mis-interpreted that to
2 mean PORB. The stuck-open safety valve is really a small
3 LOCA located at the top of the pressurizer.

4 MR. HERBEIN: That is --

5 MR. EBERSOLE: It comes under Item B2, or 4B, but
6 there is a difference in discharge in regards to the
7 reactor coolant drain tank. So you know where it was.

8 MR. HERBEIN: Yes, sir.

9 MR. EBERSOLE: But, knowing where it was doesn't
10 much change the procedure, does it because you can't
11 unstick it, it is a safety valve.

12 MR. HERBEIN: No, sir, it doesn't and the
13 guidelines for sub-cooling high-pressure injection are
14 still applicable and are contained in both procedures.

15 MR. EBERSOLE: So A and B in that context
16 are the same?

17 MR. HERBEIN: Yes, sir that is correct.

18 MR. ETHERINGTON: The behavior would be different,
19 wouldn't it. The safety valve is a large small break,
20 isn't it and blows right down.

21 MR. EBERSOLE: It depends on how much it is
22 stucked.

23 MR. HERBEIN: Yes, sir, and it also gives
24 erroneous indication of a full condition on the pressurizer.

25 MR. EBERSOLE: Well, isn't the more important

1 difference though that a small break accident may be
2 a liquid line leak like a seal failure or an inch of
3 a non-failure or something like that where the inventory
4 loss is more substantial than is it to blow the steam
5 line.

6 That is, you are going to have a liquid loss
7 to deal with as well as a steam loss.

8 MR. HERBEIN: But, in either case, you do loose
9 mass from the reactor coolant system boundary.

10 MR. EBERSOLE: Right, but you would loose it
11 to less advantage if it were below the water line and
12 you were just simply loosing water without any heat in
13 it.

14 MR. HERBEIN: Yes, sir that is true.

15 MR. EBERSOLE: So, it becomes more difficult
16 later on when you are trying to make up and steam at
17 the same time. You would have to have more make up water.

18 MR. HERBEIN: Yes.

19 MR. EBERSOLE: All right, I have no further
20 questions.

21 MR. ETHERINGTON: You say you have?

22 MR. EBERSOLE: You were going to move into
23 the ruptured steam generator?

24 MR. HERBEIN: Yes, sir.

25 MR. EBERSOLE: When you do that, by the way let

1 me call out something. B&W systems have a unique difference
2 between their design and CE and Westinghouse, in that,
3 if you have a steam generator tube break, almost invariably
4 when you look at the PSAR and SAR you will note that
5 the accident is analyzed in the presence of off-site
6 power rather than the absence of off-site power.

7 The reason being, that with a once through boiler
8 you have a steam line failure, but rather a tube failure,
9 which discharges from your cooler into the more or less
10 dry secondary side where it proceeds directly to atmosphere
11 through the duct wells, without the benefit of being
12 scavenged through the water system which exists on the
13 other type of steam generators.

14 Therefore, invariably the does levels would
15 come comparably much higher on a B&W plant for the case
16 of loss of off-site power where you don't have the benefit
17 of the condensers, do you follow me?

18 MR. HERBEIN: Yes, sir, I do.

19 MR. EBERSOLE: Is your analysis here based
20 on the fact that you retain off-site power in order to
21 run the condensers, or you do not have it for that
22 steam line break case?

23 Is my question clear?

24 MR. HERBEIN: Yes, sir, it is. I am not sure
25 that I have the answer to that.

We would look to B&W?

MR. EBERSOLE: I am saying B&W plants by and large look at the steam line break incident claiming the presence of off-site power because they don't have the benefit of scavenging through the water inventory of secondary side of a combustion of a Westinghouse plant, it is invariably a difference.

MR. SCHIELK: I would like to take exceptions to the word invariably.

MR. EBERSOLE: Well, maybe there are some plants that I didn't see that --

MR. SCHIELK: It depends on where the location of the tube rupture is.

MR. EBERSOLE: It is high, it is the worst.

MR. SCHIELK: Right. There is extensive work going on now within B&W specifically with regard to the tube rupture to examine exactly what is the proper operator action in the event of a loss of off-site power and a tube rupture. We expect to have results in connection with the ATOP program and we are scheduling that right now for about the end of March.

MR. EBERSOLE: Do you show in the analysis here what the case of off-site dose is when you don't have the condensor function on a tube failure? Is that in the -- I don't recall seeing that in the SAR's

1 MR. SCHIELK: No, in the TMI 1, FSAR --

2 MR. EBERSOLE: Do you claim off-site power?

3 MR. SCHIELK: Do we claim off-site power, right.
4 which is the historically way that that accident has --

5 MR. EBERSOLE: Yes, that is your Westinghouse
6 or CE, you know, they plan they can to get along without
7 having to have that so they use that, but you have the
8 disadvantage here of having to inject pretty much raw
9 primary coolant into atmosphere through the dump pass.

10 MR. SCHIELK: There is some thinking that
11 the main steam stop valve could be kept open steaming --

12 MR. EBERSOLE: You would be inclined to try to hang
13 on to the usual pattern as long as you can.

14 MR. SCHIELK: Yes.

15 MR. EBERSOLE: Thank you.

16 DR. LAWROSKI: Maybe this should have been
17 asked under operating procedures, but you heard of the
18 word mine set some months ago and I wonder how you have
19 addressed the matter of reducing the probability of an
20 erroneous mine set amongst the control room personnel
21 while you deliberated operating procedures.

22 Let me cite an example which was given us
23 at one time; that when a doctor is confronted with
24 a patient whose condition he is uncertain of as a result
25 of his own diagnosis he will often ask the patient if he

1 would allow a second doctor to get involved in, to assist
2 in getting a more accurate diagnosis, and the usual procedures
3 that I think have been used in the medical field reveal that
4 second doctor does not confer with the first one before
5 he talks with the patient but he first talks -- the second
6 doctor talks to the patient, makes his own diagnosis and
7 then the two doctors get together so that they avoid,
8 hopefully avoid having set in a bias too early in arriving
9 at each of their conclusions.

10 Do you follow me?

11 MR. HERBEIN: Yes, I do sir.

12 I would respond to that by saying with the training
13 program and the assignment of the sixth shift technical
14 advisors, to shift and the fact that the shift technical
15 advisors don't report directly and are not responsible to
16 administratively the shift supervisor, you do get that degree
17 of independence with regard to the accident assessment
18 function. The shift technical advisors report to the plant
19 engineering manager and while I don't know that they have a
20 separate consultation with the patient so to speak, they
21 do make their own independent assessment of plant conditions
22 and are there to specifically advise the shift supervisor
23 based on the independent assessment.

24 DR. LAWROSKI: Is that clearly spelled out
25

1 in the procedures or whatever?

2 MR. HERBEIN: I can't say that it is clearly
3 spelled out in the procedure but that is certainly our
4 intent and we have emphasized that in our instructions
5 to the shift technical advisors.

6 MR. EBERSOLE: If I can follow on, on the
7 ruptured steam tube thing, I just heard that the FFSAR
8 ran the analysis assuming that off-site power was present
9 therefore it was close to the condensor.

10 I guess I have to ask in view of the current
11 sensitivity about radiation release does Metropolitan
12 Edison, are they aware of the dose that would accrue if
13 you had a steam generator tube failure and the off-site power
14 kept to failure and are willing to take whatever risk that
15 is.

16 MR. HERBEIN: Sir, I am not specifically
17 aware of the numerical value of the off-site dose, but I
18 do recognize that it is higher in the even you don't
19 have the condensor available and must discharge to
20 atmosphere.

21 With regard to the whole tube rupture issue,
22 NRC has issued some bulletin and notice guidance to all
23 the plants following the Perry Island incident in late
24 1979.

25 We have looked at that guidance; we have also

1 looked at B&W's draft procedure guidelines that they
2 published on the 10th of January providing procedural
3 guidance for single tube rupture.

4 We recognize that the multiple tube rupture
5 issue in the steam generator in itself has some unanswered
6 questions.

7 We are working closely with B&W to arrive
8 at what we think is a mutually acceptable approach.

9 I know we have reviewed the procedure they
10 provided us, we have given them comments. We hope
11 to resolve those comments.

12 We have a lot of work to do in this area,
13 we recognize it and we are pursuing it vigorously.

14 MR. EBERSOLE: Thank you.

15 MR. ETHERINGTON: Are there any other questions?
16 All right, you can continue.

17 MR. HERBEIN: The next area listed is Item 4C
18 the method and conditions for blocking and unblocking
19 the power operated relief valve.

20 Presently, our emergency procedures require
21 the closure of the blocked valve which is upstream of
22 the power operated relief valve during a loss of coolant
23 accident.

24 Procedures also call for blocked valve
25 closure for a leaking or a failed open power operated

1 relief valve.

2 Guidance is provided in these procedures to
3 re-open the blocked valve as necessary to control
4 increasing pressure prior to lifting the pressurizer
5 code safety valves.

6 In cases where it is required to have the
7 fourth blocked valve open, such as during a loss of
8 heat sink which is addressed in loss of feed to both
9 steam generators, to steam supply system rupture procedure,
10 and the inadequate core cooling procedure.

11 The procedures require a verification that
12 the blocked valve is open.

13 This then provides a core cooling flow path
14 for high-pressure injection which would pass through
15 the core and out through the power operated relief
16 valve.

17 MR. EBERSOLE: But that last function you
18 mentioned is it present in that safety cleared?

19 Even the cellunoids and DC classifier or
20 have you changed that? It used to be considered an
21 unsafety function this opening function.

22 MR. HERBEIN: I am aware that that is one
23 of the new reg items.

24 MR. SLEAR: We have protective power supplies but
25 those valves are not safety break items, so it is not a

1 safety grade.

2 MR. EBERSOLE: So this -- including in the PORV
3 opening function is a safety function is at the moment
4 is not valid, is it?

5 MR. HERBEIN: I don't know that I would say
6 that, sir.

7 MR. EBERSOLE: It is not redundant --

8 MR. HERBEIN: I think we do have redundant
9 power supplies to the core and to the blocked valve from
10 our ES motor control centers.

11 MR. EBERSOLE: Well, you can have multiple
12 power supplies and control but you still have to focus
13 on one valve.

14 MR. HARTMAN: This comes from one CDS valve.

15 MR. HERBEIN: Which can be fed alternately from
16 either 480 volt control center.

17 I think we have got the redundant power supplies
18 to the valve, sir but you are right it doesn't meet the
19 single failure criteria.

20 MR. EBERSOLE: But in the long run the relief
21 there is a safety function you have to claim it, you have
22 to claim it the safety assumption.

23 MR. HERBEIN: Yes, sir.

24 MR. EBERSOLE: You can't really afford to claim
25 it through these lower pressure PORV's, not yet.

1 MR. HERBEIN: That is right, and our procedures
2 are prepared to, and in fact, do provide operator guidance
3 to do that.

4 MR. EBERSOLE: Thank you.

5 MR. SILVER: I would like to point out that
6 we, in a recent letter, to CON ED, dated January 21st in fact,
7 asked them to automatically close the blocked valve
8 once it had opened and pressure continued to decrease
9 below what would be the normal re-set point of the
10 blocked valve.

11 We also asked them to evaluate the effects
12 of this on the remainder of the system, which of course
13 connects with your concern about stuck open safety
14 valve. We of course do not have a response to this
15 yet.

16 MR. HERBEIN: With regard to the staff's
17 remarks, we currently are in the process of looking
18 at a design for the automatic closure of the blocked
19 valve which Mr. Silver mentioned.

20 Dave, could you comment on that?

21 MR. SLEAR: We are proceeding with a conceptual
22 design where we currently think from the standpoint of
23 a signal where we would choose a coincidence logic
24 between both low pressure and an indication of flow
25 of the tailpipe downstream of the blocked valve.

1 So, I guess there is at least a difference
2 of opinion of what signal is the appropriate signal
3 or a combination of signals is the appropriate signal
4 to use.

5 MR. HERBEIN: Okay, and I would point out
6 this, as Mr. Slear said that is still in the initial
7 phases, we are not sure about the advisability of the
8 dual signal approach that that is under evaluation.

9 MR. EBERSOLE: Yes, I think all too frequently
10 you see the presence of dual signals and dual power
11 supplies converging on one mechanical, electrical
12 device without consideration to the device itself
13 to the point of failure, and a good reason for that
14 sometimes is because that device may be very expensive.
15 On the other hand it may be useless to put two part
16 supplies or two control supplies to one valve if the
17 principal underlies those to develop proper, and I
18 don't know what improvements --

19 MR. SLEAR: The stapler and power supplies
20 one of those valves, either the PORV or I guess maybe
21 it is the blocked valve, the blocked valve is energized
22 open and fails shut mechanically. So, I guess if you
23 are trying to get this valve shut, and you lose power --

24 MR. EBERSOLE: Isn't that a motor driven
25 valve that is driven to each position?

1 MR. HERBEIN: The blocked valve is motor
2 driven.

3 MR. EBERSOLE: So it doesn't sprinkle --
4 I mean it is not internal energy to close is it or open
5 either. It is motor driven to both either position?

6 MR. HARTMAN: That is correct.

7 MR. EBERSOLE: Anyway, it is an illusion
8 sometimes to put two part supplies and two control
9 supplies to the same device.

10 It may satisfy the electrical engineers or
11 the 279, or some piece of paper somewhere, but it may
12 not improve the system.

13 MR. HERBEIN: Yes, sir.

14 MR. CLARK: Philip Clark, GPU.

15 We also in that regard are evaluating whether it is
16 in fact better to have an additional safety circuit
17 with automatic closure and introduce a complication
18 into the procedures, the operator training, and, his on
19 the spot evaluation of what is happening.

20 So, while we are developing a design, we have
21 not yet concluded whether, in our opinion, it would
22 be an improvement to have automatic closure or not.

23 MR. ETHERINGTON: What is the staff's position
24 on automatic closure?

25 MR. SILVER: The staff's position on automatic

10/26

1 closure is relatively new for one thing and I don't know
2 if we would be prepared to pound the table at this time
3 and insist on it, but our position right now is that
4 there should be automatic closure, and we certainly will
5 examine the licensee's response.

6 MR. ETHERINGTON: Well, if there are no further
7 questions we will go to loss of offsite and D. C. Power.

8 MR. HERBEIN: Our current procedures which
9 address loss of AC and DC power start first of all with
10 procedure EP 1202-2 which covers the loss of offsite
11 power.

12 In the event of a loss of offsite power, the
13 reactor trips and the on-site diesel generators automatically
14 start and energize the safeguards busses.

15 The central loads are then manually started
16 by the operator in order to stabilize and cool the plant.

17 EP 1202-2A provides guidance for the loss of
18 offsite power with the failure of both diesels.

19 In this case, the vital 120 volt AC busses
20 are supplied by the invertors which in turn are powered
21 from the batteries.

22 The turbine driven emergency feed pump is
23 used to supply emergency feed water and the steam from
24 the steam generator is discharged to the atmosphere through
25 the atmospheric relief valve because of the loss of the

10/27

1 condensor.

2 Natural circulation cooling is established in
3 the reactor coolant system, and the rate of cool down
4 is minimized until AC power from offsite is restored.

5 MR. EBERSOLE: That takes care of the cooling
6 of the core?

7 MR. HERBEIN: Yes, sir.

8 MR. EBERSOLE: What about the ambient temperature
9 is rising in a variety of places because of loss of
10 ventilation including ambient temperature that may arise
11 in areas around the steam supply line to the off-steam
12 turbine which signal to it that it had a steam-line
13 break and therefore were closed. I am saying this
14 system may fall back on itself.

15 Sometimes temperature is used as a detection
16 method for steam-line breaks to the off-steam steam line
17 supply and the rise in temperature signifies to the system
18 that it has a steam-line break and it closes the steam
19 supply to the off-steam turbine because of temperature
20 rise which occurs because of AC power failures.

21 MR. HERBEIN: Our steam line rupture detection
22 system, sir, operates on steam pressure and at 600 pounds
23 we do shut steam line valves. However, our emergency
24 feed pump turbine steam supply line comes off up-stream
25 of those stop valves.

20/28 n

1 So, there is an assured supply of steam to
2 the turbine.

3 MR. EBERSOLE: I understand that, but do you
4 not have a stop valve to close steam flow in the event
5 you lose the -- of the repeat pump steam supply line?
6 Isn't that pitch pressurized and to make up to some
7 point where the blocked valve. I realize it takes up
8 steam ahead of the mainstream isolation valve.

9 MR. HERBEIN: Yes, sir.

10 MR. EBERSOLE: Then it has its own isolation
11 valve.

12 MR. HERBEIN: Yes, that is correct, sir.

13 MR. EBERSOLE: Which is designed to cope,
14 I presume with a hypothetical failure?

15 MR. HERBEIN: Yes, sir, but it does not shut
16 on a temperature signal.

17 MR. EBERSOLE: It does not shut on temperature
18 signal.

19 MR. HERBEIN: No, sir.

20 MR. EBERSOLE: Do you use some close signal?

21 MR. HERBEIN: No, there is no automatic
22 isolation signal of -- to the blocked valve that supplies
23 steam to the --

24 MR. EBERSOLE: Are you prepared then to take
25 a continued -- that valve is not running closed however

1 isn't it?

2 MR. HERBEIN: Yes, sir.

3 MR. EBERSOLE: So you don't have any hazard
4 potential downstream of the valve, it is only when you
5 start using the line that you have a hazard potential
6 which you could discount because of the infrequent
7 use, I guess.

8 MR. HERBEIN: It would seem so.

9 MR. EBERSOLE: Right. Upstream of the valve
10 you do have a problem if you lose the pressurize aux-steam
11 supply line. Does that go into an area where it continued
12 steam discharge from that point could be tolerated?

13 Do you follow me?

14 MR. HERBEIN: Yes, I understand what you are
15 saying. Steam supply rupture to the auxiliary feed pump
16 turbine and could we, in fact, environmentally --

17 MR. EBERSOLE: Tolerate the continued --

18 MR. HERBEIN: Tolerate that.

19 MR. EBERSOLE: You don't know way of cutting
20 it off?

21 MR. HERBEIN: I don't know the answer to that exact
22 question but I know we are looking at high-energy breaks
23 inside and outside containment that is a generic issue --

24 MR. EBERSOLE: That would be one of those.

25 MR. HERBEIN: That is a generic issue and that

10-30

1 is being --

2 MR. EBERSOLE: Isn't that an old issue that
3 goes back to '72?

4 MR. HERBEIN: I don't know if it goes back
5 to '72, perhaps the staff could provide some clarification
6 on that. I think we -- I am sure we have just received
7 guidance from the NRC with regard to the concern that
8 they recently focused on high-energy breaks inside and
9 outside containment, and I believe we have made an
10 initial response in accordance with one of their bulletins.

11 MR. EBERSOLE: Well, the great letter that
12 took up this matter, it was an anonymous letter in
13 December of 1972 and I believe in the following years
14 in '73 the staff took a comprehensive effort to look
15 at steam line and other line breaks inside and rather
16 outside the containment, am I correct?

17 MR. SILVER: Outside, sir, that is correct.

18 MR. EBERSOLE: How did this then persist
19 for eight years after that?

20 MR. SILVER: I can't answer that at this
21 moment.

22 MR. EBERSOLE: I am sure that the dates are
23 correct.

24 MR. SILVER: Approximately, they are approximately
25 correct.

1 MR. EBERSOLE: I have no further questions on
2 loss of offsite and AC power, however, are you going to
3 take up DC power?

4 MR. HERBEIN: I am aware, sir, that as a result
5 of your tour yesterday, you had expressed some concerns
6 about the loss of first single battery bank and then
7 following a loss of AC power and additional battery bank,
8 I think the --

9 MR. EBERSOLE: Let me make a correction on that.
10 I didn't make reference to any AC power loss as being
11 intrinsic to the DC power loss at all. I merely said
12 that we -- because we only have two batteries, we must
13 expect sooner or later that one of them will fail and
14 that puts the second battery in a state of jeopardy,
15 mostly, probably because of potential operator interaction
16 and places the second battery or the second DC power
17 source in some unusual state of reliability wherein
18 it may cascade the failure.

19 Now, beyond that point, I didn't say that
20 any of the things were automatically the consequence
21 of that except I now know that invertors will fail
22 if the AC power source fails, but I didn't say that
23 I knew that they would fail, I suspect they will because
24 among the things that happens the token generator will
25 trip and go into a de-energized motoring operation which

10-32

1 would influence the in-coming power function.

2 I suspect that you are going to have a loss
3 of AC power for this case, but I think that has to be
4 developed in detail because a consequential aspect of
5 losing DC power and it is a very complicated business.
6 Mr. Hartman and I went over this in some detail yesterday,
7 but in the beginning, let me make clear, I didn't say
8 that AC power was either lost or not lost. It has to
9 be something that is ascertained, and I didn't just
10 invoke it as a random occurrence.

11 I would have to say that either it was a
12 consequential failure or not, and I suspect it would
13 be --

14 MR. HERBEIN: I can state, sir, that our
15 invertors are designed to go either way either from a
16 loss of AC over to the DC battery bank.

17 They are also capable of functioning on the
18 AC power supply provided from the motor control centers
19 in the event there is a loss of DC.

20 So, the invertor has the capability to go
21 either way, and I don't know that it has been established
22 That in the absence of DC that there would in fact be
23 the --

24 MR. EBERSOLE: The transition.

25 MR. HERBEIN: No, that there would, in fact, be

1 the inability to make the transition and the subsequent
2 failure of the inverter.

3 MR. EBERSOLE: I agree with you, I don't know
4 either.

5 I think this is a complicated picture and mainly
6 it says to me that a early study of which I believe you
7 and Mr. Hartman has a copy of NUREG 0305, which says that
8 if nothing works, including AC and DC and that there
9 are pretty substantial times like about an hour and a half,
10 two hours, for a typical PWR, much less time for the
11 boiler, but it simply infers that within that time you
12 can do something without actually determining whether
13 you can do anything, but one of the consequences of
14 the DC power failure, if it includes inverter failures,
15 is that the plant goes into total blackness, and none
16 of the steps which you presently outlined that the
17 operator is supposed to take in emergency can in
18 fact be taken because he can't see anything or do
19 anything other than go fix the invertors. He has
20 no information at all and, in fact, no illumination.
21 He is in total darkness, he has no signals, he has
22 no capability to operate any valves, other than
23 manual, and in a later study, and I refer here to
24 a document which is from a slide presented by and
25 was opened by Aftosky on January 11th. I find that these

10-34

1 times for you to take whatever action can be taken in
2 this darkened condition without electrical functions
3 is not any more of the roughly at one hour, but rather,
4 it is run down to 20 minutes for atypical B&W plant.

5 In this analyses I have here, it says,
6 consequence of temporary loss of all feed water in the
7 B&W set 20 minutes available to initiate HPI or AFW
8 pumps feed water.

9 So, it says to me, that this complex function
10 that we are still wearing first the inverter classified
11 to get some indication on to tell you where to go and
12 what to do, and then after that, numerous actions
13 involving energizing or rather closing certain breakers in
14 getting the diesel re-started, the diesel connected
15 to the LOCA rather, have to be done.

16 I don't think there is a match between the
17 time available and the actions necessary to be taken
18 after this event.

19 But, that has to be developed, I think in
20 considerable detail.

21 At this point in time I would merely have to
22 say that there is an imbalance between the time that
23 we have after AC power failure and the things that
24 have to be done under the conditions that existed at
25 that time.

1 In short, I believe that this DC power loss
2 leads to a cool out, certainly I will have to conclude
3 that in the absence of better information than I have
4 now.

5 Does, anybody want to argue that point?

6 MR. HERBEIN: Sir, I don't know that I want
7 to argue that, I would state that it is probably a good
8 bet that not only the B&W plants are in trouble if there
9 is a total loss of AC and DC --

10 MR. EBERSOLE: It's generic, there is no
11 particular difference, I agree with you.

12 But, it is a standing possibility which has
13 not been analyzed.

14 Right now there are no procedures for coping
15 with this event.

16 MR. HERBEIN: I would add one thing to what
17 you have said, and that is in our plant we would have
18 the capability to establish emergency feed water, there
19 would be steam available. We do have the capability to
20 run our turbine driven emergency feed pump and that
21 could provide water to the steam generators.

22 MR. EBERSOLE: Yes, I understand that the loss
23 of DC power would cause that pump to go into service and
24 the valve would open, and as I presently understand it,
25 your off steam pump will start up. What it does after

10/36

end

1 that, I don't know. It may in effect charge the secondary
2 side until it kills itself, earlier than 20 minutes.

3 In short, if it runs 20 minutes, I don't know
4 what as of now it regurgitated water back on itself and
5 stopped permanently.

6 You remember this operation is blind, I have
7 no level gauges, I have no transducers, I have no indication,
8 I am running absolutely blind.

9 MR. HERBEIN: I think we --

10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

1 MR. EBERSOLE: Let me see, I understand that you
2 all have an ongoing investigation as to what would happen
3 with DC power failure and it's premature to attempt to say
4 now what really does; so, I just am looking forward to a
5 conclusion of that examination.

6 MR. HERBEIN: I think we recognize, sir, that
7 there is a concern over this generic issue and that we have
8 some homework to do and we intend to get on with it.

9 MR. EBERSOLE: Thank you.

10 MR. ETHERINGTON: Let's see now, are we expecting
11 a new report on this?

12 MR. EBERSOLE: My understanding is you have an
13 ongoing investigation that you will reach some point in
14 time here where you will draw a conclusion as to what happen-
15 es; I don't know when that is.

16 Do you have any estimated date when you will pin
17 that together?

18 MR. HERBEIN: Not at this time, sir.

19 MR. EBERSOLE: Would it be -- well, one month,
20 two months, three months? I'm just inviting --

21 MR. HERBEIN: I would hesitate to make a guess
22 at the culmination of our ongoing effort with regard to
23 a generic problem such as you've just stated, sir.

24 MR. EBERSOLE: Well, I have to call out to the
25 Staff that NUREG 0305, which culminates in a stated time

1 before one begins to suffer core damage, which time is
2 based on the thesis that you go to core midplane doesn't
3 define what you can do in that available time; that's item
4 one. And, the time so expressed here is consistent with
5 the fact that it went to core midplane, not a very conservative
6 position, whereas Mr. Lastofski's (?) report about loss of
7 all feed water and loss of electrical power, in essence, is
8 based on going below the top of the core and those times run
9 down, in that case, to 20 minutes, not an hour or thereabouts.

10 So, there's a much diminished time and still no
11 identification of what can be done within that time. So
12 in essence, the 305 report reached a conclusion only to find-
13 ing the time that might be available which is unduly lengthen-
14 ed and then it did not close with a statement or any con-
15 clusion as to what could be done, if anything, within that
16 span of time; so therefore, it's deficient.

17 So, I would like to ask the Staff to look for an
18 Appendix on extension of that document to include what could
19 be done in that time and a reaffirmation as to whether those
20 times are accurate in the light of new investigations as to
21 TMI.

22 That's the Staff's job.

23 MR. SILVER: I will pass that information along.
24 Again, I think it's apparent this is outside of the scope
25 of the immediate focus of this thing.

1 MR. EBERSOLE: This is a generic item which is one
2 of those things which we, I understand, must not ignore
3 in just attending to the TMI specific problems.

4 MR. HERBEIN: Sir, before we leave this subject
5 I'd like to ask the Staff if it's all right.

6 If the Staff's aware of any results or conclusions
7 by anyone else with regard to this generic issue, perhaps
8 they are aware of some studies or an ongoing schedule that
9 someone else has established to resolve the issues that have
10 been identified today. If they are aware of such schedules
11 or efforts underway, we'd very much like to coordinate our
12 efforts with them.

13 MR. SILVER: We might get some more information
14 tomorrow in report on the backlog items. If there's not,
15 I will certainly see that something's developed.

16 MR. EBERSOLE: Thank you.

17 MR. ETHERINGTON: Filling pressurizer solid?

18 MR. HERBEIN: I'm prepared to leave that issue and
19 move on to the next agenda item, sir, if it's all right.

20 MR. ETHERINGTON: Sure.

21 MR. HERBEIN: Agenda item E, the policy on pre-
22 vention of filling the pressurizer solid: during normal
23 system operation, solid pressurizer operation is not permitted.
24 This limitation is expressed in OP1101-1, our plant limits
25 and precautions, as well as our makeup and purification

1 system operating procedure. In addition, the technical
2 specifications define the minimum conditions for criticality
3 within the limits on pressurizer level of 80 to 385 inches.

4 Under accident conditions, reactor coolant system
5 solid operation as indicated by a full pressurizer may be
6 required to provide adequate core cooling through the power
7 operated relief valve or code safeties. In this regard,
8 guidance is provided to open the power operated relief valve
9 on increasing pressure prior to challenging the code safety
10 valves and risking a stuck open safety.

11 Guidance for operating with an indicated solid re-
12 actor coolant system condition is provided in the following
13 procedures: a loss of feed to both steam generators; in-
14 adequate core cooling; loss of reactor coolant pressure;
15 steam supply system rupture; and the pressurizer operation
16 procedure.

17 Finally, in order to take the plant into a solid
18 condition, prior approval is required from the shift super-
19 visor.

20 MR. EBERSOLE: In going to this condition, I guess,
21 in theory, you're possibly invoking the lead feed process.

22 MR. HERBEIN: Yes, sir, in the absence of heat set.

23 MR. EBERSOLE: So, you do it when you don't have
24 secondary cooling, loss of all feed water, right?

25 MR. HERBEIN: Yes, sir. That would be an instance

1 where we might have to do it.

2 MR. EBERSOLE: I believe you said, didn't you say
3 loss of main steam?

4 MR. HERBEIN: I said steam supply system rupture, sir.

5 MR. EBERSOLE: So, steam supply system rupture --

6 MR. HERBEIN: We boil the steam generators
7 dry.

8 MR. EBERSOLE: You boil them dry so the turbine
9 pump is gone, but the electric aux feed pumps are still there.
10 Wait a minute; hang on. Isn't your answer now that in a
11 steam supply failure that you preserve a fraction of the
12 secondary system? I think that has to be your rationale
13 in view of containment pressure; isn't it?

14 MR. HERBEIN: Yes, sir. That's a good point. But
15 the procedure itself does address the steam system rupture
16 where we either isolate the steam generators or, in fact,
17 due to --

18 MR. EBERSOLE: Anyway, you hedge against it by
19 going to full operation anyway; it's the more conservative
20 thing to do.

21 MR. HERBEIN: The requirement is to maintain the
22 50 degree subcooling and anytime we're into an emergency
23 procedure where we're not able to do that the procedure
24 provides guidance to go with the high pressure injection
25 system and on an increase --

1 MR. EBERSOLE: I guess this gets down around again
2 to the matter of the level gauge and the absence of knowledge
3 of inventory primary coolant lobe. The subcooling gauge
4 will probably show subcooling, or it could show subcooling
5 even with a core coolant below the top of the core.

6 MR. HERBEIN: I don't think that's possible. I
7 think that as long as you've got the subcooling, that means
8 that the core is pressurized and, in fact, the fuel is cool
9 and you have not uncovered the core.

10 B&W care to comment on that?

11 MR. HALLMAN: Doug Hallman from B&W; I'll address
12 the case.

13 We're measuring the temperature here of the top of
14 the hot leg groups. And if, at that point, the temperature
15 and pressure indicates subcooling, you have solid water at
16 that point. You have steam underneath of that water which
17 drains out in such a way that it will provide coverage for the
18 core, so I'm able to say that in no way in which you are
19 subcooled to the top of the hot legs for the core to be
20 uncovered.

21 MR. EBERSOLE: You're subcooled at the top of the
22 hot leg; that's where you're making the measurement.

23 MR. HERBEIN: Well, that's only one of the points
24 where we're making the measurement.

25 MR. HALLMAN: Yes, sir.

1 MR. EBERSOLE: And for subcooled air, you invoke
2 the fact that there has to be water in substantial quantities
3 above the core.

4 MR. HALLMAN: There has to be water at the level
5 of the one you are referring to, yes, sir.

6 MR. EBERSOLE: Yes, that will work for you, but
7 it won't work for the CEUS deposit.

8 Thank you.

9 MR. ETHERINGTON: Does the Staff have any comments
10 to make?

11 MR. SILVER: No, sir.

12 MR. ETHERINGTON: Then, I think we're ready to
13 proceed to the emergency preparedness.

14 MR. HERBEIN: You're ready for emergency prepared-
15 ness, sir? I would like to turn it over to Mike Segaris to
16 address that.

17 MR. SEGARIS: Gentlemen, I've prepared just a
18 few remarks on emergency planning status for Three Mile
19 Island 1.

20 I'd like to start off with just bringing you up to
21 date on the chronology of the development of the revised
22 TMI 1 plan. In September of 1979, the NRC Task Force on
23 Emergency Planning met with representatives of the Metro-
24 politan Edison Company and the State of Pennsylvania to
25 describe and discuss the new requirements in the area of

1 emergency planning. Those primarily were NCFR 50, Appendix E,
2 Regulatory Guide 1.101; Emergency Plan Review Guideline
3 Number 1; TMI 1's order for restart; and a new document,
4 NUREG 610, which describes the emergency action level
5 required in the new emergency classification system.

6 Subsequent to those meetings, the State added a
7 utility to develop emergency plans to meet those requirements
8 and on October 28, 1979, a collected package of the State,
9 County, and utility plans were submitted to the Task Force
10 for review and comment.

11 In mid-November, the Metropolitan Edison Company
12 has received formal comments from the NRC after their review
13 of the plan, and made additional commitments and started
14 efforts to address these comments from the Commission.

15 On November 29, 1979, the Metropolitan Edison Com-
16 pany submitted its final revised plan for TMI 1 to the NRC for
17 review and included it into the Safety Evaluation Report for
18 the restart of TMI 1.

19 Concurrently in mid-December, a group from the
20 NRC's Office of State Programs and the Federal Emergency
21 Management Agency reviewed the State plan and presented
22 their comments in a formal meeting and discussed with the
23 State the requirements for a further upbrining to meet NRC
24 concurrence requirements.

25 During the month of December, the State then met

1 with each of the counties in the ten-mile radius to review
2 their plans in detail and discuss items which required further
3 upbringing to county plans.

4 And then finally in January of this year, the NRC
5 issued the Safety Evaluation Report on TMI 1, which you are
6 aware of and determined that the licensee's emergency plan
7 was consistent with the new and interim guidance, which I
8 mentioned.

9 Basically, there were no significant discrepancies
10 found, however, the Commission detailed several follow up
11 action items the Metropolitan Edison must address to achieve
12 full complicity. Those items are currently in progress and
13 an analysis is being performed and submittals are being
14 prepared.

15 I would just like to take a few minutes to review
16 a few of the significant conceptual changes in the emergency
17 plan. First of all, as I mentioned, the emergency plan now
18 addresses a new classification scheme; unusual event, alert,
19 site emergency, and general emergency. These classification
20 systems and the specific action levels that describe each of
21 them are based on instrument indications system status quench
22 perimeters that have been developed to describe the entire
23 spectrum of accidents from low consequence events to major
24 accidents.

25 The second conceptual change in planning has been

1 the adoption of the emergency planning zone concepts. The
2 low population zone is no longer of primary concern; there
3 are now two areas of concern: one the 50-mile emergency
4 planning zone, which you can see extends into Maryland.
5 The plan considerations for the 50-mile zone are considerations
6 for the injections exposed to the pathway. That has been
7 adopted in the State, county, and utility plan.

8 The other planning zone of interest is the 10-mile
9 emergency planning zone. The planning considerations for
10 that area are for plume exposure; the State, county, and
11 utility plans are coordinated for emergency response up to
12 and including evacuation in that area. It's significant to
13 note that the counties have maintained an evacuation
14 capability out to 20 miles and exceed the current require-
15 ments.

16 DR. FOSTER: I have a question there -- as I
17 read the intent of the NRC Staff when they put out the
18 Appendix E, these 10- and 50-mile radiuses were only intended
19 as approximations and there were some other guidance relative
20 to demographic patterns of land topographic patterns that
21 went with them.

22 I guess I was a little surprised to see that your --
23 both of these zones were, in fact, just exact 10 miles of
24 circles.

25 MR. SEGARIS: The purpose of this drawing, I do

show an exact 10-mile radius. However, the State has developed a specific map which does include demographic restraints of municipal boundaries and it is not a perfect circle. That map, I believe, is available now and you're correct; I believe the minimum distance on that map is 10 miles; however, it is jagged to coorespond with the kinds of things that you mentioned.

DR. FOSTER: Does the plume exposure zone extend up to include 2 miles beyond into Harrisburg then?

MR. SEGARIS: It's a 10-mile zone, as far as I know. Now, I'm not an expert on State's plan. It extends to the distance that I have shown, which means it intersects parts of Harrisburg.

DR. FOSTER: So, the actual planning in case of evacuation may, in fact, include a substantially larger number of people then you would indicate by your 10-mile radius.

MR. SEGARIS: Right, and as I mentioned, the counties, including Dauphin, have maintained and developed plans for evacuation up to 20 miles, which would include all of Harrisburg.

DR. FOSTER: Thank you.

MR. SEGARIS: The revised TMI 1 plan also incorporates additional accident assessment capabilities in line with the requirements of NUREG 578. Some of these items

1 include the establishment of a technical support center, the
2 ability to transmit data to that technical support center,
3 and the procedures for the engineers at the technical support
4 center to assess plant conditions. It is planned to trans-
5 mit this data to the offsite support center and there are
6 also plans and I believe that the hookup has been made to
7 transmit plant data to the Mountain Lakes' computer; that's
8 GPU headquarters.

9 The plan also includes improved organizational
10 approaches and communication systems for accident management.
11 There are detailed offsite organizations to cope with
12 accident situations and several dedicated phone systems in-
13 cluding the new NRC Red and Black phones, have been or
14 are being installed.

15 DR. FOSTER: I may have another question there.
16 This, if it's appropriate at this time, this relates to your
17 offsite monitoring teams; would this be a good time to
18 write that? In your emergency plan, it was provided with a
19 table which showed the number of people in the operations
20 group who were expected to be on plant who were available
21 for immediate call in.

22 I didn't notice on that particular table identifi-
23 cations of the monitoring-type people. Could you tell us
24 a little about where those monitoring people would come
25 from and how many are expected to be on duty all the time and

1 how long it takes to bring in people from off plant in order
2 to staff your offsite monitoring teams.

3 MR. SEGARIS: Basically, the requirements in the
4 plan call for any number of monitoring teams up to perhaps
5 three or four for on- and offsite. The teams are character-
6 istically manned by two individuals; the monitoring kits and
7 the phone communications radios are available at the site.
8 So that if you look at onsite teams and perhaps two offsite
9 teams, you're talking a total of about six people.

10 I believe that Mike Ross and -- perhaps correct me
11 if I'm wrong, but there are at least three health physics
12 technicians addressing only Unit 1 now, three health physics
13 technicians on the shift, four or five auxiliary operators
14 who are trained to the same level as the health physics
15 technicians are as far as radiation monitoring is concerned.

16 I believe the reason that you don't see that specified
17 in the plan is that during accident conditions, the coordinator
18 at the operations support center will designate who he wants
19 on what team. I do feel that there is a capability, initially,
20 to man three teams. Perhaps, not with two people; one
21 individual man who drives, stops his vehicle and takes his
22 survey.

23 DR. FOSTER: This would be three teams that would
24 handle -- a total of three teams that would handle both
25 onsite monitoring and offsite; is that right?

1 MR. SEGARIS: We're basically talking onsite
2 outside the plant and offsite. Additional individuals would
3 be require inside for monitoring purposes.

4 DR. FOSTER: So, you would probably under these
5 circumstances, wouldn't really expect to be sending more than
6 one or two cars off the plant; is that right?

7 MR. SEGARIS: I would say that initially, that
8 would be correct, perhaps two cars offsite.

9 DR. FOSTER: And are these cars dedicated to that
10 function or will they be competing with other people for them?

11 MR. SEGARIS: At any time there are vehicles
12 available for security and for the maintenance force. The
13 teams, normally, are located with the security people or
14 the maintenance foremen. And operations, I believe, also has
15 a vehicle -- no, operations has two vehicles and the shift
16 supervisor holds control over those. So, vehicles are avail-
17 able.

18 DR. FOSTER: Are there -- beyond this, do you have
19 the capability beyond that two or three people, two or three
20 teams to bring more teams in from people that are, perhaps,
21 off shift, or is that it?

22 MR. SEGARIS: Well, one of the things that I did
23 not mention is there is a large manpower force on Unit 2
24 which could be called on to supplement. What we've described
25 is the Unit 1 emergency plan with the capability for Unit 1

1 to handle any emergency in Unit 1. It has that capability.
2 Additional manpower can either be brought in from Unit 2 or
3 can be recalled, via the station recall team.

4 DR. FOSTER: What about the instrument that these
5 people need for measuring, let's say, dose rates off plant;
6 are kits available?

7 MR. SEGARIS: I believe that there are, I'm not
8 sure of the exact number, five or six seal kits which are
9 stored in emergency kit lockers in the security processing
10 center. Also in that area are six radios that are emergency
11 use only and are only to be used in cases where there is
12 an emergency. Those kits are inventoried periodically and
13 are always available for use.

14 DR. FOSTER: Will there be competition for inplant
15 and onsite use for those same kits?

16 MR. SEGARIS: Those kits are only designated for
17 offsite monitoring and for the monitoring team that would
18 be performing peripheral onsite monitoring.

19 DR. FOSTER: All right. Why don't you go ahead.

20 MR. SEGARIS: The last thing that I was going to
21 mention -- the plan details an emergency public information
22 plan which has been developed to provide the mechanism for
23 keeping the media informed of the latest technical informa-
24 tion. This information, in accordance with that plan, will be
25 provided by a single source.

Those are the only prepared remarks that I have.

DR. FOSTER: Have you had any contact at all with the FEMA people now that they're going to be entering into the emergency planning?

MR. SEGARIS: The only contact that I personally have had with the FEMA people was in a meeting in December where FEMA and the NRC Office of State Programs reviewed with the State their comments in regard to the State's plans.

DR. FOSTER: I'd kind of like to get back again to these offsite monitoring teams. I know from looking at the emergency plan that we had available that they're originally dispatched by the Met Ed people here.

I'm wondering perhaps a few hours into the situation when the Bureau of Radiological Protection is functioning. Would you anticipate that the Bureau of Rad Protection would be providing direction and guidance to these people, asking or specifying where they go or what they do?

MR. SEGARIS: Any interface between the Bureau of Radiation Protection and the Met Ed monitoring teams would be done through a relay through the control room. The Bureau of Radiation Protection does not directly control the monitoring teams. If they request some monitoring to be performed within a geographical area, they can make that request into the plant and then the plant could direct those to the monitoring locations.

1 The way the plan is designed to work is that the
2 people in charge of the control room based on the meteor-
3 ological conditions they have will place the teams in their
4 best judgment where they feel that the monitoring should be
5 done and then relay that information to the Bureau of
6 Radiation Protection.

7 DR. FOSTER: Well, would you expect perhaps after
8 the Bureau of Rad Protection got into operation that they
9 would be requesting your teams to go to certain sectors and
10 provide certain information?

11 MR. SEGARIS: What I would expect is that the
12 Bureau of Radiation Protection would dispatch its own teams
13 to perform and confirm measurements and to confirm our results
14 and perhaps monitor other areas in conjunction with the
15 Department of Energy monitoring teams.

16 I would not, I guess, expect direct requests for
17 deployment of the Met Ed teams; however, if the request
18 came, we would do that.

19 DR. FOSTER: In an initial monitoring offsite, can
20 you give us a little feel for what these monitoring teams
21 are going to be looking at and what they are going to be
22 measuring?

23 MR. SEGARIS: The monitoring teams will primarily
24 be measuring two things: direct radiation through the dose
25 rate meter, gamma and beta gamma --

1 DR. FOSTER: From what?

2 MR. SEGARIS: From a hand-held mobile instrument.

3 DR. FOSTER: Is this ground vegetation --

4 MR. SEGARIS: Well, these would be general area
5 readings. They would also be taking air samples and counting
6 those for -- to determine iodine concentration.

7 DR. FOSTER: They can do that in the field?

8 MR. SEGARIS: Yes, they can

9 DR. FOSTER: Is this generally trying to confirm
10 the direction of the plume?

11 MR. SEGARIS: Not only to confirm the direction
12 of the flume, but to confirm magnitude of the release and
13 then relay the information back to the plant so that the
14 plant can refine its measurements of source release terms
15 per second in the plant.

16 So, it's primarily for two things: to verify dir-
17 ection and to look at the magnitude of the releases based
18 on the projections being made in the plant.

19 DR. FOSTER: Are the vehicles which they will be
20 using radio equipped so that they can report back in that
21 fashion or is this a -- do they have to find a telephone?

22 MR. SEGARIS: As I mentioned when I was discussing
23 the kits, along with the kits are six, I believe six,
24 emergency radios that are constantly on charge in a desig-
25 nated locker for emergency use only. As they go out and pick

1 up a kit and a radio, then the vehicle can go.

2 DR. FOSTER: Fine. Thank you.

3 MR. ETHERINGTON: Are there any additional questions
4 from the Subcommittee or Consultants? Does the Staff
5 have any comments? Mr. Silver?

6 MR. SILVER: Excuse me one second.

7 MR. ETHERINGTON: All right.

8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

1 MR. SILVER: I'm sorry we might be able to dis-
2 cuss the role of Three Mile Island of the NRC and what
3 is happening involving the rules.

4 MR. ETHERINGTON: Yes, in general.

5 DR. FOSTER: Have you looked at the evacuation
6 plans of the State and the County?

7 MR. SILVER: Can I ask Mr. Roe of the NRC to
8 address this?

9 MR. ROE: Yes, sir. We have looked at the
10 evacuation plans of the area. We have also discussed that
11 December meeting on concurrence to State and local plans.

12 I also sent a letter to the licensee asking for
13 further information concerning the back breaking planning.

14 We ought to be able to receive the answer to that
15 letter shortly. I understand through informal contact
16 with the licensee that they have finished their discussions
17 with the Pennsylvania emergency management agency in
18 providing that information on evacuation plans.

19 The thing about general emergency management agency
20 is also in that meeting of December as part of the review
21 committee.

22 DR. FOSTER: Did that, in fact, include Harris-
23 burg?

24 MR. ROE: As Mr. Segaris said, they do have
25 evacuation plans that go through that 20-mile radius.

1 Which will include the City of Harrisburg.

2 DR. FOSTER: Do those plans include identification
3 of where the people would go to?

4 MR. ROE: Yes, sir.

5 DR. FOSTER: That's fine. Thank you.

6 DR. LAWROSKI: Is it appropriate here, or are
7 you going to cover it under item 8, your position with
8 respect to Reg guide 1.97, especially the Section C-3?

9 MR. HERBEIN: Mr. Chairman, I would like to
10 clarify one point.

11 The basic responsibility in the plans and in the
12 policies is that the State is really responsible for evacu-
13 ation. We, of course, intend to and are cooperating fully
14 with them in defining this effort and, of course, in the
15 unfortunate circumstance that were to occur, why we would
16 work with them, but the State has the ultimate responsibility
17 for evacuation.

18 MR. ETHERINGTON: Have they accepted that respons-
19 ibility to your satisfaction?

20 MR. HERBEIN: That's true. Yes, sir, they have.

21 DR. LAWROSKI: Do you think they have the re-
22 sources?

23 MR. HERBEIN: Pardon me, sir?

24 DR. LAWROSKI: Are the resources there in line
25 with what that responsibility may require?

1 MR. HERBEIN: I think that is a judgment that
2 FEMA has to make.

3 DR. LAWROSKI: Do you plan now or when to take
4 up the matter which was raised earlier today, I think,
5 by Mr. Catton on your position on Reg guide 1.97?

6 MR. HERBEIN: We are not prepared to address
7 that at this time, sir. We will see if we can't have
8 something on that tomorrow.

9 DR. LAWROSKI: Alright.

10 MR. ETHERINGTON: So, that is a matter which is
11 outstanding with the Staff still? It is unresolved with
12 the Staff?

13 MR. SILVER: Pardon me?

14 MR. ETHERINGTON: Dr. Lawroski was asking the
15 position on Reg guide 1.97.

16 MR. SILVER: We have not requested the licensee
17 to conform with Reg guide 1.97. Many of the, or some of the
18 specific items are included in the order do go in that
19 direction. No, we have not had a specific conformance with
20 the Reg guide.

21 DR. LAWROSKI: But, nevertheless, I would like
22 to hear what the licensee has to say about that.

23 MR. HERBEIN: Mr. Chairman, I would like to cor-
24 rect something that I said earlier. I indicated that we
25 would be prepared to make some remarks on the Reg guide

1.97 tomorrow morning. I would like to change that, sir. We believe we could be prepared by the time of the full Committee meeting to make some remarks on Reg guide 1.97 but it would be very difficult for us to do that tomorrow and have them be meaningful.

MR. ETHERINGTON: That would be satisfactory.

MR. HERBEIN: Thank you, sir.

MR. ETHERINGTON: Let's see. We have already covered training item 6, that brings us to item 7, scheduling our plan for long term actions listed in table B-1, NUREG 0578.

MR. SLEAR: Dave Slear, again. The discussion centered around the long term category B items, if you will, from NUREG 0578, and I have made up this slide to lead us through the specific topics, and some description of our clients.

As a general statement, from the standpoint of schedule, the engineering is proceeding on these items and I anticipate that in the March time frame we are going to be in a position to be buying equipment and we will have engineering complete in the May/June time frame, for these specific line items.

The area containment pressure which is a wide range several multiple of the design and pressure for the containment and indication of that, and we intend to comply

1 Regarding containment water level, we had in
2 advance of NUREG 0578 being issued reduced in our own
3 mind that we, in fact, wanted a wide range containment
4 water level that went above the level of the sump itself.

5 Specifically, we are going from the floor con-
6 tainment to a level of 10-feet high, with what I would
7 term a control grade instrument, fundamentally because
8 we didn't buy all the paperwork at the time when we
9 bought this particular instrument. That is being installed
10 through NUREG 0578 requires safety grade wide range and
11 in addition, requires the narrow range of the sump level
12 indicator itself be installed with the safety grade.
13 We intend to comply with those requirements operating the
14 pedigree of the existing control grade if practical and
15 buying a redundant one with a wide range and also replacing
16 the existing sump level indicator with a once again redundant
17 safety grade installation.

18 Regarding containment hydrogen this revolves
19 around the need for continuous on-line hydrogen measurement
20 from, I believe, 0 to 10%, and we intend to comply.

21 DR. CATTON: How did you choose the ten feet
22 for the containment water level?

23 MR. SLEAR: We took a look at -- Cortney you did
24 that analysis. I don't want to put my -- do you want to
25 describe how you selected that?

1 MR. SMYTHE: Courtney Smythe.

2 We did some calculations based on what water
3 was available from various tanks in this station, based
4 on the probable volume of the containment and came
5 up with an estimate of the water level that would seem that
6 is approximately six feet and .t that we should go some-
7 what beyond that as a contingency. So, ten feet
8 is selected.

9 DR. CATTON: Do you plan to move all of the
10 important instrumentation in electrical equipment and
11 so forth, above that level?

12 MR. SMYTHE: We are already proceeding the steps.

13 MR. SLEAR: I think the answer is yes, we are
14 already proceeding with steps to raise pressurizer level
15 and steam generator level instruments to the level of
16 six feet that he indicated and I guess, those are the
17 instruments that we felt were important and needed to
18 be moved and to my knowledge no other instruments have been
19 identified from the 0 to 6 elevation that would require
20 movement, if you will.

21 DR. CATTON: Aren't you at 17 already, at TMI 2?

22 MR. SLEAR: You mean the water level in TMI 2?

23 DR. CATTON: Yes.

24 MR. HERBEIN: It is seven and a half feet right
25 now, the last time I checked, but that has a different

1 capacity due to different building size than Unit 1.
2 I am not sure just how many gallons you use, Cortney,
3 that would relate to the ten feet.

4 DR. CATTON: Well, if there is a contingency
5 on your level sensors, gee, I would think there would
6 be the same contingency that you would apply to your
7 pressure transmitters and so forth.

8 Also, isn't there a box that you bring the
9 power to the pressure inter heaters? Isn't that pretty
10 low, too? Are you going to move it as well?

11 MR. HERBEIN: Charlie?

12 MR. HARTMAN: Charlie Hartman.

13 The pressurized heaters terminal box is on the
14 next floor up, it is not a very high level floor as the
15 305 elevation.

16 DR. CATTON: I was confused.

17 MR. SLEAR: With regard to RCS venting, our current
18 plans are we are proceeding with designing a remote venting
19 capability to be installed on the top of both of the
20 hotlegs themselves, and, in addition, are adding a motor
21 operator to manually operate the valve on top of the
22 pressurizer which would give us the ability to remotely
23 vent the pressurizer. The total criteria for these
24 vents is continuing to evolve where they will discharge
25 to and how they would be used, et cetera.

I feel reasonably confident the pressurizer then will remain discharging to the reactor fluent drain tank, is our normal DES path. I guess I don't know more details other than we perceive a need to vent the high points of the reactor fluent system as a mechanism of insuring if we avoided the hotlegs and for some reason natural circulation has been stopped, we can in fact vent non-condensables from the system, and re-establish natural circulation.

MR. ETHERINGTON: Is there still disagreement between you and the regulatory Staff on venting the top of the reactor vessel? I see nothing there, so maybe I should have asked the regulatory staff that question.

MR. VOLLMER: Yes, Mr. Chairman, there is still that disagreement and as I indicated earlier, this is likely one of the issues that we don't see any particular persuasion to depart from that position. I think the licensee has indicated that he can provide analysis which he would show that it is not necessary.

I think Mr. Slear was talking about the natural circulation. I think as far as the vessel venting itself and it is not a particular concern we have in that instance, it is the possibility of depressurization accident which would expand the gases in the vent and uncover the core. This is an area that still needs -----

1 MR. SLEAR: With regard to the plant shielding,
2 we are proceeding with the design review. I anticipate
3 that mid to late February that the -- well, the design
4 review is done, but, it is in the re-review state, if you will,
5 it has been done, and now it has to be gone over by the
6 various technical organizations within the company that
7 ought to have the prerogative to review this kind of assess-
8 ment in operation types of organizations, to make sure that
9 the criteria that we assumed and the assumptions made by
10 the technical engineers are, in fact, valid.

11 We have a plant shielding design review. It is
12 in the state of review, I anticipate that mid to late
13 February we will be able to draw conclusions with regard
14 to what additional shielding and/or other changes perhaps
15 might be required to meet the requirements contained in
16 NUREG 0578.

17 With regard to post accident sampling, we have
18 committed to being able to obtain a reactor coolant system
19 and to complete the analysis for heat parameters such as
20 boron and I presume, radioactivity, within 8 hours and
21 assess from the standpoint of given an accident situation
22 and the demand on people's time, the activity levels that
23 will be experienced and the need for a reasonable caution
24 and to proceeding with these samples, that 8 hours is
25 a reasonable commitment and we feel confident we can make

1 meet from the standpoint of getting a sample and having
2 it analyzed.

3 We recognize that there are heat parameters that
4 are useful in the early phases of an accident. This was
5 mentioned early before with things such as boron concentra-
6 tion and therefore, we are proceeding with an online boron
7 ometer. Things such as the hydrogen indication and insight
8 containment to assess the potential for problems due to
9 the hydrogen generation, we intend to, as the NUREG requires,
10 have it on line, continuous hydrogen monitor.

11 MR. ETHERINGTON: What is the principle of the
12 boronometer? Is it neutron absorption or --

13 MR. SLEAR: I don't think we have selected --
14 my understanding is that there are two fundamental mechanisms
15 for getting continuous boron measurements and we are
16 currently assessing which ones we think has the high
17 probability of functioning and I guess, I don't know the
18 details, I don't know if --

19 MR. HERBEIN: I can talk a little bit about boron
20 measurements.

21 Neutron source absorption is one method, using
22 a BF-3 neutron source and, of course, depending on the
23 boron concentration, why the degree of absorption and the sub-
24 sequent indication on the BF-3.

25 The other type is the titrating device. I

1 believe they use sodium mannitol.

2 The amount that has to be added to reach a given
3 end point, is a measure of the boron concentration.

4 MR. SLEAR: I think, fundamentally, the whole
5 subject of post accident sampling basically said get
6 samples, be able to analyze them for these various
7 parameters, and given the source terms that were in the
8 NUREG 0578 don't exceed extremity doses of 18 and 3/4 gram
9 and 3 1/2.

10 This to some extent revolves around the previous
11 discussion that takes a look at our existing sampling
12 capability for the reactor coolant system, for example and
13 for containment, gas samples, and assesses our ability to
14 get them with high radioactivity levels, without over-
15 exposing personnel. In addition, roles in such require-
16 ments as the on line boronometer. Should it be on the
17 left outline or there is a school of thought that says
18 the left outline of the isolator on reactor trip and
19 perhaps a new sampling sink continuously on research.

20 I guess the bottom line is, we are still establish-
21 ing criteria in this area, and determining what we feel
22 is appropriate to be done from the standpoint of post
23 accident sampling.

24 We feel that we are certainly going to meet
25 the intent of what NUREG 0578 requires, from the standpoint

1 of being able to assess the course of the accident, and
2 obviously, hope to be able to convince the NRC Staff
3 that we are, in fact, meeting the intent.

4 In regard to high range radiation monitors,
5 we fundamentally intend to comply with NUREG 0578.

6 Are there any questions?

7 DR. DILLON: Yes, there is one mild inconsistency
8 as I understand the situation, having to do with the rela-
9 vant value to you in analyzing the situation on the vola-
10 tile fission products that you might collect from the sample.

11 As I understand your sample condition is a cool
12 non-pressurized sample in which you could well have lost the
13 vol of this one sample before you get around to an analysis.

14 MR. HERBEIN: Mr. Potts, perhaps you could
15 address the -- the issue is the loss of volatile fission
16 products from a depressurized sample.

17 I believe we advocate the ability to take pres-
18 surized samples, and that is in fact the kind that we take --

19 MR. POTTS: We do, indeed, take pressurized
20 samples.

21 MR. HERBEIN: We have the capability to take
22 a pressurized sample, sir. That in turn, of course, gives
23 us all the gas.

24 MR. DILLON: Is that capability something that
25 is in prospect, or do you have it currently?

1 MR. HERBEIN: We have that capability now.

2 MR. SLEAR: I would presume this would maintain
3 the capability but also, I am sure, that the people getting
4 that sample were, in fact, overexposed, and that you
5 could get it in a timely fashion given high radiation
6 conditions.

7 That is the extent of --

8 MR. EBERSOLE: Before you turn that out, may I
9 just go back one moment to the vent.

10 Do you have the completed design for the vents,
11 and an operating procedure for them?

12 MR. SLEAR: We have what I guess you would
13 call a conceptual --

14 MR. EBERSOLE: Conceptual. How do you anticipate
15 operating the vents, are you going to vent until water
16 appears?

17 MR. SLEAR: I guess it is my understanding from
18 the technical engineers that in order to adequately utilize
19 the vents that we might provide for the hot legs that we
20 would need some sort of a void indicator on the hot leg
21 itself in order to allow the operator to assess when he
22 had been successful at removing the void.

23 The mechanism for providing that void indicator is
24 yet to be determined. There are those, I guess sound
25 is an option, light is an option, DT cells are an option,

1 and the bottom line is, yes, I think we will end up
2 with a void indicator.

3 MR. EBERSOLE: Isn't the effect that water is
4 coming through, is an option is just like the old
5 locomotives.

6 MR. SLEAR: I guess that is an option, too.

7 MR. EBERSOLE: And, that is the simplest option.

8 MR. SLEAR: Yes, sir. If we can figure out
9 a mechanism for detecting --

10 MR. EBERSOLE: There used to be a thing called
11 a tricok, which you used to guage -- in essence, that is
12 what this is.

13 If water is coming through, there must not be
14 a void in any of the valves.

15 MR. SLEAR: Yes.

16 MR. EBERSOLE: Why make it complicated when
17 you can make it simple?

18 MR. SLEAR: I think we are trying not to make
19 it complicated which is why I perhaps, wasn't saying, yes
20 we are going to have a hot leg model meter but rather trying
21 to assess how we would use it on, I guess, perhaps, I was in
22 general, saying we need a void indicator in the hot leg.

23 We need to have an indication of when the void
24 has been removed from the hot leg and certainly --

25 MR. HERBEIN: And, I don't know that that would

1 require additional instrumentation of Dave to tell us that.

2 MR. EBERSOLE: Let me go a minute.

3 Something went by me a bit too fast a while ago,
4 and I have been trying to understand it ever since.

5 Your saturation meter is not sensitive to accept
6 the two parameters, that is temperature and pressure.

7 MR. SLEAR: Yes, that is correct.

8 MR. EBERSOLE: In no way, can it sense volume or
9 inventory. For instance, let me ask you the question --
10 what do you expect your saturation meter to read? If I
11 had water covering the core by one-half inch, what would
12 your saturation meter read that would tell me that I am
13 that far down and that close to trouble?

14 MR. HERBEIN: You mean you have a half of an inch
15 of water left?

16 MR. EBERSOLE: Of water cover. Or even I might
17 go below the top of the core because --

18 MR. HERBEIN: I would expect at that point you
19 would be at saturation and you wouldn't have the margin
20 indicator on the device.

21 MR. EBERSOLE: I would not know I was there, would
22 I?

23 MR. HERBEIN: You would, in fact, know you were
24 there. You would no longer have the 50° subcooling if
25 you only had an inch of water over the core.

1 MR. EBERSOLE: Why? Couldn't it still have
2 a proper balance between pressure temperature --

3 MR. HERBEIN: Because I assume that what you have
4 got on the top of that water is steam. That steam is
5 going to --

6 MR. EBERSOLE: No, no. I said I am holding
7 pressure and temperature with a citation meter, except
8 the water is not that low.

9 MR. HERBEIN: The titazine off the hot leg and,
10 in fact, it the -- as we stated earlier, by maintaining
11 the subcooling margin at the hot leg we have got a liquid
12 full system because of the elevation of the Candycanes.

13 If you have got water in the Candycane, and you
14 have got the subcooling based on the hot leg RTD then, in
15 fact, you have a liquid full system.

16 Now, the situation that I think that you have
17 just described, I would have to assume that the Candycane
18 was not liquid full.

19 MR. EBERSOLE: Right, it is now empty. It
20 has steam in it.

21 MR. HERBEIN: And as a result of that --

22 MR. EBERSOLE: But I am still at saturation
23 conditions. I can have a margin.

24 MR. HERBEIN: That is my point, sir. You are
25 at saturation and the meter would tell us that.

1 MR. EBERSOLE: But, it wouldn't say how close
2 to trouble I am.

3 MR. HERBEIN: It would tell us that we were in
4 trouble by our procedures, because we maintain a 50°
5 subcooling requirement in our procedures and --

6 MR. EBERSOLE: I understand, but you are telling
7 me and I am may be misunderstanding this, that I could have
8 that 50° temperature mark, and in some way this would tell
9 me that I have some core inventory above the level that I
10 specified.

11 How can you -- do I have a mental block here?

12 MR. SLEAR: Yes, I don't see how you have water
13 in the hot leg --

14 MR. EBERSOLE: Oh, now, wait a minute.
15 Who said I had water in the hot leg?

16 MR. SLEAR: The only way that saturation meter is
17 going to indicate that you have 50° subcooling is to have
18 water covering the temperature detector, and the temperature
19 detector is on top of the hot leg.

20 To get water to the top of the hot leg, you filled
21 the hot leg. Unless, you had an inadvertent loss of gravity.

22 MR. EBERSOLE: You are invoking the head that is
23 there.

24 MR. SLEAR: Pardon me?
25

1 MR. EBERSOLE: You are invoking the head in the
2 hot leg. You are taking the credit for the head going up
3 to the air vent?

4 MR. SLEAR: Yes.

5 MR. EBERSOLE: Right?

6 MR. SLEAR: Yes.

7 MR. EBERSOLE: So, again, you can do this, but
8 others can't.

9 MR. HERBEIN: That's right, yes, sir.

10 MR. EBERSOLE: So, that is only a few PSI, by
11 the way, I don't know how high the hot leg is.

12 MR. SLEAR: It is about 35 feet.

13 MR. EBERSOLE: So, you are utilizing that parti-
14 cular characteristic of your system to claim that.

15 Okay, I see what you mean now. Thank you.

16 DR. CATTON: On your slide you indicated the
17 containment hydrogen and compliance, I don't recall what
18 your compliance was, could you?

19 MR. SLEAR: The NUREG 0578, as I recall, indicated
20 that we needed to have on line, continuous hydrogen indica-
21 tion in the containment atmosphere on a scale of 0 to 10%.

22 DR. CATTON: Now, where are you going to put
23 this instrument that will give you compliance?

24 MR. SLEAR: I don't think we know yet, exactly
25 where we are going to put it. I presume this is something

1 much as the existing sampling system which takes the
2 section on containment and, in fact, discharges back to the
3 containment and goes through some sort of a detector.

4 DR. CATTON: Then, I think that should say will
5 comply, rather than comply.

6 MR. SLEAR: Oh, I am sorry.

7 All of these should probably say will comply. This was
8 to be a presentation of where we are going with regard for
9 long term items and I guess you are absolutely right.
10 In every case, where I put comply, it should say we intend
11 to comply.

12 DR. CATTON: I also think you have a rather
13 difficult analysis to do to determine what the mixing
14 patterns are within the containment to decide where you
15 ought to put it.

16 MR. SLEAR: I guess -- maybe I am suffering under
17 illusion, but I was here during the accident and we are
18 all worried about hydrogen and I got the message that the
19 experts that were here said hydrogen diffusion is against
20 the law of nature, and that it is going to pocket something.
21 The diffusion is going to be everywhere unless you have a
22 little dome that is going to catch it in a room where it
23 is being generated.

24 DR. CATTON: You have a big dome to catch it.

25 MR. SLEAR: Yes, but from the standpoint of

1 you know, it is not going to just because hydrogen is
2 light it doesn't go to the top of the dome, in my under-
3 standing. It diffuses. I guess we have to confirm that in our
4 own minds, but we have not been, at least I have not been
5 perceiving that we had a major evolution and analysis to do
6 with regard to hydrogen diffusion and worrying about pocket
7 swallowing.

8 DR. CATTON: I don't know if you do or you
9 don't, but most hazards analyses associated with hydrogen
10 assume that it rises and gets in pockets and people usually
11 use skimmers to avoid it.

12 TMI 1, as far as I can tell in going through it,
13 does none of these things. Maybe your circulation is strong
14 enough and you have got your ducts pointed in the proper
15 direction that you get complete mixing but that was not
16 obvious to me.

17 MR. SLEAR: I think we have some homework to do.

18 MR. TAYLOR: Mr. Etherington, Jim Taylor from
19 B and W, and I would like - -

20 MR. ETHERINGTON: Would you come up where you
21 can speak into a mike, please?

22 MR. TAYLOR: Just a question of clarification on
23 high point vents to see if we can better understand the
24 position that the Staff is taking.

25 We have a feeling that --we have a firm feeling,

1 that because of the unique configuration of the B and W
2 system, the way the hot leg comes out above the core and
3 goes up through the Candycane, that we are in very much
4 agreement, I think that the utilities that we are working
5 with agree with us. The high point vents on the top of
6 the Candycanes and the pressurizer are appropriate.

7 Because of the configuration of the loop, we
8 think that it is not necessary to have high point vents
9 on the reactor vessel head, and in fact that there are
10 some disadvantages to having a vent there.

11 Now, it is obvious that there is a difference
12 in the configuration and the thing that we would like to
13 make sure of is that the requirement for reactor vessel
14 head vents is not just a generic thing without recognition
15 of the difference in configuration.

16 MR. SILVER: If I may respond to that. It at
17 the moment, at least, is a general thing, rather than
18 a generic thing. We certainly would like to see B and W and
19 Met Ed's justification for not having this reactor vessel
20 head vent. But, again, as Mr. Vollmer pointed out the
21 critical accident perhaps is the depressurization accident
22 with a bubble in the top of the reactor rather than in
23 TMI 2 scenario. That is with the hydrogen generation
24 and then the depressurization of that, where I don't
25 see that Candycane vents would, in fact, would do the job,

1 since you have started with the bubble in the top head.

2 MR. ETHERINGTON: Are any of the Staff's
3 analyses and according to my figuring the temperature
4 at the top of the head was not sufficiently high to
5 cause flashing at the pressure system.

6 I shouldn't have injected this now but it was
7 assumed that the metal was hot enough to cause flashing
8 of steam in the head. At the time you found this by
9 that little nicky on the level trace and the pressure
10 drop the saturation and pressure had not been reached
11 even in the head. It is something to look at anyhow.

12 MR. TAYLOR: The point that we were interested
13 in pursuing is that the way the top light comes out,
14 unless the depressurization vent were one which were
15 very subtle and if there is indeed some void indication
16 on the hot leg, as Mr. Slear said, then all of the gases
17 are going to flow up to the Candycane from which it is
18 ventilated.

19 MR. SILVER: At a slow rate. Whatever the rate
20 is.

21 MR. TAYLOR: Yes, the only kind of accident that
22 could get into trouble which would not show up by the gas
23 flow and would not allow the gas to flow up the Candycane
24 would be if there was a very , very sudden depressurization,
25 such that the Candycane vents are not going to take away

1 the gas, but under those conditions, neither is the reactor
2 vessel head vent.

3 MR. SILVER: I am not sure that it is proper to
4 engage in this stuff, but I might point out that you
5 could have vented the head previously, so that there would
6 not be this residual bubble in the head, if there were a
7 head vent.

8 MR. TAYLOR: It would be good if we could --
9 in order to bring us together, we could understand the
10 criteria. We have a unique configuration and we want that
11 recommended.

12 MR. SILVER: Indeed.

13 I do have some other comments, sir, if I may?

14 MR. ETHERINGTON: Yes, please.

15 MR. SILVER: As Mr. Slear pointed out on most of
16 these, in effect should be will comply's rather than do, and
17 this relates to our own comments in the status table where
18 we, in fact, did indicate why against the lessons learned
19 items of containment pressure water level and hydrogen level,
20 again, the requirement is to make reasonable progress against
21 these items.

22 We consider that at this time or the time of
23 safety evaluation, in fact, reasonable progress has been
24 made.

25 That, of course, is a changing requirement with

1 time. A month or six months from now, quite obviously,
2 more progress will or had to be made. We will so
3 note such progress is appropriate.

4 Again, I would repeat, I guess, what Mr. Slear
5 said that in some of these items we have not seen any
6 submittal at all at this time. For example, of plant
7 shielding which he did indicate would be submitted in
8 mid to late February, and other plants who have already
9 submitted this and counted some trouble in our review.
10 I hope that we will have less with TMI 1.

11 With regard to close to action sampling, we
12 have quoted a letter to the licensee quite recently within
13 a matter of days, pointing out the requirement of the lesson
14 learned on the task force to have a sample -- the results
15 of a sample be available in two hours.

16 In formal discussions, and I am a little bit con-
17 fused on this point, it was my understanding -- third
18 hand, I might say, that the formal discussions have
19 indicated that the licensee has, in fact, agreed to go
20 along and can accomodate this remark.

21 If that is not correct perhaps we could clarify
22 it now.

23 MR. HERBEIN: Dave, can you address that the
24 accomodation of the Staff's position that we would be able
25 to take a sample of the reactor coolant system within two

1 hours?

2 MR. SLEAR: I discussed this with Mr. Dubiel
3 last night to make sure that I was not offtrack. Mr.
4 Dubiel is the right man who would have been assessing
5 our capability to get and analyze within two hours the
6 sample and the fact that we should not be committing to
7 that because it presents difficulty in the accident
8 situation.

9 He sent it to agree with the 8-hour contract
10 that I have in here, so it is not obvious who within
11 our company agrees to it.

12 MR. HERBEIN: Harley, is this within two hours
13 of an initiating event?

14 MR. SILVER: Yes, I think that is --



15 MR. TAM. Two hours from the time they decided
16 the example.

17 MR. CLARK: Philip Clark of GPU.



18 We certainly are in agreement in trying to get
19 a sample as early as practical.

20 I don't think we yet see any concrete step that
21 we could take to get it in two hours that we aren't taking
22 already.



23 Having recently been fined for rushing in to get
24 a sample at the expense of an unnecessary radiation exposure
25 in the minds of some people, we are reluctant to commit in



**IMAGE EVALUATION
TEST TARGET (MT-3)**



MICROCOPY RESOLUTION TEST CHART



1 an emergency to, in fact, be able to carry out in two
2 hours.

3 If there are simple, practical steps that would
4 facilitate taking it in two instead of eight, we certainly
5 would consider and I think would try to take them.

6 The discussion is, do you commit two hours in an
7 emergency with the other things that have to be done, and
8 I think that is the basis for our present disagreement with
9 the Staff.

10 DR. LAWROSKI: Was the exposure primarily in
11 getting the sample or in arranging from that point on to
12 get the analysis?

13 MR. CLARK: The time limit, as I understand it,
14 is to take the sample and analyze it. So, the endpoint
15 includes both getting and analyzing the sample.
16
17
18
19
20
21
22
23
24
25

1 MR. ETHERINGTON: Okay, the next item is the last,
2 isn't it? Under the Radiation Protection Plan.

3 MR. ARNOLD: Mr. Bill Potts.

4 MR. POTTS: Good afternoon, gentlemen.

5 As the manager of radiological controls for Three
6 Mile Island Unit One, I am responsible for the development
7 implementation and enforcement of the radiological controls
8 program. I report to the Vice President --

9 MR. ETHERINGTON: What about Mohammed coming to the
10 mountain?

11 MR. POTTS: I'm here to describe the radiation
12 protection plan and the radiological control organization.
13 I'll start with the organization.

14 We've reorganized my group into three sections:
15 first is the radiological engineering group, which contains
16 a supervisor and the engineers; second, I have a field section
17 which contains a supervisor, a foreman for each shift, and
18 the technicians on those shifts; finally, I have an administra-
19 tor with clerical staff to control the paperwork and document
20 system.

21 The Radiation Protection Plan is a compilation
22 of philosophies, policies, and objectives which we feel
23 will make an excellent radiological control program. The
24 object of the plan is to maintain exposures within regulatory
25 limits as low as reasonably achievable, and also to increase

1 the effectiveness of our control program. Details of how
2 that program operates are found in our procedures manual.

3 The Radiological Control Program is based on the
4 philosophy that radiological control is everyone's responsi-
5 bility, not just those personnel bearing the title "Radiologi-
6 cal Control Department". We stress with all our personnel,
7 at TMI, their responsibility to minimize their exposure
8 at all times -- that includes actions necessary from each
9 manager, supervisor, and worker at TMI-1.

10 The policy of the control program is its verbatim
11 compliance is mandatory in all phases including operation,
12 design, maintenance, and administration.

13 The Radiation Protection Plan requires that the
14 Rad Con Department stop any work which is not in concert
15 with good radiological control practices.

16 To assure that the requirements of the control
17 program are being met, and to assist in the management of
18 that program, we have a system of audits, reviews and reports
19 that have seven elements.

20 The first element is the control technicians who
21 monitor and aid the radiological workers in performing their
22 work.

23 Second, is the radiological engineering group
24 reviews on a regular basis performance of the radiological
25 control technician, placing particular emphasis on areas

1 that have a high potential for radiological difficulties.

2 An assessment function is conducted on a continuous
3 basis by an inspector who reports independent of the Rad
4 Con Group to the Vice President.

5 Further, we have q/a audits of the Radiological
6 Control Program on a periodic basis. Periodically an outside
7 consultant will be retained and is presently advising me
8 in revising the program. We have the Plant Operations Review
9 Committee, who reviews and comments on the Radiation Protec-
10 tion Plan and such procedures as I would request.

11 Finally, we are developing a system that will
12 identify and document, resolve radiological control deficien-
13 cies no matter how insignificant they may appear.

14 The purpose of the system is to provide a mechanism
15 for continuous improvement of the control program. To provide
16 us with an increased ability to meet the objectives of
17 the Radiation Protection Plan an extensive training program
18 has been developed, parts of which Mr. Lawyer earlier dis-
19 cussed.

20 I will mention several differences -- several
21 items that he did not include in his description.

22 We have a general indoctrination for employees
23 not directly involved with radiation to provide them with
24 an understanding of radiological hazards and what restrictions
25 are placed upon them.

1 Occupationally exposed people are trained and
2 retrained to provide them with an understanding of the facts
3 and risks associated with radiation exposure to give them
4 an understanding of their responsibilities within this program
5 and also conditions under which they would be exposed.

6 Radiological workers are required to pass written
7 examinations, pass a practical practice examination, and
8 to requalify annually.

9 The work which involves higher than usual exposure,
10 we're requiring special briefings in the use of mockups.

11 Finally, the training for the radiological control
12 technicians and foremen have been considerably increased
13 to include theoretical and practical training of the use
14 of our procedures in the program and also places emphasis
15 on training to handle unusual situations such as a contaminated
16 or injured individual or a radioactive spill.

17 Following the training programs for the technicians
18 and foremen they are required to pass both the written and
19 an oral examination and also, in addition to that, there
20 are periodic drills for the shift workers.

21 Our control of exposure, external exposure, is
22 based on the assumption that any exposure involves some
23 risk, however slight, and with inaccepted limits that risk
24 is small compared to the normal hazards of life.

25 During our training and in the manual and procedures

1 we emphasized the philosophy that exposure as low as reasonably
2 achievable requires an active participation by all personnel
3 at TMI.

4 The Rad Con Department's responsibility is dis-
5 charged by way of establishing administrative exposure levels
6 lower than those in part 20. We establish manaram exposure
7 goals for each major job and for each year. We require free
8 planning of work that involves exposure and major exposure
9 jobs requiring corporation of radiological controls into the
10 design and procedure in the pre-job briefing and rehearsal.

11 Control of internal exposure, it is our policy
12 to control that to as low as reasonably achievable and that,
13 to us, means that no one should be exposed to anything greater
14 than ten percent of the internal exposure. This is accom-
15 plished, primarily, through controlling of surface contamina-
16 tion and airborne radioactivity. Exposure to airborne
17 radioactivity -- the control for that is, primarily, one
18 of engineering controls and controlling access as a first
19 priority and using respiratory protection only when with
20 medically qualified personnel and only when engineering
21 solutions are not feasible.

22 Personnel who are qualified to use respiratory
23 protection are required to requalify annually in the use
24 of the respirator with a quantitative and qualitative fit
25 and a medical examination.

1 And, finally in control of internal exposures
2 we use a whole body counter annually for all those radioactive
3 workers and any instant of internal exposure above a level
4 near a background would be investigated to determine how
5 that exposure occurred and an effort would be made to prevent
6 it in the future.

7 That concludes my prepared remarks.

8 Do you have any questions?

9 DR. FOSTER: Did the reorganization of your parti-
10 cular function that you mentioned, did this occur more or
11 less coincidental with the reorganization in unit one which
12 recently occurred or the Unit two, I should say?

13 MR. POTTS: It occurred very recently, yes, sir.

14 DR. FOSTER: During an emergency situation there
15 will be a dose evaluator, I believe that it is mentioned
16 in the plan. Is that one of your people?

17 MR. POTTS: The Dose Assessment Coordinator. Yes,
18 sir, it is.

19 DR. FOSTER: That actually makes the estimates
20 of or projections for off site as well as on site dose?

21 MR. POTTS: Yes, sir. Yeah.

22 DR. FOSTER: Back to these field monitors, are
23 those your people?

24 MR. POTTS: Yes, sir.

25 DR. FOSTER: Okay. They, in fact, then are separate

1 from the operating course.

2 MR. POTTS: That is correct, sir, I report --
3 my group reports to the Vice President.

4 DR. FOSTER: Yeah.

5 DR. LAWROSKI: Do all the hospitals around this
6 area agree to accept contaminated injuries to individuals?

7 MR. POTTS: The Hershey Medical Center hasn't, as
8 to the question of all out referred to --

9 Our plan calls for the Hershey Medical Center,
10 and they have agreed to accept those casualties.

11 DR. LAWROSKI: Is that the only one?

12 MR. POTTS: I'm sorry, I can't answer that.

13 MR. HERBEIN: Sir, we're in the process of obtaining
14 a letter of agreement similar to the ones that we obtained
15 before Unit One was licensed. That does involve a number
16 of these kinds of these activities of the State police,
17 fire departments, and area hospitals, medical assistance,
18 and so on. That's currently underway.

19 DR. LAWROSKI: Thank you.

20 DR. FOSTER: Back to the projection of these off
21 site doses, kind of focusing on this because it has a lot
22 of implications, obviously, in terms of protective action
23 and whether it is going to be taken or not, I realize that
24 the protective action is something which is initiated by
25 the State people. But, I have a feeling that a lot of their

1 decision in that matter will really come from you people
2 who are making these dose projections.

3 Is this perception correct or do you anticipate
4 that they are going to be duplicating the same sort of thing
5 which your people are doing here?

6 MR. POTTS: I'm not in a position to answer a
7 question having to do with the State's intention, sir.

8 MR. HERBEIN: Sir, to the best of my knowledge,
9 the State does plan to have capability with regard to environ-
10 mental sampling and analysis.

11 Additionally, the Brookhaven Laboratory is available
12 on short notice and that they have that kind of capability
13 so I wouldn't see that it would be only plant technicians
14 that would be involved in the off site dose assessment.

15 However, were the accident to be of great magnitude
16 without sufficient time then we do have the capability with
17 our on site abilities that Mr. Tsaggaris previously mentioned
18 to take on site and off site samples and make appropriate
19 evaluations and, of course, communicate those to the various
20 State and civil defense organizations.

21 DR. FOSTER: I noticed in your emergency plan
22 that it refers to a second implementation manual. It makes
23 reference there that you would be using this implementation
24 manual to estimate doses relative to E.P.A. Protective Action
25 Guides in providing this information to the State emergency

1 centers and I was trying to get a little better feel for,
2 you know, the people that are actually involved in -- I
3 guess -- using the manual making additional assessments
4 and feeding that kind of information.

5 MR. POTTS: The Senior Radiological Control Engineers
6 are the men who make those assessments.

7 DR. FOSTER: Incidentally, since you're going
8 to be bringing some of the training manuals tomorrow morning,
9 would it be possible to get a look at your emergency implemen-
10 tation manual. Is that practical?

11 MR. HERBEIN: I think, at the present time, that
12 implementation manual is currently under preparation because
13 it does contain all of the implementing or, at least, the
14 majority of the implementing emergency plan procedures;
15 of which, I understand, there are some 40 and approximately
16 30 are prepared so I'm not sure that the implementing emergency
17 plan manual is, in fact, available.

18 DR. FOSTER: All right, thank you.

19 MR. ETHERINGTON: Are there any further questions?
20 Would the staff like to comment?

21 MR. SILVER: Yes I would have a word of explanation
22 of our entering in our status table where indicated the
23 date of February 15th against the radiation detection plan
24 with the review complete by the supplement.

25 We have, in fact, of course received the radiation

1 detection plan formally have had a meeting with Metropolitan
2 Edison on it and have informed them of a rather large number
3 of comments we had on the original radiation detection plan.

4 We have received informally a signed copy, I guess,
5 of the plan but not a formal submittal on the docket of
6 the revision to the plan which, in fact, does answer
7 almost all of the points we have raised.

8 There are, however, four items still outstanding
9 which we will communicate to the licensee immediately and
10 hope for a response in early February sometime.

11 In fact, one or two of the items may have been
12 addressed in Mr. Potts' comments today.

13 If I may, I would like to regress, for amoment,
14 back to the lessons learned on long-term items. There was
15 a matter that I tended to discuss and elected to. I would
16 like to, before I do that, I would like to reiterate, though,
17 the staff position with regard to vessel head vents at the risk
18 of redundancy and comment what the position is at this time to
19 acquire vessel head vents and if, in fact, that it proposes and
20 B & W proposes not to provide this we would have to be con-
21 vinced that this is not, indeed, a good idea.

22 I would like to ask John Vodelwede of --

23 MR. ETHERINGTON: Could I ask on this one, does
24 Met Ed have a serious difficulty in providing a head vent?

25 MR. HERBEIN: Sir, I think we do but I'm not prepared

1 to develop the specifics at this time.

2 MR. ETHERINGTON: All right. Well it's still between
3 you and the regulatory staff at present?

4 MR. HERBEIN: That's correct, sir.

5 MR. SILVER: I would like to ask Mr. John Vodelwede
6 of the staff to discuss some other long-term items which
7 we had not listed separately under long-term groups, because
8 they are, in fact, combined with or discussed with short-
9 term items that are in the lessons learned discussion.

10 There are perhaps some items that should be dis-
11 cussed, at this time.

12 John, will you do that?

13 MR. VODELWEDE: I wonder if I could use the mike,
14 she's having trouble hearing.

15 MR. SILVER: I'm having trouble talking.

16 MR. VODELWEDE: My name is John Vodelwede. I would
17 like to comment on Mr. Slears slide in which he identified
18 long-term lessons learned items.

19 We think that it is somewhat deficient, our source
20 of information is table 8-1 in the staff's evaluation in which
21 I in light of my recall items which were not in catalog A
22 which is short-term. I come up with something like 18 rather
23 than seven. Among those items which I think should have
24 been considered on the slide which were not is the vessel
25 human level detector which was not there.

1 The current staff position is that for a long-
2 term instrumentation needs for inadequate core cooling that
3 the vessel level detector is necessary but not sufficient
4 to meet that long-term requirement.

5 Another item is we need upgrading of the Technical
6 Support Center. The short-term requirement is essentially
7 that such a center shall be established. The long-term
8 requirement is considerably more complex than that. Each
9 one of these items are coupled to the short-term requirements
10 of the new rates. Until we see some justification to turn
11 away from the current staff positions on such things as
12 the level detector we have to assume that that's still a
13 requirement.

14 MR. EBERSOLE: Pardon me. I have to make an ad-
15 mission here.

16 It just came to me with almost shocking clarity
17 that if cool temperature measurement is also a level
18 gauge, that is it has to be under liquid.

19 MR. VODELWEDE: I do not believe that that's the
20 case.

21 MR. EBERSOLE: Once it entered the steam phase
22 it can't be so cooled.

23 MR. VODELWEDE: The saturation meter takes its
24 inputs temperature and pressure, pressure transducer does
25 not need to handle liquid phase changes --

1 MR. EBERSOLE: I know, but the temperature measure-
2 ment.

3 MR. VODELWEDE: It does not either. A thermo-
4 couple for example as one wants to use that could use
5 it for the steam.

6 MR. EBERSOLE: But you put it in the top of the
7 candy cane.

8 Now, let me get my thinking straight here. You're
9 putting this measurement in the top of the candycane then
10 invoking your particular geometry here to do this rather
11 than seeking Westinghouse geometry.

12 MR. VODELWEDE: I think you're talking about the
13 steam generators.

14 MR. EBERSOLE: Yeah, the top of the steam generator.

15 Do you --

16 MR. VODELWEDE: I would prefer to have a measurement
17 close to the core as possible.

18 MR. EBERSOLE: Well, anyway, you did it up there.
19 Is that where you are -- are you not putting the temperature
20 measurement at the top of the candycane?

21 MR. VODELWEDE: I believe your question should
22 be referred to the licensee.

23 MR. HERBEIN: The temperature measurement is at
24 the top of the candy cane.

25 MR. EBERSOLE: Now, is this not true that the

1 temperature measurement made there on which you require
2 50 degrees after cooling necessarily must be under water.

3 MR. HERBEIN: Yes, sir, if we're --

4 MR. EBERSOLE: And if it isn't under water you
5 don't get the subcooling.

6 MR. HERBEIN: That's correct.

7 MR. EBERSOLE: So, therefore, it's a level gauge.

8 MR. HERBEIN: Yes, sir.

9 MR. EBERSOLE: So, therefore, you don't need a
10 level gauge because you've got one in a lefthanded way.

11 MR. HERBEIN: I would agree with that.

12 MR. ETHERINGTON: It's not a level gauge it's
13 a --

14 MR. EBERSOLE: Oh, I know it isn't a level gauge,
15 but it says there's water, and then water is there and gravity
16 hasn't failed it's going to be below.

17 MR. HERBEIN: I would also refer to the staff's
18 remark concerning the proximity of the temperature detector
19 to the fuel.

20 Yes, the subcooling meter ties off the temperature
21 detector at the top of the candycane in a hot leg.

22 Additionally, our procedures do refer to the
23 in-core thermocouples which are right above the fuel.

24 Our procedures require that we maintain subcooling
25 on both the hot leg, the cold leg, and also on the

1 thermocouples above the fuel assemblies.

2 We maintain the 50 -degree subcooling on all
3 of those temperature readouts.

4 MR. EBERSOLE: Somebody correct me if I am wrong.
5 I am reading this now as being the following: If
6 I have 50 degrees subcooling at the top of the candycane
7 I've got solid water there.

8 MR. HERBEIN: Yes, sir, that's what we have stated.

9 MR. EBERSOLE: If I've got solid water there then
10 I also have it on the core.

11 MR. HERBEIN: Yes, sir.

12 MR. EBERSOLE: Because there's no monometer blockage
13 between that point and the top of the core.

14 MR. HERBEIN: That's correct.

15 DR. CATTON: But if you reach saturation you'd
16 have no idea what you've got.

17 MR. EBERSOLE: Right.

18 DR. CATTON: Even all the way down to the core
19 because you could be reading saturation at the very high
20 void.

21 MR. EBERSOLE: But you must have the subcooled
22 condition.

23 DR. CATTON: So, once you reach saturation then
24 you have to go into your feed and bleed mode independent
25 of whether you need to or not.

1 MR. EBERSOLE: Yes.

2 DR. CATTON: Unless you do something else.

3 MR. EBERSOLE: Right.

4 DR. CATTON: Is that correct?

5 MR. HERBEIN: We need to keep the high pressure
6 injection system on, and if, in fact, that takes us out
7 through the P.O.R.V. and subsequently the code safeties
8 in order to achieve that 50 degrees of subcooling then we're
9 prepared to do that and our procedures provide that guidance.

10 DR. CATTON: So, rather than put more instrumentation
11 then you are willing to take that penalty of maybe feed
12 and bleed when you don't really need to, is that correct.

13 MR. HERBEIN: Yes, sir, I think that's an affirmative
14 statement and that's our position.

15 DR. CATTON: Okay, I understand.

16 MR. ETHERINGTON: Now, that brings with it a price
17 and that is you feed and bleed with everything you've got
18 all high pressure injections. I think your design says you can
19 feed and bleed with a hypothetical failure in the feed-bleed
20 system, that is the, you know, one-inch piece.

21 The usual concept of a single failure in the high-
22 pressure injection system. But at that point, though, you
23 could then turn off half that capacity and judge from the
24 design characteristic that you'd still be feeding and bleeding
25 at an adequate core level even though you couldn't see it,

1 Right?

2 MR. HERBEIN: Right.

3 MR. EBERSOLE: You would have no confirmatory
4 information as to where the level was. You would just say
5 I am meeting what I think is my design goal but I wouldn't
6 confirm this. You do not confirm this by actual level pres-
7 sure?

8 MR. HERBEIN: Bob Keaton, do you want to address
9 that?

10 MR. KEATON: Well, that is true as long as you're
11 talking about the water level down low, but you would get
12 a confirmation of where the water level was before you went
13 into a full feed and bleed mode, since you would measure
14 the water level in the pressurizer.

15 MR. EBERSOLE: Well that, unfortunately, has the
16 same problem in it, yet as the TMI-2 Case did. That water
17 level reference is not a valid indication of the level above
18 the core.

19 MR. KEATON: It would not be a valid reference
20 of level above the core if it was at saturation conditions,
21 that's true and in that case we would have to continue to
22 fill it and go into the feed and bleed mode. But I might
23 be able to avoid it if by the time I fill the pressurizer
24 I also had re-established the necessary subcooling. In
25 which case then my procedures would permit me to avoid going

1 into the feed and bleed mode.

2 MR. EBERSOLE: Thank you.

3 DR. CATTON: When you have an overcooling
4 situation, you are going to possibly get down to satura-
5 tion. You're going to lose your subcool.

6 Does that mean you'd come on full feed and
7 bleed as if you have a loss of fluid action?

8 MR. KEATON: Once again my answer is the same.
9 Yes, you come on with full H. P. I. but whether you
10 carry it all the way to a full feed and bleed depends
11 upon whether you can re-establish subcooling and I think
12 in the case of an overcooling accident that, in
13 fact, you would re-establish subcooling part of the
14 time that you fill the pressurizer.

15 DR. CATTON: Would you even if you lost actual
16 circulation?

17 MR. KEATON: If you lose natural circulation
18 I would --

19 DR. CATTON: Obviously, you wouldn't, I guess.
20 Okay.

21 MR. KEATON: I think, obviously you wouldn't.
22 I agree, yes.

23 DR. CATTON: Which brings up one last question
24
25

1 that I asked earlier. How low can you get in the steam
2 generator on the secondary side without -- and still maintain
3 natural circulation?

4 MR. KEATON: I'm sorry excuse me?

5 DR. CATTON: How low can you get on the secondary
6 side and still maintain natural circulation?

7 MR. KEATON: I do not have an unequivocal answer
8 to the question. We know that at 50 percent level in the
9 steam generator that there is very ample natural circulation
10 from the geometry it appears that a level of about 120 inches
11 in the steam generator corresponds to the mid-plane of the
12 core. So, on a very simplistic argument one might argue
13 that at that point it would be difficult to produce the
14 driving forces for natural circulation so somewhere between
15 a level of 50 percent and down at 120 inches is the cross-
16 over point but I don't know exactly where that is.

17 DR. CATTON: Is it important that you know it?

18 MR. KEATON: No, sir, because our procedures
19 say to take it above 50 percent.

20 MR. ETHERINGTON: No further questions on this
21 topic?

22 MR. KEATON: I might add something, it is, however,
23 as a matter of fact true that we're doing analysis to try
24 to find out where the point is. I just don't think that
25 we required the procedures.

1 DR. CATTON: When you complete your analysis and
2 find it I would very much like to know what it is.

3 MR. KEATON: Yes, sir, and we'll be glad to transmit
4 that information.

5 MR. ETHERINGTON: I think that concludes our formal
6 agenda.

7 I understand that Ms. Riley from the Pennsylvania
8 State Department of Environmental Resources has arrived
9 recently and she is willing to supply us additional information
10 about the ten-mile protective action radius.

11 Ms. Riley?
12
13
14
15
16
17
18
19
20
21
22
23
24
25

TAPE 14-1

MS. REILLY: I am Margaret Reilly and I'm with the Bureau of Radiation Department of Enviromental Resources, and I am here to discuss any questions that you might have about the 10 mile radius. The first one will probably be in reference to the agency task force report between NRC and EPA in a matter of defining what distance is to be considered in emergency planning. That's where that number came from.

Now, where--how really that number was derived that near, that was never been quite clear to me. There appears to be a mix of opinion even between the agencies who developed the guidance. EPA maintains that it is 10 miles from PAG only and NRC maintains that it is 10 miles for short term effects reasonably so.

All I can say is 10 miles, its been a bone of contention of mine for sometime; so I'm still where I was.

DR. FOSTER: Thank you, Maggie. Part of the questioning that I started out with a little earlier was that in that original document there were a lot words that said about 10 miles and you really should take into consideration topography and demography and other features and drawings of that. And the answer we received will, for the purposes of the state, that it wasn't 10 miles at all, that the evacuation zone, could in fact, go out in some cases as far as 20 miles and perhaps either the state or county plans did include

perhaps all of Harrisburg. So, I wonder how does the state view this situation?

MS. REILLY: Well, there's a lot of discussion going, as you can imagine; of course, you have the guidance which says 10 mile. The guidance says, for instance, if you have the outer edges of a densely populated area hanging on there, it is up to the state or the agency as to whether they are to include it or exclude it from the area.

As a result of the events of the weekend of March 30, 31 and April 1, which--I don't want to be disrespectful, but it sounded as if there was an auction going on in Bethesda. First, they had 10 miles in the guidance and suddenly it's 20; and 20 has been sold now, at least in terms of the counties in the area. The state is telling the countries -- the state through PEMA, that is the Pennsylvania Emergency Management Agency, is saying, 10 miles because that is what the guidance says. But the counties, especially through the county commissioners since they were given 20 before, they are going to take again. So, for this particular site the planning posture is one of 20 miles solutionating in the counties. I don't know if I answered your question or not.

DR. FOSTER. Yes, I think so. You have submitted your state plan to the NRC.

MS. REILLY: Yes, one was submitted in the fall. We got comments back from the Regional Advisory Committee

1 and another re do was going in sometime in February with
2 recommended changes and some words that were required or
3 recommended that weren't in there.

4 DR. FOSTER: Did you have this Pluming exposure
5 zone defined in your documents to them at all?

6 MS. REILLY: We discussed Pluming exposure, of
7 course, and methods of assessing or trying to develop pro-
8 tective action, based on what's going on. The general
9 approach that we have been using is one that we, the Bureau
10 of Radiation Protection, have been using as one of facing
11 protective action recommendation on what is going on in the
12 plant rather than relying on offsite mishigants (?) who take
13 offsite mishigants (?) as a conformation of things that are
14 more worse than you think they are.


15 We're--the method that we're using, if we need
16 to project Plumes, is using convection overlays; we are
17 looking into some other options, but we are looking at the
18 overlays right now.

19 DR. FOSTER: I guess the bottom line is a statement.
20 A person dealing with such emergency should they occur. Are
21 you satisfied that the existing plans at the present time
22 that can adequately respond do to conditons?

23 MS. REILLY: I think from our tehcnical side, we're
24 all right and I think, well this is still a personal opinion,
25 because I'm not really in a position to systematically

CERTIFICATE OF AUTHENTICATION


This is to certify that the attached transcript of the meeting of the Advisory Committee on Reactor Safeguards, Subcommittee on Three-Mile Island, Unit 1, Nuclear Power Plant, held in Middletown, Pennsylvania, was held as herein appears, and that this is the original transcript thereof for the file of the Commission.



Sue Glocker



Janice Smith



Sharon Corsanico

1 evaluate the generic aspects of the plant, I think that
2 they are in considerably better shape than they had been.

3 DR. FOSTER: If you had to move the people, you feel
4 the basic state plans, counties, are in place in order to
5 do this.

6 MS. REILLY: I wouldn't say they're a 102 percent
7 in place but things are being worked on rather studiously.
8 Specific routing has been worked out with what kind of traffic
9 flow possibilities, that sort of thing. There have been some
10 informal estimates made as to how long it would take to
11 evacuate, say 10 miles all around; they are working on
12 several approaches. For instance, if you are considering
13 a smaller radius, how would we do it?

14 DR. FOSTER: Okay, thank you.

15 MS. REILLY: Any questions?

16 MR. ETHERINGTON: I might mention that tomorrow
17 morning that the Committee will not hear the Item 10 on
18 Organizational Changes because of Mr. Arnold's absence.

19 I think that concludes the session for the day --

20 MR. SILVER: Sir, I'm not sure that I heard you.
21 You said that we will not hear that?

22 MR. ETHERINGTON: We will not hear that; that's
23 the first item, Item 10.

24 MR. SILVER: Thank you.

25 MR. MULLER: Will your people here start Item 2,

1 the second item?

2 MR. SILVER: I will speak with them tonight, and
3 make sure that they will be here.

4 (Whereupon, the meeting was adjourned at 6:05 p.m.)
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25