

1777

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CONT.

0	1
---	---

 REPORT SOURCE

L	0	5	0	-	0	3	2	4	7	0	1	2	3	8	0	8	0	2	1	2	8	0	9
---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---

20 31 REPORT NUMBER 40 50 EVENT DATE 64 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

VENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
During normal plant operation, 2B reactor recirculating pump tripped. On 2/10/80,

the recirculation pump again tripped in a similar manner.

Technical Specifications 3.4.1.1, 6.9.1.9b

SYSTEM CODE C B 11		CAUSE CODE E 12		CAUSE SUBCODE A 13		COMPONENT CODE G E N E R A 14		COMP. SUBCODE D 15		VALVE SUBCODE Z 16	
EVENT YEAR 8 0 21 22		SEQUENTIAL REPORT NO. 0 2 0 24 25 26		OCCURRENCE CODE 0 3 28 29		REPORT TYPE L 30		REVISION NO. 0 32			
ACTION TAKEN A 18		FUTURE ACTION X 19		EFFECT ON PLANT B 20		SHUTDOWN METHOD Z 21		HOURS 0 0 0 0 22 23 24 25		ATTACHMENT SUBMITTED N 23	
NPRD-4 FORM SUB Y 24		PRIME COMP. SUPPLIER N 25		COMPONENT MANUFACTURER G 0 8 0 26 27 28 29							

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

Fuses F18 and F19 in the voltage feedback circuitry for the voltage regulator were

I found blown. The fuses were replaced and the pump successfully restarted. This

event occurred twice in December 1979 (LER 2-79-88). A technical representative

I arrived on site on February 11, 1980, and work is progressing to resolve the

problem.

FACILITY STATUS (1) 5 (2) F (3) 28
 % POWER (4) 0 (5) 9 (6) 5 (7) 29
 OTHER STATUS (8) NA
 METHOD OF DISCOVERY (9) A (10) 31
 DISCOVERY DESCRIPTION (11) 32
 OPERATION SURVEILLANCE
 ACTIVITY CONTENT (12) 1 (13) 6 (14) Z (15) 33 (16) 34
 RELEASED OF RELEASE (17) NA
 AMOUNT OF ACTIVITY (18) NA
 LOCATION OF RELEASE (19) 36
 PERSONNEL EXPOSURES (20) 1 (21) 7 (22) 0 (23) 0 (24) 0 (25) 37 (26) Z (27) 38
 DESCRIPTION (28) 39
 PERSONNEL INJURIES (29) 1 (30) 0 (31) 0 (32) 0 (33) 40 (34) 41
 DESCRIPTION (35) 41
 LOSS OF OR DAMAGE TO FACILITY (36) 1 (37) 3 (38) Z (39) 42 (40) 43
 DESCRIPTION (41) NA
 PUBLICITY (42) 2 (43) 0 (44) N (45) 44
 ISSUED DESCRIPTION (46) 45
 NRC USE ONLY
 80022 00 437
 68 69

NAME OF PREPARER A.C. TOLLISON, JR.

PHONE: (919) 457-9521

NRC USE ONLY

NA 80022 00

POOR ORIGINAL