

LICENSEE EVENT REPORT

PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION

01 | N | C | B | E | P | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | 5

REPORT SOURCE: L 6 | 0 | 5 | 0 | - | 0 | 3 | 2 | 4 | 7 | 0 | 1 | 1 | 6 | 8 | 0 | 8 | 0 | 2 | 1 | 1 | 8 | 0 | 9

02 | To reduce the amount of contaminated water in the torus that would have to be pr-

03 | cessed during the outage when the torus is to be drained, Operations was filling the

04 | torus to near the upper limit from the CST through the core spray suction piping, re-

05 | circulating the torus with the RHR system, and then pumping the torus to a lower level

06 | to Radwaste. During one of these evolutions, the torus was filled to -25.5 inches,

07 | exceeding the -27 inch limit. Technical Specifications 3.6.2, 6.9.1.9b

09 | SYSTEM CODE: S A 11 | CAUSE CODE: A 12 | CAUSE SUBCODE: A 13 | COMPONENT CODE: Z Z Z Z Z 14 | COMP SUBCODE: Z 15 | VALVE SUBCODE: Z 16

17 | LER NO REPORT NUMBER: 8 0 | EVENT YEAR: 8 0 | SEQUENTIAL REPORT NO.: 0 1 4 | OCCURRENCE CODE: 0 3 | REPORT TYPE: L | REVISION NO.: 0

ACTION TAKEN: X 18 | FUTURE ACTION: X 19 | EFFECT ON PLANT: Z 20 | SHUTDOWN METHOD: Z 21 | HOURS: 0 0 0 0 | ATTACHMENT SUBMITTED: N 23 | NPRD-4 FORM SUB.: Y 24 | PRIME COMP. SUPPLIER: Z 25 | COMPONENT MANUFACTURER: Z 9 9 9 26

10 | The torus was immediately pumped down to the desired level. While a filling of the

11 | torus was in progress, the Operator's attention was diverted for approximately one

12 | minute on another problem, and when he returned, the level was high. Operation Pro-

13 | cedure OP-17 will be revised to require a second Operator to monitor torus level when-

14 | ever the level is being changed. All Operations personnel will review this LER.

15 | FACILITY STATUS: E 28 | % POWER: 0 9 9 29 | OTHER STATUS: NA 30 | METHOD OF DISCOVERY: A 31 | DISCOVERY DESCRIPTION: Operator Surveillance 32

16 | ACTIVITY CONTENT RELEASED OF RELEASE: Z 33 | Z 34 | AMOUNT OF ACTIVITY: NA 35 | LOCATION OF RELEASE: NA 36

17 | PERSONNEL EXPOSURES NUMBER: 0 0 0 37 | TYPE: Z 38 | DESCRIPTION: NA 39

18 | PERSONNEL INJURIES NUMBER: 0 0 0 40 | DESCRIPTION: NA 41

19 | LOSS OF OR DAMAGE TO FACILITY TYPE: Z 42 | DESCRIPTION: NA 43

20 | PUBLICITY ISSUED DESCRIPTION: N 44 | NA 45

NAME OF PREPARER: A. C. Tollison, Jr. | PHONE: 919 457-9521

8002200441

POOR ORIGINAL