LICENSEE EVENT REPORT

CONTROL BLOCK: [ ] (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | A L J M F 1 (2) | 0 0 - 0 0 0 0 0 - 0 0 (3) | 4 1 1 1 1 (4) | (5)
7 8 | 9 LICENSEE CODE 14 | 15 LICENSE NUMBER 25 | 26 LICENSE TYPE 30 | 57 CAT 58

CON'T

01 | REPORT SOURCE L (6) | 0 5 0 0 0 3 4 8 (7) | 0 1 1 8 8 0 (8) | 0 2 1 3 8 0 (9)
7 8 | 60 | 61 DOCKET NUMBER 68 | 69 EVENT DATE 74 | 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 At 1140 on 1-18-80, during the performance of FNP-1-STP-33.0 (Solid State Protection
03 System Operability Test) on B Train SSPS, the 1B Hi-Hi Steam Generator Level Logic
04 failed the logic test requirements. As a result, one train of automatic actuation
05 safeguards logic was declared inoperable. Tech. Spec. 3.3.1.1, in part, requires
06 2 trains to be operable. Tech. Spec. 3.3.1.1 action statement requirements were met.
07 Health/safety of the public were not affected.
08 9 80

09 | SYSTEM CODE I A (11) | CAUSE CODE E (12) | CAUSE SUBCODE G (13) | COMPONENT CODE I N S T R U (14) | COMP SUBCODE X (15) | VALVE SUBCODE Z (16)
7 8 | 9 10 | 11 | 12 | 13 18 | 19 | 20

(17) LER/RO REPORT NUMBER | EVENT YEAR 8 0 | — | SEQUENTIAL REPORT NO. 0 0 5 | / | OCCURRENCE CODE 0 3 | REPORT TYPE L | — | REVISION NO. 0
21 22 | 23 | 24 26 | 27 | 28 29 | 30 | 31 | 32

ACTION TAKEN C (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS 0 0 0 0 (22) | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORMSUB. N (24) | PRIME COMP. SUPPLIER N (25) | COMPONENT MANUFACTURER W 1 2 0 (26)
33 34 | 35 | 36 | 37 40 | 41 | 42 | 43 | 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

11 Event was caused by a failed "universal" card in B Train SSPS. The card was replaced
12 and FNP-1-STP-33.0 was successfully re-performed. The affected train was returned
13 to service at 1225 on 1-18-80.
14
7 8 9 80

FACILITY STATUS E (28) | % POWER 1 0 0 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY B (31) | DISCOVERY DESCRIPTION (32) Performance of surveillance test
7 8 9 | 10 12 | 13 44 | 45 | 46 80

ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA
7 8 9 | 10 | 11 44 | 45 80

PERSONNEL EXPOSURES
NUMBER 0 0 0 (37) | TYPE Z (38) | DESCRIPTION (39) NA
7 8 9 11 | 12 | 13 80

PERSONNEL INJURIES
NUMBER 0 0 0 (40) | DESCRIPTION (41) NA
7 8 9 11 | 12 80

LOSS OF OR DAMAGE TO FACILITY (43)
TYPE Z (42) | DESCRIPTION NA
7 8 9 | 10 80

PUBLICITY
ISSUED N (44) | DESCRIPTION (45) NA | NRC USE ONLY
7 8 9 | 10 68 | 69 80

8002200553

POOR ORIGINAL

NAME OF PREPARER W. G. Hairston, III PHONE: (205) 899-5156