

LICENSEE EVENT REPORT

CONTROL BLOCK.

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	N	C	B	E	P	1	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5
---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	--	--	---

CON'T

REPORT SOURCE: 01 L 6 0 5 0 - 0 3 2 5 7 0 1 1 4 8 0 3 0 2 1 1 8 0 9

02	While performing PT 3.1.2PC, CST low water level channel calibration CST level
03	switch 1E41-LSL-N002 was found to actuate at 23' 0" decreasing. This switch shifts
04	the HPCI suction from the CST to the suppression pool. The reportable limit for
05	this switch is less than 23' 4".
06	
07	
08	Technical Specifications 3.3.3, 6.9.1.9a

SYSTEM CODE S F 11		CAUSE CODE E 12		CAUSE SUBCODE E 13		COMPONENT CODE I N S T R U 14		COMP SUBCODE S 15		VALVE SUBCODE Z 16							
EVENT YEAR 8 0		SEQUENTIAL REPORT NO. 0 0 3		OCCURRENCE CODE 0 3		REPORT TYPE L		REVISION NO. 0									
ACTION TAKEN E 18		FUTURE ACTION X 19		EFFECT ON PLANT Z 20		SHUTDOWN METHOD Z 21		HOURS 0 0 0 0 22		ATTACHMENT SUBMITTED N 23		NPRD-4 FORM SUB. Y 24		PRIME COMP. SUPPLIER N 25		COMPONENT MANUFACTURER R 2 9 0 26	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1	0	The switch was found to be out of calibration. The instrument was calibrated and
1	1	returned to service. An Engineering Work Request has been submitted requesting
1	2	assistance in determining and correcting the problem.
1	3	
1	4	

1 5 E 28 0 9 5 29 NA 30
 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60
 ACTIVITY CONTENT
 1 6 Z 33 1 34 NA 35
 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60
 RELEASED OF RELEASE AMOUNT OF ACTIVITY LOCATION OF RELEASE 36

RECEIVED EXPLOSIVES									
NUMBER			TYPE	DESCRIPTION					
1	2	3	4	5	6	7	8	9	10
0	0	0	17	2	38	NA			

PERSONNEL INJURIES		DESCRIPTION		(41)		
NUMBER						
1	R	0	C	0	(40)	NA

POOR ORIGINAL

7	8	9	11	12	80
LOSS OF OR DAMAGE TO FACILITY (43)					
TYPE		DESCRIPTION			
1	9	Z	(42)	NA	

7 8 9 10
PUBLICITY
ISSUED N 14 DESCRIPTION 45
NA 8002200 613 NRC USE ONLY
2 0 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20

NAME OF PREPARER A. C. Tollison, Jr.

PHONE: 919-457-9521

NRC USE ONLY

NA

8002200613

68 69

010