(7 77)

LICENSEE EVENT REPORT

CONTROL BLOCK: [ ] (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | CT MNS2 (2) | 0 0 - 0 0 0 0 0 - 0 0 (3) | 4 1 1 1 1 (4) | (5)
LICENSEE CODE | LICENSE NUMBER | LICENSE TYPE | CAT

CON'T

01 | REPORT SOURCE L (6) | 0 5 0 0 0 3 3 6 (7) | 0 1 3 1 8 0 (8) | 0 2 2 0 8 0 (9)
DOCKET NUMBER | EVENT DATE | REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During steady-state operation, leakage was observed from the packing on 2-SI-654, "B"-
03 HPSI header isolation valve. While the operability of the valve was not affected, to
04 meet the intent of IE Circular 79-21, the valve was removed from service and repaired.
05 The plant was operated in accordance with Technical Specifications 3.5.2 for eleven
06 hours and twenty minutes. Valve data: 900# 6 inch Velan gate with motor operator.
07
08

09 | SYSTEM CODE SF (11) | CAUSE CODE X (12) | CAUSE SUBCODE Z (13) | COMPONENT CODE VALVEX (14) | COMP. SUBCODE E (15) | VALVE SUBCODE D (16)

(17) LER/RO REPORT NUMBER | EVENT YEAR 80 | — | SEQUENTIAL REPORT NO. 002 | / | OCCURRENCE CODE 03 | REPORT TYPE 1 | — | REVISION NO. 0

ACTION TAKEN A (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS 0000 (22) | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER A (25) | COMPONENT MANUFACTURER V085 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The worn packing was removed and the valve visually inspected. There was no
11 apparent damage. The valve was repacked and restored to service. The worn
12 packing did not affect the functioning of the valve, but the valve was repaired
13 to reduce ECCS system leakage.
14

15 | FACILITY STATUS E (28) | % POWER 100 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY A (31) | DISCOVERY DESCRIPTION (32) Operator Observation

16 | ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

PERSONNEL EXPOSURES

17 | NUMBER 000 (37) | TYPE Z (38) | DESCRIPTION (39) NA

PERSONNEL INJURIES

18 | NUMBER 000 (40) | DESCRIPTION (41) NA

LOSS OF OR DAMAGE TO FACILITY (43)

19 | TYPE Z (42) | DESCRIPTION NA

PUBLICITY

20 | ISSUED N (44) | DESCRIPTION (45) NA | NRC USE ONLY

8002260 6885

NAME OF PREPARER R. W. Rothgeb PHONE: 203-447-1791 EXT. 543