

LICENSEE EVENT REPORT

CONTROL BLOCK: 1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 MDCCN1 2 00-00000000-000 3 411111 4 5

CON'T
01 L 6 05000317 7 0201180 8 022780 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

02 | At 1000 during the performance of surveillance testing, it was discovered
03 | that the hose for one of two cntmt. elev. 10' hose stations was removed
04 | from the station. The hose was replaced at 1010 restoring operability
05 | to the hose station. At approximately 2100 on 2/9/80 during an operational
06 | tour, it was discovered that one of two hose stations hoses at cntmt.
07 | elev. 10' was removed from the station. The hose was replaced at approximately
08 | 2110 restoring operability to the hose station per T.S. 3.7 11.4.

09 A B 11 A 12 F 13 X X X X X X 14 7 15 7 16
17

H 18 X 19 Z 20 Z 21 00000 22 Y 23 N 24 Z 25 Z 9 9 9 9 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

10 | During the unit outage on two separate occasions a work group requested
11 | permission and obtained a permit of authorization to use the fire system
12 | for cleaning purposes on the 10' elev. of cntmt.
13 |
14 |

15 G 28 0000 29 NA 30 B 31 Surveillance Testing 32

16 Z 33 Z 34 NA 35 NA 36

17 000 37 Z 38 NA 39

18 000 40 NA 41

19 Z 42 NA 43

20 N 44 NA 45

NAME OF PREPARER J. S. Lagiewski/L. O. Wenger PHONE: (301)269-4747/4734

8002280 599

LER NO. 80-09
DOCKET NO. 50-317
EVENT DATE 02/01/80
REPORT DATE 02/27/80
ATTACHMENT

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES: (CONTINUED)

A second containment elevation 10' hose station remained operable during both events.

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS: (CONTINUED)

Although the work group was aware of recently initiated controls requiring issuance of permits for the use of the fire system, they did not interpret and fully implement the specific limitations of these controls. Specifically, the work group used existing hose station equipment (in violation of procedures) instead of providing equipment. To prevent recurrence of these events all potential users will be trained on the use of the fire system for non-fire-fighting purposes. In addition, permanent signs will be installed at each hose station cautioning and instructing personnel in the use of this equipment.