

## ENCLOSURE 2

M190192

Comment Summary Table and Draft SE Markup

Non-Proprietary Information

### **IMPORTANT NOTICE**

This is a non-proprietary version of Enclosure 1, which has the proprietary information removed. Portions of the document that have been removed are indicated by white space with an open and closed bracket as shown here [[            ]]

**Comment Summary for Draft Safety Evaluation for Licensing Topical Report  
 NEDE-33885P, Revision 0, "GNF CRDA Application Methodology"**

**Note:** Page numbers shown in this table reflect the page numbers in this enclosure.

Location	Comment
Page 1 / Line 13	Revise "Road" to "Rod."
Page 1 / Lines 14 through 17	Recommend revised language to clarify CRDA LTR as it pertains to prior TRACG and PANACEA methodologies.
Page 1 / Line 19	Recommend addition of the word "codes."
Page 2 / Lines 30 and 31	Recommend revised language to clarify licensee adoption and use of the new technology.
Page 5 / Line 48	Recommend revising "acceptance criteria" to "potential critical parameters."
Page 9 / Line 13	Should be GESTAR II and not GESTAR III.
Page 9 / Line 26	Recommend additional clarifying language.
Page 9 / Line 39	Recommend revision of [{" }] for consistency.
Page 12 / Line 41	Recommend revision of "limit the time steps to sizes" to "allow the time steps sizes."
Page 13 / Lines 3 and 4	Recommend addition of "due to control blade movement."
Page 13 / Line 6	Recommend addition of "negative reactivity insertion."
Page 14 / Line 3	Recommend change of [{" }]
Page 14 / Line 38	Recommend deletion of [{" }]
Page 15 / Line 21	Recommend change of [{" }]
Page 15 / Lines 43 through 45	Recommend revised language to better reflect the situation.
Page 22 / Line 36	Recommend addition of "of."
Page 25 / Line 14	Recommend revision of [{" }]
Page 26 / Line 1	Recommend revision of "maximum average enthalpy" to "maximum radially averaged enthalpy."
Page 27 / Line 16	We refer to our version of TRAC as "TRACG" and not "TRAC-G."
Page 31 / Various Lines	There are three instances where a "t" was added to "weighted" under Delayed Neutron Fraction.
Page 32 / Various Lines	There are two instances where we recommend "3D" rather than "3-D" under Rod and Assembly Power Distribution.
Page 35 / Line 41	Recommend deletion of ", or less than," language.

<b>Location</b>	<b>Comment</b>
Page 38 / Line 13	Should be GESTAR II and not GESTAR III.
Page 38 / Lines 43 through 46	Most recent version of GESTAR is Revision 29.
Page 39 / Lines 47 through 49	Most recent version of NEDE-33173P-A is Revision 5.

# NON-PROPRIETARY INFORMATION

## OFFICE OF NUCLEAR REACTOR REGULATION

### DRAFT SAFETY EVALUATION FOR GLOBAL NUCLEAR FUEL – AMERICAS, LLC (GNF)

#### LICENSING TOPICAL REPORT NEDE-33885P, Revision 0,

#### “GNF CRDA APPLICATION METHODOLOGY”

(EPID: L-2018-TOP-0006)

### **1.0 INTRODUCTION**

By letter dated February 28, 2018 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML18059A874), Global Nuclear Fuels – America, LLC (GNF-A), submitted for U.S. Nuclear Regulatory Commission (NRC) staff review a licensing topical report (LTR), NEDO-33885/NEDE-33885P, Revision 0, “GNF CRDA [Control Rod Drop Accident] Application Methodology” (Ref. 1), herein described as the “CRDA LTR”). **In the CRDA LTR the previously approved TRACG and PANACEA analysis methodologies are extended** The CRDA LTR is an extension of the previously approved TRACG and PANACEA analysis methodologies for evaluation of the CRDA event. This safety evaluation (SE) only addresses the applicability of the CRDA LTR to the boiling water reactor (BWR) product lines and fuel types for which the TRACG and PANACEA **codes** have previously been approved (Ref. 2). In addition, the CRDA LTR includes discussion of how the update process inherent in the GESTAR-II methodology would be used to apply this methodology to potential future scenarios such as new fuel types or methodology updates.

TRACG is a thermal hydraulics analysis code package that also includes a three dimensional (3D) kinetics model for detailed calculation of neutronic feedback during transient events. PANACEA is a 3D core simulator code that primarily functions as a stand-alone steady state core simulator and depletion code. While it includes transient calculation capabilities, the heat transfer and hydraulics models are much simpler than those utilized by TRACG. TRACG is approved by the NRC for use in a broad set of BWR transient and accident scenarios, including anticipated operational occurrences (AOOs), anticipated transients without scram (ATWS), loss-of-coolant accidents (LOCAs), and potential instability events. PANACEA is primarily used for depletion and some limited applications. However, PANACEA has been accepted by the NRC for use in CRDA calculations as part of the certification of the Economic Simplified Boiling Water Reactor design (Ref. 3). A third code that is implicitly included in the overall analysis methodology is the PRIME fuel thermal mechanical performance evaluation code, which has been previously approved by the NRC. This code is not used directly in the CRDA calculations; however, it is used to derive a number of important fuel rod properties used as input by TRACG during the CRDA evaluation. In the CRDA LTR, GNF-A proposes to use PANACEA to perform

[[

]], use TRACG to perform [[

]] to demonstrate that the acceptance criteria are met for the CRDA event.

Enclosure

NON-PROPRIETARY INFORMATION

## 2.0 BACKGROUND

The historical basis for GNF-A analysis methodologies for the CRDA event is the Banked Position Withdrawal Sequence (BPWS), as described in NEDO-21231, "Banked Position Withdrawal Sequence," January 1977. (Ref. 4). The intent of this approach is to establish a generic control rod withdrawal sequence that would ensure that control rod worths from a dropped rod would, in all cases, be sufficiently limited to meet the legacy NRC CRDA acceptance criteria (a peak enthalpy of no greater than 280 calories (cal)/gram (g), and rarely exceeding 170 cal/g for fuel cladding failure). The control rod worths are minimized through banking of control rod banks at specified positions, and generic analyses are used to demonstrate that the fuel rod enthalpies will be adequately limited by the given control rod worths.

Since NEDO-21231 (Ref. 4) was approved by the NRC, additional research in reactivity initiated accidents (RIAs) has identified that the previously mentioned legacy acceptance criteria (e.g., 280 cal/g peak enthalpy) are not adequate. In particular, two separate failure mechanisms were identified, high temperature cladding failure and pellet-clad mechanical interaction (PCMI). The former mechanism is sensitive to the differential pressure across the cladding, while the latter mechanism is sensitive to the hydrogen concentration within the cladding. This information was used to develop new interim CRDA acceptance criteria, as captured in Appendix B, "Interim Acceptance Criteria and Guidance for the Reactivity Initiated Accidents," to Chapter 4.2, "Fuel System Design," of the Standard Review Plan (SRP) (Ref. 5). These criteria have been refined using more updated knowledge and published as part of a proposed draft guide, DG-1327, "USNRC Draft Regulatory Guide DG-1327, 'Pressurized-Water Reactor Control Rod Ejection and Boiling-Water Reactor Control Drop Accidents'" (Ref. 6), that is expected to become a final regulatory guide superseding the current regulatory guide for RIAs.

The CRDA LTR describes a new methodology for analysis of the CRDA event, including evaluation against the more recent acceptance criteria. An approval of the CRDA LTR would allow licensees to **utilize this methodology in their licensing basis and in development of** ~~use this methodology to develop~~ their own rod withdrawal sequences that can be demonstrated to comply with the revised CRDA acceptance criteria, in lieu of the BPWS. At the time that this SE was written, DG-1327 is not expected to be finalized as a regulatory guide. However, the form of the acceptance criteria in DG-1327 is very similar to the interim acceptance criteria currently captured in Appendix B of SRP 4.2. As part of the review of the CRDA LTR, the NRC staff utilized both SRP 4.2 Appendix B and DG-1327, to the extent possible.

The NRC has previously approved specific applications of the PANACEA, TRACG, and PRIME codes as part of the GESTAR-II methodology. No changes were necessary to the technical models as previously reviewed and approved by the NRC, therefore, the CRDA LTR focuses on validation of the PANACEA and TRACG methods for fast reactivity transients, a description of the key technical models used to confirm the acceptance criteria for the CRDA event, and a discussion of the analysis procedure that will be used to identify and analyze all configurations that need to be evaluated. Since the NRC review of the CRDA LTR depends, in part, on the assumption that the technical models for the PANACEA, TRACG, and PRIME codes have been previously reviewed and approved by the NRC for general neutronics, transient analysis, and fuel thermal performance applications, any limitations and conditions associated with these analysis codes remain applicable. This is expected to be controlled as part of the overall GESTAR-II methodology as maintained by GNF-A.

## NON-PROPRIETARY INFORMATION

- 3 -

### 1 **3.0 REGULATORY EVALUATION**

2  
3 Title 10 of the *Code of Federal Regulations* (10 CFR) 50.34, "Contents of Applications;  
4 Technical Information," requires that the licensee/applicant provide safety analysis reports to the  
5 NRC detailing the performance of systems, structures, and components provided for the  
6 prevention or mitigation of potential accidents.

7  
8 General Design Criterion (GDC) 13, "Instrumentation and Control," of Appendix A, "General  
9 Design Criteria for Nuclear Power Plants," to 10 CFR Part 50, "Domestic Licensing of  
10 Production and Utilization Facilities," addresses the availability of instrumentation to monitor  
11 variables and systems over their anticipated ranges to assure adequate safety, and of  
12 appropriate controls to maintain these variables and systems within prescribed operating  
13 ranges. This regulatory requirement primarily applies to ensuring that the limiting system  
14 operating parameters and other controls in place (i.e., rod withdrawal limitations) are sufficient  
15 to ensure that the CRDA acceptance criteria are not exceeded. This is satisfied by ensuring  
16 that the initial conditions and limitations on rod withdrawal represented in the CRDA analyses  
17 are sufficiently representative of the most conservative condition allowed by the aforementioned  
18 controls.

19  
20 GDC 28, "Reactivity Limits," of 10 CFR Part 50, Appendix A, requires that the effects of  
21 postulated reactivity accidents result in neither damage to the reactor coolant pressure  
22 boundary greater than limited local yielding nor result in sufficient damage to impair significantly  
23 core cooling capacity.

24  
25 As per 10 CFR 100.11, "Determination of Exclusion Area, Low Population Zone, and Population  
26 Center Distance," and 10 CFR 50.67, "Accident Source Term," radiation dose limits are  
27 established for individuals at the boundary of the exclusion area and at the outer boundary of  
28 the low population zone.

29  
30 The acceptance criteria for CRDA events to satisfy GDC 28, 10 CFR 100.11, and 10 CFR 50.67  
31 are defined in Chapter 15, "Transient and Accident Analysis," of the SRP (Ref. 5). Satisfying  
32 these acceptance criteria is necessary for CRDA events to meet the aforementioned regulatory  
33 requirements. Specifically, SRP Section 15.4.9.II, "Acceptance Criteria," states in part the  
34 following acceptance criteria:

- 35
- 36 1. Acceptance criteria from SRP Chapter 4.2. Appendix B provides interim acceptance  
37 criteria for reactivity initiated accidents (RIAs).
  - 38  
39 2. The maximum reactor pressure during any portion of the assumed excursion should be  
40 less than the value that causes stress to exceed the "Service Limit C" as defined in the  
41 American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code  
42 (Ref. 7).

43  
44 SRP Section 4.2 provides an extensive discussion of acceptance criteria related to high  
45 temperature cladding failure, PCMI induced cladding failure, core coolability, and fission product  
46 inventory determination for dose assessment purposes. Regulatory Guides 1.183, "Alternative  
47 Radiological Source Terms for Evaluating Design-Basis Accidents at Nuclear Power Reactors,"  
48 (Ref. 8) and 1.195, "Methods and Assumptions for Evaluating Radiological Consequences of  
49 Design Basis Accidents at Light-Water Nuclear Power Reactors" (Ref. 9) are also referenced for  
50 further guidance related to fission product inventories.

NON-PROPRIETARY INFORMATION

## NON-PROPRIETARY INFORMATION

- 4 -

1 The NRC staff has published a draft regulatory guide, DG-1327 (Ref. 6), for public comment.  
2 This guide contains new guidance on RIA acceptance criteria that, when final, will supersede  
3 the guidance currently contained in SRP Section 4.2. As part of this review, the NRC staff  
4 considered the applicability of the LTR methodology to DG-1327 (Ref. 6). Where appropriate,  
5 the new RIA criteria along with any potential implications to acceptability of the LTR  
6 methodology are discussed in this safety evaluation.

7  
8 The CRDA LTR is an application of an evaluation model to perform licensing analyses for an  
9 accident that the evaluation model has not previously been approved for. As such, additional  
10 guidance for the evaluation may be found in SRP Chapter 15.0.2, "Review of Transient and  
11 Accident Analysis Methods" (Ref. 5). This chapter includes provisions for the review of  
12 submittals related to evaluation models.

13  
14 In summary, the NRC staff used the review guidance in SRP Chapter 15.0.2 along with the  
15 applicable acceptance criteria in SRP Chapters 4.2 and 15.4.9 in conducting its review of the  
16 CRDA LTR. The new acceptance criteria applicable to the CRDA event contained in DG-1327  
17 was also considered, with the understanding that the guidance has not yet been finalized. In  
18 accordance with SRP Chapter 15.0.2, the review covered the areas of: (1) documentation,  
19 (2) evaluation methodology, (3) accident scenario identification process, (4) code assessment,  
20 (5) uncertainty analysis, and (6) quality assurance plan. To the extent possible, the NRC staff  
21 leveraged the prior review and approval of the PANACEA, TRACG, and PRIME analysis  
22 methodologies as incorporated in the GESTAR-II methodology (Ref. 2).

### 23 24 **4.0 TECHNICAL EVALUATION**

25  
26 The CRDA LTR describes a methodology by which the PANACEA and TRACG codes approved  
27 in the GESTAR-II methodology (Ref. 2) can be extended to analysis of the CRDA event. The  
28 NRC staff review of the CRDA LTR focused on four specific areas:

- 29
- 30 1. Accident scenario description and phenomena identification and ranking – GNF-A's  
31 break-down of the CRDA event and its relevant phenomena, and characterization of the  
32 consequences. [[  
33 ]], the NRC staff utilized other available  
34 approved PIRTs and relevant guidance to inform their assessment of whether all the  
35 relevant phenomena are appropriately addressed in the validation basis, acceptance  
36 criteria, and/or procedure used to confirm that the acceptance criteria are met.  
37
  - 38 2. Evaluation methodology – the proposed CRDA analysis methodology, including initial  
39 conditions, assumptions, and approach to ensuring that the SRP Chapters 4.2 and  
40 15.4.9 acceptance criteria are met. Since this methodology includes use of the  
41 evaluation model, by extension, this area includes the application of the evaluation  
42 model to analyze the CRDA event.  
43
  - 44 3. Code assessment – the assessments performed by GNF-A to validate the PANACEA  
45 and TRACG code systems performance for CRDA specific phenomena.  
46
  - 47 4. Uncertainty analysis – GNF-A's evaluation and propagation of uncertainties in the  
48 analysis.  
49

NON-PROPRIETARY INFORMATION

## NON-PROPRIETARY INFORMATION

- 5 -

1 In addition, the NRC staff considered whether GNF-A provided adequate QA and  
2 documentation support for the CRDA methodology. This aspect is not explicitly discussed in  
3 detail for this safety evaluation because the bulk of the QA and documentation support is  
4 captured by the various QA program documents, code documentation, and methodology  
5 discussion associated with the prior NRC approval of the PANACEA, TRACG, and PRIME  
6 methodologies in GESTAR-II. The additional documentation required to address the CRDA  
7 methodology is largely captured by the CRDA LTR. As such, NRC staff acceptance of the  
8 adequacy of the licensee's discussion of each area implicitly includes acceptance of the  
9 licensee documentation associated with that area.

10  
11 Each of the four aforementioned areas will be discussed and evaluated in the following  
12 subsections.

### 13 14 **4.1 Accident Scenario Description and Acceptance Criteria**

15  
16 As per the review guidance in Chapter 15.0.2 of the SRP, the accident scenario description and  
17 phenomena identification and ranking process is intended to ensure that the dominant physical  
18 phenomena influencing the outcome of the given accident scenario are correctly identified and  
19 ranked. Once an accident scenario has been described, then figures of merit can be  
20 determined for use in evaluating whether acceptance criteria are met. The subsequent  
21 phenomena identification and ranking process will determine the physical phenomena affecting  
22 the FoMs and rank them by their importance. By doing so, an applicant can demonstrate that  
23 reasonable assurance exists that they are accurately capturing and modeling the dominant  
24 physical phenomena necessary for evaluation of the accident scenario in question.

25  
26 Section 1.1 of the CRDA LTR briefly describes the accident scenario. The description of the  
27 CRDA event is consistent with other readily available documents, such as updated final safety  
28 analysis reports and other topical reports (TRs) related to BWR CRDA events. The scenario is  
29 relatively simple in that it consists of a rapid reactivity addition due to a single control rod falling  
30 out of the core. The resulting local power excursion is terminated primarily by Doppler reactivity  
31 feedback as the fuel temperature increases. Long term shutdown is assured by negative  
32 thermal hydraulic reactivity feedback and/or a reactor scram. The CRDA event may occur  
33 during startup or when the reactor is operating at full power. In the former case, constraints  
34 imposed on rod movements due to technical specification (TS) restrictions and rod withdrawal  
35 sequences may serve to limit the potential rod patterns and the resulting rod worths. In the  
36 latter case, the initial operating characteristics of the fuel and moderator lend themselves to  
37 more effective Doppler reactivity feedback and quicker thermal hydraulic reactivity feedback  
38 through increased voiding from direct moderator heating.

39  
40 [[

41 ]] a review of NRC guidance and technical bases to identify appropriate  
42 acceptance criteria and critical parameters or characteristics. Each item was then addressed in  
43 the CRDA LTR along with a justification. Specifically, Section 3.0 of the CRDA LTR discusses  
44 the relevant technical models utilized in the PANACEA, TRACG, and PRIME analysis  
45 methodologies for analysis of the CRDA event and identifies how the relevant output  
46 parameters are to be determined for comparison to the applicable acceptance criteria. The  
47 SRP 15.4.9.II (and, by extension, the interim RIA acceptance criteria in SRP 4.2 Appendix B)  
48 ~~acceptance criteria~~ **potential critical parameters** are: (1) fuel enthalpy, (2) minimum critical  
49 power ratio (MCPR), (3) peak system pressure, (4) fission product inventory released, and (5)

NON-PROPRIETARY INFORMATION



## NON-PROPRIETARY INFORMATION

- 6 -

1 core coolability. The acceptance criteria in DG-1327 are based on the same parameters. Of  
2 these parameters, [[ ]] is addressed in the CRDA LTR. Section 4.4 of  
3 the CRDA LTR discusses the calculations performed to address the at-power CRDA scenario  
4 and indicates that the [[ ]], which is  
5 acceptable because the NRC regulatory guidance indicates that the MCPR is essentially a  
6 surrogate parameter that captures the conditions under which high temperature cladding failure  
7 would occur (i.e., dryout). The remaining three criteria only become meaningful in the event of  
8 fuel rod failure. The heat added to the coolant by CRDA events which do not result in rods  
9 exceeding the acceptance criteria is expected to be small relative to the heat capacity of the  
10 coolant, and no fission release or fuel geometry deformation would occur. Therefore, the NRC  
11 staff finds it acceptable that the CRDA LTR [[  
12 ]] because the GNF-A methodology is based on [[  
13 ]] to those which do not lead to any fuel rod failure.  
14

15 The NRC staff reviewed the PIRTs for other RIAs, prior precedents for the CRDA event, and  
16 the NRC staff's technical understanding of the relevant events in the accident progression. In  
17 summary, other PIRTs include: (1) initial conditions that would affect initial enthalpy or reactivity  
18 feedback, (2) parameters that would affect the positive reactivity addition from the rod drop, (3)  
19 parameters that would affect the timing and/or magnitude of the negative reactivity feedback  
20 terminating the power excursion, and (4) parameters affecting the transfer of heat away from the  
21 limiting locations. For BWRs, past precedents and the studies discussed in Section 4.4 of the  
22 CRDA LTR show that in the absence of specific controls intended to minimize the potential  
23 consequences of the CRDA, the conditions which maximize the potential for fuel failures occur  
24 at cold zero power (CZP) conditions. This is because increased temperatures result in  
25 increased mitigation via Doppler and moderator reactivity feedback mechanisms (see Section  
26 4.2.5.1 for further discussion). The short time scale for the CZP CRDA scenario means that  
27 thermal hydraulic feedback is of relatively little consequence, since the limiting parameters  
28 reach their maximum values before significant heat transfer occurs. Consequently, the primary  
29 phenomena affecting the CRDA event are expected to be those that affect the magnitude of the  
30 reactivity addition or the Doppler reactivity feedback. The specific technical models and  
31 parameters affecting the Doppler reactivity feedback, along with other parameters of moderate  
32 importance, are discussed in the CRDA TR.  
33

34 In summary, the NRC staff has determined that GNF-A appropriately characterized the CRDA  
35 scenario, identified the appropriate acceptance criteria, and evaluated the sensitivity of the  
36 acceptance criteria to the technical models and input parameters used to perform the CRDA  
37 evaluation.  
38

### 39 **4.2 Applicability of Evaluation Model to CRDA Event**

40  
41 Chapter 15.0.2 of the SRP describes the review of the evaluation model as part of the transient  
42 and accident analysis methods. The associated acceptance criteria indicate that models must  
43 be present for all phenomena and components that have been determined to be important or  
44 necessary to simulate the accident under consideration. The chosen mathematical models and  
45 the numerical solution of those models must be able to predict the important physical  
46 phenomena reasonably well from both qualitative and quantitative points of view. Restated in  
47 terms of the review procedures provided in Section III of Chapter 15.0.2, it must be determined  
48 if the physical modeling described in the theory manual and contained in the mathematical

NON-PROPRIETARY INFORMATION

## NON-PROPRIETARY INFORMATION

- 7 -

1 models is adequate to calculate the physical phenomena influencing the accident scenario for  
2 which the code is used.

3 Each of the proposed codes (PANACEA, TRACG, and PRIME) have been evaluated and found  
4 to be acceptable for specific applications during the review and approval of a number of  
5 individual TRs (Refs. 10, 11, and 12). No changes or enhancements to the technical models in  
6 the codes are being proposed for NRC review and approval. As a result, this review focused on  
7 how the methodologies, as implemented by the codes, are applied to analyze the CRDA event.  
8 The scope of this review included the applicability of the modeling schemes discussed in the  
9 previously approved TRs to the CRDA event, and any potential limitations to the proposed  
10 analysis procedure to identify and assess the limiting CRDA scenarios.

### 11 12 **4.2.1 Applicability of PANACEA Technical Models to CRDA**

13  
14 PANACEA is currently approved primarily for use in steady state methodologies used to  
15 establish the core design for reload licensing, monitor thermal limits, and perform selected  
16 calculations. GNF-A intends to use the steady state reactivity calculation capability in  
17 PANACEA to determine static control rod worths as part of the proposed CRDA methodology,  
18 which is discussed further in Section 4.2.1.1 of this SE. PANACEA has not formally been  
19 approved for transient calculations, however, the transient neutron kinetics model in PANACEA  
20 is identical to the model in TRACG. TRACG has been approved for AOO and stability related  
21 applications, where neutronic feedback is important. Therefore, the NRC staff review of the use  
22 of the PANACEA for transient calculations focused on the applicability of the models for their  
23 intended purpose in CRDA analyses, as discussed in Section 4.2.1.2 of this SE.  
24

#### 25 **4.2.1.1 PANACEA – [[ ]]**

26  
27 The steady state neutronics calculational capabilities of PANACEA are currently used to  
28 perform shutdown margin calculations as part of GESTAR II (Ref. 2), which are essentially static  
29 control rod worth calculations based on an all rods in (ARI) configuration. PANACEA has been  
30 extensively benchmarked for normal core operations, which involves various rod configurations.  
31 The proposed use of the PANACEA steady state neutronics capabilities is merely in its use to  
32 compute the reactivities corresponding to the initial and final rod positions for possible rod drop  
33 scenarios. The [[ ]] for each rod drop scenario can then be defined as  
34 the difference in reactivity between the initial and final position for the postulated drop scenario.  
35

36  
37  
38  
39  
40  
41  
42  
43  
44  
45

46 The [[ ]]

47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57  
58  
59  
60  
61  
62  
63  
64  
65  
66  
67  
68  
69  
70  
71  
72  
73  
74  
75  
76  
77  
78  
79  
80  
81  
82  
83  
84  
85  
86  
87  
88  
89  
90  
91  
92  
93  
94  
95  
96  
97  
98  
99  
100  
101  
102  
103  
104  
105  
106  
107  
108  
109  
110  
111  
112  
113  
114  
115  
116  
117  
118  
119  
120  
121  
122  
123  
124  
125  
126  
127  
128  
129  
130  
131  
132  
133  
134  
135  
136  
137  
138  
139  
140  
141  
142  
143  
144  
145  
146  
147  
148  
149  
150  
151  
152  
153  
154  
155  
156  
157  
158  
159  
160  
161  
162  
163  
164  
165  
166  
167  
168  
169  
170  
171  
172  
173  
174  
175  
176  
177  
178  
179  
180  
181  
182  
183  
184  
185  
186  
187  
188  
189  
190  
191  
192  
193  
194  
195  
196  
197  
198  
199  
200  
201  
202  
203  
204  
205  
206  
207  
208  
209  
210  
211  
212  
213  
214  
215  
216  
217  
218  
219  
220  
221  
222  
223  
224  
225  
226  
227  
228  
229  
230  
231  
232  
233  
234  
235  
236  
237  
238  
239  
240  
241  
242  
243  
244  
245  
246  
247  
248  
249  
250  
251  
252  
253  
254  
255  
256  
257  
258  
259  
260  
261  
262  
263  
264  
265  
266  
267  
268  
269  
270  
271  
272  
273  
274  
275  
276  
277  
278  
279  
280  
281  
282  
283  
284  
285  
286  
287  
288  
289  
290  
291  
292  
293  
294  
295  
296  
297  
298  
299  
300  
301  
302  
303  
304  
305  
306  
307  
308  
309  
310  
311  
312  
313  
314  
315  
316  
317  
318  
319  
320  
321  
322  
323  
324  
325  
326  
327  
328  
329  
330  
331  
332  
333  
334  
335  
336  
337  
338  
339  
340  
341  
342  
343  
344  
345  
346  
347  
348  
349  
350  
351  
352  
353  
354  
355  
356  
357  
358  
359  
360  
361  
362  
363  
364  
365  
366  
367  
368  
369  
370  
371  
372  
373  
374  
375  
376  
377  
378  
379  
380  
381  
382  
383  
384  
385  
386  
387  
388  
389  
390  
391  
392  
393  
394  
395  
396  
397  
398  
399  
400  
401  
402  
403  
404  
405  
406  
407  
408  
409  
410  
411  
412  
413  
414  
415  
416  
417  
418  
419  
420  
421  
422  
423  
424  
425  
426  
427  
428  
429  
430  
431  
432  
433  
434  
435  
436  
437  
438  
439  
440  
441  
442  
443  
444  
445  
446  
447  
448  
449  
450  
451  
452  
453  
454  
455  
456  
457  
458  
459  
460  
461  
462  
463  
464  
465  
466  
467  
468  
469  
470  
471  
472  
473  
474  
475  
476  
477  
478  
479  
480  
481  
482  
483  
484  
485  
486  
487  
488  
489  
490  
491  
492  
493  
494  
495  
496  
497  
498  
499  
500  
501  
502  
503  
504  
505  
506  
507  
508  
509  
510  
511  
512  
513  
514  
515  
516  
517  
518  
519  
520  
521  
522  
523  
524  
525  
526  
527  
528  
529  
530  
531  
532  
533  
534  
535  
536  
537  
538  
539  
540  
541  
542  
543  
544  
545  
546  
547  
548  
549  
550  
551  
552  
553  
554  
555  
556  
557  
558  
559  
560  
561  
562  
563  
564  
565  
566  
567  
568  
569  
570  
571  
572  
573  
574  
575  
576  
577  
578  
579  
580  
581  
582  
583  
584  
585  
586  
587  
588  
589  
590  
591  
592  
593  
594  
595  
596  
597  
598  
599  
600  
601  
602  
603  
604  
605  
606  
607  
608  
609  
610  
611  
612  
613  
614  
615  
616  
617  
618  
619  
620  
621  
622  
623  
624  
625  
626  
627  
628  
629  
630  
631  
632  
633  
634  
635  
636  
637  
638  
639  
640  
641  
642  
643  
644  
645  
646  
647  
648  
649  
650  
651  
652  
653  
654  
655  
656  
657  
658  
659  
660  
661  
662  
663  
664  
665  
666  
667  
668  
669  
670  
671  
672  
673  
674  
675  
676  
677  
678  
679  
680  
681  
682  
683  
684  
685  
686  
687  
688  
689  
690  
691  
692  
693  
694  
695  
696  
697  
698  
699  
700  
701  
702  
703  
704  
705  
706  
707  
708  
709  
710  
711  
712  
713  
714  
715  
716  
717  
718  
719  
720  
721  
722  
723  
724  
725  
726  
727  
728  
729  
730  
731  
732  
733  
734  
735  
736  
737  
738  
739  
740  
741  
742  
743  
744  
745  
746  
747  
748  
749  
750  
751  
752  
753  
754  
755  
756  
757  
758  
759  
760  
761  
762  
763  
764  
765  
766  
767  
768  
769  
770  
771  
772  
773  
774  
775  
776  
777  
778  
779  
780  
781  
782  
783  
784  
785  
786  
787  
788  
789  
790  
791  
792  
793  
794  
795  
796  
797  
798  
799  
800  
801  
802  
803  
804  
805  
806  
807  
808  
809  
810  
811  
812  
813  
814  
815  
816  
817  
818  
819  
820  
821  
822  
823  
824  
825  
826  
827  
828  
829  
830  
831  
832  
833  
834  
835  
836  
837  
838  
839  
840  
841  
842  
843  
844  
845  
846  
847  
848  
849  
850  
851  
852  
853  
854  
855  
856  
857  
858  
859  
860  
861  
862  
863  
864  
865  
866  
867  
868  
869  
870  
871  
872  
873  
874  
875  
876  
877  
878  
879  
880  
881  
882  
883  
884  
885  
886  
887  
888  
889  
890  
891  
892  
893  
894  
895  
896  
897  
898  
899  
900  
901  
902  
903  
904  
905  
906  
907  
908  
909  
910  
911  
912  
913  
914  
915  
916  
917  
918  
919  
920  
921  
922  
923  
924  
925  
926  
927  
928  
929  
930  
931  
932  
933  
934  
935  
936  
937  
938  
939  
940  
941  
942  
943  
944  
945  
946  
947  
948  
949  
950  
951  
952  
953  
954  
955  
956  
957  
958  
959  
960  
961  
962  
963  
964  
965  
966  
967  
968  
969  
970  
971  
972  
973  
974  
975  
976  
977  
978  
979  
980  
981  
982  
983  
984  
985  
986  
987  
988  
989  
990  
991  
992  
993  
994  
995  
996  
997  
998  
999  
1000

NON-PROPRIETARY INFORMATION

## NON-PROPRIETARY INFORMATION

- 8 -

1 calculated [[ ]]] will be consistent with the data used to develop [[  
2 ]]].  
3

4 Based on the calculational capabilities of PANACEA and the [[  
5 ]]] CRDA rod enthalpies, the NRC staff concludes that the use of  
6 PANACEA to determine [[ ]]] as described  
7 in the CRDA LTR is appropriate.  
8

### 9 **4.2.1.2 PANACEA – Transient Calculations for CRDA**

10  
11 PANACEA contains a transient neutronic kinetics model that was previously reviewed and  
12 approved by the NRC as part of its review of the TRACG package. The thermal hydraulic  
13 models in PANACEA are much more limited than TRACG, however, the heat transfer to the  
14 surrounding coolant is minimal during the prompt power excursion. The SPERT III  
15 assessments (see Section 4.3 of this SE) demonstrate that the PANACEA transient models  
16 perform a reasonable job of capturing the prompt power excursion. According to the CRDA  
17 LTR, [[  
18  
19  
20  
21  
22  
23  
24

]]].

25 The use of the pin power reconstruction methodology was assessed as part of the validation of  
26 the PANACEA methodology that was approved by the NRC (Ref. 10). The supporting LTR and  
27 references describe validation that was performed using cold and hot conditions. The main  
28 purpose of the pin power reconstruction methodology is to capture the impact of highly localized  
29 flux conditions experienced by individual pins, such as the presence of a nearby control rod.  
30 The validation suite referenced in the PANACEA licensing TR (Ref. 10) [[  
31  
32

33 ]]]. The pin power reconstruction methodology itself  
34 was validated by comparison to calculations performed using DIF3D, a code developed by  
35 Argonne National Laboratory, as well as gamma measurements and TIP data at hot conditions  
36 for operating power plants. While the code-to-code comparisons were representative of pin  
37 powers [[  
38 ]]].  
39

40 The PANACEA transient calculations do not capture the changes in heat transfer to the coolant  
41 as the fuel rods heat up, or the negative moderator feedback that would be expected from  
42 heatup and potential boiling of coolant. Section 4.2.4.6 of this SE contains further discussion  
43 regarding the conservatism associated with the approach used to determine the [[  
44 ]]] the PANACEA code as well as the inputs and  
45 process to determine [[ ]]].  
46

47 Based on the fact that the PPR methodology is expected to be applicable to the conditions  
48 being analyzed, and the conservatisms discussed in Section 4.2.4.6 of this SE associated with

NON-PROPRIETARY INFORMATION

## NON-PROPRIETARY INFORMATION

- 9 -

1 the [[  
2 ]], the  
3 NRC staff concludes that the calculated maximum rod enthalpies can reasonably be expected  
4 to bound the actual maximum rod enthalpies if the same scenario were to occur in the real  
5 world.

### 6 **4.2.2 Applicability of TRACG Technical Models to CRDA**

7  
8 The actual analyses of limiting CRDA events are performed using the models and correlations  
9 in TRACG that have been previously reviewed and approved by the NRC for a broad set of  
10 transients. While TRACG was not reviewed with the CRDA event in mind, the NRC staff did  
11 review the key models necessary for accurate predictions of the CRDA specific phenomena, as  
12 follows. Note that several of these models utilize correlations that are updated and/or validated  
13 for each new fuel assembly design, in compliance with the process described in GEGSTAR-II-III  
14 (Ref. 2).

- 15 • Bundle void correlations – supports void distribution calculations (for at-power CRDA)
- 16 • Transient neutron kinetics model qualification – supports calculation of neutronic  
17 response
- 18 • Gap models – supports calculation of heat transfer from fuel to coolant, as well as rod  
19 internal pressure (based on inputs from PRIME, see Section 4.2.3)
- 20 • Pressure drop and critical power tests – supports applicability of CPR calculations (for  
21 at-power CRDA)
- 22 • Peach Bottom turbine trip test – supports ability of TRACG to predict neutronic/thermal  
23 hydraulic coupled feedback (for at-power CRDA)
- 24 • Direct moderator heating model – specifies amount of fission heat that is deposited via  
25 gamma heating of moderator **and the slowing down of neutrons in the moderator**,  
26 which affects magnitude of fuel rod enthalpy increase and moderator density reactivity  
27 feedback (validated at cold conditions)
- 28
- 29

30 Additional model integral test assessments were provided to support the ability of TRACG to  
31 accurately evaluate the CRDA event for startup conditions based on tests performed at the  
32 Special Power Excursion Reactor Test III (SPERT III) reactor, as discussed in Section 4.3 of  
33 this SE.

34  
35 Some of the models within TRACG are used in specific ways for the purposes of the CRDA  
36 analyses, as follows:

- 37 • [[  
38 ]]  
39 ]]
- 40 • The fission gas inventory is predicted by PRIME [[  
41 ]].
- 42 • The fission gas inventory is increased [[  
43 ]] to account for transient fission  
44 gas release.

45 None of these proposed modeling approaches would invalidate the basis for prior NRC approval  
46 of the relevant technical models. The acceptability of the modeling approaches is discussed  
47 further in Section 4.2.4 of this SE.  
48

NON-PROPRIETARY INFORMATION

## NON-PROPRIETARY INFORMATION

- 10 -

1 The CRDA LTR describes the technical models utilized within TRACG to perform analysis of the  
2 CRDA event. The majority of the technical models have previously been validated for other  
3 applications in which the neutronics and thermal hydraulic phenomena of interest for the CRDA  
4 event are important. Additional validation is discussed in Section 4.3 of this SE related to the  
5 unique conditions that exist for a CRDA during cold startup, where the primary mitigating factor  
6 is the Doppler reactivity feedback. As discussed above, the specific models used in TRACG to  
7 obtain the necessary information for comparison to the acceptance criteria (see Section 4.2.5.4)  
8 are applied in a conservative manner, and therefore, the approach is found to be acceptable by  
9 the NRC staff for use in analysis of the CRDA event.

### 10 11 **4.2.3 Applicability of PRIME Technical Models to CRDA**

12  
13 The PRIME fuel thermal mechanical performance methodology is not used directly in the  
14 analysis of the CRDA event, however, several inputs for TRACG are derived from PRIME. For  
15 example, the data needed for the TRACG dynamic gap model is obtained from PRIME and is  
16 directly applicable based on the NRC review and approval of the implementation within TRACG.  
17 Additionally, the fission gas inventories assumed in the gap for the TRACG calculation are  
18 obtained from PRIME. The gap inventories are developed based on PRIME's steady state  
19 depletion capability to determine the fission gas production and release from the fuel pellet as a  
20 function of exposure, LHGR history, and instantaneous LHGR. This capability has been  
21 reviewed and approved by the NRC (Ref. 12) and is appropriate for use directly in the TRACG  
22 calculation. As discussed in Section 4.2.2 of this SE, the PRIME generated data  
23 [[ ]].  
24

25 The CRDA LTR states that the PRIME fuel files [[ ]] are  
26 assumed to be appropriate for use as inputs [[ ]] in TRACG for CRDA  
27 analyses. Use of data from [[ ]]  
28

29 ]]. The justification given for use of data from fuel rods [[ ]]  
30  
31  
32  
33

34 ]]. Gadolinium does have a second order effect in reducing the pellet thermal  
35 conductivity slightly. The impact of a slightly reduced pellet thermal conductivity on the  
36 calculated pellet enthalpy values is expected to have a negligible impact on the prompt enthalpy  
37 rise, since it occurs prior to any significant heat transfer from the fuel pellet. The relatively small  
38 potential effect on the total enthalpy, due to slowing of heat transfer from the fuel pellet, is  
39 expected to be less than the conservatism inherent in use of a [[ ]] for  
40 the gadolinium-bearing fuel, [[ ]]  
41  
42 ]].  
43

44 The PRIME technical models used to produce input data for the CRDA analyses have  
45 previously been reviewed and approved by the NRC, and the application of the data for CRDA  
46 analysis purposes is consistent with NRC approved applications. The NRC staff evaluated the  
47 applicant's description of how the PRIME information would be used within TRACG for CRDA  
48 analyses and found the proposed approach to be acceptable.  
49

NON-PROPRIETARY INFORMATION

#### 1 **4.2.4 Modeling Guidance**

2  
3 The CRDA LTR indicates that the general plant model is consistent with the models created for  
4 the application of PANACEA and TRACG to analyze AOO, ATWS, and stability events  
5 (Refs. 10) (and 11). Several of these transients require accurate predictions of rapidly changing  
6 axial flux shapes. When combined with the assessment against data from the SPERT III  
7 experiments (see Section 4.3), the NRC staff finds that reasonable assurance exists that the  
8 overall modeling as described in the licensing TRs describing the aforementioned PANACEA  
9 and TRACG applications is acceptable for use in modeling the CRDA event. A few specific  
10 modeling and input parameters are adjusted to accommodate the unique needs of the CRDA  
11 analysis procedure. These parameters are discussed in the following subsections.

##### 12 13 **4.2.4.1 TRACG Channel Grouping, Vessel Nodalization, & Time Step Guidance**

14  
15 The CRDA event primarily impacts the fuel assemblies grouped near the control rod of interest,  
16 so computational time savings can be realized by [[

17 ]] far from the control rod of interest. This is a strategy in which [[  
18  
19 ]]. This modeling approach effectively [[  
20 ]] calculating the thermal hydraulic properties for  
21 every individual assembly.

22  
23 When this type of approach is adopted, to ensure that the results are not non-conservative, the  
24 guidance for grouping channels must be established in a manner that ensures that:

- 25  
26 1. Individual fuel channels are modeled when necessary, to capture highly localized limiting  
27 phenomena;  
28  
29 2. Fuel channels that are [[ ]] do not  
30 lead to a change in the hydraulic response of the channels of interest; and  
31  
32 3. Any other variations in input parameters would yield equivalent or conservative results  
33 relative to a higher resolution model.

34  
35 The CRDA LTR describes the approach used to determine how to select the fuel channel  
36 groups. First, the individual fuel assemblies are explicitly modeled as individual channels [[  
37 ]] for the drop evaluation. Secondly, the [[  
38 ]]. Finally, the vessel is nodalized such that  
39 the [[

40  
41 ]].  
42  
43 Requirement (1), above, is met by the use of individual fuel channels [[ ]]  
44 surrounding the target rod for the drop evaluation. The use of individual fuel channels also  
45 ensures that the hydraulic response of the channels of interest are explicitly captured, and the  
46 non-channel parameters (e.g., bypass flow) are captured with reasonable accuracy by the  
47 vessel nodalization strategy. Figure 4-2 of the LTR provides some representative enthalpy rises  
48 for fuel around a target dropped rod, showing that the enthalpy response [[

## NON-PROPRIETARY INFORMATION

- 12 -

]].

The averaging of specified properties in areas less important to the enthalpy calculation may lead to variations in the peripheral neutron flux or changes in the boundary conditions for hydraulics. In general, averaging of thermal hydraulic quantities for areas closer to the target rod with those for areas farther from the target rod will lead to more conservative results due to the fact that averaging the moderator temperature and density for fuel close to the region of interest with fuel farther from the region of interest leads to a suppressed negative Doppler reactivity feedback response due to the lower temperatures of the farther fuel. A similar logic can be used to infer that other influences such as variations in burnup or power within a channel grouping would yield slightly more conservative results due to the dampening of the Doppler reactivity feedback mechanism for the more reactive fuel elements in the group. Therefore, the grouping strategy is primarily an attempt to simplify the calculation without becoming overly conservative in doing so. Hence, the above requirements (2) and (3) are met.

The CRDA LTR does not go into details regarding how the thermal hydraulic behavior for mixed cores will be treated. However, the fact that the fuel assemblies [[

]]. Based on the [[  
]], the NRC staff did not find it necessary to review a detailed description of  
the [[  
]].

The axial nodalization of the fuel channels is consistent with the accepted nodalization of the PANACEA and TRACG methodologies, as supported by their respective assessment bases. The CRDA event is primarily analyzed at zero power conditions when the coolant is below saturation (and thus more or less uniform except for pressure changes as a result of flow resistance and elevation), and the changes in the coolant properties outside the fuel channel boxes is minimal. As a result, the nodalization of the reactor vessel and other components is relatively little importance but is reasonable. The CRDA LTR, as submitted, lacked information regarding guidance for time step sizes. Since the CRDA event is a very rapid transient that may require shorter time steps relative to other transients, the NRC staff asked RAI-5 to better understand the sensitivity of the TRACG results to the time step size. In its response (Ref. 13), GNF-A provided justification that the internal logic used by TRACG to adjust the time step size coupled with the standard time step inputs will not **allow** limit the time steps to sizes larger than necessary to capture the prompt power excursion. The code assessment (see Section 4.3 of this SE) provides additional assurance that the time step logic within TRACG is applicable to the CRDA event.

As a result of the above considerations regarding the potential impacts of the channel grouping strategy and vessel nodalization on the results calculated for the CRDA event, the NRC staff finds the proposed channel and vessel modeling strategy to be acceptable.

NON-PROPRIETARY INFORMATION

#### 4.2.4.2 TRACG Reactivity Insertion Modeling

The CRDA event includes up to two separate reactivity insertions **due to control blade movement**. The first is the control rod drop that triggers the event, which is (for limiting cases) a positive reactivity insertion that is sufficient to cause a prompt excursion. The second **negative reactivity insertion** may not always be necessary to terminate the event, but if necessary, a scram is expected to occur based on the flux-based or period-based trip functions of the various core monitoring systems. The CRDA LTR describes a conservative modeling of both reactivity insertions.

The control rod is assumed to begin falling instantaneously at a speed of 3.11 ft/s. This speed is the maximum possible drop speed based on the velocity limiter associated with the control rods tested as documented in NEDO-10527 (Ref.14). This maximum drop speed would need to be confirmed for all control rod designs in the core that were not included in NEDO-10527. Since the control rod will begin accelerating from a resting position and may not reach the maximum velocity, this is a conservative approach in ensuring that the positive reactivity insertion occurs as quickly as possible. Since the maximum drop speed is a key assumption, a limitation and condition is imposed to ensure that this assumption remains valid for all future control rod designs that are not included in NEDO-10527.

The reactor scram trips [[

]].

The CRDA LTR describes highly simplified inputs for the reactivity insertions corresponding to the rod drop itself and any subsequent reactor scram (if needed). As discussed above, the simple inputs are inherently conservative, and therefore, acceptable for use in analysis of the CRDA event.

#### 4.2.4.3 TRACG Fuel Rod Fission Gas Inventory

The inputs to be used at the beginning of the CRDA analyses include some key assumptions associated with the fuel rod fission gas inventory. The fission gas inventory is used to determine the rod internal pressure, which is needed for evaluation of the high temperature rod failure acceptance criterion, and to compute the thermal conductivity of the gap between the fuel rod and cladding. In both cases, a higher fission gas inventory is more conservative. High temperature rod failure may be predicted to occur at lower total enthalpies when the rod internal pressure is higher, which is directly proportional with the fission gas inventory due to the fixed available volume in the gap. A larger amount of fission gas in the gap leads to degraded heat transfer capability across the gap, which may increase the total enthalpy due to greater heat retention within the fuel during the trailing "tail" of the power excursion.



1 [[

2

3

4

]]

5

6 Secondly, the initial fission gas inventory at the beginning of the CRDA analysis was [[

7

8

9

10

11

12

]].

13

14 As a result of the above considerations regarding the potential impacts of the fission gas  
15 inventory on the results calculated for the CRDA event, the NRC staff finds the proposed fission  
16 gas inventory modeling strategy to be acceptable.

17

#### 18 4.2.4.4 Initial Parameters

19

20 As part of the input description in the CRDA TR, GNF-A provided guidance and justification for  
21 the core operating parameters that should be assumed during the CRDA analysis, namely the  
22 coolant temperature, power, and flow. In order to evaluate the impact of the initial conditions on  
23 the results from the CRDA event, GNF-A performed a series of sensitivity studies using a  
24 worst-case drop scenario for a representative plant at BOC, MOC, and EOC.

25

26 The coolant temperature has a strong effect on the calculated enthalpies from the limiting CRDA  
27 event, with the enthalpies increasing as the initial coolant temperature reduces to cold  
28 conditions. This is consistent with trends that the NRC staff has observed in similar studies.

29 [[

30

31

32

33

34

35

36

37

]]

38

39

40 The power and flow sensitivity studies showed [[

41

42

43 ]]. The NRC staff has seen sensitivities in other studies that exhibited [[

44

45 ]] to the power and flow, however, this effect may be dependent on the reference  
46 plant/fuel used in the calculation or the specific methodology being utilized. The CRDA analysis  
47 methodology being proposed in the CRDA LTR contains [[

47

48 ]], so any small sensitivities would not affect the ability of this methodology to  
demonstrate compliance with regulatory limits.

## NON-PROPRIETARY INFORMATION

- 15 -

1 The NRC staff reviewed the recommended input parameters for the initial conditions of the core,  
2 and the information presented to support the recommendations. The recommended initial core  
3 temperature will be set in a way that ensures that it bounds the intended application, [[  
4 ]]. Specific applications may  
5 exhibit [[ ]], however, there is sufficient conservatism in the  
6 methodology to accommodate these kinds of variations (see Section 6.0 of this SE for further  
7 discussion). As a result, the NRC staff finds the initial condition input recommendations to be  
8 reasonable.

### 9 10 **4.2.4.5 Doppler Coefficient Application**

11  
12 The most important phenomena for mitigation of the CRDA event is the Doppler reactivity  
13 feedback, which arrests and largely reverses the prompt power excursion that may occur after a  
14 rod drop. Consequently, the consequences of the CRDA event are expected to be very  
15 sensitive to how the Doppler reactivity feedback is modeled in the analysis methodology. In the  
16 CRDA TR, GNF-A states that TRACG utilizes [[  
17  
18  
19  
20  
21  
22 ]].

23  
24 The NRC staff asked RAI-1 to better understand the behavior of the [[ ]] Doppler  
25 coefficients [[ ]]  
26 ]] to be applicable to all fuel assembly designs. In response to this RAI (Ref. 13),  
27 GNF-A provided a more detailed comparison [[  
28 ]] Doppler coefficients calculated with TGBLA (which is capable of  
29 performing the explicit lattice calculations at cold conditions). [[  
30  
31 ]]

32 However, the trends are not conclusive and the technical basis for this behavior is not well  
33 understood. Instead, GNF-A addressed the relevant considerations through the following  
34 technical bases:

- 35  
36 1) Applicability to fuel assembly designs or lattices of interest – GNF-A performed the  
37 comparative calculations to determine [[  
38 ]] GNF2 and GNF3 fuel assembly designs.  
39 These two fuel assembly designs represent most of the GNF-A fuel assembly designs  
40 currently in operation. The exclusion of the [[  
41 ]] is reasonable for typical configurations because the higher reactivity  
42 region [[  
43  
44 ]], **when the CRDA cases are most limiting** to the  
45 gradual upward shift in power for burned fuel as the bottom lattices become depleted.  
46 To ensure that the [[  
47 ]] new fuel assembly designs, GNF-A proposed an addition to their  
48 procedure for performing TRACG analyses which will be applied [[

NON-PROPRIETARY INFORMATION



## NON-PROPRIETARY INFORMATION

- 17 -

1 The approach used within PANACEA and TRACG to calculate the Doppler reactivity feedback  
2 has previously been reviewed and approved by the NRC for hot operating conditions, as part of  
3 the methodologies for analyzing other transients (Refs. 10 and 11). The conditions for the  
4 limiting CRDA event occur at cold conditions, which means that the temperature profiles within  
5 the fuel pellet will be different. Initially, the temperature across the fuel pellet will be uniform.  
6 When the power excursion occurs, the temperature increase will be proportional to the power  
7 generation within the pellet. The radial power profile for the pellets in fresh and burned fuel will  
8 differ, because the power generation will be significantly higher near the outer surface of the  
9 pellet for burned fuel due to the "rim effect" (increased Pu production relative to the interior of  
10 the pellet due to self-shielding). This may cause the Doppler reactivity response to differ from  
11 that expected during hot conditions. However, as discussed in Section 4.2.4.6 of this SE, [[  
12 ]]  
13 ] TRACG to determine the final peak rod enthalpies are developed using a  
14 conservative approach. The NRC staff finds, based on engineering judgment, this inherent  
15 conservatism [[ ]] is sufficient to accommodate any small potential  
16 effects due to variations in the Doppler reactivity response based on differing pellet radial power  
17 distributions (due to self-shielding).

18 The approach used to predict the Doppler reactivity feedback is one of the most important  
19 aspects of the CRDA analysis methodology, since this is the primary source of accident  
20 mitigation. The NRC staff evaluated how the Doppler reactivity feedback is evaluated in  
21 TRACG and determined that the approach can reasonably be expected to yield conservative  
22 values for the peak rod enthalpies used for comparison to the acceptance criteria for the CRDA  
23 event. Additionally, the uncertainty in the Doppler reactivity feedback is treated in an acceptably  
24 conservative manner.  
25

### 26 4.2.4.6 Fuel Rod Enthalpy Determination

27  
28 One of the major output parameters from the calculations done to predict the consequences of a  
29 CRDA event is the peak fuel rod enthalpies for fuel assemblies surrounding the dropped control  
30 rod. The overall thermal hydraulics and neutronics response of the fuel and surrounding coolant  
31 is captured by TRACG, using neutronics inputs from PANACEA, on a nodal basis [[  
32  
33  
34

35 ]]  
36 ]] the overall thermal hydraulic or neutronics calculations in  
37 TRACG, [[ ]] to predict the coupled  
38 feedback mechanisms. This is consistent with what the NRC has previously reviewed and  
39 approved for the use of TRACG in analysis of other events, as well as general practices in the  
40 industry. The additional information that is needed to determine the enthalpy [[  
41 ]]  
42 ] enthalpy for all rods is discussed in the next paragraph.

43 The CRDA LTR states that the enthalpy for individual rods is determined through use of a  
44 [[  
45  
46  
47  
48  
49

NON-PROPRIETARY INFORMATION

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49

]]. There are two separate enthalpy acceptance criteria, one based on the maximum enthalpy value attained during the transient (“total enthalpy”) and one based on the increase in enthalpy during a defined time interval (“prompt enthalpy rise”), which are discussed further in Section 4.2.5.4 of this SE. However, all rods are initially at the same enthalpy for CZP conditions, so the limiting rod will be the same for both enthalpy criteria.

The approach used by GNF-A to determine the limiting enthalpy values for comparison to the acceptance criteria for the CRDA event was found to be acceptable by the NRC staff, based on standard practices for this type of analysis, qualification of the codes used to perform the calculations, and several conservatisms, as described above.

**4.2.5 CRDA Analysis Procedure**

The CRDA LTR provides a specific procedure for performance of the CRDA analysis, which includes a description of what conditions should be evaluated, which control rods should be selected for evaluation, and how the acceptance criteria should be verified to have been met. Section 4.2.5.1 discusses the at-power CRDA scenario, and the remainder of the subsections discuss the CZP CRDA scenario.

**4.2.5.1 Hot/At-Power/Intermediate CRDA Scenario**

Section 4.4 of the CRDA LTR focuses on the range of applicability for the proposed CRDA analysis procedure. It strives to define the core conditions for which the CRDA event is clearly non-limiting. GNF-A does this by performing sensitivity studies to define a minimum power level and minimum reactor dome pressure for which the CRDA event is no longer limiting. The at-power CRDA scenario is distinguished from the CZP CRDA scenario by the presence of increased negative reactivity via the following mechanisms:

## NON-PROPRIETARY INFORMATION

- 19 -

- 1  
2 1. The presence of significant voiding in the coolant results in less moderation, so neutron  
3 spectrum skews more towards faster neutrons (i.e., the spectrum is "harder").  
4 Consequently, the control rod absorber material is less effective at neutron absorption  
5 (i.e., rod worths are lower) and the reactivity consequence of the rod drop itself is milder.  
6
- 7 2. The coolant is at saturated conditions, so the direct heating of the coolant can produce  
8 voiding. This produces a significant negative moderator density feedback effect that is  
9 not present for CZP conditions where the direct coolant heating does not result in a  
10 significant change in the coolant density.  
11
- 12 3. While the magnitude of the Doppler reactivity coefficient tends to be smaller at higher  
13 fuel temperatures, the harder neutron spectrum results in a larger number of neutrons  
14 available for Doppler capture in the resonance regions.  
15

16 All of these mechanisms only come into play when the coolant reaches saturation conditions.  
17 GNF-A performed a series of analyses for different core dome pressures and power levels at  
18 saturation condition, and the results generally confirm that the results from the at-power CRDA  
19 analyses are much less limiting than the results from the CZP CRDA event, despite the lack of  
20 the restrictions on control rod positions that normally ensure that the CRDA does not result in  
21 fuel rod failures. To provide convenient triggers for plant operators to identify when the CRDA  
22 event can safely be assumed to have become non-limiting enough to preclude the need to  
23 follow the rod withdrawal sequence explicitly, GNF-A chose 5 percent power as the Low Power  
24 Set Point (LPSP) and 300 psig as the Low Dome Pressure Set Point (LDPSP). Anything below  
25 these limits would require adherence to an analyzed rod withdrawal sequence and associated  
26 requirements.  
27

28 The calculations performed by GNF-A show that all predicted limiting enthalpies at saturation  
29 conditions are much less limiting than the maximum enthalpies at cold conditions. The primary  
30 consideration is to ensure that the core is at saturation conditions, so that void reactivity  
31 feedback begins to make a significant contribution to mitigation of the consequences from a  
32 CRDA event. A power level of 5 percent or a reactor dome pressure of 300 psig would both  
33 clearly indicate that the coolant has heated to saturation conditions, based on core heatup  
34 practices employed by plant operators. The 5 percent limit on power accounts for the inherent  
35 uncertainties associated with power measurement under low flux conditions, and the 300 psig  
36 limit on reactor dome pressure is significantly higher than any expected measurement  
37 uncertainties relative to saturation at atmospheric conditions. The NRC staff did note that some  
38 of the maximum total enthalpy values may increase significantly with increasing power.  
39 However, this is due to the initial peak enthalpy being higher for hot rods that are already  
40 operating at partial power or starting from a higher fuel average temperature. The enthalpy rise  
41 is still mitigated such that the total enthalpy values remain non-limiting relative to the CZP  
42 CRDA values.  
43

44 The analyses performed by GNF-A for CRDA events beyond cold conditions are limited and not  
45 necessarily conclusive to prove that the CRDA event will be non-limiting for hot and  
46 intermediate power conditions for all plants and core loadings. However, these results are  
47 consistent with previous analyses of the CRDA event using other methodologies and the NRC  
48 staff's understanding of the relevant phenomena. Therefore, the NRC staff finds the information  
49 presented in the CRDA LTR to be acceptable to demonstrate that the CRDA event continues to  
50 be limiting at cold conditions, and furthermore, that GNF-A identified reasonable setpoints for

NON-PROPRIETARY INFORMATION

## NON-PROPRIETARY INFORMATION

- 20 -

1 plant operators to use in identifying when rod withdrawal banking requirements are no longer  
2 needed to ensure that a CRDA event does not result in fuel rod failures.

### 3 4 **4.2.5.2 CZP CRDA Scenario:** [[ ]]

5  
6 The methodology described in the CRDA LTR to verify that the CRDA acceptance criteria are  
7 met on a plant/cycle specific basis [[

8  
9  
10  
11  
12 ]]. The NRC  
13 staff agrees that there will be a strong correlation between [[  
14 ]], given that the power excursion is almost completely  
15 defined by two parameters—the reactivity insertion as defined by the control rod worth and the  
16 Doppler coefficient (which itself is largely defined by the initial core temperature). [[  
17 ]] the hydrogen content and rod internal pressure, which are  
18 the parameters other than rod enthalpy that are necessary to evaluate the CRDA acceptance  
19 criteria. The hydrogen content and rod internal pressure are strong functions of exposure, since  
20 hydrogen uptake can be correlated with exposure (as in the NRC provided best estimate  
21 hydrogen uptake model used by GNF-A) and the rod pressure is proportional to the total fission  
22 gas inventory in the gap (which increases with exposure).

23  
24 Use of the PPE value [[ ]] ensures that the  
25 hydrogen concentration and transient fission gas release (FGR) for all fuel rods are bounded,  
26 because the rod failure thresholds are more limiting for higher exposures and the PPE is used  
27 directly as the basis for determining the hydrogen pickup and transient FGR for a given  
28 exposure. The PRIME calculations used to generate the steady FGR [[

29  
30 ]]. The NRC staff noted that the hydrogen concentration is not a linear function of  
31 exposure, [[

32  
33  
34 ]].  
35

36 [[ ]] are validated through a series of TRACG calculations that utilize  
37 conservative initial conditions (as determined through sensitivity studies, if necessary) that  
38 evaluate a postulated startup sequence. The TRACG modeling is discussed in greater detail in  
39 Section 4.2.4 of this SE. The postulated startup sequence is designed to achieve control rod  
40 patterns with dropped control rod worths that are [[  
41 ]]. This may include consideration of out of sequence control rods (see Section  
42 4.2.5.3.3, “Allowed Out of Sequence Control Rods,” of this SE for further discussion). The  
43 control rod patterns may not match the actual control rod sequences that are developed by plant  
44 operators for a given cycle, however, the intent is to accurately capture the control rod worth,  
45 which is the driving force behind the prompt power excursion that defines the CRDA event. Any  
46 other significant influences are captured by limiting the applicability [[

47 ]].  
48

NON-PROPRIETARY INFORMATION

NON-PROPRIETARY INFORMATION

1 [[ ] may be developed for different initial core temperatures, [[  
2 ]]. This is intended to provide flexibility to plant operators by allowing use of less  
3 restrictive rod banking sequences when the core is at higher temperatures, since the  
4 consequences of a CRDA can clearly be demonstrated as being bounded by lower  
5 temperatures [[ ]] (see Section 4.2.4.4 of this SE). [[  
6  
7  
8  
9  
10  
11  
12  
13 ]] Therefore, an initial core temperature [[ ]] can be  
14 used as a representative temperature [[  
15 ]], to  
16 confirm that the rod withdrawal sequences are acceptable until the LPSP or LDPSP discussed  
17 in Section 4.2.5.1 of this SE are met.  
18  
19 The NRC staff noted that [[  
20  
21 ]]. Since some of the aforementioned additional fuel assemblies may  
22 experience enthalpies that approach the limiting enthalpies [[ ]], the  
23 NRC staff asked RAI-2 to better understand how the [[  
24 ]]  
25 surrounding the dropped rod. In the RAI response, GNF-A indicated that even though [[  
26  
27 ]]. The NRC staff agrees with this explanation; however, the NRC  
28 staff also notes that an unstated assumption in this approach is that the results from the fuel rod  
29 failure criteria for the surrounding fuel assemblies is [[  
30  
31  
32 ]]. This assumption is acceptable because: (1) [[  
33 ]], and (2)  
34 [[  
35  
36 ]].  
37  
38 The CRDA LTR described [[ ]] but did not  
39 satisfactorily describe [[  
40 ]]. Since Section 4.2 of the CRDA LTR states that [[  
41 ]], the NRC staff asked RAI-3 to understand how  
42 [[  
43 ]]. This RAI was primarily intended to address the potential for use of  
44 [[  
45 ]]. In the response to  
46 RAI-3, GNF-A proposed [[  
47



1 ]]. The NRC staff agrees that [[

2 ]].

3  
4  
5 Overall, the NRC staff found that the [[ ]] process described in  
6 the CRDA LTR, as updated by the RAI responses, is an acceptable approach to develop [[

7  
8 ]]. In some cases, assumptions implicit in the process used to develop [[  
9 ]] may not be sufficient to assure that all possible results are bounded  
10 because they neglect specific local characteristics that may be important for evaluating whether  
11 individual rods fail. [[ ]] also do not explicitly check for high temperature  
12 fuel failures, though the quantities used [[ ]] are expected to be correlated  
13 to the high temperature fuel failure criteria. However, the TRACG enthalpy calculation  
14 demonstration in Section 5.1.3 of the CRDA LTR clearly shows that even for rod worths [[  
15 ]] TRACG evaluation shows significant  
16 margin to both the PCMI and high temperature failure thresholds. The NRC staff also notes that  
17 there are several conservatisms inherent in the methodology (as discussed in Section 6.0 of this  
18 SE) which would provide additional margin for “outlier cases” where [[

19  
20 ]] process may also consider out of sequence control rods, as discussed in  
21 Section 4.2.5.3.3.

22  
23 In conclusion, the NRC staff has evaluated the guidance described by GNF-A in the CRDA LTR  
24 and RAI responses for the purpose of developing [[

25  
26 ]]. The NRC staff understands that use of the  
27 acceptance criteria will be subject to the requirements described in the CRDA LTR, as updated  
28 by the RAI responses. Based on the described process and requirements for use of a given set  
29 of criteria, the NRC staff finds the approach proposed by GNF-A [[  
30 ]] is acceptable.

#### 31 32 **4.2.5.3 CZP CRDA Scenario: Analysis Procedure**

33  
34 The analysis procedure involves defining several inputs for a plant-specific, cycle-specific CRDA  
35 evaluation. The intent of the methodology described in the CRDA LTR is to allow for  
36 development of control rod withdrawal sequences [[

37 ]]. The reference loading  
38 pattern for the given cycle is appropriate for use, since any changes in control rod worth (which  
39 drives the CRDA response) due to changes which do not require any core redesigns or  
40 re-evaluation of the reload licensing basis are expected to be minimal. The initial core  
41 conditions are discussed in Section 4.2.4.4. The analysis is performed for all steps starting from  
42 [[ ]] until the point at which the at-power CRDA disposition becomes applicable  
43 (as discussed in Section 4.2.5.1 of this SE). This is acceptable because a [[  
44 ]] reactivity anomaly band has previously been justified for GNF-A methodologies (Ref. 15).  
45 The remaining inputs are determined through specific procedures, as discussed below.

#### 46 47 **4.2.5.4 Cycle Exposure**

1  
2 The CRDA LTR, as submitted, included [[ ]] options to define the exposures for  
3 which each CRDA analysis is to be performed. [[  
4  
5 ]] To better understand how these options would be applied, the NRC  
6 staff asked RAI-4 to obtain further detail on how the proposed approach would ensure that the  
7 [[ ]]. In response, GNF-A proposed [[  
8  
9 ]] The resulting options are:  
10 [[  
11  
12  
13  
14  
15  
16  
17  
18  
19 ]]  
20

21 These options provide reasonable flexibility to licensees in optimizing their banking  
22 requirements to meet their needs or preferences, while ensuring that the CRDA analysis results  
23 can be applied across the entire cycle length.  
24

#### 25 **4.2.5.5 Control Rod Withdrawal Order**

26  
27 The control rod withdrawal sequence used by the plant operator can be defined through defining  
28 three constraints on the sequence: the rods assigned to each group, the order in which each  
29 control rod group is withdrawn, and the order for rod withdrawal within a group. Out of these  
30 three constraints, the first two are explicitly defined by the plant operator as part of the basis for  
31 the CRDA analyses. If the control rod groups or group withdrawal order is modified, this would  
32 require re-evaluation of the CRDA event. However, the last constraint, the order in which  
33 control rods are withdrawn within a given control rod group, may be specified in a more flexible  
34 manner.  
35

36 [[ ]] options are provided for plant operators to specify the rod withdrawal order within a  
37 rod group:  
38

- 39 1. Fixed order – the entire control rod withdrawal order is pre-determined and cannot be  
40 altered.

41 [[  
42  
43  
44  
45  
46  
47

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49

]]  
Option 1 ensures that the control rod withdrawal order is consistent with the CRDA evaluation.

[[

]]

**4.2.5.6 Allowed Out of Sequence Control Rods**

Typical plant TSs allow a predetermined number of control rods to be inoperable. Additionally, a plant operator may find it necessary to deviate from an analyzed withdrawal sequence by leaving a control rod fully inserted when the sequence prescribes that the rod should be withdrawn. The CRDA LTR specifies 8 control rods as a typical number, though a plant operator can specify any number of out of sequence control rods as part of their analysis input requirements. The out of sequence control rods are addressed as part of the CRDA evaluation using both PANACEA and TRACG, and the results may be used to support [[

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49

]].

This approach may also not conservatively increase the [[

]]. Two considerations result in a low risk significance for this type of scenario becoming the limiting scenario for the CRDA event. First, the local reactivity for at least one symmetric location associated with the above postulated scenario will most likely be maximized [[ ]]. Second, the evaluation of fuel assemblies for which [[ ]]] to become more likely due to reduced ductility of the cladding or higher internal rod pressure is done in a very conservative manner, as discussed in Section 6.0 of this SE, which is sufficient to offset the variations [[ ]]] for symmetric locations.

The NRC staff finds that the approach described in the LTR for selecting out of sequence rods for evaluation of a given withdrawal order is acceptable because the most likely rod configurations that would challenge the CRDA acceptance criteria will be analyzed. The low risk and safety significance of potentially more limiting configurations does not warrant further constraints on use of this approach.

#### 4.2.5.7 CZP CRDA Scenario: Evaluation Against Acceptance Criteria

For CRDA evaluations utilizing TRACG, the relevant output parameters are compared to the fuel rod failure threshold curves as provided by the NRC. [[

]] The CRDA LTR references a technical document (Ref. 16) that serves as the basis for draft regulatory guide DG-1327 (Ref. 6), which is intended to supersede the current acceptance criteria for RIAs (including CRDAs). As such, the failure threshold curves are acceptable for use in determining whether a fuel rod will be expected to fail based on enthalpy, rod internal pressure, and/or hydrogen content, based on available data. These curves are applied directly as discussed in Section 4.2.5.3 of this SE. The limiting total enthalpy is defined

## NON-PROPRIETARY INFORMATION

- 26 -

1 as the maximum **radially averaged** enthalpy achieved by any fuel rod during the CRDA event.  
2 The limiting delta enthalpy is based a quantity called "prompt enthalpy rise" which only  
3 considers the enthalpy increase during a time interval equal to the width of the power pulse.  
4 This definition is consistent with the current NRC acceptance criteria for PCMI failure in SRP 4.2  
5 Appendix B; this definition was carried over to the current version of DG-1327.

6  
7 The CRDA LTR discusses a third potential mechanism for fuel failures, based on the cladding  
8 perforation model in TRACG that was developed for LOCA conditions. As discussed in the  
9 CRDA TR, [[

10  
11  
12  
13 ]]. In a small number of cases, the TRACG perforation model  
14 [[ ]].  
15 GNF-A indicates in the CRDA LTR that the failure possibility as predicted by the TRACG  
16 perforation model will be used in addition to the two sets of enthalpy based criteria in current  
17 NRC guidance. This is conservative in that it will increase the number of scenarios in which fuel  
18 rod failures are assumed. However, the perforation model has not been validated for the  
19 specific conditions associated with a CZP CRDA event and there is currently no research  
20 indicating that this phenomenon would be a significant concern. Therefore, the NRC staff is not  
21 drawing any conclusions about the applicability of the perforation model or its conclusions for  
22 CRDA scenarios.

23  
24 As a result of the above discussion, the NRC staff finds that the proposed procedure is  
25 acceptable to confirm that the acceptance criteria for the CRDA event are met. This review  
26 considered the acceptance criteria for both SRP 4.2 Appendix B and the draft acceptance  
27 criteria in DG-1327. At this time, DG-1327 has not been finalized and may be subject to  
28 change, but as long as the basis for the above findings continue to remain valid in the final  
29 regulatory guidance, then the methodology outlined in the CRDA LTR should remain valid for  
30 use in demonstrating that NRC requirements are met.

### 31 **4.3 Code Integral Assessment**

32  
33 Following the review guidance provided in Chapter 15.0.2 of the SRP, the next area of review  
34 for transient and accident analysis methods focuses on assessment of the code. The  
35 associated acceptance criteria indicates that all models need to be assessed over the entire  
36 range of conditions encountered in the transient or accident scenarios. The review procedures  
37 provided in Section III of Chapter 15.0.2 of the SRP also indicate that the assessment of these  
38 models is commensurate with their importance and required fidelity. This assessment is  
39 generally performed via comparison of predicted results against both separate effects tests and  
40 integral effects tests. Additionally, assessments must compare code predictions to analytical  
41 solutions, where possible, to show the accuracy of the numerical methods used to solve the  
42 mathematical models.

43  
44 Separate effects tests are generally used to demonstrate the adequacy of individual models and  
45 the closure relationships contained therein. Complementary to these types of tests are integral  
46 tests, which are generally used to demonstrate physical and code model interactions that are  
47 determined to be important for the full size plant. In either case, some tests may not be  
48 full-scale, and, in demonstrating applicability to full-scale plant conditions, the tests may contain

NON-PROPRIETARY INFORMATION

## NON-PROPRIETARY INFORMATION

- 27 -

1 scaling distortions. These distortions can affect both local and overall elements. It is therefore  
2 necessary to examine the nature of the tests involved in the assessments.  
3 The abilities of TRACG, with incorporation of key models and inputs from PRIME and  
4 PANACEA, has been assessed against integral and separate effect data and found to be  
5 acceptable for performing AOOs, stability, and ATWS calculations (Refs. 10, 11, and 12).  
6 These kinds of events and their associated validation databases provide a robust assessment of  
7 the capability of these codes to capture coupled thermal hydraulic-neutronics physics  
8 phenomena, along with the dynamic fuel rod thermal mechanical response. As a result, the  
9 majority of this section of the report will focus on the specific assessments that were performed  
10 to demonstrate that the codes provide adequate predictions of the phenomena of interest for the  
11 CRDA event.

12  
13 Additional model integral test assessments were provided to support the ability of PANACEA  
14 and TRACG to evaluate the CRDA event for startup conditions based on tests performed at the  
15 Special Power Excursion Reactor Test III (SPERT III) reactor. These tests provide a valuable  
16 assessment of the ability of PANACEA and TRAC-G to capture the Doppler reactivity feedback,  
17 since the SPERT III reactor does not include moderator voiding and the power pulses are short  
18 enough to ensure that no significant heat transfer to the moderator occurs prior to the mitigation  
19 of the prompt power excursion due to Doppler reactivity feedback. As such, this assessment  
20 provides confidence that the PANACEA and TRACG codes will predict the Doppler reactivity  
21 feedback in the absence of other reactivity feedback mechanisms (such as void feedback, as  
22 captured by the Peach Bottom turbine trip tests that were included in the prior assessments).  
23 The data available from the SPERT test documentation (Rev. 17) has some notable limitations,  
24 including a lack of detail regarding the exact worth of the control rod used to simulate the rod  
25 drop and the speed of withdrawal. Therefore, some assumptions had to be made to model the  
26 tests in PANACEA and TRACG, but the key quantities, such as the reactivity insertion, were  
27 explicitly captured via the appropriate model parameters.

28  
29 The assessment shows that PANACEA predicts the prompt power pulse from the SPERT III  
30 experiments well for a variety of different reactivity insertions. Only one calculation was  
31 performed with TRACG, for the test with the largest reactivity insertion. This is acceptable  
32 because the transient being simulated is so short that no significant heat transfer to the coolant  
33 occurs, therefore, the more realistic heat transfer features of TRACG will have little effect. [[

34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44 ]] When this is taken  
45 into consideration, the results compare very favorably.

46  
47 The NRC staff reviewed the previous assessments performed to support the use of the models  
48 and data computed from the PRIME, PANACEA, and TRACG methodologies to analyze AOO,  
49 stability, and ATWS events, and determined that they were applicable to demonstrate that

NON-PROPRIETARY INFORMATION

NON-PROPRIETARY INFORMATION

1 specific phenomena relevant to the CRDA event are appropriately assessed. The one  
2 significant assessment gap, related to determining the Doppler reactivity feedback in the  
3 absence of any other significant reactivity feedback mechanisms, was filled by assessing  
4 PANACEA and TRACG against data from SPERT III tests of rod ejection accidents. Therefore,  
5 the NRC staff has determined that the PRIME, PANACEA, and TRACG have been satisfactorily  
6 assessed for their abilities to model the relevant phenomena for the CRDA event, within the  
7 bounds of their intended applications within the CRDA analysis methodology.  
8

9 **4.4 Uncertainty Analysis**

10  
11 Following the review guidance provided in Chapter 15.0.2 of the SRP, the next area of review  
12 for transient and accident analysis methods discussed in this SE focuses on uncertainty  
13 analysis. The associated acceptance criteria indicate that the analysis must address all  
14 important sources of code uncertainty, including the mathematical models in the code and user  
15 modeling such as nodalization. The major sources of uncertainty must be addressed consistent  
16 with the results of the accident scenario identification process.  
17

18 The CRDA LTR discusses each of the individual parameters identified as being high importance  
19 in available regulatory guidance. In general, the uncertainty associated with each parameter  
20 was dispositioned in one of the following ways:  
21

- 22 1. The parameter is set to bounding values, therefore, no uncertainty needs to be  
23 considered. (example: [[ ]])  
24
- 25 2. Studies were performed to establish the sensitivity of the results to the parameter across  
26 the range of uncertainty (based on available references). (example: [[  
27 ]])  
28
- 29 3. The uncertainty within a parameter is accommodated by conservatisms in the analysis  
30 (example: [[ ]])  
31

32 The following table summarizes the parameters evaluated, how the uncertainties were  
33 addressed in the proposed CRDA analysis methodology, and the NRC staff's assessment of the  
34 acceptability of the approach used for the purpose of determining the expected impact on the  
35 limiting enthalpy rises for the CRDA analysis. Most of the parameters are identified in the  
36 CRDA TR, but the NRC staff identified some additional parameters that are expected to impact  
37 the results from the CRDA analysis. GNF-A addressed these parameters in their response to  
38 the NRC RAIs.  
39

Parameter	GNF-A Analysis	NRC Assessment
Doppler reactivity coefficient	[[ ]]	The Doppler reactivity coefficients are expected to have a direct relationship to the severity of the power excursion, given that the Doppler reactivity is the primary mechanism by which the power excursion is arrested. The information provided by GNF-A is a reasonable basis to infer some general conclusions. The two sigma uncertainty of [[ ]] is consistent with previously

**NON-PROPRIETARY INFORMATION**

Parameter	GNF-A Analysis	NRC Assessment
	]]	approved NRC methodologies (Rev. 10). There is clearly an effect on the enthalpies, and the application of [[ ]] Doppler coefficients has been shown to capture sufficient margin to offset the observed effects (see Section 4.2.4.5 of this SE). Therefore, the NRC staff finds the conservatism in the application of the Doppler coefficients to be sufficient to accommodate the uncertainty in the Doppler reactivity feedback.
Void reactivity coefficient	[[          ]]	The range of feedback variation analyzed is somewhat arbitrary, but significantly larger than expected based on the assessment of PANACEA and TRACG for AOO and ATWS events. The impact of void reactivity feedback on the limiting enthalpies is expected to be very small due to the fact that significant heating of the moderator would be required to reach saturation conditions, so significant voiding is not expected to occur. Therefore, the NRC staff finds this analysis to be sufficient to demonstrate that the impact of the void reactivity feedback [[          ]].
Manufacturing uncertainties	[[          ]]	The NRC staff agrees that the use of a [[ ]] is sufficient to account for any impacts (expected to be small) due to manufacturing tolerances on the [[ ]]. However, the more important aspect is that the NRC fuel cladding failure thresholds were established based on test results that covered a variety of fuel rod designs and claddings. Therefore, a variety of different manufacturing specifications are already implicit in the failure thresholds. Therefore, manufacturing tolerances do not need to be explicitly addressed in the CRDA model.
Fuel Cladding Failure Thresholds	GNF-A discusses the basis for the failure thresholds. Also, uncertainties in the best estimate hydrogen pickup model used to evaluate the PCMI failure threshold	The NRC is currently in the process of finalizing the failure thresholds, as described in draft regulatory guide DG-1327. Once final, the thresholds can be used without further justification. The NRC staff finds that [[          ]] is sufficient to



**NON-PROPRIETARY INFORMATION**

Parameter	GNF-A Analysis	NRC Assessment
	are accounted for by [[ ]].	account for the two sigma uncertainty in the best estimate model used by GNF-A.
Burnup	[[       ]]	The NRC staff agrees that the conservative assumption [[  ]] is sufficient to bound any variations in fission gas release from the pellets. The NRC staff discussion of the approach used to ensure that the limiting exposure for a cycle is identified can be found in Section 4.2.5.3 of this SE.
Fission Gas Release	[[       ]]	The NRC staff discussion of the fission gas release assumptions can be found in Section 4.2.4.3 of this SE.
Control Rod Worths	[[       ]]	The NRC staff agrees that the approach used to model the reactivity insertion due to the control rod drop generally models all relevant parameters [[  ]]. However, the CRDA LTR states [[       ]]. The NRC staff asked RAI-6 to request justification that the results of this evaluation approach would bound [[  ]]. In their response (Ref. 13), GNF-A stated that [[       ]].

**NON-PROPRIETARY INFORMATION**

Parameter	GNF-A Analysis	NRC Assessment
	<p align="center">]]</p>	<p>The NRC staff noted that there is also an uncertainty associated with manufacturing tolerances for the control rod. However, the NRC staff does not expect that this uncertainty would be significant because if it were, it would adversely impact the reactivity anomaly by significantly broadening the variance in measured eigenvalues compared to predicted values.</p> <p>The overall CRDA analysis procedure is discussed in Section 4.2.5 of this SE.</p>
Reactor Scram	<p>[[</p> <p align="center">]]</p>	<p>The NRC staff agrees that this is a conservative assumption, [[</p> <p align="center">]].</p>
Delayed Neutron Fraction	<p>The initial submittal of the CRDA LTR did not address the uncertainty in the delayed neutron fraction. In response to RAI-7 from the NRC (Ref. 13), GNF-A provided information from an uncertainty analysis performed by [[</p> <p align="center">]]</p> <p>delayed neutron fraction values from a normal distribution corresponding to a standard deviation of 12%. This standard deviation was based on a weighted combination of the delayed neutron fraction uncertainties for U-235, U-238, and Pu-239 near the end of life for a fuel assembly, which is when the weighted total uncertainty is at a maximum. The results showed small impacts on</p>	<p>Prior assessments of the PANACEA neutron kinetics model indicate that the [[</p> <p align="center">]]. The delayed neutron fraction used by PANACEA is [[</p> <p align="center">]]. Therefore, the uncertainty in delayed neutron fraction is expected to originate from two [[</p> <p align="center">]] sources: (1) the uncertainty in the relative number densities of the isotopes contributing to fission as a result of accumulated code and cross section uncertainties during the depletion, and (2) uncertainty in the experimental values determined for the delayed neutron fraction for each contributing isotope.</p> <p>GNF-A used an appropriate reference from open literature to calculate a weighted uncertainty that accounts for the different fission yields of each contributing isotope. The 12% value was selected as the highest standard deviation, driven by the higher percentage of uncertainty in the delayed neutron fraction for Pu-239 which dominates at the end of a fuel assembly's life. The first uncertainty was not addressed by GNF-A, however, the expected maximum variation</p>

**NON-PROPRIETARY INFORMATION**

Parameter	GNF-A Analysis	NRC Assessment
	<p>the peak enthalpy and PCT.</p>	<p>would be small compared to the overall increase in Pu-239 relative to U-235 and U-238, and the limiting CRDA events would be driven by lattices that are still relatively early in their life.</p> <p>As discussed in the RAI response, GNF-A performed a statistical analysis [[</p> <p align="center">]] to assess the impact of the uncertainty on the calculated power, enthalpy, and PCT in TRACG. The results show that the estimated 95/95 increase in enthalpy and PCT due to uncertainty in the delayed neutron fraction is on the order of [[</p> <p align="center">]].</p>
<p>Rod and Assembly Power Distribution</p>	<p>The 3-D neutronic models in PANACEA and TRACG have an inherent uncertainty associated with local rod and assembly power distributions. This uncertainty was not addressed in the CRDA LTR, so NRC staff requested further justification in RAI-8. In response (Ref. 13), GNF-A provided some discussion stating that the power distribution uncertainties are addressed by the fact that [[</p> <p align="center">]].</p>	<p>The NRC staff agrees that the effect of the power distribution uncertainties is implicitly captured in [[</p> <p align="center">]].</p> <p>However, the NRC staff also expects that there would be a more direct impact on the results of the enthalpy calculation—an increase in local power generation for the limiting rod would result in a higher enthalpy rise. The 3-D neutronic models may not exhibit a consistent bias, but the analysis of the CRDA event is intended to investigate the highly local conditions associated with the single most limiting fuel rod. Therefore, the power distribution uncertainties should be addressed. The total uncertainty may be conservatively considered to have a direct proportionate impact on the enthalpy rise—i.e., a [[</p> <p align="center">]] increase in power would produce a [[</p> <p align="center">]] increase in deposited enthalpy. In reality, greater power deposition in the fuel rod would cause a more rapid Doppler reactivity response, dampening the power pulse and reducing the total power deposition. As discussed in Section 6.0, the NRC staff believes that the inherent conservatism in the proposed CRDA</p>

NON-PROPRIETARY INFORMATION

Parameter	GNF-A Analysis	NRC Assessment
		analysis methodology are sufficient to offset this uncertainty.
Core Initial Conditions	Sensitivity studies were performed to identify bounding or representative values.	See Section 4.2.4.4 of this SE.

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42

Based on the above discussion, the NRC staff finds that GNF-A has appropriately considered and accommodated all uncertainties through demonstrations that the uncertainty would have a minimal impact on the results of the CRDA analysis, or through conservative modeling approaches that bound the effects of the uncertainties.

**4.5 Methodology Implementation**

Section 6.0 of the CRDA LTR describes changes to GESTAR II methodology and standard TSs (STS) that will be necessary to allow licensees to use the proposed CRDA methodology. The NRC staff reviewed the proposed changes to confirm that they are consistent with the intended use of the CRDA methodology.

The changes to GESTAR II primarily consist of the addition of the proposed CRDA methodology as an option for licensees to utilize for their licensing basis associated with CRDA analyses. Several documentation requirements are incorporated into the application of the CRDA methodology as part of GESTAR II, namely:

1. [[ ]] will be included in the fuel product compliance report. [[ ]] Inclusion of this information in the fuel product compliance report ensures that this information is readily available for NRC audit. [[ ]]
2. Control rod withdrawal sequences that have been confirmed to meet the acceptance criteria in the CRDA LTR are to be captured in the plant reload document associated with each cycle. In addition, the plant’s supplement reload design report will confirm that the methodology described in the CRDA LTR, as approved, was used to validate the cycle as being compliant with the plant licensing basis for the CRDA event.

The STS changes are provided only for the BWR/4 STS, which contain required actions and surveillances that are specific to the BPWS. Since this CRDA analysis methodology is intended to provide an alternative to the BPWS, the proposed changes are intended to replace the references to the BPWS with requirements applicable to the control rod withdrawal sequences developed using the methodology described in the CRDA LTR. The NRC staff confirmed that the revised requirements include references to all the relevant constraints to ensure that the CRDA analyses remain valid, including adherence to the analyzed control rod withdrawal sequence, the maximum number of fully inserted out of sequence rods, and the reactor power/pressure at which the at-power CRDA basis becomes applicable.

1  
2 As a result of the above review of the proposed changes to GESTAR II and the STS, the NRC  
3 staff finds that the proposed updates will be adequate to incorporate the proposed CRDA  
4 analysis methodology in plant licensing bases by capturing the relevant details in licensing basis  
5 documentation.  
6

7 **4.6 Methodology Updates & Extended Applicability**  
8

9 The final area of review for the NRC staff pertains to the allowed updates and extended  
10 methodology applications discussed in Section 7.0 of the CRDA LTR. The intent of this section  
11 is to indicate when new models and codes can be substituted in lieu of the ones assumed to be  
12 used in the CRDA LTR, and to clarify acceptable applications of the proposed CRDA analysis  
13 methodology beyond that described in the CRDA LTR. The NRC staff considerations regarding  
14 each item are provided below.  
15

- 16 1. (Section 7.1 of the CRDA LTR) The NRC staff agrees that, [[  
17  
18  
19

20 ]].  
21

- 22 2. (Section 7.2.1 of the CRDA LTR) The NRC staff agrees that the procedure described in  
23 Section 4.1 may be used to allow use of [[  
24  
25

26 ]].  
27

- 28 3. (Sections 7.2.2 and 7.2.3 of the CRDA LTR) The failure threshold curves and hydrogen  
29 pickup model used in the CRDA LTR are both provided in NRC guidance, and are only  
30 used to determine whether the enthalpy results from TRACG indicate fuel failure or not.  
31 Consequently, if the NRC approves new curves or models that are applicable to the fuel  
32 being analyzed, the new curves or models can be used without affecting the  
33 acceptability of the analysis methodology.  
34

- 35 4. (Section 7.2.4 of the CRDA LTR) [[ ]] are generally expected to be  
36 analyzed using [[

37 ]]. However, an alternative approach is to confirm  
38 [[ ]]. This is  
39 consistent with one possible application of item 1 (above).  
40

- 41 5. (Section 7.3 of the CRDA LTR) The NRC staff agrees that the methodology described in  
42 the CRDA LTR is primarily a procedure that utilizes functional models and elements  
43 associated with approved codes for predicting fuel rod thermal mechanical, core  
44 neutronic, and thermal hydraulic performance. As such, other models and elements that  
45 serve a similar purpose may be substituted as long as they are consistent with the  
46 applicable NRC approvals. However, the NRC staff notes that the approval of the  
47 proposed CRDA analysis methodology is partly dependent on the offsetting effects of  
48 methodology conservatisms, sensitivities, and uncertainties as determined by use of the  
49 codes specified in the CRDA LTR. Therefore, use of updated models or elements,

1 including use of new approved codes such as LANCR or AETNA, is acceptable only if  
2 the updated or new codes do not have larger uncertainties than those discussed in the  
3 CRDA LTR and RAI responses. A limitation and condition is placed on the use of  
4 updated or new codes to ensure that the uncertainties remain within the bounds of those  
5 considered as part of the NRC review and approval of the CRDA LTR.  
6

7 **5.0 CONDITIONS AND LIMITATIONS**

8  
9 As discussed in Section 2.0 of this SE, conditions and limitations have been applied to use of  
10 the PANACEA, TRACG, and PRIME models as part of their application-specific approvals in  
11 (Refs. 10, 11, and 12. These conditions and limitations must be addressed in addition to the  
12 below conditions and limitations, which have previously been discussed in this SE and are  
13 summarized here.  
14

- 15 1. For each application of this methodology to perform licensing basis evaluations of the  
16 CRDA event, the maximum drop speed for all control rods shall be confirmed to be  
17 bounded by the 3.11 ft/s speed assumed in this LTR or the actual maximum drop speed  
18 shall be applied.  
19
- 20 2. When utilizing Option 2 in prescribing the control rod withdrawal order within a group, as  
21 described in Section 4.3.5.1 of this LTR, if control rods other than the highest worth rod  
22 [[  
23  
24  
25  
26  
27  
28  
29  
30  
31 ]].  
32
- 33 3. When utilizing Option 3 in prescribing the control rod withdrawal order within a group, as  
34 described in Section 4.3.5.1 of this LTR, [[  
35  
36 ]] control rod withdrawal sequences (i.e., all control rods within a group are  
37 withdrawn to the same intermediate position before any control rod is withdrawn past  
38 that position).  
39
- 40 4. If updated models, elements, or codes are used with this methodology as described in  
41 Section 7.3 of this LTR, the validation results shall be similar to, ~~or less than,~~ the results  
42 for the specific models, elements, and codes referenced in this LTR. Within this context,  
43 validation results [[  
44 ]] with consistent results, but also code/model uncertainties that are  
45 similar to, or less than, those determined for the models, elements, and codes  
46 referenced in this LTR.  
47

48 **6.0 CONCLUSIONS**

## NON-PROPRIETARY INFORMATION

- 36 -

1 In the CRDA LTR, GNF-A presented a new methodology to use previously approved codes—  
2 PRIME, PANACEA, and TRACG—for evaluation of the CRDA event. The new methodology is  
3 applicable for all BWR types and fuel product lines for which the approved codes are qualified.  
4 Part of the methodology includes development and application of [[

5  
6 ]].  
7

8 The CRDA LTR presents a description of the CRDA event and discusses the ability of the  
9 relevant technical models utilized in the PRIME, PANACEA, and TRACG analysis  
10 methodologies to capture the relevant phenomena for the CRDA event. The acceptance criteria  
11 for the CRDA event are also discussed. In the CRDA LTR, fuel rod enthalpy is the most  
12 significant output parameter considered, since this parameter drives the potential for fuel failure  
13 during a CRDA event. GNF-A specifies that this methodology is intended to ensure that no fuel  
14 failures occur, therefore, acceptance criteria such as the peak system pressure, fission product  
15 inventory release, or core coolability do not need to be addressed due to the lack of significant  
16 enthalpy production, radioisotope release, or deformation of the fuel.  
17

18 No new elements, models, or codes were necessary to use the proposed methodology;  
19 therefore, the description of the methodology primarily consists of input requirements and  
20 analysis procedure guidance. This formed the bulk of the NRC staff review of the CRDA LTR  
21 and included a review for acceptability of model nodalization guidance, modeling input  
22 specifications, recommended initial conditions, control rod evaluation procedure, and  
23 acceptance criteria. The analysis procedure is specific to the CRDA event at CZP conditions;  
24 the NRC staff also reviewed information presented in the CRDA LTR to generically identify the  
25 CRDA event as non-limiting for other core conditions.  
26

27 The NRC staff identified several technical issues that were not explicitly addressed as part of  
28 the proposed CRDA analysis methodology. The most significant general issues were the lack  
29 of an explicit disposition within the methodology for the delayed neutron fraction uncertainty  
30 (estimated impact: [[ ]]) and the rod/assembly power distribution uncertainty  
31 (estimated impact: [[ ]]). Additional technical issues were identified with use of  
32 relatively simple procedures to address specific considerations which did not consider the  
33 dependence of fuel failure thresholds on not only enthalpy [[  
34 ]], but also on the hydrogen concentration and rod pressures of the surrounding fuel  
35 [[ ]]. In yet other cases, reasonable qualitative evidence was  
36 presented to indicate that the limiting cases would probably be bounded by the analysis, but  
37 insufficient quantitative evidence existed to confirm these findings. To address these issues,  
38 the NRC staff considered the significant conservatisms that were incorporated in the proposed  
39 methodology, as follows:  
40

- 41 1. The proposed methodology is designed to confirm that no fuel failures occur. This is a  
42 more conservative approach than required to meet regulatory limits. In reality, limited  
43 numbers of fuel failures are likely to be accommodated by typical licensing bases as  
44 long as the radioisotope release is not large enough to challenge dose release limits.  
45

- 46 2. The Doppler reactivity feedback is modeled [[

47  
48 ]]. Due to the  
49 natural variation of exposures for fuel within core loading patterns, conservatism in the

NON-PROPRIETARY INFORMATION

## NON-PROPRIETARY INFORMATION

- 37 -

1 Doppler reactivity feedback modeling is expected to exist for most, if not all dropped  
2 rods, especially at more limiting cycle exposures such as EOC.  
3

4 3. The core is expected to be critical at the given minimum temperature for a given control  
5 rod sequence evaluation. In reality, this will be the case (or nearly the case) for a very  
6 limited number of steps. For steps prior to this point, the control rod worth will be  
7 partially or fully offset by the subcriticality of the core, and for steps beyond this point, the  
8 increasing core temperature will reduce control rod worths.  
9

10 4. [[ ]], which contain several  
11 simplifications that are expected to [[  
12 ]] (as discussed in Section 4.2.4.6 of this SE). Consequently, the calculated [[  
13 ]] enthalpy for all fuel assemblies will be higher than the [[ ]]  
14 enthalpy during a CRDA event.  
15

16 5. The PPE and peak enthalpy [[  
17 ]]. For exposures at which the enthalpy for fuel failure decreases  
18 significantly due to loss of cladding ductility (for PCMI failure) or higher rod internal  
19 pressures (for high temperature failure), the reactivity of the fuel rod is expected to be  
20 significantly lower than the fuel rods driving the prompt power excursion. Consequently,  
21 the deposited enthalpy for the higher burnup fuel rods will not be as high as the [[  
22 ]]. Therefore, use of a PPE combined with the maximum enthalpy  
23 [[ ]] will lead to a conservative evaluation against the  
24 acceptance criteria for higher burnups.  
25

26 6. [[  
27 ]]  
28 ]]. This will produce a more conservative value for the prompt enthalpy  
29 rise, since the [[ ]] at the time of the peak pulse (when the prompt enthalpy rise is  
30 determined) will tend to be smaller. Consequently, the PCMI failure criteria will be  
31 evaluated with conservative peak enthalpy values.  
32

33 7. The FGR for fuel rods is calculated in PRIME [[  
34 ]]. This conservatively increases the rod pressure, so evaluation of the high  
35 temperature criteria is more likely to occur when the enthalpy threshold is lower. This  
36 effect can be observed in Figure [[ ]] of the CRDA LTR, where a significant number  
37 of rods are evaluated based on the lower enthalpy threshold corresponding to a higher  
38 differential pressure than expected based on the PPEs shown in Figure [[ ]].  
39  
40

41 Three limitations and conditions were imposed to ensure that key assumptions inherent in the  
42 NRC staff understanding of the methodology are consistent with the plant/cycle configurations  
43 being analyzed, due to the sensitivity of the CRDA event to these assumptions.  
44 In order to demonstrate the capability of the PRIME, PANACEA, and TRACG codes to analyze  
45 the CRDA event, assessments have been made against separate effects tests and integral  
46 tests. In most cases, these assessments were already performed as part of the qualification of  
47 these codes for analysis of AOO, stability, and ATWS events. One additional assessment was  
48 added, for tests performed at the SPERT III reactor to simulate rapid rod withdrawal scenarios.

NON-PROPRIETARY INFORMATION



## NON-PROPRIETARY INFORMATION

- 38 -

1 The data from this assessment was valuable in that it provided confidence that the neutron  
2 kinetics models in PANACEA and TRACG could accurately predict the Doppler-only component  
3 of the reactivity feedback.

4  
5 Finally, the CRDA LTR presented an evaluation of the uncertainties associated with the  
6 proposed CRDA analysis methodology. GNF-A dispositioned each uncertainty in one of three  
7 different ways: (1) by demonstration that the effect on the peak enthalpy was minimal; (2) by  
8 conservatively bounding the effect of the uncertainty; or (3) by indicating that the remaining  
9 uncertainties were bounded by the inherent conservatism in the methodology (as discussed  
10 earlier in this section).

11  
12 In addition to the description of the methodology, the CRDA LTR also included a description of  
13 the changes that would be needed to GESTAR-III-II and the STS in order to allow full use of the  
14 new CRDA methodology, as well as a discussion of the updates or applications that could be  
15 used with this methodology without requiring additional NRC review and approval. The NRC  
16 staff agreed with the implementation changes and the scope of the methodology applications,  
17 except for the assertion that new elements, models, or codes that had received NRC approval  
18 for other purposes could be utilized with the CRDA analysis methodology without NRC review  
19 and approval. Since some of the considerations in determining this methodology to be  
20 acceptable for use depend on the findings from the validation and uncertainty quantification for  
21 the codes, a limitation and condition was imposed to appropriately define the scope of how such  
22 applications of the CRDA analysis methodology can be implemented.

23  
24 In summary, the NRC staff finds that the assessment of the PRIME, PANACEA, and TRACG  
25 codes, as described in the CRDA LTR and responses to NRC staff RAIs, adequately  
26 demonstrates that the codes are suitable to analyze the CRDA event by demonstrating  
27 acceptable predictions of the highly ranked phenomena. In addition, the NRC staff finds that the  
28 procedure described in the CRDA LTR for performance of the CRDA analyses provides  
29 appropriate guidance to appropriately identify and analyze potential limiting scenarios. Since  
30 the CRDA event is relatively insensitive to thermal hydraulic performance of the plant and  
31 appropriate guidance has been presented to address the relevant factors, the NRC approval of  
32 this CRDA analysis methodology purposes extends to all operating conditions up to and  
33 including Extended Power Uprate conditions with expanded power and flow windows.  
34 Additionally, NRC approval of the methodology described in this LTR for analysis of the CRDA  
35 event is contingent on adherence to the conditions and limitations set forth in Section 5.0.

### 36 37 **7.0 REFERENCES**

- 38  
39 1. Global Nuclear Fuel Report NEDO-33885/NEDE-33885P, Revision 0, "GNF  
40 CRDA Application Methodology," February 2018 (ADAMS Accession  
41 Nos. ML18059A878 (Public)/ML18059A880 (Non-Public)).  
42  
43 2. Global Nuclear Fuel Report NEDE-24011-P-A-2629-US, "General Electric  
44 Standard Application for Reactor Fuel (GESTAR II) (Supplement for United  
45 States)," ~~January~~ **October** 2018~~9~~ (as approved by NRC in ADAMS Accession  
46 No. ~~ML19199A053~~ **ML1927D426**).  
47 3. General Electric Hitachi Letter, "Response to NRC Request for Additional  
48 Information Letters No. 115 and No. 137 – Related to ESBWR Design  
49 Certification Application – RAI Numbers 4.6-23 Supplement 2 and 4.6-38,

NON-PROPRIETARY INFORMATION

## NON-PROPRIETARY INFORMATION

- 39 -

- 1                    Respectively," April 14, 2008 (ADAMS Accession Nos. ML081090147  
2                    (Public)/ML081090148 (Non-Public)).  
3
- 4                    4.        General Electric Company Report NEDO-21231, "Banked Position Withdrawal  
5                    Sequence," January 1977 (ADAMS Accession No. ML090771242 (Non-Public)).  
6
- 7                    5.        USNRC Document NUREG-0800, "Standard Review Plan for the Review of  
8                    Safety Analysis Reports for Nuclear Power Plants: Light Water Reactor Edition,"  
9                    March 2007 (ADAMS Accession No. ML070660036).  
10
- 11                   6.        USNRC Draft Regulatory Guide DG-1327, "Pressurized-Water Reactor Control  
12                    Rod Ejection and Boiling-Water Reactor Control Drop Accidents," released for  
13                    public comment July 2019 (ADAMS Accession No. ML18302A106).  
14
- 15                   7.        American Society of Mechanical Engineers Boiler and Pressure Vessel Code, as  
16                    incorporated by reference in 10 CFR 50.55a.  
17
- 18                   8.        USNRC Regulatory Guide 1.183, "Alternative Radiological Source Terms for  
19                    Evaluating Design Basis Accidents at Nuclear Power Reactors," July 2000  
20                    (ADAMS Accession No. ML003716792).  
21
- 22                   9.        USNRC Regulatory Guide 1.195, "Methods and Assumptions for Evaluating  
23                    Radiological Consequences of Design Basis Accidents at Light-Water Nuclear  
24                    Power Reactors," May 2003 (ADAMS Accession No. ML031490640).  
25
- 26                   10.       General Electric Hitachi Report NEDE-32906P-A, Supplement 3-A, Revision 1,  
27                    "Migration to TRACG04/PANAC11 from TRACG02/PANAC10 for TRACG AOO  
28                    and ATWS Overpressure Transients," April 2010 (approved by USNRC in  
29                    ADAMS Accession Nos. ML091751102 (Public)/ML091400057 (Non-Public)).  
30
- 31                   11.       General Electric Company Report NEDE-32906P-A, Revision 3, "TRACG  
32                    Application for Anticipated Operational Occurrences (AOO) Transient Analyses,"  
33                    September 2006 (ADAMS Accession No. ML062720163).  
34
- 35                   12.       Global Nuclear Fuel Report NEDC-33840P-A, Revision 1, "The PRIME Model for  
36                    Transient Analysis of Fuel Rod Thermal-Mechanical Performance," August 2017  
37                    (ADAMS Accession No. ML17230A008).  
38
- 39                   13.       Global Nuclear Fuel Letter, "Response to Request for Additional Information for  
40                    NEDE-33885P, 'GNF CRDA Application Methodology,'" April 25, 2019 (ADAMS  
41                    Accession No. ML19115A084).  
42
- 43                   14.       General Electric Company Report NEDO-10527, "Rod Drop Accident Analysis for  
44                    Large Boiling Water Reactors," March 1972 (ADAMS Accession  
45                    No. ML010870249).  
46
- 47                   15.       General Electric Hitachi Report NEDE-33173P-A, Revision 45, "Applicability of  
48                    GE Methods to Expanded Operating Domains," ~~November 2012~~ **August 2019**  
49                    (ADAMS Accession No. ~~ML123130130~~ **ML19234A243**).  
50

NON-PROPRIETARY INFORMATION

**NON-PROPRIETARY INFORMATION**

- 40 -

- 1           16.    USNRC Memorandum, "Technical and Regulatory Basis for the Reactivity-  
2                    Initiated Accident Acceptance Criteria and Guidance, Revision 1," March 16,  
3                    2015 (ADAMS Accession No. ML14188C423).  
4
- 5           17.    AEC Research and Development Report IDO-17281 (TID-4500), "Reactivity  
6                    Accident Test Results and Analysis for the SPERT III E-Core - A Small Oxide-  
7                    Fueled, Pressurized Water Reactor," March 1969 (ADAMS Accession  
8                    No. ML080320431).  
9

10 Principal Contributor: Scott Krepel, NRR/DSS/SNPB

11  
12 Date: October 16, 2019

13