

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: \_\_\_\_\_ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 ARAN01 00-000000-00 411111 \_\_\_\_\_

CON'T  
01 REPORT SOURCE L 05000313 7020579 8030579

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES  
02 During plant startup following a maintenance outage, the review of the  
03 Shift Supervisor's Log during shift change over revealed that the Nuclear  
04 Instrumentation was not calibrated as required by T.S. 4.1 Table 4.1-1.  
05 The limiting reactor power level used by operations is the highest as  
06 indicated by Heat Balance or NI indication. Similar to LER 50-313/78-31,  
07 78-14, 77-16, 77-11, 76-31, 76-23, and 76-19, Reportable per T.S.  
08 6.12.3.1(b).

09 SYSTEM CODE I D 11 CAUSE CODE A 12 CAUSE SUBCODE A 13 COMPONENT CODE Z Z Z Z Z Z 14 COMP SUPCODE Z 15 VALVE SUBCODE Z 16  
17 LER/RO REPORT NUMBER 79 21 EVENT YEAR 79 22 SEQUENTIAL REPORT NO. 002 24 OCCURRENCE CODE 01 28 REPORT TYPE I 30 REVISION NO. 0 32  
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRD-4 FORM SUB PRIME COMP SUPPLIER COMPONENT MANUFACTURER  
18 19 20 21 22 23 24 25 26 27 28 29 30 31 32  
F Z Z Z 0000 Y N Z Z Z 9999

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS  
10 The event was caused by personnel error. Power escalation was stopped  
11 and Nuclear Instrumentation was calibrated on 2/7/79 per OP 1304.32.  
12 Occurrence is believed to be an isolated event. Occurrence was discussed  
13 with Shift Supervisors and I&C Supervisors.

14  
15 FACILITY STATUS E 28 % POWER 07 29 OTHER STATUS NA 30 METHOD OF DISCOVERY A 31 NA 32 DISCOVERY DESCRIPTION

16 ACTIVITY CONTENT Z 33 Z 34 NA 35 AMOUNT OF ACTIVITY NA 36 LOCATION OF RELEASE

17 PERSONNEL EXPOSURES NUMBER 000 37 TYPE Z 38 DESCRIPTION NA 39

18 PERSONNEL INJURIES NUMBER 000 40 DESCRIPTION NA 41

19 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43

20 PUBLICITY ISSUED N 44 DESCRIPTION NA 45

NAME OF PREPARER Chris N. Shively PHONE 501/968-2519

7903180375

Mr. W. D. Johnson  
U. S. Nuclear Regulatory  
Commission  
P. O. Box 2090  
Russellville, Arkansas 72801

Mr. Norman M. Haller, Director  
Office of Management & Program  
Analysis  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555