

COPY

PACIFIC GAS AND ELECTRIC COMPANY

LAW DEPARTMENT - 77 • E STREET, 31ST FLOOR • SAN FRANCISCO, CALIFORNIA 94106 • (415) 781-4211

March 12, 1980

Mr. R. H. Engelken, Director
Office of Inspection and Enforcement
Region V
U. S. Nuclear Regulatory Commission
1990 N. California Boulevard
Walnut Creek Plaza, Suite 202
Walnut Creek, California 94596

Re: Docket No. 50-133
License No. DPR-7

Dear Mr. Engelken:

Pursuant to Section IX.I.2.b.(1) of Appendix A to the Humboldt Bay Unit No. 3 Operating License, we are submitting the enclosed Licensee Event Report LER-80-001/03L-0 covering setpoint drift of the pressure switch that automatically starts the plant fire pumps.

Very truly yours,

Philip A. Crane, Jr.

Enclosure

CC w/enc.: Director
Office of Management Information
and Program Control
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

1002
S.11

8003180-553