

Unit 3

LICENSEE EVENT REPORT

Report No. 3-80-4/3L

CONTROL BLOCK: \_\_\_\_\_ (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01	P	A	P	B	S	3	2	0	0	-	0	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4	5							
7	8	9	LICENSEE CODE					14	15	LICENSE NUMBER										25	26	LICENSE TYPE JO					57	58	59	60	61	62	63	64

01	L	6	0	5	0	-	0	2	7	8	7	0	2	0	5	8	0	8	0	3	0	6	8	0	9
7	8	REPORT SOURCE		60	61	DOCKET NUMBER					68	69	EVENT DATE					74	75	REPORT DATE					80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | During the startup of Unit 3, the reactor water conductivity increased

03 | and exceeded Tech. Spec. 3.6.B.3.(a) limit of 10 umho/cm. The reactor

04 | water conductivity peaked at 12.6 umho/cm and was greater than 10 for

05 | approximately 4.5 hours. During the reactor startup and conductivity

06 | spike, the reactor pressure remained below 520 psig. Due to the short

07 | period of this occurrence and the low reactor pressure, no effects are

08 | expected to the materials in the primary system boundary.

09	H	G	11	B	12	C	13	D	E	M	I	N	X	14	Z	15	Z	16				
7	8	SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE						COMP. SUBCODE		VALVE SUBCODE						
17	8	0	-	0	0	4	/	0	3	L	-	0										
21	22	23	24	26	27	28	29	30	31	32												
LER/RO REPORT NUMBER		EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.												
18	G	19	C	20	Z	21	0	0	0	0	22	Y	23	N	24	A	25	G	2	2	0	26
33	34	35	36	37	40	41	42	43	44	47												
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER						

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | The reactor water conductivity increase is believed to be due to resin

11 | injection. The mechanism for the resin injection is unknown but is be-

12 | lieved to be from the condensate filter/demineralizer system. Upon ex-

13 | ceeding the Tech. Spec. conductivity limit the reactor was shutdown and

14 | the primary coolant chemistry was brought within limits using the RWCU.

15	C	28	0	0	1	29	N/A	30	B	31	Routine startup chemistry testing	32															
7	8	FACILITY STATUS		% POWER			OTHER STATUS			METHOD OF DISCOVERY				DISCOVERY DESCRIPTION													
16	Z	33	Z	34	N/A	35	N/A	36	N/A	37	N/A	38	N/A	39	N/A	40	N/A	41	N/A	42	N/A	43	N/A	44	N/A	45	N/A
7	8	ACTIVITY CONTENT RELEASED OF RELEASE		AMOUNT OF ACTIVITY												LOCATION OF RELEASE											
17	0	0	0	37	Z	38	N/A	39	N/A	40	N/A	41	N/A	42	N/A	43	N/A	44	N/A	45	N/A	46	N/A	47	N/A	48	N/A
7	8	PERSONNEL EXPOSURES NUMBER		TYPE		DESCRIPTION																					
18	0	0	0	40	N/A	41	N/A	42	N/A	43	N/A	44	N/A	45	N/A	46	N/A	47	N/A	48	N/A	49	N/A	50	N/A	51	N/A
7	8	PERSONNEL INJURIES NUMBER		DESCRIPTION																							
19	0	0	0	40	N/A	41	N/A	42	N/A	43	N/A	44	N/A	45	N/A	46	N/A	47	N/A	48	N/A	49	N/A	50	N/A	51	N/A
7	8	LOSS OF OR DAMAGE TO FACILITY TYPE		DESCRIPTION																							
20	Z	42	N/A	43	N/A	44	N/A	45	N/A	46	N/A	47	N/A	48	N/A	49	N/A	50	N/A	51	N/A	52	N/A	53	N/A	54	N/A
7	8	PUBLCITY ISSUED DESCRIPTION		N/A																							
21	N	44	N/A	45	N/A	46	N/A	47	N/A	48	N/A	49	N/A	50	N/A	51	N/A	52	N/A	53	N/A	54	N/A	55	N/A	56	N/A
7	8	PUBLCITY ISSUED DESCRIPTION		N/A																							

NAME OF PREPARER *M. J. Cooney* M. J. Cooney

PHONE: (215) 841-5020

8008180

567