NRC FORM 366 (7-77)

Unit 2

LICENSEE EVENT REPORT

Report No. 2-80-1/1X-1

CONTROL BLOCK: | | | | | | | ① (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

PAPBS2 ②	00-00000-00 ③	41111 ④	⑤
LICENSEE CODE	LICENSE NUMBER	LICENSE TYPE	CAT

CON'T

REPORT SOURCE	DOCKET NUMBER	EVENT DATE	REPORT DATE
L ⑥	0 5 0 - 0 2 7 7 ⑦	1 2 3 1 7 9 ⑧	0 3 1 2 8 0 ⑨

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES ⑩

With Unit 2 at power and the drywell being deinerted in preparation for a planned outage, two drywell ventilation isolation valves (AO-2521A & AO-2521B) were discovered to be fully open. During reactor operation these valves are limited to a maximum opening of 37° to insure valve closure within the maximum allowable five seconds. This occurrence is reportable under Technical Specification 6.9.2a(6). It was on 1/3/80 that the event was indentified as reportable.

SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE
SD ⑪	D ⑫	Z ⑬	VALVEX ⑭	B ⑮	D ⑯

⑰ LER/RO REPORT NUMBER

EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
80	—	001	/	01	X	—	1

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS ㉒	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
X ⑱	G ⑲	Z ⑳	Z ㉑	0000	Y ㉓	N ㉔	A ㉕	F135 ㉖

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS ㉗

The apparent cause was lack of procedural control insuring that the valves are maintained at less than 37° during reactor operation. When discovered, the valves were reset to less than 37° and cautionary tags have been placed on all drywell vent isolation valve pressure regulators. Procedural changes will be made to insure proper operation.

FACILITY STATUS	% POWER	OTHER STATUS ㉚	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION ㉜
D ㉘	092 ㉙	N/A	A ㉛	Operator Observation

ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY ㉟	LOCATION OF RELEASE ㊱
Z ㉝	Z ㉞	N/A	N/A

PERSONNEL EXPOSURES

NUMBER	TYPE	DESCRIPTION ㊴
000 ㊲	Z ㊳	N/A

PERSONNEL INJURIES

NUMBER	DESCRIPTION ㊶
000 ㊵	N/A

LOSS OF OR DAMAGE TO FACILITY ㊸

TYPE	DESCRIPTION
Z ㊷	N/A

PUBLICITY

ISSUED	DESCRIPTION ㊺
N ㊹	N/A

NRC USE ONLY

NAME OF PREPARER M. J. Cooney PHONE: (215) 841-5020

8003180593