NRC FORM 366 (7-77)

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | N C B E P 1 (2) | 0 0 - 0 0 0 0 0 - 0 0 (3) | 4 1 1 1 1 (4) | (5)

7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T

0 1 | REPORT SOURCE L (6) | 0 5 0 - 0 3 2 5 (7) | 0 2 1 4 8 0 (8) | 0 3 1 0 8 0 (9)

7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | While running ID RHR pump in the torus cooling mode in preparation for HPCI

0 3 | surveillance testing, the pump tripped. This made the "B" loop of LPCI inoperable.

0 4 |

0 5 |

0 6 |

0 7 |

0 8 | Technical Specifications 3.5.3.2, 6.9.1.9b

7 8 9 80

0 9 | SYSTEM CODE C F (11) | CAUSE CODE X (12) | CAUSE SUBCODE X (13) | COMPONENT CODE C K T B K R (14) | COMP. SUBCODE A (15) | VALVE SUBCODE Z (16)

7 8 9 10 11 12 13 18 19 20

(17) LER/RO REPORT NUMBER: EVENT YEAR 8 0 | — | SEQUENTIAL REPORT NO. 0 1 6 | / | OCCURRENCE CODE 0 3 | REPORT TYPE L | — | REVISION NO. 0

21 22 23 24 26 27 28 29 30 31 32

ACTION TAKEN X (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0 0 0 0 | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. Y (24) | PRIME COMP. SUPPLIER N (25) | COMPONENT MANUFACTURER G 0 8 0 (26)

33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | A thorough investigation of the breaker could not detect a problem. No fault

1 1 | indicators were present and no problem with any interlock logic could be found. The

1 2 | breaker was reset and the pump successfully started and run. This is considered an

1 3 | isolated event and no further action is required.

1 4 |

7 8 9 80

1 5 | FACILITY STATUS E (28) | % POWER 0 9 9 (29) | OTHER STATUS (30) N/A | METHOD OF DISCOVERY A (31) | DISCOVERY DESCRIPTION (32) Operator Surveillance

7 8 9 10 12 13 44 45 46 80

1 6 | ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) N/A | LOCATION OF RELEASE (36) N/A

7 8 9 10 11 44 45 80

1 7 | PERSONNEL EXPOSURES NUMBER 0 0 0 (37) | TYPE Z (38) | DESCRIPTION (39) N/A

7 8 9 11 12 13 80

1 8 | PERSONNEL INJURIES NUMBER 0 0 0 (40) | DESCRIPTION (41) N/A

7 8 9 11 12 80

1 9 | LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) | DESCRIPTION (43) N/A

7 8 9 10 80

2 0 | PUBLICITY ISSUED Z (44) | DESCRIPTION (45) N/A | NRC USE ONLY

7 8 9 10 68 69 80

NAME OF PREPARER A. C. Tollison, Jr. PHONE (919) 457-9521

GPO 917-926

8003180621