



Commonwealth Edison
Quad Cities Nuclear Power Station
22710 206 Avenue North
Cordova, Illinois 61242
Telephone 309/654-2241

NJK-80-85

March 5, 1980

Mr. Edson G. Case, Deputy Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Mr. Case:

Enclosed please find a listing of those changes, tests, and experiments completed during the month of February 1980, for Quad-Cities Station Units 1 and 2, DPR-29 and DPR-30. A summary of the safety evaluation is being reported in compliance with 10 CFR 50.59.

Thirty-nine copies are provided for your use.

Very truly yours,

COMMONWEALTH EDISON COMPANY
QUAD-CITIES NUCLEAR POWER STATION

N. J. Kalivianakis
Station Superintendent

NJK/B8/san

Enclosure

cc: R. F. Janecek

8008190 457

M-4-1 & 2-78-37

Pressure Suppression Chamber
Ring Girder Drain Slot Enlargement

Description of Modification

These modifications enlarged the drain slots on the bottom of the pressure suppression chamber ring girders. The larger drain holes are intended to increase complete draining capabilities of the suppression chamber by eliminating the blockage which occurs when using the small drain slots.

Summary of Safety Evaluation

The increased drain hole size does not reduce the stiffener section properties below the minimum design requirements, therefore the probability of an occurrence or consequence of an accident previously evaluated in the FSAR has not been increased. And since the suppression chamber stiffeners are passive structural components, the possibility for an accident of a different type than previously evaluated in the FSAR is not created.

M-4-1-77-36

Drywell Mechanical Snubber

Description of Modification

This modification involved replacement of the hydraulic snubbers in the drywell with mechanical type. The mechanical snubbers were obtained from Pacific Scientific and are of the same rating at the hydraulic units they replaced. This modification was installed because the mechanical snubbers are more reliable than the hydraulic type due to the elimination of relatively radiation-sensitive components such as hydraulic fluids and seals and the non-leaking character of the mechanical type.

Summary of Safety Evaluation

The design function of the affected systems will not be altered. The performance characteristics of the snubbers will not be altered since the mechanical and hydraulic snubbers are of the same ratings. However, the mechanical snubbers will provide greater reliability because the consideration of hydraulic fluid degradation and leakage does not exist. No design basis margin of safety as defined in the Technical Specifications is affected by this modification.

M-4-2-78-12

Recirculation Pump Suction Valves

Description of Modification

This modification removed the LPCI loop selection closure of the recirculation system suction valves (MO 2-202-4A & B). Both valves will now remain in the open position in case of a line break between the recirculation suction and discharge valves thus allowing the reactor to depressurize. This modification was installed to prevent a situation where inventory in the vessel is decreased while system pressure remains high during a recirculation line break.

Summary of Safety Evaluation

The probability of an occurrence or the consequence of an accident as previously evaluated in the FSAR is not increased because maintaining both recirculation suction valves in the open position decreases chances of vessel pressure buildup in case of a water line break. No new accident or malfunction is created. The modified valves will be surveillance tested as before and the margin of safety is unaffected.