

Alabama Power Company  
600 North 18th Street  
Post Office Box 2641  
Birmingham, Alabama 35291  
Telephone 205 323-5341

F. L. CLAYTON, JR.  
Senior Vice President



March 14, 1980

Director  
Office of Management Information  
& Program Control  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555


Dear Sir:

Re: Joseph M. Farley Nuclear Plant  
Unit No. 1  
Docket No. 50-348  
Monthly Operating Data Report

Attached are two (2) copies of the February, 1980 monthly operating report for Joseph M. Farley Nuclear Plant, Unit 1, as required by Section 6.9.1.6 of the Appendix A Technical Specifications. As requested by letter from Mr. John F. Stolz to Mr. Alan R. Barton, dated October 21, 1977, a "Narrative Summary of Operating Experience" is included in the attached report.

If you have any questions, please advise.

Yours very truly,

  
F. L. Clayton, Jr.

FLCjr/TNE/nmb

Attachments

cc: Mr. Ted Cintula (1 copy)  
Director, IE (10 copies)  
Director, R11 (1 copy)

Aug 5, 11

80(319) 459

JOSEPH M. FARLEY NUCLEAR PLANT  
UNIT 1

NARRATIVE SUMMARY OF OPERATIONS  
FEBRUARY, 1980

On February 1, the unit outage for performing NUREG 0578 related design changes continued. There were four (4) automatically initiated shutdowns, one (1) manual shutdown and four (4) controlled power reductions in the month of February.

The following safety-related maintenance was performed in February:

1. Overhauled 1A and 1B Reactor Makeup Water Pumps.
2. Overhauled vent air particulate radiation monitor RE-21.
3. Installed valve position indicators on the POR's and pressurizer safety valves.
4. Installed a core subcooling monitor.
5. Replaced a bearing on the TDAFW pump.
6. Repaired a casing leak and replaced bearings on "B" MDAFW pump.
7. Continued installing additional instrumentation on 1B charging pump.