

APPENDIX A
NOTICE OF DEVIATION

Florida Power Corporation
Crystal River 3

License No. DPR-72

Based on the results of the NRC inspection conducted on November 26-29, 1979, certain of your activities appear to deviate from applicable codes, guides, or standards approved by the Commission as indicated below.

Branch Technical Position APCS 9.5-1, Appendix A, Section C.6 requires in part that "Fire extinguishers should be provided in accordance with guidelines of NFPA 10 and 10A, "Portable Fire Extinguishers, Maintenance and Use." The Fire Protection Program Review, Crystal River Unit 3, dated June 1979 and submitted to the NRC states in part in Section 6.E.6 that "the (above) requirement is met. Fire extinguishers are provided in accordance with NFPA 10."

Contrary to the above, surveillance procedures for portable fire extinguishers SP-800, revision 3 and SP-801, revision 1 do not reference NFPA-10 or the inspection and maintenance sections therein and do not contain all of the checks and acceptance criteria used in NFPA 10.

8003190 ⁶⁶⁸ ~~666~~