

APPENDIX A

NOTICE OF VIOLATION

Florida Power Corporation
Crystal River Unit 3

License No. DPR-72

Based on the NRC inspection January 15-17, 1980, certain of your activities were apparently not conducted in full compliance with NRC requirements as indicated below. These items have been categorized as described in correspondence to you dated December 31, 1974.

As required by Technical Specification 4.3.3.2.b., the incore detector system shall be demonstrated operable at least once per 18 months by performance of a Channel Calibration which does not include the neutron detectors.

Contrary to the above, the incore neutron detectors, last calibrated in September 1977, were not calibrated by July 1979; the latest date permitted by technical specification 4.0.2.a. The calibration was not completed until January 14, 1980.

This is an infraction.