

*Tera*



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

January 9, 1980

Docket Nos.: 50-282  
50-306

Northern States Power Company  
ATTN: Mr. L. O. Mayer  
Manager of Nuclear Support  
Services  
414 Nicollet Mall, 8th Floor  
Minneapolis, Minnesota 55401

Dear Mr. Mayer:

We have reviewed the information you have submitted regarding the containment purge system on the Prairie Island Plant. We find that we need the additional information identified in the enclosure to this letter in order to complete our evaluation of the electrical override/bypass aspects of the long term containment purge matter. In order to maintain our review schedule we need the information in 45 days from the receipt of this letter.

Sincerely,

A handwritten signature in cursive script, appearing to read "A. Schwencer".

A. Schwencer, Chief  
Operating Reactors Branch #1  
Division of Operating Reactors  
Office of Nuclear Reactor Regulation

Enclosure:  
Request for Additional  
Information

P

8008250 401

Mr. L. O. Mayer  
Northern States Power Company

- 2 -

January 9, 1980

cc: Gerald Charnoff, Esquire  
Shaw, Pittman, Potts and Trowbridge  
1800 M Street, N.W.  
Washington, D. C. 20036

Ms. Terry Hoffman  
Executive Director  
Minnesota Pollution Control Agency  
1935 W. County Road B2  
Roseville, Minnesota 55113

The Environmental Conservation Library  
Minneapolis Public Library  
300 Nicollet Mall  
Minneapolis, Minnesota 55401

Mr. F. P. Tierney, Plant Manager  
Prairie Island Nuclear Generating Plant  
Northern States Power Company  
Route 2  
Welch, Minnesota 55089

Joclyn F. Olson, Esquire  
Special Assistant Attorney General  
Minnesota Pollution Control Agency  
1935 W. County Road B2  
Roseville, Minnesota 55113

Robert L. Nybo, Jr., Chairman  
Minnesota-Wisconsin Boundary Area  
Commission  
619 Second Street  
Hudson, Wisconsin 54016

Clarence D. Fierabend  
U. S. Nuclear Regulatory Commission  
P. O. Box 374  
Red Wing, Minnesota 55066

REQUEST FOR ADDITIONAL INFORMATION  
FOR CONTAINMENT PURGE SYSTEM AND  
CONTAINMENT VENTING SYSTEM FOR  
PRAIRIE ISLAND UNITS 1 & 2  
DOCKET NOS. 50-282/306

1. With the exception of the containment ventilation isolation (CVI) system, the docketed information as to the design of Engineered Safety Features (ESF) does not adequately address the following areas. Please discuss how your ESF design conforms with each:
  - 1 - The overriding\* of one type of safety actuation signal (e.g., radiation) should not cause the blocking of any other type of safety actuation signal (e.g., pressure) to the isolation valves.
  - 2 - Sufficient physical features (e.g., key lock switches) should be provided to facilitate adequate administrative controls.
  - 3 - The system-level annunciation of the overridden status should be provided for the containment isolation system and for every safety system impacted when an override is active.
  - 4 - Diverse signals should be provided to initiate isolation of the containment ventilation system. Specifically, containment high radiation, safety injection actuation, and containment high pressure should automatically initiate Containment Ventilation Isolation (CVI).
  - 5 - The instrumentation and control systems provided to initiate ESF should be designed and qualified as safety-grade equipment.
  - 6 - The overriding or resetting\* of the isolation actuation signal should not cause the automatic motion of any ESF valve.
2. Provide the process and instrumentation (P&ID) and schematic drawings for your purge and vent system and control room heating, ventilation and air conditioning system.
3. With regard to Criterion 4 of question 1 above, justify not providing for containment ventilation isolation on high containment pressure.
4. With regard to Criterion 5 of question 1 above, please indicate if the radiation monitors that initiate CVI are Class 1E or not. If they are not justify their use for a required safety function.

\*The following definitions are given for clarity of use in this issue:  
Override - the signal is still present, and it is blocked in order to perform a function contrary to the signal; Reset - the signal has come and gone, and the circuit is being cleared to return to the normal condition.