

### LICENSEE EVENT REPORT

CONTROL BLOCK: \_\_\_\_\_ (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	N	C	B	E	P	2	0	0	-	0	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4	5
7	8	9	14	15	LICENSE NUMBER										25	26	LICENSE TYPE					30	57	58			

0	1	L	0	5	0	-	0	3	2	4	7	0	2	2	5	8	0	8	0	3	1	3	8	0	9
7	8	REPORT SOURCE		60	61	DOCKET NUMBER					68	69	EVENT DATE					74	75	REPORT DATE					80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 While performing PT 2.1.1PC, HPCI Steamline High Differential Pressure Channel Cali-

0 3 bration and Functional Check, main steamline high flow instrument 2E41-DPIS-N004 was

0 4 found out of tolerance. The value found was 225 inches of water and the reportable

0 5 limit is greater than 219 inches of water (300% flow).

0 6

0 7

0 8

0	9	S	F	11	E	12	G	13	I	N	S	T	R	U	14	S	15	Z	16				
7	8	SYSTEM CODE		9	10	CAUSE CODE		11	CAUSE SUBCODE		12	COMPONENT CODE					13	COMP. SUBCODE		19	VALVE SUBCODE		20
17	LER/RO REPORT NUMBER		EVENT YEAR		21	22	SEQUENTIAL REPORT NO.		24	26	OCCURRENCE CODE		28	REPORT TYPE		30	REVISION NO.		32				
18	A	19	Z	20	Z	21	HOURS		22	ATTACHMENT SUBMITTED		23	NPRD-4 FORM SUB		24	PRIME COMP. SUPPLIER		25	COMPONENT MANUFACTURER		26	27	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The out of tolerance setpoint was attributed to instrument drift. The instrument was

1 1 recalibrated and returned to service. This is considered an isolated event and no

1 2 further action is required. Although this is an isolated event on this instrument, it

1 3 is scheduled to be replaced with an analog transmitter during the current refueling

1 4 outage.

1	5	E	28	0	9	5	29	NA	30	B	31	Periodic Test					32						
7	8	FACILITY STATUS		9	10	% POWER		11	OTHER STATUS		13	METHOD OF DISCOVERY					14	DISCOVERY DESCRIPTION					15

1	6	Z	33	Z	34	NA	35	NA	36								
7	8	ACTIVITY CONTENT		9	10	RELEASED OF RELEASE		11	AMOUNT OF ACTIVITY		13	LOCATION OF RELEASE					14

1	7	0	0	0	37	Z	38	NA	39								
7	8	PERSONNEL EXPOSURES		9	10	NUMBER		11	TYPE		12	DESCRIPTION					13

1	8	0	0	0	40	NA	41							
7	8	PERSONNEL INJURIES		9	10	NUMBER		11	DESCRIPTION					12

1	9	Z	42	NA	43									
7	8	LOSS OF OR DAMAGE TO FACILITY		9	10	TYPE		11	DESCRIPTION					12

2	0	N	44	NA	45						
7	8	PUBLICITY ISSUED		9	10	DESCRIPTION					11

NAME OF PREPARED: A. C. Tollison, Jr. PHONE 919-457-9521

8003250474