



Metropolitan Edison Company
Post Office Box 480
Middletown, Pennsylvania 17057
717 944-4041

Writer's Direct Dial Number

March 20, 1980
TLL 120

Office of Inspection and Enforcement
Attn: B. H. Grier, Director
Region I
U. S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pa. 19406

Dear Sir:

Three Mile Island Nuclear Station, Unit I (TMI-1)
Operating License No. DPR-50
Docket No. 50-289
LER 80-004/01T-0

Attached please find Licensee Event Report (LER) 80-004/01T concerning the potential for exceeding code allowable stress in Decay Heat Removal System piping associated with valves DH-V1 and DH-V2. This event was initially reported to you for the DH-V2 piping via telecon on March 6, 1980 and in a telegram dated March 7, 1980. In a subsequent phone call to D. R. Havercamp on March 11, 1980, we informed him that the event was also reportable for DH-V1. We told him that we would not issue an additional telegram for DH-V1 and would expand the 14 day report to include the piping for both valves. He agreed with this approach.

This event is considered reportable under the requirements of Technical Specification 6.9.2.A(9).

Sincerely,

/s/ J. G. Herbein

J. G. Herbein
Vice President
Nuclear Operations

JGH:CFM:hah

Attachments

cc: J. T. Collins


*A02
3/11*