NRC FORM 366 (7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: [| | | | | |] (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 — LICENSEE CODE: P A B V S 1 (2) — LICENSE NUMBER: 0 0 - 0 0 0 0 0 - 0 0 (3) — LICENSE TYPE: 4 1 1 1 1 (4) — CAT: (5)

CON'T 0 1 — REPORT SOURCE: L (6) — DOCKET NUMBER: 0 5 0 0 0 3 3 4 (7) — EVENT DATE: 0 3 0 2 8 0 (8) — REPORT DATE: 0 3 2 0 8 0 (9)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 While performing a maintenance surveillance procedure on Cooling Tower Blowdown
0 3 Temperature Indicator [T-CW-101], the instrument was found to be out of
0 4 calibration (high). The instrument was immediately calibrated. There were no
0 5 environmental implications because the previous surveillance test was performed on
0 6 10/19/79 and, since that time, the plant river water blowdown temperature never
0 7 increased above 75F.
0 8

0 9	SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP SUBCODE	VALVE SUBCODE
	W A (11)	X (12)	Z (13)	I N S T R U (14)	E (15)	Z (16)

(17) LER/RO REPORT NUMBER	EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
	8 0	—	0 1 3	/	0 4	T	—	0

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
E (18)	Z (19)	Z (20)	Z (21)	0 0 0 0	N (23)	N (24)	X (25)	Z 9 9 9 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The cause of the out-of-calibration condition is attributed to instrument drift.
1 1 The instrument was immediately calibrated using the appropriate maintenance
1 2 surveillance procedure. No previous failures of this instrument due to instrument
1 3 drift have been experienced.
1 4

1 5	FACILITY STATUS	% POWER	OTHER STATUS (30)	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION (32)
	H (28)	0 0 0 (29)	N/A	B (31)	Surveillance test results

1 6	ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
	Z (33)	Z (34)	N/A	N/A

PERSONNEL EXPOSURES

1 7	NUMBER	TYPE	DESCRIPTION (39)
	0 0 0 (37)	Z (38)	N/A

PERSONNEL INJURIES

1 8	NUMBER	DESCRIPTION (41)
	0 0 0 (40)	N/A

LOSS OF OR DAMAGE TO FACILITY (43)

1 9	TYPE	DESCRIPTION
	Z (42)	N/A

PUBLICITY

2 0	ISSUED	DESCRIPTION (45)
	N (44)	N/A

8003260624

NRC USE ONLY

NAME OF PREPARER J. A. Werling PHONE 412-643-1258