

BOSTON EDISON COMPANY  
GENERAL OFFICES 800 BOYLSTON STREET  
BOSTON, MASSACHUSETTS 02199

G. CARL ANDOGNINI  
SUPERINTENDENT  
NUCLEAR OPERATIONS DEPARTMENT

March 19, 1980

BECO. Ltr. #80-44

Mr. Darrell G. Eisenhut, Acting Director  
Division of Operating Reactors  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
Washington, D. C. 20555

License No. DPR-35  
Docket No. 50-293


NRC Letter Concerning LWR Primary  
Coolant System Pressure Isolation Valves

Dear Sir:

In response to the subject NRC letter, all systems at Pilgrim Nuclear Power Station Unit #1 were reviewed to determine if an Event V isolation valve configuration exists within the Class I boundary of the high pressure piping and low pressure piping; e.g., (1) two check valves in series, or (2) two check valves in series with a motor operated valve. The results of this review showed that no such valve lineups exist at Pilgrim Nuclear Power Station Unit #1.

Should you have any further questions or concerns on this subject, please contact us at your convenience.

Very truly yours,



Commonwealth of Massachusetts)  
County of Suffolk )

Then personally appeared before me G. Carl Andognini, who, being duly sworn, did state that he is Superintendent - Nuclear Operations Dept. of Boston Edison Co., the applicant herein, and that he is duly authorized to execute and file the submittal contained herein in the name and on behalf of Boston Edison Company and that the statements in said submittal are true to the best of his knowledge and belief.

My Commission expires:

1/17/88

Harmon R. Bayliss 1/0  
Notary Public

A001  
S

ADD: 42 E

P. Polt 1 0

E. Butcher 1 0

8008260 642

P