



TIC

ARKANSAS POWER & LIGHT COMPANY  
POST OFFICE BOX 551 LITTLE ROCK, ARKANSAS 72203 (501) 371-4000

January 28, 1980

1-010-25  
2-010-21

Mr. K. V. Seyfrit, Director  
Office of Inspection and Enforcement  
U. S. Nuclear Regulatory Commission  
Region IV  
611 Ryan Plaza Drive, Suite 1000  
Arlington, TX. 76011

Subject: Arkansas Nuclear One-Units 1 & 2  
Docket Nos. 50-313 & 50-368  
License Nos. DPR-51 & NPF-6  
Concrete Block Wall Attachments  
(File: 1510, 2-1510)

Gentlemen:

The following summarizes the results (to date) of our walkdown performed to identify seismic category I piping and safety related systems attached to or in close proximity to concrete block walls. These numbers are preliminary and may be adjusted once the survey is complete.

ANO-1

The Unit 1 walkdown should be completed January 30, 1980. To date we have located 283 concrete block walls. All but 19 of these have been reviewed in order to determine if seismic category I piping or safety related systems are attached to or in close proximity to them. These are in high radiation areas and will be surveyed when accessible. Of the remaining 264 walls 182 have been determined to not affect seismic category I or safety related systems. The remaining 82 will be analyzed further. Large pipe is supported by concrete block walls in 5 locations.

ANO-2

The Unit 2 walkdown is essentially complete. Of the 328 walls surveyed (20 have not been surveyed due to existing high radiation levels) 98 walls have seismic category I piping or safety related systems attached or in close proximity to the wall. No large pipe is attached to concrete block walls in Unit 2.

Very truly yours,

*David C. Trimble*

David C. Trimble  
Manager, Licensing

DCT/MOW/gp

8004110 508